



**Programme des  
Nations Unies pour  
l'environnement**

Distr.  
GÉNÉRALE

UNEP/OzL.Pro/ExCom/85/9  
9 mai 2020

FRANÇAIS  
ORIGINAL : ANGLAIS

COMITÉ EXÉCUTIF  
DU FONDS MULTILATÉRAL AUX FINS  
D'APPLICATION DU PROTOCOLE DE MONTRÉAL  
Quatre-vingt-cinquième réunion  
Montréal, 25 – 29 mai 2020  
Reportée: 19 – 22 juillet 2020\*

**RAPPORTS PÉRIODIQUES ET RAPPORT SUR LES PROJETS COMPORTANT DES  
EXIGENCES PARTICULIÈRES DE REMISE DE RAPPORTS**

1. Le présent document offre un suivi aux questions soulevées dans les derniers rapports annuels et financiers présentés à la 84<sup>e</sup> réunion,<sup>1</sup> et en lien avec les projets et activités pour lesquels des rapports particuliers ont été demandés lors de réunions précédentes.
2. Le document est divisé en cinq parties :
  - Partie I : Projets connaissant un retard dans la mise en œuvre et pour lesquels des rapports de situation spéciaux ont été demandés
  - Partie II : Rapports sur les projets comportant des exigences particulières de remise de rapports pour lesquels il n'y a aucune question d'orientation, de coût ou autre en instance, et pour lesquels le Comité exécutif pourrait prendre des décisions basées sur les recommandations du Secrétariat, sans autre échange (« approbation générale »). Le rapport de la réunion du Comité exécutif présentera individuellement chacun des rapports contenus dans cette partie avec la décision adoptée par le Comité exécutif
  - Partie III : Rapports sur les projets comportant des exigences particulières de remise de rapports pour examen individuel par le Comité exécutif
  - Partie IV : Liste des entreprises financées au titre du PGEH accusant du retard et/ou assujetties aux changements dans le plan de mise en œuvre, et entreprises devant reconvertir à des technologies à faible PRG connaissant des retards à cause de

\* À cause du coronavirus (COVID-19)

<sup>1</sup> UNEP/OzL.Pro/ExCom/84/16-21

problèmes d'accès sur les marchés locaux et/ou de coûts plus élevés (décisions 84/27 et 84/42)

Partie V : Projets d'investissement et activités de facilitation en lien avec les HFC financés au moyen des contributions supplémentaires d'un groupe de 17 pays non visés à l'article 5 (décision 84/12 b))

## **PARTIE I : PROJETS CONNAISSANT UN RETARD DANS LA MISE EN ŒUVRE ET POUR LESQUELS DES RAPPORTS PÉRIODIQUES SPÉCIAUX ONT ÉTÉ DEMANDÉS**

### **Retards dans la mise en œuvre**

3. Cinq projets en cours (un projet mis en œuvre par le PNUE et quatre projets mis en œuvre par l'ONUDI) ont été classés parmi les projets connaissant des retards de mise en œuvre, à la 84<sup>e</sup> réunion. Ces projets, indiqués à l'annexe I au présent document, sont assujettis à la procédure d'annulation de projet et ne peuvent pas être retirés de la liste de suivi avant l'achèvement, conformément à la décision 32/4.

4. Le PNUE et l'ONUDI ont indiqué que certains progrès avaient été accomplis depuis le dernier rapport périodique et qu'ils continueraient à faire le suivi de ces projets jusqu'à leur achèvement.

### **Projets pour lesquels des rapports périodiques supplémentaires ont été demandés<sup>2</sup>**

5. Le Comité exécutif, à sa 84<sup>e</sup> réunion, a demandé des rapports de situation supplémentaires pour 58 projets (décision 84/12 a) iii). Les agences bilatérales et d'exécution concernées ont remis les rapports demandés à la décision 84/12 a) iii) à la 85<sup>e</sup> réunion. Au cours de l'examen, le Secrétariat a pris note que des progrès avaient été accomplis dans 27 projets. Cinq des 31 projets restants pour lesquels des questions sont en instance en lien avec la République populaire démocratique de Corée sont examinés à la partie III du présent document. Les 26 autres projets pour lesquels des questions sont en instance figurent à l'annexe II au présent document.

### **Recommandation**

6. Le Comité exécutif pourrait souhaiter :

a) Prendre note :

- i) Des rapports sur les retards dans la mise en œuvre et des rapports de situation soumis par les agences bilatérales et d'exécution présentés dans le document UNEP/OzL.Pro/ExCom/85/9;
- ii) Que les agences bilatérales et d'exécution remettent des rapports au Comité exécutif, à sa 86<sup>e</sup> réunion, sur cinq projets accusant du retard dans la mise en œuvre et 26 projets pour lesquels la remise de rapports périodiques supplémentaires a été demandée, indiqués respectivement aux annexes I et II au présent document, faisant partie du rapport périodique annuel et financier 2019 des agences bilatérales et d'exécution;

---

<sup>2</sup> Les projets de renforcement des institutions, de banques de halons, de formation des douaniers, de récupération et recyclage et de démonstration ne sont pas assujettis à la procédure d'annulation. Le Comité exécutif a toutefois décidé de poursuivre leur suivi, selon qu'il convient (décision 36/14 b)).

- b) Approuver les recommandations sur les projets en cours comportant des questions particulières précisées dans la dernière colonne du tableau de l'annexe II au présent document.

## RAPPORTS SUR LES PROJETS COMPORTANT DES EXIGENCES PARTICULIÈRES DE REMISE DE RAPPORTS

7. Le tableau 1 dresse la liste des rapports sur les projets comportant des exigences particulières de remise de rapports proposés pour approbation générale à la 85<sup>e</sup> réunion.

**Tableau 1 : Rapports sur les projets comportant des exigences particulières de remise de rapports recommandés pour approbation générale**

Pays	Titre du projet	Paragraphes
<b>Projets d'élimination des résidus de SAO</b>		
Liban	Projet de démonstration pilote sur la gestion et l'élimination des résidus de SAO : Rapport final	9 – 13
<b>Pays</b>		
<b>Titre du projet</b>		
<b>Paragraphes</b>		
<b>Utilisation temporaire d'une technologie à potentiel de réchauffement de la planète (PRG) élevé dans des projets approuvés</b>		
Liban	PGEH (phase II) : Rapport sur l'état de la reconversion des entreprises bénéficiaires restantes dans les secteurs de fabrication de mousses et de systèmes de climatisation	14 – 20
<b>Rapports en lien avec les plans de gestion de l'élimination des HCFC (PGEH)</b>		
Argentine	PGEH (phase II) : Compte rendu sur la viabilité financière de l'entreprise Celpack	21 – 23
Brésil	PGEH (phase I) : Rapport sur l'utilisation temporaire d'une technologie à PRG élevé à la société de formulation U-Tech et rapport périodique final	24 – 44
Brésil	PGEH (phase II) : État de la mise en œuvre des projets dans le secteur de la fabrication de climatiseurs individuels	45 – 52
Costa Rica	PGEH (phase) : Rapport périodique	53 – 62
Honduras	PGEH (phase I) : Rapport périodique sur la mise en œuvre des activités relevant du PNUE	63 – 73
Inde	PGEH (phase II) : Compte rendu sur l'évaluation des entreprises de fabrication de panneaux de mousse en continu concernant le respect de l'interdiction	74 – 78
Indonésie	PGEH (phase I) : Compte rendu sur l'état de la reconversion des entreprises de fabrication de réfrigérateurs et de climatiseurs, et plan d'action révisé	79 – 93
Malaisie	PGEH (phase II) : Changement de technologie dans 14 entreprises	94 – 100
Maroc	PGEH (phase I) : Rapport périodique	101 – 115
République de Moldova	PGEH (phase II) : Rapport détaillé sur l'état de la mise en œuvre des projets de démonstration sur l'utilisation d'une technologie à base de CO <sub>2</sub> dans le secteur de la réfrigération commerciale	116 - 126
<b>Projets de démonstration sur les solutions de remplacement à faible PRG pour les HCFC</b>		
Argentine et Tunisie	Projet de démonstration sur l'introduction d'une technologie à base de CO <sub>2</sub> transcritique dans les supermarchés : Rapport final	127-247 (rapport à l'annexe III)
Mondial	Projet de démonstration sur la qualité et le confinement des frigorigènes et l'introduction de substances de remplacement à faible PRG (régions de l'Afrique de l'Est et des Caraïbes)	148-168 (rapport à l'annexe IV)
Régions de l'Europe et de l'Asie centrale	Développement d'un centre régional d'excellence pour la formation et la certification, et démonstration de substances de remplacement possibles à faible potentiel de réchauffement de la planète pour les températures ambiantes élevées : Rapport final	169-180 (rapport à l'annexe V)
Arabie saoudite	Projet de démonstration sur l'élimination des HCFC en utilisant les HFO comme agents de gonflage dans la mousse à vaporiser dans le secteur de la climatisation, dans des milieux à température ambiante élevée : Rapport final	181-193 (rapport à l'annexe VI)
Arabie saoudite	Projets de démonstration sur la promotion de frigorigènes à base de HFO à faible potentiel de réchauffement de la planète dans des milieux à température ambiante	194-202

Pays	Titre du projet	Paragraphes
	élevée : Rapport périodique	
Asie occidentale	Projet de démonstration sur la promotion de frigorigènes de remplacement dans les systèmes de climatisation pour les pays à température ambiante élevée (PRAHA-II) : Rapport final	203-217 (rapport à l'annexe VII)
<b>Rapports de vérification financière des secteurs de la production de CFC, des halons, de la mousse de polyuréthane, de l'entretien de l'équipement de réfrigération et des solvants en Chine</b>		
Chine	Agent de transformation II : Renseignements supplémentaires sur les activités à entreprendre	218 – 230
<b>Demande de prorogation des activités de facilitation</b>		231 – 233

8. Le tableau 2 présente la liste des projets comportant des exigences particulières de remise des rapports soumise à la 85<sup>e</sup> réunion pour examen individuel et une courte explication des questions les concernant.

**Tableau 2 : Rapport sur les projets comportant des exigences particulières de remise de rapport proposés pour examen individuel**

Pays	Titre du projet	Question	Paragraphes
<b>Rapports lis aux plans de gestion de l'élimination des HCFC (PGEH)</b>			
République populaire démocratique de Corée	PGEH (phase I) : Rapport périodique sur la mise en œuvre des activités	Demande d'orientation concernant les difficultés à mettre en œuvre les activités à cause des résolutions du Conseil de sécurité des Nations Unies	234 – 244
<b>Rapports de vérification financière sur les secteurs de la production de CFC, des halons, de la mousse de polyuréthane, de l'agent de transformation II, de l'entretien de l'équipement de réfrigération et des solvants de la Chine</b>			
Chine	Rapports de vérification financière des secteurs de la production de CFC, des halons, de la mousse de polyuréthane, de l'agent de transformation II, de l'entretien de l'équipement de réfrigération et des solvants	Retour des soldes des secteurs de la production de CFC, de la mousse de polyuréthane, de l'entretien de l'équipement de réfrigération et des solvants	245 – 250

## **PARTIE II : RAPPORTS SUR LES PROJETS COMPORTANT DES EXIGENCES PARTICULIÈRES DE REMISE DE RAPPORTS RECOMMANDÉS POUR APPROBATION GÉNÉRALE**

### **Projets d'élimination des résidus de SAO**

Liban : Projet de démonstration pilote sur la gestion et l'élimination des résidus de SAO : Rapport final (ONUDI)

#### **Contexte**

9. Le Comité exécutif, à sa 73<sup>e</sup> réunion, a approuvé le projet de démonstration pilote sur la gestion et l'élimination des résidus de SAO pour le Liban pour la somme de 123 475 \$US, plus les coûts d'appui à l'agence de 11 113 \$US pour l'ONUDI.

10. À sa 79<sup>e</sup> réunion, le Comité exécutif a demandé aux agences bilatérales et d'exécution de remettre un rapport final sur les projets de démonstration sur l'élimination des SAO en instance, autres que ceux pour le Brésil et la Colombie, et de retourner les soldes des projets pour lesquels des rapports n'ont pas été remis aux 80<sup>e</sup> et 81<sup>e</sup> réunions à la 82<sup>e</sup> réunion (décision 79/18 d)). Par la suite, le Secrétariat a préparé un rapport de synthèse sur le projet pilote d'élimination des SAO examiné par le Comité exécutif à sa

82<sup>e</sup> réunion. Le Comité exécutif, à sa 82<sup>e</sup> réunion, a prolongé le projet pilote pour le Liban jusqu'en juin 2019. Le rapport final devait être remis à la 84<sup>e</sup> réunion tout comme les soldes décision 82/15 c)).<sup>3</sup>

### Observations du Secrétariat

11. Le Secrétariat a reçu le rapport final sur le projet d'élimination des SAO au Liban pour examen à la 85<sup>e</sup> réunion le 5 mai 2020, cinq semaines après l'échéance. À cause de ce retard dans la réception du document, le Secrétariat a été incapable d'examiner la soumission et fournira un sommaire de ce rapport à la 86<sup>e</sup> réunion.

12. D'après l'état de la situation financière précisé dans le rapport final, l'ONUDI devrait restituer un solde de 7 701 \$US à la 85<sup>e</sup> réunion.<sup>4</sup>

### Recommandation

13. Le Comité exécutif pourrait souhaiter prendre note de la soumission, par l'ONUDI, du rapport final du projet de démonstration pilote sur la gestion et l'élimination des résidus de SAO pour le Liban, qui sera examiné et présenté par le Secrétariat à la 86<sup>e</sup> réunion.

### Utilisation temporaire d'une technologie à potentiel de réchauffement de la planète élevé dans des projets approuvés<sup>5</sup>

Liban : Plan de gestion de l'élimination des HCFC (phase II : Rapport sur l'état de la reconversion des entreprises bénéficiaires restantes dans les secteurs de la fabrication de mousses et de systèmes de climatisation) (PNUD)

### Contexte

14. Le PNUD, en tant qu'agence d'exécution désignée, a remis au nom du gouvernement du Liban, un rapport sur la mise en œuvre des reconversions des entreprises dans les secteurs de la mousse et de la fabrication de climatiseurs, des mises à jour sur l'obtention de la technologie de remplacement à faible potentiel de réchauffement de la planète (PRG) et les résultats des essais de deux solutions de remplacement dans le secteur des mousses, conformément à la décision 84/29 b).<sup>6</sup>

### Rapport périodique

15. L'approvisionnement en HFO demeure difficile pour la reconversion des deux dernières entreprises et l'assistance technique pour la reconversion de 11 petites entreprises du secteur de la mousse. Un consultant technique dans le domaine de la mousse a été recruté et des essais de méthylal et de formiate de méthyle devaient avoir lieu dans quelques entreprises choisies au début de 2020, mais la

<sup>3</sup> D'approuver la prorogation du projet de démonstration pilote sur la gestion et l'élimination des résidus de SAO au Liban (LEB/DES/73/DEM/83) jusqu'au 30 juin 2019, étant entendu que le rapport final du projet et le rapport d'achèvement de projet seraient remis à la 84<sup>e</sup> réunion, au plus tard, et que les soldes seraient retournés conformément à la décision 28/7.

<sup>4</sup> UNEP/OzL.Pro/ExCom/85/4

<sup>5</sup> Le rapport sur l'utilisation temporaire d'une technologie à PRG élevé dans des projets approuvés pour Cuba est joint au document de proposition de projet (UNEP/OzL.Pro/ExCom/85/23).

<sup>6</sup> Décision 84/29(b) : De demander au PNUD de continuer à aider le gouvernement libanais à assurer la fourniture de technologies de remplacement à faible PRG, et de rendre rapport, à la 85<sup>e</sup> réunion, sur les conclusions des essais portant sur deux solutions de remplacement dans le secteur des mousses, ainsi que sur la reconversion des entreprises bénéficiaires restantes dans les secteurs de la fabrication de mousses (SPEC, Prometal et les petites entreprises) et de la fabrication des systèmes de climatisation (CGI Halawany et ICR).

situation économique et les questions de sécurité au pays ont empêché la tenue des essais. La situation entourant la COVID-19 a retardé davantage la mise en œuvre. Les essais utilisant divers agents de gonflage, dont les formules à base de HFO, devraient reprendre au pays dès que la situation entourant la COVID-19 s'améliorera. La reconversion des 11 petites entreprises pourrait être menée à terme d'ici le premier trimestre de 2021 et celle des entreprises individuelles restantes (SPEC et Prometal) d'ici à juin 2021.

16. La 84<sup>e</sup> réunion a été informée que deux entreprises restantes dans le secteur de la fabrication de systèmes de climatisation (CGI Halawany et ICR) n'avaient pas encore décidé si elles utiliseraient le HFC-32 ou une autre substance à faible PRG comme frigorigène de remplacement. Ces entreprises ont finalement décidé de reconvertir leurs activités au HFC-32. La reconversion commencera au cours du troisième trimestre de 2020 en vue d'un achèvement au premier trimestre de 2021. Aucune difficulté n'est envisagée concernant la technologie choisie et le coût de la reconversion.

### **Observations du Secrétariat**

17. Le PNUD a réitéré que le gouvernement du Liban est engagé à interdire l'importation de HCFC-141b d'ici le 1<sup>er</sup> janvier 2021, ce qui permettrait de terminer les essais des divers agents de gonflage et la reconversion de toutes les entreprises de mousse d'ici la fin de 2020. Dans l'éventualité où la reconversion serait menée à terme au premier trimestre de 2021 (surtout à cause de la COVID-19), les entreprises pourraient être autorisées à importer et stocker du HCFC-141b avant que l'interdiction n'entre en vigueur.

18. Quant aux deux entreprises de fabrication de systèmes de climatisation restantes (CGI Halawany et ICR), le PNUD a indiqué que le gouvernement demeure confiant que ces entreprises achèveront leur reconversion d'ici le premier trimestre de 2021.

19. Le Secrétariat a pris note des efforts du PNUD pour aider les entreprises de mousse restantes et les deux entreprises de systèmes de climatisation à terminer leur reconversion à des substances de remplacement sans SAO.

### **Recommandation**

20. Le Comité exécutif pourrait souhaiter :

- a) Prendre note du rapport du PNUD et du gouvernement du Liban présenté dans le document UNEP/OzL.Pro/ExCom/85/9, décrivant les difficultés perpétuelles que rencontre le gouvernement pour trouver une source de substances de remplacement à faible potentiel de réchauffement de la planète (PRG) commercialement viable, telles que les HFO, et les efforts du gouvernement et du PNUD pour faciliter l'approvisionnement d'une technologie à faible PRG dans les entreprises financées à la phase II du plan de gestion de l'élimination des HCFC pour le Liban; et
- b) Demander au PNUD de continuer à aider le gouvernement du Liban à trouver un fournisseur de technologie de remplacement à faible PRG et de faire rapport à la 86<sup>e</sup> réunion et à toutes les réunions suivantes sur l'état de la reconversion des entreprises bénéficiaires restantes dans le secteur de la fabrication de la mousse (SPEC, Prometal et les petites entreprises de mousse) et dans le secteur de la fabrication de systèmes de climatisation (CGI Halawany et ICR), jusqu'à ce que la technologie choisie à l'origine ou une autre technologie à faible PRG ait été complètement intégrée au marché.

## **Rapport en lien avec les PGEH<sup>7</sup>**

### **Argentine : Plan de gestion de l'élimination des HCFC (phase II) : Compte rendu sur la viabilité financière de l'entreprise Celpack (ONUDI)**

#### **Contexte**

21. Le Comité exécutif, à sa 84<sup>e</sup> réunion, a examiné la demande de financement de la deuxième tranche de la phase II du PGEH pour l'Argentine.<sup>8</sup> La demande comprenait un rapport périodique sur la mise en œuvre des activités approuvées à la première tranche. Le rapport indiquait notamment que la reconversion de l'entreprise de mousse de polystyrène extrudé Celpack du HCFC-22 au CO<sub>2</sub> avait été retardée à cause des difficultés économiques auxquelles faisait face l'entreprise et son intérêt à évaluer le butane comme solution de remplacement des HCFC. En approuvant la tranche de financement, le Comité exécutif a demandé à l'ONUDI de remettre un compte rendu sur la viabilité financière de l'entreprise à la 85<sup>e</sup> réunion et d'indiquer si elle comptait faire appel à l'assistance du Fonds multilatéral, étant entendu que les sommes destinées à la reconversion devront être restituées si l'entreprise est retirée du projet (décision 84/64 (d) (ii)).

22. En réponse à la décision 84/64 d) ii), l'ONUDI a informé le Secrétariat que le gouvernement de l'Argentine et l'ONUDI n'avaient pas été capables de terminer l'évaluation de la viabilité financière de Celpack. L'ONUDI a expliqué que la procédure d'évaluation de la viabilité financière de Celpack, qui consiste à nommer un syndic, à vérifier les dettes et à négocier avec les créanciers, avait été lancée. La vérification des dettes de Celpack était en cours à la fin mars 2020. Une visite de suivi planifiée par le Bureau national de l'ozone a été reportée jusqu'à ce que le gouvernement lève les mesures d'isolement imposées à cause de la COVID-19. Les négociations avec les créanciers devraient être menées à terme et la viabilité financière déterminée au cours de la deuxième moitié de 2020. Le rapport sera donc soumis à la 86<sup>e</sup> réunion.

#### **Recommandation**

23. Le Comité exécutif pourrait souhaiter demander au gouvernement de l'Argentine, par l'entremise de l'ONUDI, de remettre à la 86<sup>e</sup> réunion un compte rendu de la viabilité financière de l'entreprise Celpack, bénéficiaire d'un soutien financier à la phase II du plan de gestion de l'élimination des HCFC, de faire connaître la décision de l'entreprise concernant l'assistance du Fonds multilatéral, conformément à la décision 84/64 d) ii), et de retourner les sommes associées à la reconversion à la 86<sup>e</sup> réunion, si l'entreprise est éliminée du projet.

### **Brésil : Plan de gestion de l'élimination des HCFC (phase I : Rapport sur l'utilisation temporaire d'une technologie à PRG élevé à la société de formulation U-Tech et rapport périodique final) (PNUD et gouvernement de l'Allemagne)**

#### **Contexte**

24. Le PNUD, en qualité d'agence d'exécution principale, a remis à la 85<sup>e</sup> réunion,<sup>9</sup> au nom du gouvernement du Brésil, un rapport final sur le programme de travail associé à la phase I du PGEH et le rapport d'achèvement de projet,<sup>10</sup> conformément à la décision 84/32 b) i).<sup>11</sup>

<sup>7</sup> Le rapport sur le PGEH pour l'Uruguay est joint à la proposition de projet (UNEP/OzL.Pro/ExCom/85/52).

<sup>8</sup> UNEP/OzL.Pro/ExCom/84/39

<sup>9</sup> Conformément à la lettre datée du 26 mars 2020, du gouvernement du Brésil au PNUD.

<sup>10</sup> La cinquième et dernière tranche de la phase I du PGEH a été approuvée à la 75<sup>e</sup> réunion pour la somme totale de 2 035 094 \$US, comprenant 1 470 700 \$US, plus les coûts d'appui à l'agence de 110 303 \$US pour le PNUD, et

*Consommation de HCFC*

25. Le gouvernement du Brésil a déclaré une consommation de 826,26 tonnes PAO de HCFC en 2018, ce qui représente 38 pour cent de moins que la valeur de référence pour les HCFC aux fins de conformité. Le gouvernement a aussi communiqué des données sectorielles sur la consommation de HCFC dans son rapport sur la mise en œuvre du programme de pays conformes aux données déclarées en vertu de l'article 7 du Protocole. La consommation de HCFC pour 2019 n'est pas encore connue.

**Rapport final sur la mise en œuvre de la phase I du PGEH**

*Secteur de la fabrication de mousse de polyuréthane*

*Reconversion de 12 entreprises autonomes de mousse de polyuréthane (79,71 tonnes PAO)*

26. Onze entreprises de fabrication de panneaux en continu et de mousse souple moulée ou à pellicule incorporée (dont la consommation s'élève à 76,74 tonnes PAO de HCFC-141b) ont terminé leur reconversion (trois ont choisi les hydrocarbures, trois ont choisi le formiate de méthyle, trois ont choisi le méthylal, une a choisi le chlorure de méthylène et une a choisi une technologie à base d'eau). Une entreprise (Panisol), dont la consommation totale s'élève à 3,0 tonnes PAO de HCFC-141b, s'est retirée du PGEH, de sorte que la consommation associée à l'entreprise n'a pas été éliminée à la phase I. Le solde de financement de 301 695 \$US (plus les coûts d'appui à l'agence de 22 627 \$US) sera retourné au Fonds multilatéral à la 86<sup>e</sup> réunion, au plus tard.

*Reconversion de 11 sociétés de formulation et de 370 utilisateurs de mousse en aval (89,1 tonnes PAO)*

27. Dix des 11 sociétés de formulation visées par le projet ont terminé leur reconversion et développé et mis sur le marché des formules à faible potentiel de réchauffement de la planète (PRG) chez leurs utilisateurs de mousse en aval associés. La somme de 179 300 \$US, plus les coûts d'appui à l'agence de 13 448 \$US pour une entreprise (Arinos), reconnue comme étant non admissible au financement au cours de la mise en œuvre du projet, a été retournée à la 75<sup>e</sup> réunion. De plus, la somme de 135 300 \$US, plus les coûts d'appui à l'agence de 10 148 \$US, affectée à une société de formulation (Polysystem) qui s'est retirée du PGEH, sera retournée au Fonds multilatéral d'ici la 86<sup>e</sup> réunion, au plus tard.

28. Le PNUD a joint au rapport la liste des utilisateurs de mousse en aval visés à la phase I, ainsi que la consommation de HCFC-141b éliminée, le sous-secteur, l'équipement de référence et la technologie adoptée, conformément à la décision 84/32 b) ii). Le rapport indique :

- a) Que 225 entreprises ont terminé leur reconversion à des substances de remplacement à faible PRG, éliminant 85,11 tonnes PAO de HCFC-141b;
- b) Que 39 entreprises de mousse en aval (8,48 tonnes PAO) se sont retirées du PGEH; la consommation de HCFC-141b associée à ces entreprises a été éliminée;
- c) Que 22 entreprises de mousse en aval ont été trouvées non admissibles au soutien financier (consommation non disponible);

---

409 091 \$US, plus les coûts d'appui à l'agence de 45 000 \$US, pour le gouvernement de l'Allemagne. Le Comité exécutif, à la 80<sup>e</sup> réunion, a approuvé le report de la date d'achèvement de la phase I du projet au 31 décembre 2019, étant entendu qu'aucune autre prorogation ne serait demandée (décision 80/12 b)).

<sup>11</sup> Le gouvernement du Brésil, le PNUD et le gouvernement de l'Allemagne ont été priés de remettre le rapport final sur la mise en œuvre du programme de pays associé à la phase I du PGEH jusqu'à son achèvement et le rapport d'achèvement de projet à la 85<sup>e</sup> réunion.



- d) Au cours de la mise en œuvre du projet, il a été découvert que 84 entreprises de mousse en aval, recensées lors de la soumission de la phase I du PGEH, avaient été accidentellement comptées plus d'une fois parce qu'elles achetaient des polyols auprès de plusieurs sociétés de formulation; et
- e) Un solde de 1 597 282 \$US correspondant aux entreprises de mousse en aval qui n'avaient pas reconverti leurs activités pour des raisons de non-admissibilité ou de non-participation au PGEH.

29. Ainsi, le solde total de la mise en œuvre de tous les projets individuels et de groupe dans le secteur de la mousse de polyuréthane s'élève à 2 034 278 \$US, qui sera retourné d'ici la 86<sup>e</sup> réunion, conformément à la décision 84/32 b) iii).

*Secteur de l'entretien de l'équipement de réfrigération*

30. Toutes les activités prévues dans le secteur de l'entretien de l'équipement de réfrigération ont été menées à terme comme indiqué en détail dans les rapports précédents, et la somme totale dépensée a été de 4 090 909 \$US. Il n'y a aucun solde à retourner au Fonds.

*Bureau de la mise en œuvre et du suivi de projet*

31. Le Bureau de la mise en œuvre et du suivi de projet a continué à prêter son appui au Bureau national de l'ozone dans la mise en œuvre des activités du PGEH pendant la mise au point de la phase I du PGEH. La somme de 800 000 \$US a été affectée au Bureau de la mise en œuvre et du suivi de projet de 2012 à 2019.<sup>12</sup>

*Niveau de décaissement*

32. Une somme de 17 323 588 \$US (90 pour cent) des 19 417 866 \$US approuvés avait été décaissée en date de décembre 2019 pour la phase I,<sup>13</sup> (à raison de 13 292 679 \$US pour le PNUD et 4 090 909 \$US pour le gouvernement de l'Allemagne). Le PNUD effectue encore des paiements mineurs à partir du solde de 2 034 278 \$US, et un solde de l'ordre de 2 millions \$US sera retourné au Fonds (tableau 3).

**Tableau 3 : Rapport financier de la phase I du PGEH pour le Brésil**

Agence	Sommes approuvées (\$US)	Sommes décaissées (\$US)		Solde (\$US)
		(\$US)	(%)	
PNUD	15 326 957	13 292 679	87	2 034 278
Gouvernement de l'Allemagne	4 090 909	4 090 909	100	0
<b>Total</b>	<b>19 417 866</b>	<b>17 383 588</b>	<b>90</b>	<b>2 034 278</b>

33. Le PNUD a confirmé que toutes les activités de la phase I étaient terminées en date de décembre 2019, conformément à la décision 80/12 b).

<sup>12</sup> Les détails de la structure de coût du Bureau de la mise en œuvre et du suivi de projet seront remis avec la demande pour la prochaine tranche de la phase II du PGEH à la 86<sup>e</sup> réunion.

<sup>13</sup> Ne comprend pas les 179 300 \$US associés à une entreprise non admissible retournés au Fonds.

## Observations du Secrétariat

### *Secteur de la mousse de polyuréthane*

#### *Achèvement du projet et retour des soldes*

34. Le Secrétariat prend note avec satisfaction du travail méthodique effectué par le gouvernement du Brésil et le PNUD concernant la vérification de l'admissibilité d'un grand nombre de petites et moyennes entreprises de mousse visées à la phase I et de l'achèvement du projet à la date reportée de décembre 2019.<sup>14</sup>

35. En ce qui concerne les 84 entreprises non prises en compte dans le rapport final, le PNUD a confirmé que 76 de ces entreprises figuraient sur la liste finale pendant la mise en œuvre du projet. Quelques entreprises avaient été accidentellement comptées plus d'une fois lors de la préparation du PGEH car elles achetaient des polyols de plusieurs sociétés de formulation. Cette incertitude a été reconnue lors de l'approbation du PGEH, de sorte qu'une des principales tâches lors de la mise en œuvre a été de vérifier l'information sur le terrain et de dresser une liste complète des entreprises admissibles et de l'équipement de référence dans les entreprises de mousse en aval participant au projet. Après avoir vérifié les doublons, le PNUD a regroupé la consommation de ces entreprises et les a traitées comme une seule entreprise de mousse en aval associée à une seule société de formulation. Voilà pourquoi la liste finale contient un moins grand nombre d'entreprises.

36. Le PNUD a aussi confirmé que tous les paiements versés aux entreprises de mousse en aval respectent scrupuleusement les niveaux approuvés par le Comité exécutif (c.-à-d., 15 000 \$US pour les nouveaux distributeurs ou l'adaptation des distributeurs haute pression, 10 000 \$US pour l'adaptation des distributeurs basse pression, 3 000 \$US pour l'assistance technique, les essais et la formation dans les entreprises dont la consommation s'élève à plus de 500 kg par année, et 1 300 \$US pour les entreprises qui consomment moins de 500 kg par année). Le type d'équipement des différentes entreprises participantes et son admissibilité (notamment en ce qui concerne la date limite) ont été vérifiés au cours de la mise en œuvre du projet et convenus pendant la préparation du projet. La liste finale des entreprises proposée par le PNUD précise l'équipement de référence de chacune des entreprises et l'assistance fournie (adaptation du distributeur, nouveau distributeur ou aucune mesure).

37. Le PNUD a aussi souligné que bien que le nombre d'entreprises de mousse en aval figurant sur la liste finale ait été inférieur au nombre figurant sur la liste initiale, 80,06 tonnes PAO ont été éliminées dans les entreprises de mousse en aval ayant reçu de l'assistance, ce qui représente 95 pour cent des 89,1 tonnes PAO financées aux fins d'élimination dans ces entreprises, et que le solde de ce volet s'élevait à 1,6 million \$US. La consommation de HCFC-141b associée aux entreprises non admissibles sera éliminée grâce à un soutien financier à l'extérieur du Fonds multilatéral.

38. Se fondant sur les données détaillées et les explications du PNUD, le Secrétariat a pris note que le PNUD avait suivi scrupuleusement les principes convenus du projet et réalisé l'élimination à un meilleur rapport coût-efficacité que celui de la proposition approuvée. Le tableau 4, ci-dessous, présente un sommaire de la mise en œuvre de la phase I du PGEH pour le Brésil.

---

<sup>14</sup> La phase I du PGEH pour le Brésil a été prolongée à deux reprises; une fois jusqu'en décembre 2017 (UNEP/OzL.Pro/ExCom/75/40) et une autre fois jusqu'en décembre 2019 (décision 80/12 b)).

**Tableau 4 : Sommaire de la mise en œuvre de la phase I du PGEH au Brésil**

Activité	Approbation				Mise en œuvre				Solde (\$US)
	Nbre d'entreprises	Tonnes PAO	Somme approuvée (\$US)	CE (\$US/kg)	Nbre d'entreprises	Tonnes PAO	Somme décaissée (\$US)	CE (\$US/kg)	
Pellicule incorporée	11	47,34	2 238 819	5,20	11	47,34	2 238 819	5,20	-
Panneaux en continu	4	32,35	2 218 791	7,54	3	29,39	1 917 095	7,18	301 696 **
Projet de groupe	11 SF 370 UA	89,03	9 949 347*	12,29	10 SF 225 UA	85,11	8 216 765	10,62	1 732 582 ***
<b>Total pour la mousse</b>	<b>396</b>	<b>168,73</b>	<b>14 406 957</b>	<b>9,39</b>	<b>249</b>	<b>161,84</b>	<b>12 372 680</b>	<b>8,41</b>	<b>2 034 278</b>
Mesures réglementaires	S.o.	1,50	120 000	4,40	S.o.	1,50	120 000	4,40	-
Secteur de l'entretien	S.o.	50,00	4 090 909	4,50	S.o.	50,00	4 090 909	4,50	-
Bureau de la mise en œuvre et du suivi de projet	S.o.		800 000		S.o.		800 000		-
<b>Total</b>		<b>220,23</b>	<b>19 417 866</b>	<b>7,86</b>		<b>213,34</b>	<b>17 383 588</b>	<b>7,22</b>	<b>2 034 278</b>

C.E. : Rapport coût-efficacité; SF : Sociétés de formulation, UA : Utilisateurs de mousse en aval.

\* Comprend une déduction de 179 300 \$US à la cinquième tranche (75<sup>e</sup> réunion) correspondant à la SF Arinos, déclarée non admissible.

\*\* Sommes pour l'entreprise Panisol (3,0 tonnes PAO) qui s'est retirée du PGEH.

\*\*\* Ce solde comprend 135 300 \$US de la SF Polysystem qui s'est retirée du PGEH et environ 1 597 282 \$US des UA.

39. Le solde sera retourné à la 86<sup>e</sup> réunion. Le PNUD a précisé qu'il restait encore certains paiements mineurs à faire, mais a confirmé que la somme à retourner sera de l'ordre de 2 millions \$US.

#### *Utilisation temporaire d'une technologie à PRG élevé*

40. À la 80<sup>e</sup> réunion, le PNUD a expliqué que deux sociétés de formulation (Shimtek et U-Tech) avaient demandé à utiliser temporairement des formules de polyols à base de HFC comprenant des agents de gonflage à PRG élevé, car les HFO n'étaient pas encore vendues commercialement au pays. Les deux sociétés de formulation s'étaient engagées par écrit à cesser l'utilisation temporaire des mélanges à base de HFC dès que les HFO seraient vendues commercialement et que les formules aient été développées et optimisées, sans coût supplémentaire pour le Fonds multilatéral.

41. En conséquence, le Comité exécutif a demandé au PNUD de continuer à aider Shimtek et U-Tech à s'approvisionner en technologie de remplacement choisie, étant entendu que les surcoûts d'exploitation ne seraient payés que lorsque l'utilisation de la technologie de remplacement choisie ou d'une autre technologie à faible PRG sera bien établie. Le Comité exécutif a aussi demandé au PNUD de remettre un rapport sur l'état de l'utilisation de la technologie temporaire jusqu'à ce que la technologie choisie à l'origine ou une autre technologie à faible PRG soit bien établie (décision 80/12 e)), ainsi qu'un compte rendu des fournisseurs sur les progrès accomplis pour faire en sorte que les technologies choisies, ainsi que leurs composants, soient vendus commercialement au pays (décision 81/9). À la 83<sup>e</sup> réunion, le PNUD a rapporté que Shimtek avait choisi une technologie de gonflage à base d'eau en remplacement des HFO pour la fabrication de mousse souple, les modifications nécessaires aux formules devant être payées à même les ressources de la société de fabrication, car le prix des HFO sur le marché demeurerait très élevé, empêchant un approvisionnement en formules à un prix concurrentiel. L'entreprise n'utilise plus les HFC.

42. Le PNUD a reconfirmé que la reconversion de la société de formulation U-Tech était terminée et qu'elle n'utilisait plus de HCFC dans ses polyols, conformément à la décision 84/32 c). U-Tech a adopté le formiate de méthyle pour remplacer le HCFC-141b dans toutes ses applications, sauf la production chez Froth System, où elle compte remplacer le HCFC-22 par des HFO, mais utilise temporairement le HFC-134a. U-Tech a fait l'essai de formules à base de HFO (selon les échantillons reçus à 22 \$US/kg) pendant six mois, afin d'évaluer la stabilité du produit. U-Tech et le fournisseur (Honeywell) sont en voie de mettre au point les derniers détails de l'approvisionnement en agent de gonflage et en composés chimiques connexes. Cependant, selon l'estimation du prix final des HFO à 19,75 \$US/kg, et comme l'a

confirmé verbalement le fournisseur, le coût des formules de polyols augmentera de 33 pour cent, rendant sa part de marché irréalisable.

43. Le Secrétariat a pris note que la phase I du PGEH est terminée et que par conséquent, aucun surcoût d'exploitation ne sera payé aux utilisateurs en aval associés à la reconversion de Froth System à une technologie à faible PRG fournie par U-Tech. Soulignant que U-Tech participera également à la phase II du PGEH, le Secrétariat recommande que le PNUD continue à faire rapport sur les progrès supplémentaires qu'accomplit de U-Tech concernant l'introduction d'une technologie de remplacement à faible PRG dans la production chez Froth System.

### **Recommandation**

44. Le Comité exécutif pourrait souhaiter :

- a) Prendre note :
  - i) Du rapport final sur la mise en œuvre du plan de gestion de l'élimination des HCFC (PGEH) (phase I) pour le Brésil proposé par le PNUD et présenté dans le document UNEP/OzL.Pro/ExCom/85/9;
  - ii) Qu'il existe un solde estimatif de 2 034 278 \$US associé à la mise en œuvre de projets dans le secteur de la mousse de polyuréthane et que le PNUD retournera le solde réel du financement au Fonds multilatéral à la 86<sup>e</sup> réunion; et
- b) Demander au PNUD de continuer à aider le gouvernement du Brésil à approvisionner la société de formulation U-Tech en technologies de remplacement à faible potentiel de réchauffement de la planète (PRG), étant entendu que les surcoûts d'exploitation liés à la reconversion des applications de Froth System ne seront pas payés à la phase II jusqu'à ce que la technologie choisie à l'origine ou une autre technologie à faible PRG ne soit entièrement établie, et de remettre à chaque réunion, jusqu'à ce que la technologie choisie ou une autre technologie à faible PRG soit entièrement établie, un rapport sur l'état de la reconversion, ainsi qu'un compte rendu des fournisseurs sur les progrès accomplis afin que les technologies choisies, ainsi que leurs composants, soient vendus commercialement au pays.

Brésil : Plan de gestion de l'élimination des HCFC (phase II : État de la mise en œuvre des projets dans le secteur de la fabrication de climatiseurs individuels) (ONUDI, PNUD, gouvernements de l'Allemagne et de l'Italie)

### **Contexte**

45. Le gouvernement du Brésil et l'ONUDI ont informé le Comité exécutif, à la 82<sup>e</sup> réunion, que les trois entreprises de climatiseurs individuels visées à la phase II du PGEH n'avaient pas encore débuté leur reconversion au R-290 à cause des incertitudes entourant la réglementation sur l'utilisation de frigorigènes inflammables, de l'acceptation de ces frigorigènes sur le marché, de la crainte des prix plus élevés des climatiseurs reconvertis et de l'absence possible de pièces pour les climatiseurs sur le marché. En conséquence, en approuvant la troisième tranche de la phase II, le Comité exécutif a demandé à l'ONUDI de remettre un rapport à la 84<sup>e</sup> réunion sur l'état de la mise en œuvre des projets dans le secteur de la fabrication des climatiseurs individuels (décision 82/62 c)).

46. En réponse à la décision 82/62 c), l'ONUDI a informé la 84<sup>e</sup> réunion qu'elle avait organisé un atelier pour plus de 60 représentants du secteur de la climatisation en mars 2019 sur l'utilisation de frigorigènes de remplacement dans les climatiseurs individuels, afin d'aborder les craintes des entreprises

de climatiseurs individuels concernant l'introduction de la technologie à base de R-290. De plus, l'ONUDI comptait présenter un deuxième atelier à la fin de 2019 et entreprendre une étude de marché en 2020, en coordination avec le ministère de l'Environnement, portant sur l'acceptabilité du marché, l'évaluation de la perception des clients, l'évaluation des normes de sécurité existantes, les coûts et la disponibilité des pièces, ainsi que les obstacles possibles.

47. Le Comité exécutif a pris note du rapport de l'ONUDI sur l'état de la mise en œuvre des projets dans le secteur de la fabrication de climatiseurs individuels<sup>15</sup> et a demandé à l'ONUDI de présenter de nouveau un rapport sur l'état de la mise en œuvre des projets dans le secteur de la fabrication des climatiseurs individuels à la 85<sup>e</sup> réunion.

### **Rapport périodique**

48. L'ONUDI a soumis un rapport périodique à la 85<sup>e</sup> réunion, dans lequel il rappelle que les préoccupations les plus pertinentes pour les trois entreprises de climatiseurs individuels concernaient l'acceptabilité de l'équipement à base de frigorigènes inflammables sur le marché brésilien, la difficulté à suivre le produit sur le marché secondaire, en précisant qu'une mauvaise installation et un entretien inadéquat peuvent causer des accidents qui nuiraient à l'image de l'entreprise, et le besoin de mettre sur pied des programmes de formation et de renforcement des capacités pour le nouvel équipement.

49. L'ONUDI a organisé un deuxième atelier en novembre 2019 pour les entreprises de fabrication de climatiseurs individuels sur les expériences et les perspectives concernant l'utilisation du R-290 comme frigorigène dans les climatiseurs individuels, afin de régler ces questions. L'atelier offrant des sessions sur les expériences sur le terrain d'entreprises qui travaillaient déjà avec de l'équipement reconverti (telles que Midea en Chine et Godrej en Inde) et a contribué à hausser le niveau de sensibilisation à la technologie. Le gouvernement et l'ONUDI ont aussi lancé un appel d'offres afin de retenir les services d'une entreprise pour réaliser une étude de marché en 2020 sur l'acceptabilité du marché, l'évaluation de la perception des consommateurs, l'évaluation des normes de sécurité existantes, le coût et la disponibilité des pièces, et les obstacles possibles. L'étude devrait prendre fin en septembre 2020.

### **Observations du Secrétariat**

50. Le Secrétariat prend note avec satisfaction des efforts supplémentaires du gouvernement du Brésil et de l'ONUDI pour aider les entreprises de climatiseurs individuels à calmer leur hésitation à choisir une technologie de reconversion à faible de PRG.

51. Prenant note que des craintes persistent concernant l'adoption de frigorigènes inflammables chez les entreprises de climatiseurs individuels et tenant compte des efforts du gouvernement du Brésil et de l'ONUDI pour éviter l'adoption de la technologie à base de R-410A, le Secrétariat recommande que le gouvernement et l'ONUDI continuent à travailler avec les entreprises de climatiseurs individuels afin d'introduire la technologie choisie et de remettre un rapport périodique sur l'état du choix des technologies par les entreprises de climatiseurs individuels à la 86<sup>e</sup> réunion.

### **Recommandation**

52. Le Comité exécutif pourrait souhaiter :

- a) Prendre note du rapport sur l'état de la mise en œuvre des projets dans le secteur de la fabrication de climatiseurs individuels de la phase II du plan de gestion de l'élimination

<sup>15</sup> Décision 84/33 a) i) et c). Le rapport est présenté dans le document UNEP/OzL.Pro/ExCom/84/22

des HCFC (PGEH) pour le Brésil, proposé par l'ONUDI et présenté dans le document UNEP/OzL.Pro/ExCom/85/9; et

- b) Demander à l'ONUDI de remettre un rapport sur l'état de la mise en œuvre des projets dans le secteur de la fabrication des climatiseurs individuels de la phase II du PGEH pour le Brésil à la 86<sup>e</sup> réunion.

### Costa Rica : Plan de gestion de l'élimination des HCFC (phase I : Rapport périodique) (PNUD)

#### Contexte

53. Le Comité exécutif a approuvé la cinquième et dernière tranche de la phase I du PGEH pour le Costa Rica à la 83<sup>e</sup> réunion et a demandé au gouvernement et au PNUD, en tant qu'agence d'exécution désignée, de remettre un rapport périodique sur la mise en œuvre du programme de travail de la dernière tranche de la phase I du PGEH à la 85<sup>e</sup> réunion et le rapport d'achèvement de projet à la première réunion du Comité exécutif de 2022 (décision 83/49).

54. Le PNUD a remis un rapport périodique à la 85<sup>e</sup> réunion, au nom du gouvernement du Costa Rica.

#### Rapport périodique

##### *Consommation de HCFC*

55. Le gouvernement du Costa Rica fait état d'une consommation de 6,31 tonnes PAO de HCFC en 2019 dans son rapport sur la mise en œuvre du programme de pays, ce qui représente 55 pour cent de moins que la valeur de référence pour les HCFC aux fins de conformité. La consommation de 2015-2019 est présentée dans le tableau 5.

**Tableau 5 : Consommation de HCFC au Costa Rica (2015-2019, données communiquées en vertu de l'article 7)**

HCFC	2015	2016	2017	2018	2019*	Référence
<b>Tonnes métriques</b>						
HCFC-22	155,69	155,40	152,56	138,20	92,96	181,88
HCFC-123	19,93	0,00	0,00	(0,64)	0,00	0,36
HCFC-124	2,10	1,50	0,48	0,48	0,00	3,95
HCFC-141b	2,45	20,30	15,22	10,88	10,88	32,59
HCFC-142b	0,67	0,45	0,14	0,14	0,00	6,17
HCFC-225ca	0,00	0,00	0,00	0,00	0,00	-
HCFC-225cb	0,00	0,00	0,00	0,00	0,00	-
<b>Total (tm)</b>	<b>180,84</b>	<b>177,65</b>	<b>168,40</b>	<b>149,06</b>	<b>103,84</b>	<b>224,94</b>
HCFC-141b contenu dans des polyols prémélangés importés*	10,00	11,50	4,49	3,66	3,31	164,64**
<b>Tonnes PAO</b>						
HCFC-22	8,56	8,55	8,39	7,60	5,11	10,00
HCFC-123	2,19	0,00	0,00	(0,01)	0,00	0,01
HCFC-124	0,14	0,10	0,03	0,03	0,00	0,09
HCFC-141b	0,05	2,23	1,67	1,20	1,20	3,58
HCFC-142b	0,01	0,01	0,00	0,00	0,00	0,40
HCFC-225ca	-	0,00	0,00	0,00	0,00	-
HCFC-225cb	-	0,00	0,00	0,00	0,00	-
<b>Total (tonnes PAO)</b>	<b>10,96</b>	<b>10,89</b>	<b>10,10</b>	<b>8,82</b>	<b>6,31</b>	<b>14,10</b>
HCFC-141b contenu dans des polyols prémélangés importés*	1,10	1,27	0,49	0,40	0,36	18,11**

\* Données relatives au programme de pays.

\*\* Point de départ établi dans l'accord avec le Comité exécutif.

56. L'application du programme d'octroi de permis et de quotas, la mise en œuvre des activités dans le secteur de l'entretien de l'équipement de réfrigération au titre du PGEH, la reconversion du plus grand consommateur de HCFC-141b contenu dans des polyols prémélangés importés et l'introduction d'équipement de réfrigération et de climatisation sans HCFC-22 ont entraîné une diminution dans la consommation de HCFC.

*Activités mises en œuvre dans la cinquième et dernière tranche du PGEH*

57. Les activités suivantes ont été mises en œuvre de juillet 2019 à mars 2020 :

- a) Un projet de réglementation pour réglementer les activités des techniciens en entretien d'équipement de réfrigération et de climatisation est à l'étude; l'Instituto Nacional de Aprendizaje (INA) émet actuellement des certificats de bonnes pratiques aux techniciens en réfrigération et climatisation ayant suivi avec satisfaction la formation sur les bonnes pratiques en entretien;
- b) Le Comité technique national (CTN) prépare actuellement une nouvelle série de normes sur l'utilisation sécuritaire d'ammoniaque et d'hydrocarbures dans le secteur de la réfrigération et de la climatisation, en collaboration avec le Bureau national de l'ozone;
- c) Une visite technique pour les étudiants, les techniciens et les propriétaires d'équipement de réfrigération et de climatisation a été organisée en collaboration avec le CTN afin de montrer les nouvelles technologies de remplacement utilisées en réfrigération et en climatisation au pays (p. ex., NH<sub>3</sub>/CO<sub>2</sub> chez Pinova, refroidisseurs à base de R-290); de faire la démonstration de l'efficacité énergétique plus élevée, d'un moins grand nombre d'interventions d'entretien, du niveau moins élevé de fuites de frigorigène et des coûts moins élevés des frigorigènes associés à la technologie, et d'appuyer l'adoption de la norme nationale pour l'ammoniaque;
- d) Suite de la mise en œuvre du programme de destruction des gaz frigorigènes, pour lequel l'accord entre le ministère de l'Environnement et de l'Énergie (MINAE) et le propriétaire du four de cimenterie adapté à la destruction de frigorigènes (Holcim) a été prolongé de deux ans; et coordination avec un réseau d'entreprises autorisées afin de regrouper les gaz frigorigènes recueillis des clients potentiels aux fins de destruction par Holcim; et
- e) Choix de deux consultants techniques qui aideront le Bureau national de l'ozone à effectuer le suivi de la mise en œuvre des activités du PGEH, en tant que membres du Bureau de gestion du projet.

*Niveau de décaissement des sommes*

58. Toutes les sommes destinées au secteur de la mousse et 491 000 \$US pour le secteur de l'entretien avaient été décaissés en décembre, sur la somme totale approuvée de 1 153 523 \$US (comprenant 593 523 \$US pour le projet de reconversion de la mousse et 560 000 \$US pour les activités dans le secteur de l'entretien), ce qui représente 91 pour cent de l'ensemble des fonds. Le solde de 69 000 \$US sera décaissé en 2020.

**Observations du Secrétariat**

59. Le PNUD a indiqué que la contraction économique au cours de la deuxième moitié de 2019 et l'impact de la COVID-19 pourraient retarder l'achèvement de certaines activités du PGEH, notamment l'adoption de technologies éconergétiques à faible potentiel de réchauffement de la planète (PRG).

60. Le plan de travail de la dernière tranche comprenait la formation des douaniers et des techniciens d'entretien, et des ateliers pour les utilisateurs finaux qui n'avaient pas encore été réalisés. Le PNUD a mentionné que la formation des techniciens et les ateliers pour les utilisateurs finaux avaient été prévus pour le premier trimestre de 2020, mais qu'ils ont été retardés à cause de la COVID-19. Malgré l'absence de formation des douaniers, il y a quand même eu coordination entre le ministère des Finances, la Direction générale des douanes, le ministère de la Santé et la Direction générale de l'environnement du MINAE, afin de planifier la formation à offrir lorsque la situation reviendra à la normale. Le PNUD a aussi indiqué que les parties prenantes et les partenaires sont prêts à terminer ces activités de manière efficace le moment venu.

61. Le Secrétariat a pris note des efforts du PNUD pour que les activités prévues à la dernière tranche du PGEH soient mises en œuvre et que la planification et la coordination puissent être réalisées, afin que les activités puissent être menées à terme lorsque la situation reviendra à la normale.

### **Recommandation**

62. Le Comité exécutif pourrait souhaiter :

- a) Prendre note du rapport périodique sur la mise en œuvre de la cinquième et dernière tranche de la phase I du plan de gestion de l'élimination des HCFC (PGEH) pour le Costa Rica proposé par le PNUD et présenté dans le document UNEP/OzL.Pro/ExCom/85/9; et
- b) Demander au gouvernement du Costa Rica et au PNUD de remettre un rapport final sur la mise en œuvre de la phase I du PGEH ainsi que le rapport d'achèvement de projet demandé à la première réunion du Comité exécutif de 2022.

Honduras : Plan de gestion de l'élimination des HCFC (phase I : Rapport périodique sur la mise en œuvre des activités relevant du PNUE) (PNUE)

### **Contexte**

63. Le Comité exécutif, à sa 81<sup>e</sup> réunion, a approuvé la quatrième tranche de la phase I du PGEH pour le Honduras (parmi les projets recommandés pour approbation générale) et le plan de mise en œuvre de la tranche 2018-2020 correspondant, étant entendu que le PNUE et le gouvernement du Honduras intensifieraient leurs efforts pour mettre en œuvre des activités de formation pour les techniciens en réfrigération, que le PNUE remettrait un rapport périodique sur les activités de mise en œuvre relevant du PNUE, comprenant les décaissements, à chaque réunion jusqu'à la soumission de la cinquième tranche de la phase I, que les cibles de décaissement pour la somme totale approuvée pour les activités du volet relevant du PNUE pour la première, deuxième et troisième tranches étaient de 50 pour cent au 30 septembre 2018, 80 pour cent au 31 mars 2019 et 100 pour cent en décembre 2019, et que les cibles de décaissement pour les volets relevant du PNUE pour la quatrième tranche étaient de 20 pour cent au 31 mars 2019 et de 50 pour cent en décembre 2019.

64. Le PNUE a par la suite remis un rapport périodique aux 82<sup>e</sup>, 83<sup>e</sup> et 84<sup>e</sup> réunions. Le gouvernement du Honduras et le PNUE ont mis en œuvre certaines activités de formation pour les techniciens en réfrigération, mais d'autres activités n'ont pas connu les progrès escomptés et les cibles de décaissement fixées à la 81<sup>e</sup> réunion n'ont pas été atteintes. Comme des mesures devaient encore être prises afin de respecter certains engagements, le Comité exécutif a pris note, à la 84<sup>e</sup> réunion, que la cinquième tranche de la phase I ne pourra être soumise que lorsque les conditions suivantes auront été respectées :



- a) Achèvement de la formation des douaniers et des agents chargés de l'application sur la réglementation des importations de HCFC et d'équipement à base de HCFC, couvrant 31 points d'entrée de douane;
- b) Achèvement de la mise en place d'un système électronique d'enregistrement des importateurs, fournisseurs et utilisateurs finaux;
- c) Progrès importants dans la révision des normes techniques, dont les mesures de sécurité concernant les frigorigènes inflammables; et
- d) Décaissement complet de toutes les sommes approuvées pour les volets relevant du PNUE des première, deuxième et troisième tranches de la phase I du PGEH, et décaissement de 70 pour cent pour le volet du PNUE à la quatrième tranche.

65. Le Comité exécutif a aussi demandé au PNUE de continuer à remettre un rapport périodique sur la mise en œuvre de toutes les activités des volets relevant du PNUE, et les décaissements effectués, à chaque réunion, jusqu'à la soumission de la cinquième tranche de la phase I du PGEH (décision 84/18).

66. Le PNUE a remis un rapport périodique et un rapport financier sur la mise en œuvre des activités du PNUE de la phase I à la 85<sup>e</sup> réunion, conformément à la décision 84/18.<sup>16</sup>

### Rapport périodique

67. Les activités suivantes ont été mises en œuvre depuis la 84<sup>e</sup> réunion :

- a) Un consultant international a préparé un programme de formation pour les douaniers et les agents chargés de l'application;
- b) Des arrangements ont été faits pour embaucher un expert régional avant avril 2020, qui aurait pour mandat d'élaborer le système électronique d'enregistrement des importateurs, fournisseurs et utilisateurs finaux; la matière des modules d'apprentissage en ligne a été préparée; et la base de données devrait être créée et entièrement fonctionnelle d'ici août 2020;
- c) Trois membres du personnel du Bureau national de l'ozone et neuf instructeurs de l'institut national de formation (INFOP) ont été certifiés en bonnes pratiques de manipulation des frigorigènes et des lubrifiants en Colombie;<sup>17</sup> le Bureau national de l'ozone et l'INFOP ont organisé un atelier pour poursuivre le développement d'un programme national de certification des techniciens en réfrigération conformément à la norme de main-d'œuvre du Honduras;<sup>18</sup> et des activités de sensibilisation du public aux bonnes pratiques de réfrigération, ainsi que des documents d'information pour les techniciens sur le processus de certification ont été organisés;
- d) Un nombre total de 129 élèves et 98 techniciens ont reçu une formation en bonnes pratiques de réfrigération et en manipulation sécuritaire des substances de remplacement des SAO; et

<sup>16</sup> La cinquième et dernière tranche de la phase I du PGEH pour le Honduras présentée à la 85<sup>e</sup> réunion par l'ONUDI, en qualité d'agence d'exécution principale, a été retirée pendant l'examen des projets, car les conditions énoncées à la décision 84/18 n'avaient pas toutes été respectées.

<sup>17</sup> Norme de main-d'œuvre de la Colombie 280501022.

<sup>18</sup> La norme de main-d'œuvre du Honduras (code B712703) sur « Les bonnes pratiques en réfrigération et en climatisation » a été adoptée en septembre 2019.

- e) L'utilisation des centres de recyclage et de régénération a été encouragée au cours des séminaires et des ateliers, et il y a eu des discussions pour mettre sur pied trois centres de régénération des frigorigènes couvrant les régions géographiques dans lesquelles la consommation de frigorigènes est la plus élevée.

#### *Niveau de décaissement*

68. Une somme de 144 514 \$US (82,6 p. cent) des 175 000 \$US approuvés pour le PNUE pour les trois premières tranches avait été décaissée au 15 mars 2020, et la somme totale de 8 213 \$US (16,4 p. cent) des 50 000 \$US approuvés pour le PNUE pour la quatrième tranche a été décaissée,<sup>19</sup> comme indiqué dans le tableau 6.

**Tableau 6 : Rapport financier de la phase I du PGEH pour le Honduras (\$US)**

Tranche	Somme approuvée	Somme décaissée*	Taux de décaissement (%)	Somme avancée**	Total	Décaissement + taux d'avancement (%)
Première	75 000	67 047	89,4	7 953	75 000	100,0
Deuxième	50 000	49 467	98,9	0	49 467	98,9
Troisième	50 000	28 000	56,0	22 000	50 000	100,0
<b>Total partiel</b>	<b>175 000</b>	<b>144 514</b>	<b>82,6</b>	<b>29 953</b>	<b>174 467</b>	<b>99,7</b>
Quatrième	50 000	8 213	16,4	25 900	34 113	68,2

\* Consigné dans Umoja.

\*\* Financement avancé par le PNUE au gouvernement du Honduras et pas encore consigné dans Umoja.

#### *Compte rendu sur le plan de mise en œuvre de la phase I du PGEH*

69. Les activités suivantes sont prévues d'ici décembre 2020 :

- a) Achèvement de la formation des douaniers et des agents chargés de l'application sur la réglementation des importations de HCFC et de l'équipement à base de HCFC, couvrant 31 points d'entrée de douane;
- b) Mise au point du système électronique d'enregistrement des importateurs, fournisseurs et utilisateurs finaux, et développement des modules d'apprentissage en ligne;
- c) Mise en œuvre du programme de certification des techniciens en réfrigération et promotion de son application, et mise à jour du matériel technique et de sensibilisation du public;
- d) Élaboration d'une norme de certification pour la manipulation des frigorigènes inflammables;
- e) Certification en bonnes pratiques d'entretien de 100 techniciens en réfrigération; et
- f) Hausse du niveau de sensibilisation à la valeur de la régénération des frigorigènes, formation en utilisation de frigorigènes naturels, amélioration du programme de certification des techniciens en réfrigération, mise sur pied d'un programme de confinement des frigorigènes, de contrôle des fuites et de bonnes pratiques de

<sup>19</sup> Comprenant des sommes engagées ou avancées par le PNUE au Honduras (sommés pas encore consignés dans Umoja, le logiciel de planification des ressources utilisé par le PNUE). La somme totale des fonds décaissés ou avancés, ou engagés dans le cadre des trois premières tranches s'élevait à 174 467 \$US (99,6 p. cent) et à 18 107 \$US (68 p. cent) pour la quatrième tranche, au 15 mars 2020

réfrigération à l'intention des utilisateurs finaux, et réalisation de mises à jour techniques au centre de régénération et recyclage.

### **Observations du Secrétariat**

70. Les conditions fixées dans la décision 84/18 d) pour la soumission de la cinquième tranche de la phase I du PGEH n'ont pas encore été respectées, plus particulièrement le programme de formation des douaniers et des agents chargés de l'application qui devait débiter au mois de mars 2020 et qui a été retardé à cause de l'éclosion de la COVID-19; la base de données électronique pour l'enregistrement des importateurs, fournisseurs et utilisateurs finaux devrait être fonctionnelle d'ici août 2020; la formulation d'une norme de manipulation des frigorigènes inflammables devrait débiter en août 2020; et le programme de promotion du confinement des frigorigènes destiné aux utilisateurs finaux n'a pas encore été établi.

71. De plus, les taux de décaissement pour les trois premières tranches (100 p. cent) et la quatrième tranche (70 p. cent) n'ont pas été atteints. Le PNUE a engagé 55 853 \$US qui seront décaissés à l'achèvement des activités en cours, une somme supplémentaire de 16 420 \$US n'a pas été engagée.

72. L'ONUDI a aussi présenté une demande pour la cinquième tranche de la phase I du PGEH pour le Honduras à la 85<sup>e</sup> réunion. Toutefois, comme plusieurs engagements énoncés à la décision 84/18 n'ont pas été respectés, le Comité exécutif n'a pas pu examiner la tranche de financement. Le PNUE et l'ONUDI espèrent que la dernière tranche de la phase I pourra être soumise avec la phase II du PGEH pour le Honduras, à la 86<sup>e</sup> réunion.

### **Recommandation**

73. Le Comité exécutif pourrait souhaiter prendre note :

- a) Du rapport périodique sur la mise en œuvre des activités du volet de la phase I du plan de gestion de l'élimination des HCFC (PGEH) pour le Honduras qui relèvent du PNUE, proposé par le PNUE et présenté dans le document UNEP/OzL.Pro/ExCom/85/9;
- b) Que la cinquième et dernière tranche de la phase I du PGEH pourra être soumise lorsque les conditions énoncées dans la décision 84/18 b) auront été respectées.

Inde : Plan de gestion de l'élimination des HCFC (phase II : Compte rendu sur l'évaluation des entreprises de fabrication de panneaux de mousse en continu concernant le respect de l'interdiction) (PNUD, PNUE et gouvernement de l'Allemagne)

## Contexte

74. Le gouvernement de l'Inde interdit l'utilisation des HCFC, dont le HCHC-141b pur et contenu dans des polyols prémélangés, dans la fabrication de mousse isolante pour les réfrigérateurs domestiques et les panneaux sandwich en continu depuis le 1<sup>er</sup> janvier 2015. Pourtant, le PNUD a soumis la demande de la deuxième tranche de la phase II du PGEH<sup>20</sup> à la 82<sup>e</sup> réunion<sup>21</sup> et a rapporté que deux fabricants de panneaux sandwich en continu avaient signé un protocole d'entente avec le gouvernement. Dans ces circonstances, le PNUD a précisé que le gouvernement était en train d'évaluer si ces entreprises avaient respecté l'interdiction.

75. Par conséquent, le Comité exécutif a demandé au gouvernement de l'Inde, par l'entremise du PNUD, de remettre à la 83<sup>e</sup> réunion, un compte rendu de l'évaluation visant à déterminer si les entreprises de fabrication de panneaux de mousse en continu avaient respecté l'interdiction visant les HCFC, en précisant que si le gouvernement devait déterminer que ces entreprises ne respectaient pas l'interdiction, le protocole d'entente avec ces entreprises prendrait fin et toute somme décaissée devra être retournée au Fonds multilatéral, conformément à la décision 77/43 d) ii).<sup>22</sup> Il a aussi été indiqué qu'aucune entreprise de fabrication de panneaux de mousse en continu ne pourra participer à la phase II jusqu'à ce que le Comité exécutif d'évalue son admissibilité.<sup>23</sup>

76. Le PNUD a rapporté à la 83<sup>e</sup> réunion que l'évaluation menée par le gouvernement était toujours en cours. En conséquence, le Comité exécutif a demandé au gouvernement, par l'entremise du PNUD, de présenter l'évaluation à la 84<sup>e</sup> réunion.<sup>24</sup> Le PNUD a indiqué à la 84<sup>e</sup> réunion que l'évaluation se poursuivait toujours et a confirmé qu'aucune somme n'avait été décaissée à ces entreprises et que les sommes seraient retournées si l'évaluation devait conclure que les deux entreprises n'avaient pas respecté les cibles d'élimination du 1<sup>er</sup> janvier 2015. Le PNUD a également mentionné que l'évaluation devait encore subir la procédure légale et gouvernementale établie en Inde et qu'il n'était pas possible de savoir quand la procédure serait terminée. Par conséquent, le Comité exécutif a demandé au gouvernement de l'Inde, par l'entremise du PNUD, de remettre les conclusions de son évaluation quant au respect de l'interdiction par les entreprises à la 85<sup>e</sup> réunion, conformément à la décision 82/74 b) et c).<sup>25</sup>

77. Au cours des préparatifs pour la 85<sup>e</sup> réunion, le PNUD a fait savoir qu'il était impossible de confirmer l'état de l'évaluation et que le compte rendu ne pourra pas être présenté comme demandé, à cause de la COVID-19.

## Recommandation

78. Le Comité exécutif pourrait souhaiter demander au gouvernement de l'Inde, par l'entremise du PNUD, de remettre à la 86<sup>e</sup> réunion l'évaluation du gouvernement quant au respect de l'interdiction visant les HCFC par les entreprises de fabrication de panneaux de mousse en continu depuis le 1<sup>er</sup> janvier 2015, conformément à la décision 82/74 b) et c).

---

<sup>20</sup> La phase II du PGEH a été approuvée à la 77<sup>e</sup> réunion.

<sup>21</sup> 3-7 décembre 2018.

<sup>22</sup> Décision 82/74 b) i)

<sup>23</sup> Décision 82/74 c)

<sup>24</sup> Décision 83/21

<sup>25</sup> Décision 84/34 b) ii)

Indonésie : Plan de gestion de l'élimination des HCFC (phase I: Compte rendu sur l'état de la reconversion des entreprises de fabrication de réfrigérateurs et de climatiseurs, et plan d'action révisé) (PNUD)

79. Le PNUD, en qualité d'agence d'exécution principale, a soumis à la 85<sup>e</sup> réunion, au nom du gouvernement de l'Indonésie :

- a) Un rapport sur l'état des entreprises qui fabriquent temporairement de l'équipement de réfrigération et de climatisation à base de frigorigènes à potentiel de réchauffement de la planète (PRG) élevé ayant reçu un soutien financier pour reconvertir à des substances de remplacement à faible PRG, conformément aux décisions 77/35, 81/11 c) et 83/22 c); et
- b) Un plan d'action révisé pour la reconversion des entreprises Gita Mandrin Teknik, Fata Sarana Makmur et Sumo Elco Mandiri, ainsi qu'une autre demande de reporter la date d'achèvement de la phase I du plan de gestion de l'élimination des HCFC (PGEH), conformément à la décision 84/35 d) ii).

### Contexte

80. La phase I du PGEH portait sur la reconversion de 48 entreprises du secteur de la fabrication d'équipement de réfrigération et de climatisation à des technologies à faible PRG. Au cours de la mise en œuvre, 28 entreprises (16 entreprises du secteur de la climatisation et 12 entreprises du secteur de la réfrigération commerciale) ont décidé de reconvertir à des technologies à PRG élevé en utilisant leurs propres ressources, et ont retourné la somme de 3 134 216 \$US plus les coûts d'appui à l'agence au Fonds multilatéral.

81. Il a été rapporté à la 83<sup>e</sup> réunion qu'une seule (Panasonic) des 20 entreprises restantes fabriquait de l'équipement de climatisation en utilisant une technologie à base de HFC-32. Huit moyennes et grandes entreprises avaient fabriqué des prototypes d'équipement à base de HFC-32, huit petites entreprises n'avaient pas reçu de commandes pour de l'équipement à base de HFC-32 et les trois autres entreprises attendaient toujours le marché pour l'équipement à base de HFC-32 avant de reconvertir leurs activités. À l'heure actuelle, 19 entreprises fabriquent de l'équipement en utilisant des frigorigènes à PRG élevé.

82. Le PNUD a rapporté à la 84<sup>e</sup> réunion que onze entreprises<sup>26</sup> s'étaient retirées du projet. De plus, une entreprise (Aneka Cool) avait décidé de confier son processus de mousse isolante de polyuréthane à base de HCFC-141b en sous-traitance. Le Comité exécutif a ainsi pris note du retrait de onze entreprises du projet et que le financement connexe (764 842 \$US plus les coûts d'appui à l'agence de 57 363 \$US pour le PNUD) serait retourné à la 85<sup>e</sup> réunion (décision 84/35 b) i); et que le financement (60 000 \$US plus les coûts d'appui à l'agence de 4 538 \$US pour le PNUD) associé à l'entreprise ayant confié son processus de mousse isolante en sous-traitance serait retourné à la 85<sup>e</sup> réunion (décision 84/35 b) ii)).

83. Le PNUD a aussi indiqué que les deux entreprises ci-dessous avaient éprouvé des difficultés techniques pendant leur reconversion :

- a) Metropolitan Bayu Industri, une entreprise de fabrication de climatiseurs commerciaux, avait construit huit prototypes utilisant des frigorigènes à base de HFC-32; d'autres améliorations ont toutefois été nécessaires. Le PNUD a proposé de continuer à fournir

<sup>26</sup> Trois entreprises de réfrigération commerciale (Mentari Metal Pratama, Polysari Citratama et Inti Tunggal) et huit entreprises du sous-secteur de l'assemblage d'équipement de réfrigération commercial (Sabindo Refrigeration, Global Technic, AVIS Alpin Servis Tr, Aneka Froze Triutama, Graha Cool Technic, United Refrigeration, Gaya Technic Supply and Ilthabi Mandiri Tech).

une assistance technique et de décaisser des surcoûts d'exploitation lorsque la fabrication à base de HFC-32 commencerait; et

- b) Rotaryana Prima, une entreprise de fabrication de réfrigérateurs et de climatiseurs, avait fabriqué huit prototypes utilisant un frigorigène à base de HFC-32, mais à faible rendement. À la suite de récentes mises à jour de la norme 60335-2-89 de la Commission électrotechnique internationale, qui permettent une charge de frigorigènes A3 pouvant atteindre 500 g,<sup>27</sup> l'entreprise a décidé de reconverter au frigorigène à base de R-290. Dans ces circonstances, le Comité exécutif a approuvé le changement de technologie sans coût supplémentaire pour le Fonds (décision 84/35 c)).

84. Le PNUD a aussi indiqué que trois entreprises supplémentaires, Gita Mandrin Teknik, Fata Sarana Makmur et Sumo Elco Mandiri, fabriquaient de l'équipement sous la marque de l'entreprise et une marque de fabricant d'équipement d'origine. Les équipements de cette dernière sont à base de frigorigènes à PRG élevé, tandis que les premiers sont à base de HFC-32. Le PNUD a proposé que la portion des surcoûts d'exploitation approuvés associée à la fabrication d'équipement sous la marque de l'entreprise soit dégagée lorsque la fabrication à base de HFC-32 sera confirmée, et que la portion sous la marque du fabricant d'équipement d'origine soit retournée au Fonds multilatéral à la 85<sup>e</sup> réunion. Enfin, trois autres entreprises, Tata Udari, Alpine Cool et Aneka Cool, ont décidé de continuer à participer au projet et de reconverter leur fabrication au HFC-32. Ces entreprises ne fabriquent pas d'équipement d'origine.

85. À l'issue d'échanges informels entre les membres du Comité exécutif intéressés, le Comité exécutif a décidé :

- a) De prendre note que Gita Mandrin Teknik, Fata Sarana Makmur et Sumo Elco Mandiri avaient décidé de reconverter leurs chaînes de production à une technologie à base de HFC-32, qu'elles fabriqueraient de l'équipement à base de HFC-32 sous les marques de leurs entreprises et qu'elles fabriqueraient temporairement de l'équipement utilisant des frigorigènes à PRG élevé pour les commandes d'équipement provenant des fabricants d'équipement d'origine;
- b) De reporter la date d'achèvement de la phase I du PGEH pour l'Indonésie au 30 juin 2020, étant entendu que le PNUD remettrait à la 85<sup>e</sup> réunion, un plan d'action révisé pour la reconversion de ces entreprises et une demande possible de reporter la date d'achèvement de la phase I du PGEH; et
- c) D'examiner les conséquences possibles de la consommation de HFC sur le point de départ de la réduction globale durable à la 85<sup>e</sup> réunion, conformément à la décision 82/30 g) ii) (décision 84/35).

#### Progrès accomplis en date de la 85<sup>e</sup> réunion

86. Le PNUD a présenté le compte rendu suivant sur l'état de la reconversion des cinq entreprises de réfrigération et climatisation que ne fabriquent pas d'équipement sous la marque de fabricant d'équipement d'origine :

- a) La reconversion d'Industri Tata Udari est terminée, y compris la reconversion des échangeurs de chaleur et des chaînes de transformation des feuilles, et l'adaptation

---

<sup>27</sup> Les frigorigènes A3 sont caractérisés par la propagation de flammes à 60°C et 101,3 kPa, et ont une limite d'inflammabilité inférieure ou égale à 0,1 kg/m<sup>3</sup> ou moins ou une chaleur de combustion supérieure ou égale à 19 000 kJ/kg

requis de la chaîne d'assemblage. Des prototypes ont été fabriqués et approuvés par les clients, et l'entreprise commercialise de l'équipement à base de HFC-32. Les surcoûts d'exploitation (14 161 \$US) devraient être décaissés d'ici décembre 2020;

- b) Metropolitan Bayu Industri a amélioré la conception de l'échangeur de chaleur; les prototypes d'appareils attendent d'être déployés et les surcoûts d'exploitation (14 287 \$US) seront décaissés d'ici décembre 2020;
- c) Rotaryana a terminé la reconversion de sa chaîne de fabrication au R-290, et les premiers prototypes ont été déployés et ont été déclarés entièrement fonctionnels. L'entreprise travaille à améliorer l'efficacité énergétique de ses appareils et à former davantage son personnel et les utilisateurs finaux sur l'utilisation sécuritaire et l'entretien. Les surcoûts d'exploitation (25 296 \$US) devraient être décaissés d'ici décembre 2020; et
- d) Alpine Cool et Aneka Cool ont terminé leur reconversion au frigorigène à base de HFC-32, les prototypes ont été conçus et mis à l'essai chez les clients, et les appareils sont commercialisés. Les surcoûts d'exploitation (40 160 \$US pour Alpine Cool et 17 510 \$US pour Aneka Cool) devraient être décaissés d'ici décembre 2020.

87. En ce qui concerne les trois entreprises qui fabriquent également de l'équipement d'origine, le PNUD a rapporté :

- a) Que Gita Mandiri Teknik s'est engagée à ne plus fabriquer de l'équipement d'origine à cause des pertes de parts de marché de l'équipement d'origine qu'elle fabrique et des coûts plus élevés de cet équipement, et à fabriquer exclusivement de l'équipement à base de HFC sous sa propre marque;
- b) Que Fata Sarana Makmur ne fabrique pas d'équipement d'origine utilisant des frigorigènes à PRG élevé à l'heure actuelle à cause d'une absence de demande de la part du fabricant d'équipement d'origine et parce que le contrat avec le fabricant d'équipement d'origine, qui prend fin en juin 2020, ne sera pas reconduit. L'entreprise fabriquera exclusivement de l'équipement à base de HFC-32, sous sa propre marque; et
- c) Que Sumo Elco Mandiri fabriquait de l'équipement pour deux fabricants d'équipement d'origine, dont un fabricant installé dans un pays visé à l'article 5 ayant ratifié l'Amendement de Kigali. Le fabricant de l'équipement d'origine a décidé de mettre fin à son contrat avec l'entreprise à cause de la réduction progressive des HFC dans ce pays et des défis qu'aurait posé le maintien des exportations d'équipement à base de frigorigènes à PRG élevé dans ce pays. L'autre fabricant d'équipement d'origine a cessé ses activités en Indonésie en janvier 2020 à cause des restrictions du marché des exportations, et la société mère continue à vendre des pièces et des composants en Indonésie par l'entremise de ses distributeurs. L'entreprise ne fabrique que de l'équipement sous sa propre marque depuis janvier 2020, et tout l'équipement fabriqué sera à base de HFC-32.

88. Les trois entreprises ont terminé leur reconversion à un frigorigène à base de HFC-32. Gita Mandiri et Sumo Elco commercialisaient déjà de l'équipement à base de HFC-32 en Indonésie, tandis que Fata Sarana Makmur prévoit commercialiser l'équipement à base de HFC-32 en juin 2020, lorsque le contrat avec le fabricant d'équipement d'origine prendra fin. Les surcoûts d'exploitation (249 738 \$US) pour les trois entreprises devraient être décaissés aux entreprises d'ici décembre 2020, à l'achèvement du projet. Le gouvernement de l'Indonésie a proposé de prolonger la mise en œuvre de la phase I du PGEH jusqu'au 31 décembre 2020 afin de permettre aux entreprises restantes de commercialiser de l'équipement utilisant une technologie à faible PRG.

89. Le PNUD a retourné la somme de 825 342 \$US plus les coûts d'appui à l'agence de 61 901 \$US à la 85<sup>e</sup> réunion, conformément à la décision 84/35 b) et comme indiqué dans le Rapport sur les soldes et la disponibilité des ressources.<sup>28</sup>

### Observations du Secrétariat

90. Le Secrétariat a pris note avec satisfaction des efforts du gouvernement, de l'industrie et du PNUD pour surmonter les difficultés à introduire de l'équipement à faible PRG sur le marché et a pris note en particulier que les entreprises ayant décidé de continuer à participer au projet ne fabriquent plus d'équipement de réfrigération et de climatisation utilisant un frigorigène à PRG élevé.

91. Quant aux conséquences possibles sur le point de départ de la réduction globale durable de la consommation de HFC (décision 82/30 g) ii), le Secrétariat recommande de n'effectuer aucun changement au point de départ car les entreprises qui ont décidé de continuer à participer au projet ne fabriquent plus d'équipement de réfrigération et de climatisation à base de frigorigènes à PRG élevé.

92. Prenant note que les entreprises continuant à participer au projet ont reconverti leurs activités à des technologies à faible PRG, le Secrétariat a recommandé que le PNUD ne soumette qu'un seul rapport périodique final complet à la 88<sup>e</sup> réunion au lieu de soumettre des rapports périodiques annuels, étant entendu qu'il comprendrait les données globales sur les ventes d'équipement de réfrigération et de climatisation à base de HCF-32 et de R-290 fabriqué par les entreprises participant toujours au projet.

### Recommandation

93. Le Comité exécutif pourrait souhaiter :

94. Prendre note du compte rendu sur l'état de la reconversion des entreprises de fabrication de réfrigérateurs et de climatiseurs et du plan d'action révisé pour la phase I du plan de gestion de l'élimination des HCFC (PGEH) pour l'Indonésie, proposé par le PNUD et présenté dans le document UNEP/OzL.Pro/ExCom/85/9;

- a) Reporter la date d'achèvement de la phase I du PGEH pour l'Indonésie au 31 décembre 2020; et
- b) Demander au gouvernement de l'Indonésie et au PNUD de remettre un rapport périodique final sur la mise en œuvre de la phase I du PGEH qui comprendrait des données globales sur les ventes d'équipement à faible potentiel de réchauffement de la planète par les entreprises participant au projet et le rapport d'achèvement de projet d'ici le 30 juin 2021.

Malaisie : Plan de gestion de l'élimination des HCFC (phase II : Changement de technologie dans 14 entreprises) (PNUD)

### Contexte

95. Le Comité exécutif, à sa 77<sup>e</sup> réunion, a approuvé, en principe, la phase II du plan de gestion de l'élimination des HCFC (PGEH) pour la Malaisie<sup>29</sup> pour la période 2016 à 2022, afin de réduire la consommation de HCFC de 42,9 pour cent de sa valeur de référence, pour la somme de 6 138 063 \$US, plus les coûts d'appui à l'agence de 429 665 \$US pour le PNUD.

---

<sup>28</sup> UNEP/OzL.Pro/ExCom/85/4.

<sup>29</sup> UNEP/OzL.Pro/ExCom/77/54



96. La phase II comprenait le financement de la reconversion de 67 entreprises de mousse de polyuréthane, dont 57 étaient de petites et moyennes entreprises (PME), à des solutions de remplacement à faible potentiel de réchauffement de la planète (PRG); dix entreprises non admissibles élimineront leur consommation sans l'appui du Fonds multilatéral, ce qui contribuera à une élimination complète du HCFC-141b dans le secteur de la mousse de polyuréthane d'ici le 1<sup>er</sup> janvier 2022. Une démarche par étapes a été utilisée, dans le cadre de laquelle les entreprises qui consommaient 20 tonnes métriques (tm) ou plus reconvertiraient leurs activités au cyclopentane ou à des formules de polyols prémélangés à base de cyclopentane, et les plus petites entreprises reconvertiraient leurs activités à des formules à base d'hydrofluorooléfines réduites (HFO) à la deuxième et à la troisième phases, bien que certains pourraient reconvertir au méthylal.

97. Le PNUD a indiqué à la 84<sup>e</sup> réunion que des protocoles d'entente avaient été signés avec 12 entreprises, dont deux qui ont terminé leur reconversion au cyclopentane et ainsi éliminé 12,32 tonnes PAO de HCFC-141b; la reconversion de huit autres entreprises suit son cours et entraînera l'élimination de 28,99 tonnes PAO de HCFC-141b, et deux plus petites entreprises, dont la consommation s'élève à 2,54 tonnes PAO de HCFC-141b, devraient terminer leur reconversion en 2020.

98. Le PNUD a également indiqué que sept entreprises (Allied Foam, Astino, Century, Gai Hin, Hewgant, Insulated Box et Roto Speed) envisageaient un changement de technologie des HFO au cyclopentane prémélangé pour le gonflage de la mousse à cause des inquiétudes entourant l'approvisionnement stable en formules de polyols prémélangés à base de cyclopentane provenant de quatre sociétés de formulation au pays. Ces entreprises n'ont pas encore pris de décision car les différentes formules sont encore à l'essai. Le Secrétariat a évalué les surcoûts admissibles de la reconversion à des formules de polyols prémélangés à base de cyclopentane, et a confirmé que ce changement de technologie ne donnerait lieu à aucune économie. Le PNUD a aussi confirmé que les entreprises cofinanceraient les coûts supplémentaires associés au changement de technologie. En conséquence, le Comité exécutif a décidé que ces entreprises pourront, si elles le souhaitent, adopter une technologie à base de cyclopentane prémélangé lors de la mise en œuvre, étant entendu que la reconversion ne doit pas être retardée et que les coûts supplémentaires seront payés par les entreprises; et que le PNUD remettrait un rapport sur cette situation lors de la demande de financement de la troisième tranche du PGEH (décision 84/77 b)).

#### Demande de changement de technologie

99. Le gouvernement, par l'entremise du PNUD, a soumis à la 85<sup>e</sup> réunion une demande de changement de technologie pour 14 entreprises, pour passer des HFO aux formules de polyols prémélangés à base de cyclopentane, conformément au paragraphe 7 a) v) de l'accord entre le gouvernement de la Malaisie et le Comité exécutif, comme indiqué dans le tableau 7. Le PNUD a confirmé que les entreprises cofinanceraient les coûts supplémentaires associés au changement de technologie, s'il y a lieu.

**Tableau 7 : Entreprises reconvertissant des HFO aux formules de polyols prémélangés à base de cyclopentane**

Entreprise	Application	HCFC-141b (tm)	Financement approuvé (\$US)
Komiya Roofing (M) Sdn Bhd	Panneaux en discontinu	9,00	55 731
Power Cool Engineering S/B	Réfrigération commerciale	8,40	52 393
Coolaxis sdn Bhd	Panneaux en discontinu	7,80	49 054
CoolMax Refrigeration Industries	Panneaux en discontinu	7,00	44 603
SJ Classic Industries Sdn Bhd	Panneaux en discontinu	6,91	44 092
PS Coldroom Panels Supplies	Panneaux en discontinu	6,80	43 491
Hi-tech Preinsulated Pipes S/B	Tuyaux	6,11	39 652
Ngui Soon ColdRoom & Refrigeration (Snowfall)	Transport	6,00	39 040

Entreprise	Application	HCFC-141b (tm)	Financement approuvé (\$US)
P.K.T Insulation Trading	Panneaux en discontinu	6,00	39 040
NYC Products Sdn bhd	Panneaux en discontinu	5,75	37 649
Top Amity Sdn Bhd	Panneaux en discontinu	5,01	33 532
Chong Brothers Coldroom Eng. Sdn Bhd	Panneaux en discontinu	5,00	33 476
Perniagaan Nam Sing S/B	Réfrigération commerciale	3,00	22 349
Lian Pang Refrigeration & Electrical S/B	Réfrigération commerciale	1,20	12 334
<b>Total</b>		<b>83,98</b>	<b>546 436</b>

### Observations du Secrétariat

100. Les sept entreprises qui avaient demandé une certaine souplesse pour le changement de technologie à du cyclopentane prémélangé à la 84<sup>e</sup> réunion ont maintenant terminé les essais et décidé de changer au cyclopentane prémélangé. Le Secrétariat a effectué une évaluation approfondie des surcoûts admissibles de la reconversion des 14 entreprises aux formules de polyols prémélangés à base de cyclopentane, qui a confirmé que le changement de technologie ne donnerait lieu à aucune économie. En conséquence, prenant note de la disponibilité sur le marché des formules de cyclopentane prémélangé provenant des quatre sociétés de formulation au pays et de la reconversion réussie des autres entreprises de mousse à cette technologie de remplacement, le Secrétariat a recommandé l'approbation du changement de technologie.

### Recommandation

101. Le Comité exécutif pourrait souhaiter :

- a) Prendre note de la demande présentée par le PNUD au nom du gouvernement de la Malaisie concernant le changement de technologie des hydrofluorooléfines (HFO) aux formules de polyols prémélangés à base de cyclopentane dans 14 entreprises de mousse à la phase II du plan de gestion de l'élimination des HCFC (PGEH), présentée dans le document UNEP/OzL.Pro/ExCom/85/9; et
- b) D'approuver le changement de technologie pour ces 14 entreprises, des HFO aux formules de polyols prémélangés à base de cyclopentane, étant entendu que les reconversions ne doivent pas être retardées et que les coûts supplémentaires seront payés par les entreprises.

Maroc : Plan de gestion de l'élimination des HCFC (phase I : Rapport périodique) (ONUDI et PNUD)

### Contexte

102. L'ONUDI, en qualité d'agence d'exécution principale, soumet au nom du gouvernement du Maroc, le rapport périodique annuel sur la mise en œuvre du programme de travail associé à la troisième et dernière tranche du PGEH,<sup>30</sup> conformément à la décision 83/57 d).<sup>31</sup>

### *Consommation de HCFC*

<sup>30</sup> Approuvé à la 83<sup>e</sup> réunion pour la somme totale de 35 000 \$US, plus les coûts d'appui à l'agence de 2 625 \$US pour l'ONUDI.

<sup>31</sup> Demander au gouvernement du Maroc et à l'ONUDI de remettre des rapports périodiques sur la mise en œuvre du programme de travail associé à la troisième et dernière tranche, chaque année jusqu'à l'achèvement du projet, des rapports de vérification jusqu'à l'approbation de la phase II du PGEH et le rapport d'achèvement de projet à la première réunion du Comité exécutif en 2022.

103. Le gouvernement du Maroc a estimé la consommation de HCFC à 25,50 tonnes PAO pour l'année 2019, ce qui représente 38 pour cent de moins que l'objectif établi dans l'accord avec le Comité exécutif pour cette même année, et 50 pour cent de moins que la valeur de référence de 51,35 tonnes PAO.

#### *Rapport de vérification*

104. La vérification de la consommation de HCFC pour l'année 2019 avait été planifiée avant la soumission du rapport périodique associé à la troisième tranche du PGEH. Les contraintes imposées dans le sillage de la pandémie de la COVID-19 au moment de la publication du document ont fait en sorte que la vérification n'a pu avoir lieu.

#### *Secteur de la fabrication*

105. La reconversion des activités de fabrication de mousse à Manar Company est terminée et a entraîné l'élimination de 11,0 tonnes PAO de HCFC-141b. L'interdiction d'importer du HCFC-141b pur est entrée en vigueur le 1<sup>er</sup> janvier 2015 et le niveau d'importation de HCFC-141b est nul depuis 2014.

#### *État de la mise en œuvre des activités prévues à la troisième tranche*

106. Vingt-six identifiants de frigorigènes supplémentaires ont été achetés en vue d'une livraison en avril 2020, conformément au plan de mise en œuvre de la troisième tranche, et une distribution subséquente aux douanes, à l'association de réfrigération et au centre de formation situé dans la capitale (Rabat). Un atelier de formation sur l'utilisation des frigorigènes devrait être offert à l'arrivée des identifiants.

107. Deux techniciens internationaux ont été recrutés afin d'offrir une formation théorique et pratique aux techniciens d'entretien. La formation sera axée sur les dernières technologies et la pénétration du marché, les questions de sécurité et la bonne gestion des frigorigènes inflammables pendant l'entretien, et les meilleures pratiques d'entretien, dont la récupération et le recyclage.

108. L'achat d'outils et d'équipement d'entretien de l'équipement de réfrigération aux fins de distribution aux techniciens formés, notamment les appareils de récupération et de recyclage, a été entrepris, mais a dû être interrompu à cause de la pandémie de la COVID-19. Le processus d'achat sera mené à terme en quelques semaines lorsqu'il reprendra. On prévoit que l'équipement sera distribué avant la fin de l'année 2020, au plus tard.

109. Le matériel de sensibilisation à la qualité des frigorigènes est en voie d'être mis à jour. Il sera traduit dans les langues locales et distribué aux parties prenantes.

110. La phase I du PGEH pour le Maroc sera achevée à la fin de 2020, comme prévu.

#### *Niveau de décaissement des fonds*

111. Une somme totale de 192 635 \$US (58 p. cent) des 335 000 \$US approuvés avait été décaissée en date du mois de mars 2020. Le solde de 142 365 \$US sera décaissé d'ici décembre 2020, comme indiqué dans le tableau 8.

**Tableau 8 : Rapport financier de la phase I du PGEH pour le Maroc, en date de mars 2020 (\$US)**

Tranche	Somme approuvée	Somme décaissée	Pourcentage décaissé (%)	Solde
Première	80 000	77 078	96	2 922
Deuxième	220 000	115 557	53	104 443
Troisième	35 000	0	0	35 000
<b>Total</b>	<b>335 000</b>	<b>192 635</b>	<b>58</b>	<b>142 365</b>

## Observations du Secrétariat

112. La consommation de HCFC pour l'année 2018, au moment de la soumission de la demande de financement de la troisième tranche du PGEH, était basée sur la consommation déclarée dans le rapport de vérification (23,24 tonnes PAO),<sup>32</sup> car la consommation en vertu de l'article 7 du Protocole de Montréal et relative au rapport sur la mise en œuvre du programme de pays n'avait pas encore été déclarée. Par la suite, le gouvernement du Maroc a déclaré une consommation de 25,66 tonnes PAO en vertu de l'article 7 et en lien avec le programme de pays. L'ONUDI a expliqué les divergences dans les données en précisant que les données communiquées en vertu de l'article 7 et dans le rapport relatif au programme de pays représentaient le total du quota émis pour 2018, une quantité supérieure à la quantité réellement importée, confirmée par le rapport de vérification. L'ONUDI a informé le gouvernement de la nécessité de réviser les données communiquées en vertu de l'article 7 et dans le rapport relatif au programme de pays pour l'année 2018. Le PNUE (l'agence d'exécution pour le renforcement des institutions) aidera le gouvernement à présenter une demande de correction des données sur la consommation de 2018 en fonction du rapport de vérification de 2018.

113. Le rapport périodique de la troisième tranche de la phase I du PGEH doit être accompagné d'un rapport de vérification. Prenant note que l'achèvement du rapport de vérification serait retardé à cause des contraintes imposées par la pandémie de la COVID-19 et que la consommation de HCFC pour l'année 2019 a été de 50 pour cent de moins que la valeur de référence, le Secrétariat recommande l'approbation de ce rapport périodique, à titre exceptionnel et sans établir de précédent, étant entendu que :

- a) L'ONUDI s'est engagée à remettre le rapport de vérification accompagné du rapport périodique sur la mise en œuvre de la troisième tranche au plus tard douze semaines avant la 87<sup>e</sup> réunion;
- b) Les recommandations contenues dans le rapport de vérification seront abordées au cours de la mise en œuvre de la troisième tranche et que les mesures prises à cet égard seront intégrées au rapport périodique de la phase I du PGEH; et
- c) Advenant la situation improbable où le gouvernement du Maroc ne respecterait pas son accord avec le Comité exécutif, le Comité exécutif prendra des mesures pertinentes.

114. Le Secrétariat a posé des questions sur l'intégration de la formation sur la protection de la couche d'ozone au programme de formation de routine des douaniers. L'ONUDI a indiqué que cette intégration est prévue à la phase II du PGEH. Le gouvernement prévoit également renforcer les instituts de formation professionnelle et mettre sur pied un programme de certification à la phase II, afin de soutenir la formation des techniciens en réfrigération et en climatisation.

115. En ce qui concerne les progrès accomplis dans la préparation d'un inventaire de l'équipement à base de HCFC-22 et l'introduction de normes d'efficacité énergétique, l'ONUDI a indiqué que ces normes concernant l'étiquetage des valeurs énergétiques de l'équipement de réfrigération et de climatisation ont été publiées; les normes concernant l'étiquetage des valeurs énergétiques des autres produits, tels que les chauffe-eau, les sècheuses et les chauffe-eau à cuve d'accumulation, sont en voie de développement. Elles devraient contribuer à améliorer l'efficacité énergétique de l'équipement à base de HCFC-22.

---

<sup>32</sup> UNEP/OzL.Pro/ExCom/83/32

## Recommandation

116. Le Comité exécutif pourrait souhaiter prendre note du rapport périodique sur la mise en œuvre de la phase I du plan de gestion de l'élimination des HCFC (PGEH) pour la Maroc proposé par l'ONUDI et présenté dans le document UNEP/OzL.Pro/ExCom/85/9, étant entendu que :

- a) L'ONUDI s'est engagée à ce que le rapport de vérification soit remis au Secrétariat au plus tard douze semaines avant la 87<sup>e</sup> réunion, que les recommandations figurant dans ce rapport soient abordées pendant la mise en œuvre de la troisième tranche de la phase I du PGEH, et que les mesures mises en œuvre à cet égard soient intégrées au rapport périodique de la phase I du PGEH; et
- b) Advenant que le rapport de vérification confirme que le Maroc ne respecte pas le Protocole de Montréal et son accord avec le Comité exécutif, le Secrétariat en informerait le Comité exécutif afin que des mesures pertinentes, notamment l'imposition d'une pénalité, puissent être envisagées.

République de Moldova : Plan de gestion de l'élimination des HCFC (phase II – Rapport détaillé sur l'état de la mise en œuvre des projets de démonstration sur l'utilisation de technologie à base de CO<sub>2</sub> dans le secteur de la réfrigération commerciale) (PNUD)

## Contexte

117. 1. Lors de sa 84<sup>e</sup> réunion, le Comité exécutif a approuvé le financement de la deuxième tranche de la phase II du PGEH pour la République de Moldova, en étant entendu que le gouvernement, par le truchement du PNUD, présentera à la 85<sup>e</sup> réunion un rapport détaillé sur l'état de la mise en œuvre des projets de démonstration pour l'utilisation de technologie à base de CO<sub>2</sub> dans le secteur de la réfrigération commerciale (décision 84/55 a)). Par la suite, le PNUD a remis le rapport sur l'état de la mise en œuvre des projets de démonstration.

118. Voici les objectifs des projets de démonstration : promouvoir des économies d'énergie et de coûts associées, entre autres, à la réduction de la consommation de frigorigènes; démontrer l'utilisation sécuritaire de la technologie innovatrice; sensibiliser les utilisateurs finaux aux technologies disponibles et au fait que l'utilisation de la technologie à base de CO<sub>2</sub> entraîne une augmentation de l'espace disponible à l'intérieur des installations; et démontrer les avantages environnementaux connexes, à la fois pour l'ozone et le climat, associés à cette technologie.

119. À l'issue d'un appel d'offres, les deux entreprises suivantes ont été sélectionnées :

- a) Forward International SRL, impliquée dans des opérations d'entreposage frigorifique. La capacité de réfrigération de l'équipement à installer est de 189,6 kW pour refroidir un espace d'entreposage d'environ 11 000 mètres cubes; et
- b) STS Trading SRL, impliquée dans des opérations de commerce de détail en épicerie. La capacité de réfrigération de l'équipement à installer est de 5 kW dans une pièce avec quatre comptoirs.

120. Forward International SRL a déjà importé l'équipement et finalisé tous les travaux de construction et de rénovation. L'équipement sera testé et devrait être fonctionnel d'ici la fin mars 2020. Concernant STS Trading SRL, le contrat pour l'acquisition de l'équipement, l'assemblage sur place, la mise en service et l'entretien initial a été signé, les travaux de rénovation sont en cours et l'équipement devrait être importé d'ici la mi-mars 2020.

121. Les deux projets devraient être opérationnels et achevés d'ici la fin juin 2020; toutefois il pourrait y avoir des retards à cause de la COVID-19 qui affecte la disponibilité des composantes. La diffusion des résultats et des enseignements tirés des projets de démonstration se fera dans le cadre d'un séminaire qui se tiendra au cours du deuxième semestre de 2020.

### **Observations du Secrétariat**

122. Suite à une question sur la réglementation visant à promouvoir l'adoption de frigorigènes naturels, le PNUD a expliqué que le gouvernement de la République de Moldova harmonise progressivement son cadre réglementaire avec la législation de l'Union européenne, y compris le cadre réglementaire dans le secteur de la réfrigération et de la climatisation; le gouvernement a aussi l'intention de ratifier l'Amendement de Kigali au Protocole de Montréal, en 2021. Le gouvernement élaborera un plan d'action pour la réduction progressive des HFC et continuera de renforcer le cadre réglementaire afin de soutenir la transition graduelle vers des technologies à base de frigorigènes à faible potentiel de réchauffement de la planète (PRG), tels que les hydrocarbures, l'ammoniac et le CO<sub>2</sub> et des technologies de remplacement, telles que le refroidissement naturel et autres procédés.

123. En termes d'efficacité énergétique, on s'attend à des gains d'environ 20 pour cent; toutefois les gains réels seront connus après avoir mesuré les résultats durant de multiples saisons.

124. Quant à une intensification de l'adoption de cette technologie, le PNUD a expliqué que le gouvernement prévoit prendre des mesures de sensibilisation et de diffusion des expériences auprès des bénéficiaires et mettre en place une formation et une accréditation obligatoire pour les techniciens qui travaillent avec des frigorigènes naturels. L'adoption de ces technologies à une plus grande échelle sera un processus à plus long terme, au fur et à mesure de l'acquisition de connaissances et d'expériences nouvelles avec les frigorigènes naturels et lorsque les coûts deviendront comparables à ceux des technologies disponibles.

125. Le Secrétariat a demandé des précisions sur les différences dans les niveaux de cofinancement par les deux entreprises, en prenant note que le projet fournissait 32 000 \$US à chaque entreprise et que Forward International SRL et STS Trading SRL fournissaient respectivement un cofinancement de 192 000 \$US et de 18 000 \$US. Le PNUD a expliqué que ces deux entreprises étaient les seules qui avaient décidé de participer aux projets de démonstration; donc la subvention octroyée par le projet a été partagée également entre les deux. Les coûts totaux de la reconversion et les niveaux de cofinancement différaient en raison des différences dans la configuration de l'équipement et dans l'infrastructure des composantes de chaque entreprise.

126. Le PNUD a précisé aussi que le solde de 2 000 \$US serait utilisé pour le soutien technique et la sensibilisation aux résultats des projets de démonstration.

### **Recommandation**

127. Le Comité exécutif pourrait souhaiter prendre note du rapport détaillé sur l'état de la mise en œuvre des projets de démonstration qui utilisent une technologie à base de CO<sub>2</sub> dans le secteur de la réfrigération commerciale de la phase II du plan de gestion de l'élimination des HCFC en République de Moldova, soumis par le PNUD et contenu dans le document UNEP/OzL.Pro/ExCom/85/9.

## **Projets de démonstration sur les solutions de remplacement à faible PRG pour les HCFC**

Argentine et Tunisie : Projet de démonstration sur l'introduction d'une technologie à base de CO<sub>2</sub> transcritique pour les supermarchés : Rapport final (ONUDI)

### **Contexte**

128. Le Comité exécutif, à sa 76<sup>e</sup> réunion, a approuvé le projet de démonstration sur l'introduction d'une technologie à base de CO<sub>2</sub> transcritique dans les supermarchés (Argentine et Tunisie)<sup>33</sup> pour la somme de 846 300 \$US, plus les coûts d'appui à l'agence de 59 241 \$IS pour l'ONUDI (décision 76/27).

129. Le projet a été approuvé dans le but d'aider à l'introduction d'une technologie de réfrigération à base de CO<sub>2</sub> transcritique dans les pays visés à l'article 5 en éliminant les obstacles tels que le manque de connaissance sur les systèmes de réfrigération à base de CO<sub>2</sub> transcritique, la disponibilité limitée des pièces d'équipement et le coût initial élevé de la reconversion. Il permettrait également d'évaluer le rendement et l'efficacité énergétique de la technologie à base de CO<sub>2</sub> transcritique dans des scénarios réels et l'efficacité énergétique de l'utilisation de CO<sub>2</sub> dans les systèmes centralisés de réfrigération dans les supermarchés.

130. Le projet comprend l'introduction de systèmes de réfrigération à base de CO<sub>2</sub> transcritique dans deux supermarchés choisis en Argentine et en Tunisie, situés dans des conditions climatiques moyennement chaudes. Le projet devrait être reproduit dans d'autres pays, afin d'encourager l'utilisation de frigorigènes à faible PRG dans le secteur de l'assemblage.

131. Le sous-projet conçu pour le supermarché La Anónima à Lincoln, en Argentine, a été mis en œuvre avec succès. Le sous-projet destiné au supermarché Monoprix en Tunisie a été annulé après l'étape initiale de la conception, par manque d'intérêt.<sup>34</sup> Les soldes de financement des deux sous-projets seront retournés au Fonds multilatéral au 31 décembre 2020, au plus tard.

132. L'ONUDI a soumis le rapport final du projet de démonstration au nom du gouvernement de l'Argentine (le rapport final est joint à l'annexe III au présent document).

### **Mise en œuvre du projet**

133. Le sous-projet en Argentine a permis l'introduction d'un système auxiliaire de CO<sub>2</sub> transcritique comprenant une compression en parallèle et un système de sous-refroidissement à base de R-290 dans le supermarché La Anónima, doté de systèmes de réfrigération centrale à basse et haute températures à base de HCFC-22 et plusieurs congélateurs autonomes (îlots et congélateur d'étalage vertical) à base de HFC-404A. La consommation d'électricité des systèmes de réfrigération de La Anónima a été mesurée séparément avant et après la reconversion, afin de comparer la consommation du système de référence à celle du système reconverti. Les données sur les températures et les conditions climatiques en général ont aussi été recueillies auprès de la station météorologique la plus proche pour la durée de la période de mesure.

134. Le système à base de CO<sub>2</sub> transcritique a été développé par EPTA<sup>35</sup> avec l'assistance de ses sièges en Italie et au Royaume-Uni, d'après les exigences techniques fournies par l'ONUDI et le Bureau national de l'ozone. L'équipement des systèmes centraux de réfrigération à base de CO<sub>2</sub> transcritique, les évaporateurs et le sous-refroidisseur ont été fabriqués par EPTA en Italie et livrés sur place, et tous les calculs de tuyauterie ont été rajustés localement.

<sup>33</sup> UNEP/OzL.Pro/ExCom/76/56

<sup>34</sup> Paragraphe 157 du document UNEP/OzL.Pro/ExCom/82/20 et décision 82/22 d).

<sup>35</sup> EPTA refrigeration: <https://www.eptarefrigeration.com/en>

135. L'aménagement du supermarché et la configuration du nouveau système de réfrigération sont presque identiques à ceux du système de référence. Les appareils autonomes à base de R-404A ont été remplacés et intégrés au système centralisé à base de CO<sub>2</sub>. La capacité réfrigérante du nouveau système est de 78,32 kW (68,79 kW pour le circuit à température moyenne et 9,53 kW pour le circuit à basse température), ce qui est légèrement inférieur à celle du système d'origine, qui est de 82,14 kW (72,09 kW pour les armoires à température positive à base de HCFC-22 et la chambre froide et 10,05 kW pour les armoires à basse température et les chambres froides à base de R-404A).

136. Un système de réfrigération centrale à plusieurs compresseurs a été installé afin de répondre à la demande de réfrigération. Un sous-refroidisseur à base de R-290 (charge de frigorigène de 1,7 kg) a été installé dans une aire ouverte afin d'augmenter l'efficacité énergétique pendant les périodes chaudes de l'année. La tuyauterie a été changée afin d'accommoder des pressions de fonctionnement plus élevées de la boucle et harmoniser le système à la charge de frigorigène moins élevée. Des soupapes de sécurité ont été installées pour dégager la pression lorsqu'elle dépasse 120 barres et assurer la sécurité associée à l'utilisation de CO<sub>2</sub>. Des détecteurs de fuite et des alarmes ont été installés afin de détecter les fuites de CO<sub>2</sub> et déclencher la fermeture des robinets électroniques pour éviter les risques de suffocation et développer la concentration de CO<sub>2</sub>.

137. Le nouveau système de réfrigération a été installé en décembre 2017 et fonctionne depuis janvier 2018. Les données ont été recueillies afin d'évaluer le rendement du système et sa consommation d'énergie. Il n'y a eu aucune fuite de CO<sub>2</sub> depuis le début de l'utilisation du système. Le frigorigène à base de CO<sub>2</sub> peut être acheté localement en cas de fuite du système. La mise en œuvre du processus de reconversion a été menée à terme sans interruption des activités du supermarché. La machinerie de référence n'a été démantelée qu'après la mise en marche et les essais réussis du nouveau système.

138. Le personnel de La Anónima a reçu une formation du fabricant sur l'installation, la mise en marche, le fonctionnement et l'entretien du système, ainsi que sur la procédure à suivre pour intervenir dans un système à base de CO<sub>2</sub> sous pression, les procédures d'entretien telles que le remplacement du filtre et de l'huile, et le contrôle du voyant en verre, la gestion des commandes électroniques des grilles et du système de réfrigération, et le fonctionnement du système de suivi. Le Bureau national de l'ozone a aussi offert une formation en bonnes pratiques de manipulation des frigorigènes à faible PRG, dont le CO<sub>2</sub>, et plus de 700 techniciens ont été formés. Un atelier a été organisé en marge de la réunion de Groupe de travail à composition non limitée à Bangkok, en juillet 2019, afin de diffuser les résultats du projet.

### **Résultats de la démonstration**

139. La mise en œuvre du sous-projet en Argentine a eu les résultats suivants :

- a) Le système de réfrigération à base de CO<sub>2</sub> transcritique est techniquement viable aux fins d'utilisation dans les supermarchés dans des conditions climatiques semblables à celles de Lincoln, en Argentine, et toutes les pièces du système sont vendues localement et ailleurs au monde à prix raisonnable;
- b) Selon l'expérience industrielle et la documentation technique, l'investissement initial du système de réfrigération à base de CO<sub>2</sub> transcritique est plus élevé que pour un système à base de HFC car les pressions plus élevées exigent de la tuyauterie plus robuste et un travail de soudure supérieur lors de l'installation. L'installation d'un système semblable à base de R-404A coûte environ 20 pour cent de moins qu'un système à base de CO<sub>2</sub> transcritique et de 10 à 13 pour cent de moins qu'un système à base de HFC/glycol, aux prix actuels;
- c) La consommation d'électricité d'un système à base de CO<sub>2</sub> transcritique est de 27,64



pour cent de moins que celle du système de référence à base de HCFC-22/R-404A<sup>36</sup> selon les mesures prises sur une période de onze mois (janvier à novembre) avant la reconversion en 2017 et en 2018. La facture d'électricité (comprenant d'autres utilisations de l'électricité) a entraîné des économies annuelles d'environ 9 200 \$US;

- d) La réduction des émissions de gaz à effet de serre calculée par l'ONUDI s'est élevée à 856,33 t d'éqCO<sub>2</sub> pour les émissions directes,<sup>37</sup> à 834,90 t d'éqCO<sub>2</sub> attribuables au remplacement du HCFC-22 et du R-404A, et à 21,43 t d'éqCO<sub>2</sub> pour les émissions indirectes<sup>38</sup> et les économies d'électricité de 68 453 kW;
- e) Le taux de fuite inférieur du système à base de CO<sub>2</sub>, le prix plus bas du frigorigène à base de CO<sub>2</sub> par rapport aux frigorigènes synthétiques, et une consommation d'électricité plus faible semblent aboutir à des coûts de fonctionnement moins élevés; et
- f) La fréquence de l'entretien préventif du système à base de CO<sub>2</sub> transcritique est semblable à celle des systèmes à base de HCFC-22/R-404A.

140. Grâce aux bons résultats du projet de démonstration, La Anónima a conclu une entente avec EPTA pour l'adoption du CO<sub>2</sub> transcritique comme technologie par défaut dans les nouvelles installations et comme technologie de remplacement dans ses 162 installations réparties dans 85 villes en Argentine. Le nombre de supermarchés équipés de systèmes à base de CO<sub>2</sub> transcritique en Argentine est maintenant de 13 répartis dans sept chaînes de supermarchés. Sur la scène régionale, EPTA a installé trois autres systèmes au Chili, un en Colombie et 12 en Équateur depuis 2017.

### Rapport financier

141. Une somme de 508 135 \$US a été décaissée sur les 527 169 \$US approuvés pour le sous-projet en Argentine. Le sous-projet en Tunisie a été annulé après la mobilisation des équipes techniques et l'élaboration et l'approbation des mandats par tous les partenaires. Des coûts de 20 000 \$US ont été engagés pour ces préparatifs. Le solde sera retourné au Fonds d'ici la fin de 2020, conformément à la décision 82/22. Les dépenses réelles du projet de démonstration par rapport aux sommes budgétées sont présentées dans le tableau 9.

**Tableau 9 : Ventilation des coûts du projet de démonstration sur les systèmes de réfrigération à base de CO<sub>2</sub> transcritique (\$US)**

Élément	Budget approuvé	Décaissements	Solde
<b>Sous-projet en Argentine</b>			
Nouvel équipement de réfrigération	389 866	484 372	
Armoires vitrées pour la nourriture	102 303		
Travaux d'ingénierie et transport	15 000		
Ateliers pour diffuser les résultats du projet	20 000	23 763	
<b>Total partiel en Argentine</b>	<b>527 169</b>	<b>508 135</b>	<b>19 034</b>
<b>Sous-projet en Tunisie</b>			
Nouvel équipement de réfrigération	245 347	0	
Armoires vitrées pour la nourriture	43 784	0	

<sup>36</sup> Les données des onze premiers mois (janvier à novembre), calculées d'après la consommation annuelle cumulative d'électricité en 2017 (avant la reconversion) et en 2018 (après l'installation du système à base de CO<sub>2</sub> transcritique) ont été mesurées et les données du dernier mois ont été extrapolées à partir des mesures prises pour les onze mois.

<sup>37</sup> Selon l'hypothèse de l'absence de fuites de CO<sub>2</sub> et de R-290 dans le système de réfrigération à base de CO<sub>2</sub> transcritique.

<sup>38</sup> Basé sur 313 t d'éqCO<sub>2</sub>/kWh pour obtenir l'intensité nécessaire pour produire l'électricité en Argentine.

Élément	Budget approuvé	Décaissements	Solde
Travaux d'ingénierie et transport	10 000	0	
Ateliers, consultant, réunions et déplacements	20 000	20 000	
<b>Total partiel en Tunisie</b>	<b>319 131</b>	<b>20 000</b>	<b>299 131</b>
<b>Totaux (Argentine + Tunisie)</b>	<b>846 300</b>	<b>528 135</b>	<b>318 165</b>

### Observations du Secrétariat

142. Le Secrétariat a pris note que le projet devait être achevé en 30 mois, à l'origine. La consommation d'électricité du système de réfrigération a été mesurée avant et après la reconversion afin d'obtenir des données sur l'amélioration de l'efficacité énergétique associée au système de réfrigération à base de CO<sub>2</sub> transcritique. Il s'agit du premier projet dans lequel la consommation d'électricité d'un système de réfrigération est réellement mesurée et qui procure des données directes sur l'amélioration de l'efficacité énergétique d'un système après la reconversion d'un système à base de HCFC/HFC à un système de réfrigération à base de CO<sub>2</sub> transcritique dans un supermarché.

143. La mise en œuvre du projet a permis d'acquérir énormément de connaissances sur la conception, l'installation, la mise en marche, le fonctionnement et l'entretien du système de réfrigération à base de CO<sub>2</sub> transcritique dans les supermarchés. Le projet a fait la démonstration que la technologie de réfrigération à base de CO<sub>2</sub> transcritique est techniquement et économiquement viable aux fins d'installation dans les pays visés à l'article 5 ayant des conditions climatiques douces et a donné confiance pour l'adoption de la technologie pour remplacer les systèmes à base de HCFC et de HFC dans les supermarchés dans les pays visés à l'article 5.

144. L'information contenue dans le rapport final indique que l'investissement supérieur peut être récupéré avec le temps grâce à une consommation d'électricité réduite et à la réduction possible des fuites de frigorigènes pendant le fonctionnement.

145. L'adoption de la technologie entraînera une réduction permanente des gaz à effet de serre et aura des conséquences positives pour le climat. La démonstration a offert une solution technologique durable pour l'élimination des HCFC et des HFC dans les supermarchés et la technologie est en voie d'être adoptée dans plusieurs pays de la région, ce qui contribuera à l'élimination durable des HCFC et des HFC en général.

146. Le Secrétariat a demandé des explications concernant les mesures de sécurité en lien avec l'installation du sous-refroidisseur dans une aire ouverte. L'ONUDI a précisé qu'il est important de délimiter un espace autour du sous-refroidisseur dans lequel la chaleur, les étincelles, les flammes ouvertes, les surfaces chaudes et le tabagisme sont interdits, et de développer des mesures de sécurité convenables qui respectent les règles nationales de sécurité et l'envergure de la charge sur le site d'installation, car le R-290 est un frigorigène inflammable. En Argentine, le sous-refroidisseur a été installé sur le toit, où il existe une bonne ventilation naturelle, et il n'a donc pas été nécessaire d'installer des capteurs spéciaux.

147. Le Secrétariat a pris note que le rapport final regroupait le coût de l'équipement de réfrigération, des armoires vitrées pour la nourriture, des travaux d'ingénierie et du transport dans une somme globale non ventilée comme dans le budget proposé. L'ONUDI a indiqué que le projet a été contracté par EPTA, qui considère les détails des coûts comme étant confidentiels, et qui ne les a pas communiqués à l'ONUDI. Le Secrétariat a pris note que le projet de démonstration est le premier projet de la région ayant pour but de quantifier l'amélioration de l'efficacité énergétique de la technologie et que les coûts détaillés changeront avec l'installation d'un plus grand nombre de systèmes. De plus, le coût global du système de réfrigération à base de CO<sub>2</sub> transcritique indiqué dans le rapport est un bon indicateur du coût initial.

## Recommandation

148. Le Comité exécutif pourrait souhaiter :

- a) Prendre note avec satisfaction du rapport final du projet de démonstration sur l'introduction d'une technologie à base de CO<sub>2</sub> transcritique pour les supermarchés en Argentine et en Tunisie proposé par l'ONUDI et présenté dans le document UNEP/OzL.Pro/ExCom/85/9; et
- b) Inviter les agences bilatérales et d'exécution à tenir compte du rapport final du projet de démonstration dont il est question à l'alinéa a) ci-dessus lorsqu'elles aident les pays visés à l'article 5 à préparer des projets dans le secteur de la réfrigération commerciale.

Mondial (régions de l'Afrique de l'Est et des Caraïbes) : Projet de démonstration sur la qualité et le confinement des frigorigènes et l'introduction de substances de remplacement à faible PRG dans le secteur de la réfrigération et de la climatisation (rapport final) (ONUDI)

## Contexte

149. Le Comité exécutif a approuvé, à sa 76<sup>e</sup> réunion, le projet de démonstration sur la qualité et le confinement des frigorigènes, et l'introduction de substances de remplacement à faible potentiel de réchauffement de la planète (PRG) pour les régions de l'Afrique et l'Est et des Caraïbes pour la somme de 425 650 \$US, comprenant 50 000 \$US, plus les coûts d'appui à l'agence de 6 500 \$US pour le PNUE, et 345 000 \$US, plus les coûts d'appui à l'agence de 24 150 \$US pour l'ONUDI, conformément à la décision 72/40 (décision 76/36).

150. Le Comité exécutif a annulé le volet mis en œuvre par le PNUE à la 82<sup>e</sup> réunion, car aucun progrès n'avait été accompli, et a reporté la date d'achèvement du volet mis en œuvre par l'ONUDI au 31 juillet 2019, étant entendu qu'aucun autre report ne serait demandé, et l'ONUDI a été invitée à remettre le rapport final à la 84<sup>e</sup> réunion, au plus tard (décision 82/22 c)). Le PNUE a retourné l'ensemble du financement pour son volet à cette même réunion (56 500 \$US).

151. Conformément à la décision 82/22 c), l'ONUDI a remis un rapport périodique sur le projet de démonstration à la 84<sup>e</sup> réunion. Au cours de l'examen du rapport périodique, le Secrétariat a pris note que des renseignements supplémentaires étaient nécessaires, notamment en ce qui concerne la sécurité lors de l'adaptation d'équipement à base de HCFC-22 à des frigorigènes inflammables, les résultats du rendement et de l'entretien des appareils à base d'hydrocarbures installés dans tous les pays des Caraïbes, l'examen de l'impact des réglementations et des normes sur l'acquisition de la technologie dans ces pays, les conclusions sur les outils nécessaires pour assurer le fonctionnement des appareils dotés de frigorigènes inflammables selon l'expérience acquise au centre régional de Grenade, la pertinence des frigorigènes contrefaits pour le Bureau national de l'ozone, les enseignements tirés des mesures pratiques pour garantir la qualité des frigorigènes sur les marchés des pays, les mesures de suivi et d'application nécessaires afin de réduire le risque d'importation et de vente locale de frigorigènes contrefaits, et un rapport financier détaillé.

152. Prenant note du peu de temps disponible pour aborder toutes les questions soulevées par le Secrétariat, le Comité exécutif a décidé de prendre note que l'ONUDI soumettrait un rapport final sur le projet ainsi que le rapport d'achèvement de projet à la 85<sup>e</sup> réunion, et que les soldes inutilisés seraient retournés à la 86<sup>e</sup> réunion (décision 84/24).

## Rapport final

153. L'ONUDI a remis le rapport final du projet de démonstration, joint à l'annexe IV au présent document, conformément à la décision 84/24.

### *Volet de l'Afrique de l'Est*

154. Ce volet du projet s'appliquait à la région de l'Afrique englobant l'Érythrée, le Kenya, le Rwanda, la République unie de Tanzanie et la Zambie. Il avait pour but de mettre en évidence la disponibilité des frigorigènes contrefaits sur les marchés locaux, les écarts dans la réglementation et le manque de sensibilisation à la question, et de proposer une stratégie pour garantir la qualité des frigorigènes sur le marché et améliorer l'efficacité du fonctionnement de l'équipement de réfrigération et de climatisation, et ainsi prolonger la durée de vie des appareils et réduire le besoin pour de nouveaux frigorigènes. La République Unie de Tanzanie a été choisie pays pilote pour la mise en œuvre d'activités techniques précises du projet à cause de sa situation géographique, de sa plus grande taille et de sa population plus nombreuse.

155. Plusieurs activités ont été réalisées dans le cadre du projet, dont des enquêtes sur la disponibilité des frigorigènes; la formation des techniciens en réfrigération, des douaniers, des inspecteurs environnementaux et des importateurs; la remise d'équipement d'identification des frigorigènes aux parties prenantes; la mise sur pied de centres de vérification des frigorigènes et les activités de sensibilisation en guise de soutien. Le projet a atteint son objectif d'établir un inventaire des frigorigènes contrefaits dans la région et a cerné les lacunes ayant permis la pénétration des frigorigènes contrefaits sur le marché dans la région. Les parties prenantes ont été formées sur l'utilisation de l'équipement d'analyse des frigorigènes, l'identification des frigorigènes contrefaits et la mesure du rendement de l'équipement de réfrigération et de climatisation à base de frigorigènes purs et contrefaits. Le projet a renforcé les centres de vérification des frigorigènes en leur offrant des outils et de l'équipement, et a haussé le niveau de sensibilisation à la disponibilité des frigorigènes contrefaits sur les marchés locaux et les conséquences de leur utilisation.

156. Voici quelques conséquences de l'utilisation de frigorigènes contrefaits : consommation d'énergie accrue associée aux émissions indirectes de CO<sub>2</sub>; dommages causés aux composants des systèmes, dont le compresseur; diminution du rendement et de la durée de vie de l'équipement; utilisation par inadvertance de frigorigènes inflammables ou toxiques; dégagement probable de frigorigène pendant l'entretien, car il ne peut pas être recyclé ni régénéré; augmentation possible de la consommation de frigorigène vierge; augmentation possible de fuites lors du chargement d'un frigorigène à pression plus élevée; perte de crédibilité des techniciens, et risques possibles pour la sécurité.

157. Les résultats de ce volet indiquent que les frigorigènes contrefaits sont très présents dans plusieurs pays visés à l'article 5 et qu'il y avait un manque de réglementation permettant de corriger le problème; il y a aussi un manque de sensibilisation chez les douaniers et les importateurs. Ces questions doivent être abordées au cours de la mise en œuvre des PGEH et des activités de facilitation pour réduire progressivement les HFC, car toutes sortes de frigorigènes récupérés sont embouteillés et vendus ou exportés comme neufs.

158. Le projet de démonstration a aussi fourni des mesures détaillées pour empêcher les frigorigènes contrefaits/contaminés de pénétrer les marchés locaux, notamment une interaction permanente entre les Bureaux nationaux de l'ozone et les importateurs de frigorigènes afin d'accroître la transparence et l'échange d'information; des programmes permanents de renforcement des capacités des douaniers, des autorités environnementales et des administrateurs des Bureaux nationaux de l'ozone; la collaboration interagences entre les Bureaux nationaux de l'ozone, les bureaux des normes, les services douaniers, les autorités portuaires et les autres agents chargés de l'application; des identifiants de frigorigènes aux points d'entrée; l'utilisation d'un système de codification harmonisé par les douaniers, comprenant l'utilisation

des numéros des Nations Unies<sup>39</sup>, des numéros de formule chimique et du code ASHRAE<sup>40</sup> entre autres; la participation des associations et des techniciens en réfrigération aux campagnes de sensibilisation afin de réduire au minimum les importations et l'utilisation des frigorigènes contrefaits; des mesures d'encouragement et des récompenses pour les douaniers qui saisissent des frigorigènes contrefaits; et du matériel de sensibilisation à afficher à tous les postes frontaliers afin d'informer les douaniers et les Bureaux nationaux de l'ozone de la composition chimique des différents frigorigènes pendant l'analyse.

#### *Volet des Caraïbes*

159. Le volet du projet pour les Caraïbes englobait les Bahamas, Grenade, Sainte-Lucie, Saint-Vincent-et-les-Grenadines et le Suriname. Il avait pour but de faciliter l'introduction de frigorigènes à faible PRG dans le secteur de l'entretien en améliorant l'expertise des techniciens et la formation de formateurs spécialisés; en mettant à niveau les programmes de formation dans les centres professionnels; en offrant de l'équipement de base dans les centres de formation régionaux (p. ex., climatiseurs à base d'hydrocarbures, collecteurs avec robinets pour les hydrocarbures, détecteurs de fuites électroniques pour les frigorigènes inflammables, postes de charge portables pour les hydrocarbures, bouteilles de propane et de butane et autres outils), en offrant des séances de formation au pays et en fournissant de l'information aux parties prenantes sur les plus récents équipements à base d'hydrocarbures en vente sur le marché.

160. Plusieurs activités ont été mises en œuvre, dont l'élaboration d'un programme de formation sur la manipulation sécuritaire des frigorigènes inflammables à faible PRG; un atelier régional pour les responsables des politiques et les développeurs de programmes auquel ont participé des représentants des Bureaux nationaux de l'ozone et des fournisseurs de formation; la distribution d'outils et d'équipement qui conviennent aux frigorigènes à faible PRG au centre de formation régional de Grenade; la présentation d'un atelier régional de formation des formateurs à Grenade, où les participants ont reçu une formation sur les aspects théoriques de l'entretien de l'équipement de réfrigération, y compris la manipulation sécuritaire des frigorigènes de remplacement; la conception d'un centre régional de formation et d'un programme de certification pour faire en sorte que seuls les techniciens certifiés manipulent et entretiennent l'équipement et les frigorigènes inflammables; la présentation de deux climatiseurs à base de R-290 dans quatre pays; et la tenue de la réunion régionale d'un groupe d'experts à la suite d'une réunion des administrateurs de l'ozone au Suriname.

161. En conséquence du projet, le centre régional de formation est devenu entièrement fonctionnel pour les techniciens en réfrigération et climatisation de Grenade en 2019 et sera ouvert aux techniciens des autres pays de la région en 2020. Une évaluation a été effectuée à la fin du cours de formation et les participants ayant réussi ont reçu des certifications en « gaz fluorés » et « VÉRITABLES gaz de remplacement ».<sup>41</sup>

162. Des recommandations ont été émises à partir des observations de la mise en œuvre du projet : tous les pays doivent adopter le programme développé par le projet; la capacité du centre régional de formation de Grenade doit être évaluée régulièrement; prendre compte un deuxième centre régional de formation dans un autre pays si les capacités sont insuffisantes; élaborer des mécanismes et créer des partenariats pour encourager les fournisseurs ou fabricants internationaux d'équipement et d'outils à base d'hydrocarbures à assurer une présence plus forte dans la région; envisager l'achat régional d'équipement et d'outils à base d'hydrocarbures; envisager la création d'une association régionale de la réfrigération; attirer davantage de soutien financier des organismes de financement internationaux pour l'introduction de frigorigènes de remplacement à faible PRG; envisager de développer un programme d'étiquetage

<sup>39</sup> Numéro à quatre chiffres attribué par le Comité d'experts en matière de transport de marchandises dangereuses des Nations Unies, identifiant des marchandises et articles dangereux dans un contexte de transport international.

<sup>40</sup> American Society of Heating, Refrigerating, and Air-Conditioning Engineers.

<sup>41</sup> Il s'agit de certifications mondialement reconnues du niveau de compétence des techniciens à manipuler des frigorigènes gazeux, dans ce cas-ci les gaz fluorés et les frigorigènes inflammables.

écologique pour les appareils de refroidissement et/ou des programmes de récompenses lorsque les consommateurs achètent des appareils de refroidissement écologiques; envisager l'imposition de droits pour l'importation d'équipement à PRG élevé; envisager d'imposer des exigences techniques obligatoires à la conception, la construction ou l'adaptation de bâtiments civils (p. ex., bureaux, hôtels, hôpitaux, écoles, immeubles à logements et installations de service) ayant une certaine superficie; exécuter les évaluations techniques d'appareils à base de R-290 afin d'examiner leur fonctionnement à une alimentation électrique de 110V/60hz; et développer des plateformes pour que les techniciens puissent partager de l'information.

### **Observations du Secrétariat**

163. Ayant pris connaissance des observations et des résultats du volet de l'Afrique de l'Est, le Secrétariat a demandé plus d'information sur la façon d'encourager les techniciens et les utilisateurs finaux à dénoncer les cas d'utilisation de frigorigènes contrefaits de façon sécuritaire, et quelles mesures punitives pourraient être imposées aux importateurs ou aux distributeurs locaux de frigorigènes contrefaits.

164. L'ONUDI a expliqué que les techniciens et autres parties prenantes pourraient dénoncer à situation auprès de l'association des techniciens en réfrigération. En l'absence d'une association, les techniciens ont été invités à dénoncer la situation directement auprès du Bureau national de l'ozone du pays. L'ONUDI a expliqué les résultats du projet de démonstration aux autres Bureaux nationaux de l'ozone. Les mesures punitives pour les transgresseurs varient d'un pays à l'autre. Certains pays commencent par des campagnes de sensibilisation, comprenant la distribution de brochures de l'ONUDI et imposent ensuite des amendes. L'ONUDI considère également que l'information sur le sujet peut être échangée pendant les réunions de réseaux régionaux organisées par le Programme d'aide à la conformité du PNUE.

165. En réponse à la question visant à savoir si les PGEH des pays visés à l'article 5 avaient été rajustés en conséquence du projet, l'ONUDI a indiqué que la qualité des frigorigènes figure au programme de formation des techniciens. La formation comprend des méthodes de base pour identifier les frigorigènes potentiellement contrefaits et, si possible, la démonstration du fonctionnement de l'équipement avec des frigorigènes purs et de faux frigorigènes achetés localement. Le Bureau national de l'ozone et les techniciens ont bien accueilli le sujet, mais ceux-ci doivent être plus sensibilisés.

166. Dans ses explications de la principale contribution du volet des Caraïbes du projet et ses impacts sur la mise en œuvre de leurs PGEH aux pays participants, l'ONUDI a indiqué que le projet avait mis en évidence la nécessité de resserrer la coopération régionale afin de rendre l'équipement à base d'hydrocarbures disponible dans les pays participants. En particulier :

- a) Le développement d'un programme de formation et de matériel de référence sur les frigorigènes inflammables pouvant être incorporés aux stratégies du PGEH une fois adaptés aux pays précis dans lesquels ils sont nécessaires;
- b) La création d'un centre régional de formation bien équipé à Grenade mis à la disposition des techniciens de la région afin qu'ils apprennent comment utiliser les frigorigènes inflammables en toute sécurité. Les capacités des centres de formation des autres pays ont aussi été renforcées. Le centre régional et les installations de formation mises à niveau ont déjà offert des séances de formation aux techniciens en complément des ateliers de formation offerts dans le cadre du PGEH; et
- c) Les Bahamas, Grenade et le Suriname ont déjà créé un bassin de formateurs de chaque pays participant capable de former les techniciens en réfrigération et climatisation dans le cadre des PGEH.

167. En ce qui concerne la disponibilité des outils critiques dont les techniciens ont besoin pour travailler avec les frigorigènes inflammables,<sup>42</sup> l'ONUDI a indiqué que ces outils ne sont toujours pas vendus sur les marchés régionaux et que les pays comptent sur leur PGEH et d'autres programmes pour se les procurer sur le marché international. Il faut aussi un plus grand nombre d'appareils à base de frigorigènes inflammables pour la formation, afin d'augmenter et de remplacer la capacité installée dans les centres de formation de la région. L'ONUDI a fourni les détails de l'équipement essentiel à la formation et à l'entretien des frigorigènes inflammables dans le cursus du programme, joints à l'annexe A au volet des Caraïbes du rapport final.

168. L'ONUDI a confirmé qu'il reste un solde de 709 \$US qui sera retourné à la 86<sup>e</sup> réunion, conformément à la décision 84/12.

### **Recommandation**

169. Le Comité exécutif pourrait souhaiter :

- a) Prendre note du rapport sur le projet de démonstration sur la qualité et le confinement des frigorigènes et l'introduction de substances de remplacement à faible PRG dans le secteur de la réfrigération et de la climatisation des régions de l'Afrique de l'Est et des Caraïbes proposé par l'ONUDI et présenté dans le document UNEP/OzL.Pro/ExCom/85/9; et
- b) Inviter les agences bilatérales et d'exécution à tenir compte du rapport dont il est question à l'alinéa a) ci-dessus lorsqu'elles aident les pays visés à l'article 5 à préparer et mettre en œuvre leurs projets dans le secteur de l'entretien de l'équipement de réfrigération.

Région de l'Europe et de l'Asie Centrale : Développement d'un centre d'excellence régional pour la formation et la certification, et démonstration de substances de remplacement possibles à faible potentiel de réchauffement de la planète (rapport final) (Fédération de Russie)

### **Contexte**

170. Le Comité exécutif, à sa 76<sup>e</sup> réunion, a approuvé un projet de démonstration pour la région de l'Europe et de l'Asie centrale sur le développement d'un centre régional d'excellence pour la formation et la certification, et la démonstration de frigorigènes de remplacement à faible potentiel de réchauffement de la planète (PRG), pour la somme de 591 600 \$US, plus les coûts d'appui à l'agence de 75 076 \$US pour le gouvernement de la Fédération de Russie (décision 76/35)).

171. Le projet avait pour objectif d'améliorer la capacité technique des secteurs de la réfrigération et de la climatisation dans les pays de l'Europe de l'Est et de l'Asie centrale, afin de surmonter les obstacles à l'adoption de frigorigènes à faible PRG, d'améliorer les pratiques d'entretien, de réduire les niveaux d'émission de gaz fluorés de l'équipement de réfrigération et climatisation, et d'inculquer des connaissances en conception énergétique efficace et en fonctionnement de l'équipement de réfrigération et climatisation aux techniciens et fabricants d'équipement. Le gouvernement de la Fédération de Russie a demandé l'assistance de l'ONUDI pour la mise en œuvre du projet.

172. L'ONUDI, en tant qu'agence d'exécution désignée, a soumis le rapport final de la mise sur pied d'un centre régional d'excellence pour la formation, la certification et la démonstration des frigorigènes

---

<sup>42</sup> Collecteur muni d'un robinet pour les frigorigènes inflammables, détecteurs de fuites électroniques de frigorigènes inflammables et bouteilles convenant aux frigorigènes inflammables.

de remplacement à faible PRG, conformément à la décision 83/30 c).<sup>43</sup> Le rapport complet est joint à l'annexe V au présent document.

### Rapport final

173. Le centre régional d'excellence a été établi en Arménie, dans le complexe international de science et éducation « Shirakatsy Lyceum », sous la responsabilité du ministère de la Protection de la nature. Il a été inauguré en septembre 2019 lors d'une cérémonie réunissant plus de 50 participants, dont des ministres et sous-ministres du Conseil écologique inter-États des États indépendants du Commonwealth, des représentants de l'ONUDI, d'associations et d'entreprises de réfrigération et de climatisation, des experts techniques, et des étudiants.

174. Le centre régional est maintenant fonctionnel et offre des services de formation et consultatifs aux pays de la région de l'Europe de l'Est et de l'Asie centrale, notamment des programmes de formation, des programmes de certification et la formation de formateurs, et propose un programme commun d'études professionnelles et de culture générale que peuvent adopter les pays au cours de la mise en œuvre des activités de leur plan de gestion de l'élimination des HCFC.

175. Les activités ci-dessous, entre autres, ont été réalisées dans le cadre du projet :

- a) Cinq formateurs ont été formés et certifiés dans le cadre de programmes sur les gaz fluorés et les véritables gaz de remplacement, et un accord de coopération spécial a été signé avec un centre de formation de Moscou afin d'offrir des cours de formation et de certification en sécurité électrique, en travail en hauteur, en récipients à pression et en habiletés de soudage, reconnus sur le territoire de la Russie et des États de l'Union économique eurasiatique;
- b) Traduction en russe de la réglementation sur les gaz fluorés harmonisée à la réglementation n° 513014 de l'UE et élaboration d'un programme simplifié de certification des techniciens sur la réglementation régissant les gaz fluorés, afin de faciliter le lancement des programmes de certification dans tous les pays de la région de l'Europe de l'Est et de l'Asie centrale;
- c) Offre de services conseils et d'assistance technique pour l'harmonisation des lois et des réglementations nationales après la ratification de l'Amendement de Kigali par le biais du Conseil technique inter-États des associations nationales de réfrigération;
- d) Un projet de démonstration sur les frigorigènes inflammables utilisés dans les entrepôts de fruits et de légumes a été mis en œuvre dans la province de Kotayk, en Arménie, et des critères de sécurité à respecter pour le fonctionnement et l'entretien de l'équipement ont été appliqués. Une démonstration en a été faite dans un contexte d'installation et de fonctionnement. Le nouvel équipement a permis de réaliser des améliorations de l'efficacité énergétique d'environ 34 pour cent, et la reproduction du projet de démonstration pourrait aboutir au remplacement d'environ 500 installations par année dans les pays de l'Europe de l'Est et de l'Asie centrale;
- e) Neuf programmes d'assistance technique, comprenant un apprentissage électronique, des séances pratiques au centre régional d'excellence et des démonstrations pratiques du fonctionnement des nouvelles technologies ont été élaborées avec l'appui des fabricants

---

<sup>43</sup> Un rapport périodique sur le projet a été examiné à la 83<sup>e</sup> réunion, et prenant note des progrès importants accomplis, la date d'achèvement a été reportée au 31 décembre 2019.



d'équipement dans le cadre d'un programme commun d'études professionnelles et de culture générale; les stagiaires féminines ont été encouragées à participer au programme au centre, et 77 professionnels en réfrigération et climatisation ont été formés au centre; et

- f) Un site Web (<http://hvacccenter.am/>) a été créé afin d'offrir un milieu pour la formation en ligne à distance.

176. Le développement et la mise en fonction du centre de formation ont été publicisés lors de réunions régionales de consultation du personnel technique, des Bureaux nationaux de l'ozone et autres réunions de consultation, et la création du centre a été publicisée dans des médias imprimés et électroniques auprès des parties prenantes de la région.

177. La somme approuvée de 591 600 \$US a été entièrement décaissée pour le développement et la mise en service du centre de formation (181 044 \$US), la mise en œuvre d'un projet de démonstration (188 261 \$US), la traduction de la réglementation en anglais et en russe (55 500 \$US), le développement du site Web pour les programmes de formation électronique et le rayonnement (92 795 \$US) et des activités de communication de l'information et de sensibilisation et autres activités de gestion du projet (71 000 \$US).

### **Observations du Secrétariat**

178. L'ONUDI a précisé que les retards ont surtout été causés par l'allocation du financement pour la mise en œuvre du projet et, dans une moindre mesure, la mise à niveau des infrastructures du centre de formation, le changement de bénéficiaire du projet de démonstration et des changements de décideurs au sein du gouvernement arménien.

179. En réponse à une demande de précisions, l'ONUDI a expliqué que le projet de démonstration portait sur le remplacement de l'équipement utilisé dans un entrepôt de fruits et de légumes, car l'équipement existant était très vieux. Le bénéficiaire a fourni un cofinancement d'environ 30 000 \$US, comprenant la préparation des lieux, les travaux de génie civil et électrique pour l'installation de l'équipement, des activités de sensibilisation du public et l'obtention de permis nationaux et des certificats/inspections de sécurité. Le projet a un potentiel de variabilité d'échelle dans la région et pour l'adoption plus rapide de technologies basées sur des frigorigènes à faible PRG; les pays adopteraient une réglementation nationale pour promouvoir de telles technologies à faible PRG.

180. Le projet a atteint son objectif d'établir un centre régional d'excellence pour la formation des techniciens et des ingénieurs en manipulation sécuritaire, et la démonstration d'applications fondées sur les frigorigènes à faible PRG dans les systèmes de réfrigération et de climatisation dans les pays de l'Europe de l'Est et de l'Asie centrale.

### **Recommandation**

181. Le Comité exécutif pourrait souhaiter :

- a) Prendre note du rapport final sur le développement d'un centre régional d'excellence pour la formation et la certification, et démonstration de substances de remplacement possibles à faible potentiel de réchauffement de la planète pour la région de l'Europe et de l'Asie centrale proposé par le gouvernement de la Fédération de Russie et l'ONUDI, présenté dans le document UNEP/OzL.Pro/ExCom/85/9;
- b) Encourager les agences bilatérales et d'exécution à utiliser complètement les ressources offertes par le centre régional, mentionnées à l'alinéa a), pour la mise en œuvre des plans

de gestion de l'élimination des HCFC et les projets de réduction progressive des HFC dans la région de l'Europe et de l'Asie centrale et les régions avoisinantes.

Arabie saoudite : Projet de démonstration sur l'élimination des HCFC en utilisant les HFO comme agents de gonflage dans la mousse à vaporiser dans des milieux à température ambiante élevée (rapport final) (ONUDI)

## Contexte

182. Le Comité exécutif, à sa 76<sup>e</sup> réunion, a adopté, entre autres, le projet de démonstration sur l'élimination des HCFC en utilisant des HFO comme agents de gonflage de la mousse dans la fabrication de mousse à vaporiser dans des milieux à température ambiante élevée, pour la somme de 96 250 \$US, plus les coûts d'appui à l'agence de 8 663 \$US pour l'ONUDI, et a demandé au gouvernement de l'Arabie saoudite et à l'ONUDI de mener le projet à terme dans les seize mois suivant son approbation, et de remettre un rapport final exhaustif peu après l'achèvement du projet (décision 76/31).<sup>44</sup>

183. L'ONUDI a remis un rapport périodique sur le projet de démonstration à la 83<sup>e</sup> réunion, dans lequel il indique que des activités supplémentaires, telles que des essais sur le terrain (c.-à-d., force d'adhésion, absorption de l'eau, contenu en cellules fermées, durabilité de la résistance thermique et force de compression contre le vieillissement/dégradation) devront être mises en œuvre avant que le projet ne puisse être achevé. Afin de mener à terme les activités qui fourniraient des informations importantes et constatant les progrès considérables accomplis, le Comité exécutif a accepté de reporter la date d'achèvement du projet au 31 octobre 2019, étant entendu qu'aucune autre prorogation de la mise en œuvre du projet ne serait demandée. Le Comité exécutif a également demandé à l'ONUDI de remettre le rapport final du projet à la 84<sup>e</sup> réunion, au plus tard (décision 83/35 b) et c)).

184. L'ONUDI a remis le rapport final sur le projet de démonstration le 11 novembre 2019, conformément à la décision 83/35 c). Le Comité exécutif a pris note de la remise du rapport, qui serait examiné par le Secrétariat et présenté à la 85<sup>e</sup> réunion.<sup>45</sup> La présente partie contient l'examen du rapport et de ses conclusions par le Secrétariat.

## Rapport final

185. Le projet a été approuvé afin de faire la démonstration des avantages, de l'applicabilité et de la possibilité de reproduire l'utilisation du HFO-1233zd(E) et du HFO-1336mzz(Z) gonflés avec de l'eau en tant que coagent de gonflage dans les applications de mousse de polyuréthane à vaporiser dans des milieux à température ambiante élevée, et d'analyser les réductions de coûts d'investissement et d'exploitation réalisées en utilisant de l'eau en tant que coagent de gonflage, et en examinant les changements de densité de la mousse et de conductivité thermique.

186. Le projet a été mis en œuvre chez Sham Najd International, un fabricant local de mousse de polyuréthane rigide et de mousse de polyisocyanurate (PIR) à vaporiser servant à isoler et à imperméabiliser les structures de bâtiments (murs, plafonds, toitures et planchers). Le HFO-1233zd(E) a été le seul agent de gonflage essayé car le HFO-1336mzz(Z) n'est pas vendu sur le marché.

187. Les résultats des essais révèlent que la formule de mousse à base de HFO-1233zd(E) pourrait vraisemblablement remplacer les formules à base de HCFC et de HFC, car elle possède des caractéristiques techniques et physiques semblables, ainsi qu'un faible PRG et aucune SAO. Le projet de démonstration a abouti aux conclusions suivantes :

---

<sup>44</sup> La date d'achèvement du projet a été reportée au 31 décembre 2019 à la 80<sup>e</sup> réunion (décision 80/26 i)).

<sup>45</sup> Paragraphe 120 du document UNEP/OzL.Pro/ExCom/84/75.

- a) Le rendement du HFO-1233zd(E) est le même que celui du HCFC-141b en ce qui concerne l'adhésion, la conductivité thermique, la stabilité dimensionnelle, la peignabilité, la densité générale de la mousse et la force de compression;
- b) La surface vaporisée de mousse à base de HFO-1233zd(E) comportait plus de trous d'épingle que la surface vaporisée de mousse à base de HCFC-141b, mais a quand même satisfait aux attentes du client;
- c) Le HFO-1233zd(E) n'exige pas d'équipement de gonflage; tous les essais ont été réalisés avec l'équipement de base de Sham Najd (c.-à-d., applicateur Graco E-XP1);
- d) Le HFO-1233zd(E) doit être mélangé dans le réacteur, à une température inférieure à 18°C, 15°C de préférence, à cause de son faible point d'ébullition de 19,5°C, afin d'éviter la perte d'agent de gonflage pendant le processus de mélange;
- e) Une plus petite quantité de HFO-1233zd(E) peut être mélangée au polyol, car le point d'ébullition du mélange de polyol sera lui aussi inférieur au point d'ébullition du HCFC-141b;
- f) Le polyol prémélangé à base de HFO-1233zd(E) a été entreposé pour une durée de cinq mois par la société de formulation et l'utilisateur final, sans changement observé dans la réactivité. Le mélange doit être entreposé à une température maximum de 28°C à cause du faible point d'ébullition du HFO-1233zd(E), car le produit chimique pourrait s'évaporer/bouillir à température plus élevée;
- g) La formule de polyol prémélangé à base de HFO-1233zd(E) a besoin d'additifs spéciaux (surfactants et catalyseurs) afin d'éviter la détérioration du mélange de polyol; le catalyseur offre une durée de vie de plus de huit mois;
- h) Les surcoûts d'exploitation des formules à base de HFO-1233zd(E) sont de 4,30 \$US/kg de plus que ceux des formules à base de HCFC-141b. Cependant, en tenant compte de la conductivité thermique plus basse (meilleure isolation) et de la plus faible densité de la mousse produite en utilisant le HFO-1233zd(E), les surcoûts ont été réduits à 0,33 \$US/kg; et
- i) Le HFO-1233zd(E) acheté pour le projet a été acheté au prix de 9,50 \$US/kg; le prix réel du produit acheté en petites quantités est de 14 \$US/kg, ce qui augmenterait les surcoûts d'exploitation. Ces coûts devraient diminuer d'ici quelques années, lorsque le prix du HFO-1233zd(E) diminuera et celui du HCFC-141b augmentera à cause d'une disponibilité réduite.

#### *Résultats des essais supplémentaires sur le terrain*

188. Le rapport final comprend les résultats d'essais entrepris par un laboratoire indépendant de la Finlande, 18 mois après l'application de mousse à vaporiser à base de HFO dans des milieux à température ambiante élevée. Après avoir pris connaissance des résultats, l'ONUDI a conclu que la mousse de polyuréthane à base de HFO-1233zd(E) présentait un comportement au moins semblable à celui de la mousse de polyuréthane à base de HCFC-141b. De plus, la période de vieillissement de la mousse à vaporiser appliquée dans des milieux à température ambiante élevée n'a pas entraîné de changements significatifs dans les indicateurs de rendement de la mousse, et la mousse a quand même respecté toutes les spécifications.

189. Des ateliers ont eu lieu en juin 2019 à Jeddah, Riyadh et Dammam afin de fournir de l'information sur les résultats de la mousse à vaporiser et coulée sur place à base de HFO-1233zd(E) en comparaison à d'autres technologies et analyses de coût.

### **Observations du Secrétariat**

190. Le Secrétariat a relevé quelques variantes dans les valeurs obtenues dans les essais menés après 18 mois par rapport aux données des essais initiaux, mais les propriétés physiques de la mousse étaient encore comparables à celles de la mousse à base de HCFC-141b. L'ONUDI a fourni une interprétation des données obtenues lors de chaque essai, ce que le Secrétariat a trouvé utile, et il a suggéré qu'elle soit ajoutée au rapport. Le rapport final révisé est joint à l'annexe VI au présent document.

#### *Disponibilité et adoption de la technologie*

191. Dans ses précisions sur l'origine et la disponibilité des formules utilisées pour faire l'essai du HFO-1233zd(E), l'ONUDI a indiqué que la formule utilisée pour les premiers essais a été entièrement développée par Covestro (un fournisseur mondial de polymères dans les Émirats arabes unis) et n'était pas disponible aux autres sociétés de formulation au pays. Tous les détails de la formule de la mousse font partie des développements des sociétés de formulation et sont généralement secrets. Par contre, les fournisseurs d'additifs (c.-à-d., Evonik et Momentive) et de l'agent de gonflage (Honeywell et Chemours) soutiennent activement les développeurs de formules des sociétés de formulation. Comme la mousse à vaporiser est désormais vendue localement en Arabie saoudite, tous les utilisateurs de mousse à vaporiser utiliseront les formules locales de mousse à vaporiser.

192. Dans sa description des principaux obstacles à l'intégration de l'utilisation de cette technologie en Arabie saoudite, l'ONUDI a indiqué que bien que les formules à base de HFO existantes puissent être utilisées dans toutes les applications du secteur de la construction, les sociétés de formulation ont encore des formules complètement développées de mousse à vaporiser à base de HCFC-141b et des stocks de HCFC-141b pur largement disponibles. L'acceptation sur le marché des nouvelles formules de mousse à vaporiser à faible PRG est limitée à cause de la publicité négative concernant les attentes de rendement médiocre de ces formules. L'ONUDI et le PNUE prévoient mettre sur pied un programme de normes et de certification dans le cadre du PGEH, qui n'utilisera que des formules de mousse certifiées, ce qui pourrait aider à surmonter les obstacles actuels à l'adoption à plus grande échelle de la technologie.

#### *Cofinancement*

193. Le coût total du projet de démonstration a été de 94 000 \$US pour le Fonds multilatéral, dont 28 000 \$US pour les services de consultation et les déplacements, 48 000 \$US pour l'équipement et les produits chimiques et 18 000 \$US pour les essais en laboratoire et l'atelier de diffusion. L'ONUDI a rapporté sur demande que selon l'information disponible, les sociétés de formulation bénéficiaires ont contribué au moyen d'investissements à hauteur de 250 000 \$US pour l'équipement et les produits chimiques.

### **Recommandation**

194. Le Comité exécutif pourrait souhaiter :

- a) Prendre note du rapport final sur le projet de démonstration sur l'élimination du HCFC en utilisant le HFO comme agent de gonflage de la mousse dans les applications de mousse à vaporiser dans les milieux à température ambiante élevée en Arabie saoudite proposé par l'ONUDI et présenté dans le document UNEP/OzL.Pro/ExCom/85/9; et

- b) Inviter les agences bilatérales et d'exécution à tenir compte du rapport mentionné à l'alinéa a) ci-dessus lorsqu'elles aident les pays visés à l'article 5 à préparer et à mettre en œuvre leurs projets de mousse en polyuréthane.

Arabie saoudite : Projet de démonstration sur la promotion de frigorigènes à base de HFO à faible potentiel de réchauffement de la planète dans le secteur de la climatisation dans des milieux à température ambiante élevée (rapport périodique) (ONUDI)

### Contexte

195. L'ONUDI a présenté à la 85<sup>e</sup> réunion, au nom du gouvernement de l'Arabie saoudite, un rapport sur le projet de démonstration sur la promotion de frigorigènes à base d'hydrofluorooléfines (HFO) à faible potentiel de réchauffement de la planète (PRG) dans le secteur de la climatisation, dans des milieux à température ambiante élevée.

196. Le projet a été approuvé à la 76<sup>e</sup> réunion afin de fabriquer, mettre à l'essai et optimiser les modèles de climatiseurs pilotes à base de mélanges de HFO/HFC à faible PRG et de R-290, d'entreprendre une production de démonstration et de reconvertir une chaîne de production, pour la somme de 1 300 000 \$US, plus les coûts d'appui à l'agence de 91 000 \$US pour l'ONUDI.

197. Le Comité exécutif, à sa 80<sup>e</sup> réunion, a accepté de reporter la date d'achèvement du projet de mai 2018 à décembre 2018, étant entendu qu'aucune autre prorogation ne serait demandée, et a demandé aux agences d'exécution de remettre le rapport final avant la 83<sup>e</sup> réunion, au plus tard (décision 80 /26 g)). Un court rapport périodique a été remis à la 82<sup>e</sup> réunion, révélant des progrès substantiels dans plusieurs activités, dont l'achat de l'équipement et la livraison des composants (c.-à-d., des compresseurs), et que la livraison de l'équipement de production et la production des premiers appareils à base de R-290 étaient toujours en attente. Ces activités devaient être menées à terme en décembre 2018.

198. Il a été indiqué à la 83<sup>e</sup> réunion, que l'équipement de fabrication avait été livré, mais pas encore installé, car l'entreprise avait décidé de déménager sa chaîne de production. L'entreprise prévoyait néanmoins procéder à une installation temporaire de l'équipement afin que des essais puissent être effectués et le personnel formé; la chaîne serait déplacée avant septembre 2019. De plus amples essais et l'optimisation des appareils étaient nécessaires. Ces activités devaient être achevées et un atelier devait être tenu afin de diffuser les résultats du projet, avant décembre 2019. Par conséquent, le Comité exécutif a décidé de proroger le projet, à titre exceptionnel, jusqu'au 31 décembre 2019, en prenant note des progrès considérables accomplis et du potentiel de reproduction des résultats dans plusieurs pays visés à l'article 5, étant entendu qu'aucune autre prorogation ne serait demandée, et a demandé à l'ONUDI de remettre le rapport final du projet à la 85<sup>e</sup> réunion, au plus tard, et de retourner les soldes à la 86<sup>e</sup> réunion (décision 83/33).

### Rapport périodique

199. D'autres essais et l'optimisation des appareils ont été entrepris, dont l'optimisation du condensateur au moyen de tubes de cuivre d'un diamètre extérieur de 5 mm et striés à l'intérieur, pour laquelle l'entreprise a mis à niveau sa chaîne de fabrication d'échangeurs de chaleur afin que la fabrication puisse se faire sur place, et ainsi obtenir un avantage économique par rapport aux échangeurs de chaleur à microcanaux qui doivent être achetés auprès de fournisseurs. Un prototype de mini-climatiseur à deux blocs à base de R-290 et d'une capacité de 18 000 unités thermiques britanniques (1,5 tonne de réfrigération) utilisant un condensateur à tubes de cuivre de 5mm striés à l'intérieur a été développé; aucune optimisation supplémentaire n'a été nécessaire. L'appareil a dépassé les normes minimales locales de rendement énergétique en offrant une efficacité énergétique de 12,5 à 35°C (T1) et de 9,6 à 46°C (T3). Cependant, les essais par un tiers n'avaient pas encore été effectués car de nouveaux prototypes de condensateurs étaient toujours attendus et qu'il fallait encore trouver un laboratoire

convenable. Le développement d'un mini-climatiseur à deux blocs à base de R-290 est conforme aux nouvelles normes minimales locales de rendement énergétique de l'Organisation des normes, de la météorologie et de la qualité saoudienne; l'optimisation se poursuivra. À cet égard, 48 compresseurs à base de R-290 de conception améliorée ont été commandés afin de mener d'autres essais sur les prototypes de climatiseurs à deux blocs à base de R-290.

200. La chaîne de fabrication a été déplacée, les travaux de génie civil sont terminés et tout l'équipement, dont un système complet de contrôle de la qualité, a été installé. Par contre, la mise en service de la chaîne, qui devait se faire en février 2020, a été retardée à cause de la pandémie de COVID-19; les essais de la chaîne de fabrication auront lieu dès que les interdictions de voyager imposées à cause de la COVID-19 seront levées. De même, les laboratoires et les chambres d'essai sur place ont été mis à niveau en y installant l'équipement et l'instrumentation requis, mais la mise en service a été retardée. La formation des techniciens sur la chaîne de fabrication et l'atelier final pour la diffusion des résultats du projet aux parties prenantes sont toujours en attente.

### **Observations du Secrétariat**

201. Le projet n'a pas pu être mené à terme à cause de la pandémie de la COVID-19. L'ONUDI a proposé un échéancier provisoire pour l'achèvement du projet qui comprend le déplacement d'un expert pour la mise en service et la formation en mai 2020, les essais des prototypes avec un nouveau lot de 48 compresseurs à base de R-290 à conception améliorée sont prévus entre juin et août 2020 et le dernier atelier devrait avoir lieu en septembre 2020.

202. Prenant note que l'échéancier proposé est provisoire et qu'il dépend de la situation entourant la COVID-19, y compris la possibilité d'effectuer des voyages internationaux, le Secrétariat recommande de proroger le projet jusqu'au 15 décembre 2020, et de demander à l'ONUDI de remettre le rapport final du projet avant le 1<sup>er</sup> janvier 2021 et de retourner les soldes d'ici la 87<sup>e</sup> réunion.

### **Recommandation**

203. Le Comité exécutif pourrait souhaiter :

- a) Prendre note du rapport périodique sur le projet de démonstration sur la promotion de frigorigènes à base d'hydrofluorooléfines et à faible potentiel de réchauffement de la planète pour le secteur de la climatisation dans des milieux à température ambiante élevée en Arabie saoudite proposé par l'ONUDI et présenté dans le document UNEP/OzL.Pro/ExCom/85/9;
- b) Reporter la date d'achèvement du projet dont il est question à l'alinéa a) ci-dessus au 15 décembre 2020, à titre exceptionnel, compte tenu de la pandémie de la COVID-19 et des progrès considérables accomplis; et
- c) Demander à l'ONUDI de soumettre le rapport final du projet dont il est question à l'alinéa a) ci-dessus avant le 1<sup>er</sup> janvier 2021 et de retourner les soldes d'ici la 87<sup>e</sup> réunion.

Région de l'Asie occidentale : Projet de démonstration sur la promotion de frigorigènes de remplacement dans les systèmes de climatisation pour les pays à température ambiante élevée (PRAHA-II) (rapport final) (PNUE et ONUDI)

204. Le Comité exécutif, à sa 76<sup>e</sup> réunion, a approuvé le projet de démonstration sur la promotion des

frigorigènes de remplacement dans les systèmes de climatisation pour les pays à température ambiante élevée de l'Asie occidentale,<sup>46</sup> mieux connu sous le nom de PRAHA-II, pour la somme totale de 771 500 \$US, comprenant 375 000 \$US, plus les coûts d'appui à l'agence de 48 750 \$US pour le PNUE, et 325 000 \$US, plus les coûts d'appui à l'agence de 22 750 \$US pour l'ONUDI. Le PNUE et l'ONUDI ont soumis le rapport final complet du projet, présenté à l'annexe VII au présent document.<sup>47</sup>

205. Le projet avait pour but de prendre appui sur les progrès réalisés dans le cadre du projet de démonstration afin de promouvoir les solutions de remplacement à faible potentiel de réchauffement de la planète (PRG) pour l'industrie de la climatisation dans les pays à température ambiante élevée de l'Asie occidentale (PRAHA-I).<sup>48</sup> Le PRAHA-II proposait trois objectifs principaux : renforcer les capacités de l'industrie locale pour la conception et l'essai de l'équipement à base de frigorigènes inflammables à faible PRG, évaluer et optimiser les prototypes construits pour PRAHA-I et développer un modèle d'évaluation des risques dans les pays à température ambiante élevée.

206. Afin de renforcer les capacités locales, les prototypes développés pour le PRAHA-I ont été analysés et optimisés en obtenant des cartes de rendement pour les composants (compresseurs, ventilateurs); en évaluant les configurations de conception des échangeurs de chaleur, dont les échangeurs de chaleur à microcanaux; et en optimisant les travaux techniques afin d'atteindre ou de dépasser le rendement de l'appareil de référence, notamment en installant de nouveaux compresseurs à niveau pour les mêmes frigorigènes que ceux utilisés pour le PRAHA-I, qui n'étaient pas disponibles au moment où les prototypes de PRAHA-I ont été construits, ou des compresseurs pour les frigorigènes non essayés lors de PRAHA-I. Les appareils optimisés ont été mis à l'essai avec des frigorigènes à faible PRG (notamment le R-290, le HFC-32 et certains mélanges à base de HFO) et les conséquences de recharge des fuites sur le rendement des solutions de remplacement à glissement élevé<sup>49</sup> ont été analysées. Des ateliers de formation sur la conception de prototypes, des consultations entre les fabricants locaux d'équipement de climatisation et les fournisseurs de technologie, des visites sur le terrain chez les membres de l'industrie et dans les centres de recherche de la Chine et du Japon, et une visite d'étude aux États-Unis d'Amérique ont été organisés. Un modèle d'évaluation des risques correspondant aux habitudes et aux conditions d'utilisation courantes dans les pays à température ambiante élevée a été développé en collaboration avec des instituts locaux et l'Association japonaise de l'industrie de la réfrigération et de la climatisation (JRAIA).

### *Conclusions et recommandations*

207. Les résultats de l'optimisation des prototypes de PRAHA-I ont démontré que la modélisation, la conception et la sélection permettent d'améliorer le rendement du système. La reprise de la conception des composants a porté sur le compresseur, le condensateur et le détendeur. Les prototypes de PRAHA-I étaient surtout dotés de compresseurs dont la taille correspondait spécifiquement au R-310A ou au HCFC-22, ce qui a permis de choisir parmi un plus grand éventail de compresseurs car un compresseur conçu pour un type de frigorigène précis améliore l'efficacité énergétique de l'appareil. La réduction du diamètre du tube de l'échangeur de chaleur permet de réduire la taille de la charge car le coefficient de transfert de chaleur est inversement proportionnel au diamètre du tube; par contre, un diamètre réduit entraîne une baisse de pression. De plus, bien que la réduction du diamètre du tube ou autres changements apportés aux échangeurs de chaleur favoriseraient une augmentation de l'efficacité du système et une

<sup>46</sup> Bahreïn, Égypte, Koweït, Qatar, Oman, Arabie saoudite et Émirats arabes unis. L'Arabie saoudite n'a reçu aucun soutien financier. L'industrie locale a construit les prototypes et assisté aux sessions du PRAHA à ses frais.

<sup>47</sup> Le rapport a été soumis à la 84<sup>e</sup> réunion, mais comme le temps manquait, le Secrétariat entreprendrait l'examen et présenterait ses conclusions à la 85<sup>e</sup> réunion (paragraphe 122 du document UNEP/OzL.Pro/ExCom/84/75).

<sup>48</sup> Approuvé à la 69<sup>e</sup> réunion aux fins de mise en œuvre par le PNUE et l'ONUDI (UNEP/OzL.Pro/ExCom/69/19). Le rapport final du projet est présenté dans le document UNEP/OzL.Pro/ExCom/76/10

<sup>49</sup> Le glissement de la température est la différence de température entre les températures de la vapeur saturée et du liquide saturé à pression constante.

charge réduite, les changements à la conception d'un échangeur de chaleur sont limités en fonction des dimensions de l'enveloppe : la reprise complète de la conception offrirait une occasion de concevoir des échangeurs de chaleur offrant une efficacité encore plus élevée. En outre, bien que le choix du ventilateur et des souffleurs puisse également améliorer l'efficacité, ces changements n'ont pas été envisagés pour des raisons de coût et de temps, et parce que le compresseur est responsable de 80 à 90 pour cent de la consommation d'énergie.

208. Les essais effectués sur les appareils optimisés ont révélé une diminution marquée de la consommation d'énergie dans les conditions d'essai à température ambiante élevée (46°C). L'analyse par simulation a révélé que les frigorigènes à courbes de saturation plus élevées sont plus efficaces pour une charge moins grande lorsque l'équipement n'a subi aucune modification. Les résultats indiquent toutefois qu'en choisissant les composants appropriés, tels que des compresseurs à plus grand volume de déplacement et à taux supérieur de débit de la masse, la capacité refroidissante et le rendement général des autres frigorigènes sont du même ordre d'importance.

209. Les résultats des essais sur les frigorigènes à glissement élevé révèlent que le fractionnement du frigorigène, comme manifesté lors du test de fuites, ne semble pas être une préoccupation importante, car un changement de la capacité refroidissante de moins de 2 pour cent a été observé après la recharge du système, et les différences d'efficacité énergétique devraient être minimales.

210. Les travaux d'évaluation des risques ont porté sur les différentes utilisations de la climatisation, les pratiques d'entretien et les habiletés des techniciens dans des conditions à température ambiante élevée; la température n'a aucun effet direct sur les risques. Un modèle d'évaluation des risques a été élaboré en collaboration avec les experts de JRAIA et avec la contribution des experts du Comité technique des solutions en réfrigération et du Comité technique des choix de halons. Il a été utilisé comme exemple d'un système de climatisation à deux blocs de 5,3 kW (1 tonne de réfrigération) utilisant un frigorigène A2L, comme suit :

- a) Utilisé dans un bureau comprenant plusieurs sources d'allumage telles que du charbon de bois et un briquet utilisés pour brûler de l'encens, une bougie parfumée, ainsi que des cigarettes et des briquets. La probabilité d'allumage causé par ces événements a été évaluée à environ  $10^{-9}$ ; et
- b) Pendant les réparations et le brasage, en présence de trois sources d'allumage, à savoir du charbon de bois et un briquet utilisés pour brûler de l'encens, le brûleur de brasage, une cigarette et un briquet. La probabilité d'allumage était d'environ  $10^{-3}$ , mettant en évidence l'importance des pratiques d'entretien sécuritaires (dont l'interdiction de fumer dans l'aire d'entretien).

211. Principales recommandations de PRAHA-II :

- a) Le renforcement des capacités a fourni une plateforme de coopération entre les gouvernements, les instituts de recherche, les associations de l'industrie et l'industrie; celle-ci est devenue une plateforme d'échange d'information et de résultats sur la conception, le positionnement sur le marché et l'entretien d'équipement de climatisation à base de frigorigènes à faible PRG; elle a aidé les parties prenantes à acquérir des connaissances sur la manipulation des frigorigènes à faible PRG; elle a aidé les fabricants à développer ou à participer à des projets de recherche; elle a permis à l'industrie d'évaluer les solutions de rechange à long terme et elle a haussé le niveau de sensibilisation au besoin de choisir des solutions de rechange. Les visites d'étude ont exposé les parties prenantes aux dernières technologies en matière de réfrigération. Ce projet est réalisable et devrait se poursuivre;



- b) Le remplacement des frigorigènes est une solution viable qui peut concurrencer les frigorigènes à PRG élevé, mais qui exige la conception et le choix des bons composants (surtout le compresseur et le détenteur). L'utilisation d'un frigorigène de remplacement sur un appareil non adapté n'est jamais recommandée. Des simulations numériques et certaines analyses d'optimisation fourniront de l'information pour la reprise de la conception à coût beaucoup moins élevé que les changements graduels par tâtonnements;
- c) Une évaluation des risques sur mesure est essentielle afin de mieux comprendre les conséquences pour la sécurité associées au déploiement de frigorigènes de remplacement, compte tenu des particularités des différents types d'équipement et de leur durée de vie, notamment le transport, l'entreposage, l'installation, l'utilisation, l'entretien et la mise hors service. Les évaluations des risques associés aux autres étapes portant sur les aspects culturels et de mode de vie devraient être envisagées. Les mesures pour atténuer les risques dépendent du type de normes et des codes des différents pays, ainsi que des pratiques d'entretien. Les pays visés à l'article 5 pourraient bénéficier de l'expérience de PRAHA-II pour l'élaboration d'un modèle d'évaluation des risques, afin de passer par-dessus les difficultés techniques et d'élaborer rapidement un modèle; et
- d) L'optimisation des prototypes de PRAHA-I a révélé que les composants, surtout les compresseurs, conçus pour les frigorigènes de remplacement à faible PRG n'étaient pas offerts sur le marché à l'époque, et que la situation n'a pas changé dans plusieurs cas. Un processus qui informe constamment les fabricants des nouveaux développements aiderait ces derniers à prendre des décisions informées.

### Observations du Secrétariat

212. Le Comité exécutif, à sa 83<sup>e</sup> réunion, a décidé de reporter, à titre exceptionnel, la date d'achèvement du projet au 15 novembre 2019, afin de permettre l'achèvement des essais des prototypes de climatiseurs, valider les résultats des tests d'optimisation et le modèle d'évaluation des risques et de diffuser les résultats des essais, et a demandé au PNUD et à l'ONUDI de retourner les soldes à la 85<sup>e</sup> réunion. Toutes ces activités sont maintenant terminées, sauf que le sixième symposium international sur les frigorigènes de remplacement pour les pays à température ambiante élevée devant avoir lieu en mars 2020 à Dubaï a été reporté à cause de la pandémie de la COVID-19. Le symposium a été reporté provisoirement au premier trimestre de 2021, selon l'évolution de la COVID-19. Entretemps, le PNUE et l'ONUDI prévoient diffuser les résultats du projet aux pays à température ambiante élevée dans le cadre d'un webinaire spécial, présenté provisoirement en juin 2020. Le PNUE et l'ONUDI ont engagé toutes les sommes nécessaires au 15 novembre 2019. Bien que les sommes non engagées puissent être retournées, un paiement non liquidé demeure en instance à cause du report du symposium. En conséquence, le PNUE et l'ONUDI ont été invités à retourner les soldes à la 86<sup>e</sup> réunion, à titre exceptionnel.

213. La conclusion que le fractionnement des frigorigènes à glissement élevé lors de la recharge de fuites de frigorigènes aura vraisemblablement peu de conséquences sur la capacité refroidissante et l'efficacité énergétique de l'équipement est significative et pourrait faciliter l'adoption de tels frigorigènes.

214. Une des principales conclusions de PRAHA-I, qui a été confirmée par PRAHA-II, est que le processus d'améliorer les normes d'efficacité énergétique de l'équipement de climatisation dans les pays à température ambiante élevée avance plus rapidement que le processus d'évaluation et de sélection des frigorigènes de remplacement; par conséquent, il est urgent d'aborder en même temps la question de l'efficacité énergétique et des solutions de remplacement à faible PRG afin d'éviter la promotion des solutions de remplacement à PRG élevé. PRAHA a donné lieu à la création d'un processus grâce auquel l'industrie peut participer à la recherche et au développement, et partager l'information et les meilleures pratiques de la transition à de l'équipement de climatisation éconergétique et à faible PRG. Le PNUE a

aussi créé une plateforme de coopération interne entre les Bureaux nationaux de l'ozone et les autorités énergétiques dans le cadre de programmes de jumelage dans le secteur de l'ozone/énergie, mis en œuvre en 2018-2019, et a mis en place des ententes de coopération locale dans plusieurs pays. De plus, la différence de la fréquence à laquelle les normes d'efficacité énergétique sont mises à jour par rapport au processus de développement et de déploiement des frigorigènes à faible PRG dans le secteur de la fabrication de climatiseurs est entrée en ligne de compte à l'échelle nationale (p. ex., projet de reconversion des climatiseurs en Égypte approuvé à la 84<sup>e</sup> réunion<sup>50</sup>).

215. Le Secrétariat a pris note que le PNUE et l'ONUDI ont l'intention de transformer le projet PRAHA en programme réel offrant une rétroaction et un soutien continus aux pays à température ambiante élevée, et ont cherché à comprendre comment assurer la pérennité de PRAHA. PRAHA comprend maintenant des fonctions de renforcement des capacités pour des pays à température ambiante élevée et n'étant pas à température ambiante élevée, par exemple :

- a) Des visites d'étude en Chine et au Japon auxquelles ont participé des experts de l'Algérie, du Bahreïn, de l'Égypte, de la Jordanie, du Koweït, du Pakistan, de l'Arabie saoudite et des Émirats arabes unis;
- b) Des sessions spéciales lors des réunions de réseaux régionaux afin de transmettre les connaissances et l'information sur le PRAHA;
- c) Une série de cinq symposiums réunissant plusieurs pays à température ambiante élevée et n'étant pas à température ambiante élevée, ainsi que des experts de l'industrie, et un sixième symposium dont la documentation et le matériel seront partagés dans le cadre d'un webinaire spécial, malgré le report, et les leçons du projet seront publiées sur les sites Web du PNUE et de l'ONUDI; et
- d) Des sessions spéciales lors des réunions des groupes de travail à composition non limitée et des conférences internationales de réfrigération, climatisation et ventilation pertinentes.

216. Le PRAHA a mis l'accent, à ce jour, sur les pays à température ambiante élevée ayant des installations de fabrication. Cependant, la majorité des pays à température ambiante élevée ne possèdent pas d'installations locales de fabrication de climatiseurs, mais profitent de la technologie. Le PNUE et l'ONUDI tentent d'aborder la question en :

- a) Continuant à utiliser les ressources créées par le PRAHA afin d'aider les pays et accroître leurs connaissances sur les substances de remplacement; et
- b) Proposant au Comité exécutif un nouveau projet ayant pour but d'offrir une assistance technique pour le déploiement de substances de remplacement, comprenant une évaluation des risques dans les pays à température ambiante élevée qui ne fabriquent pas de climatiseurs, un soutien technique pour développer une stratégie d'acceptation par le marché et un plan de déploiement de l'équipement à base de frigorigènes à faible PRG, la conception d'un modèle de code de réfrigération, climatisation et ventilation et des outils pour son application afin de faciliter la bonne utilisation de frigorigènes à faible PRG, et un programme de formation à l'intention des autorités locales qui réglementent, autorisent ou assurent le suivi de l'équipement et des projets fondés sur les frigorigènes à faible PRG.

---

<sup>50</sup> UNEP/OzL.Pro/ExCom/84/49.

217. Le Secrétariat a toutefois noté que le Comité exécutif n'avait pas offert de cadre supplémentaire pour d'autres projets de démonstration sur les HCFC.

### **Recommandation**

218. Le Comité exécutif pourrait souhaiter :

- a) Prendre note avec satisfaction du rapport final sur le projet de démonstration sur la promotion de frigorigènes de remplacement dans les systèmes de climatisation pour les pays à température ambiante élevée de l'Asie occidentale (PRAHA-II) proposé par le PNUD et l'ONUDI et présenté dans le document UNEP/OzL.Pro/ExCom/85/9;
- b) Demander au PNUE et à l'ONUDI de retourner les soldes d'ici la 86<sup>e</sup> réunion au lieu de la 85<sup>e</sup> réunion, compte tenu du report du sixième symposium international sur les frigorigènes de remplacement dans les pays à température ambiante élevée causé par la pandémie de la COVID-19; et
- c) Inviter les agences bilatérales et d'exécution à partager le rapport final du projet de démonstration mentionné à l'alinéa a) ci-dessus lorsqu'elles aident les pays visés à l'article 5 à préparer des projets dans le secteur de la climatisation des pays à température ambiante élevée.

### **Rapports de vérification financière sur les secteurs de la production de CFC, des halons, de la mousse de polyuréthane, de l'entretien de l'équipement de réfrigération et des solvants en Chine**

Chine : Agent de transformation II : Renseignements supplémentaires sur les activités à entreprendre (Banque mondiale)

### **Contexte**

219. Le gouvernement de la Chine a proposé à la 84<sup>e</sup> réunion d'entreprendre les activités ci-dessous afin d'améliorer le suivi et la gestion à long terme des SAO, en utilisant le solde non engagé d'environ 1,24 million \$US pour le plan sectoriel de l'agent de transformation II :

- a) Construction et mise à niveau du système de suivi en ligne de la production de tétrachlorure de carbone. Ce système agirait comme complément au système d'information sur la gestion des SAO en mettant l'accent sur la production, la reconversion, la vente et le stockage du tétrachlorure de carbone chez les producteurs de chlorométhane;
- b) Investigations sur la production et l'utilisation du tétrachlorure de carbone. Cette activité serait un complément à l'étude sur la production et l'utilisation de tétrachlorure de carbone aux fins de matière première proposée conformément à la décision 75/18 et comprendrait une étude et une vérification sur place de la production et de l'utilisation de tétrachlorure de carbone comme matière première. Les usines de perchloroéthylène (PERC) ne sont pas visées;
- c) Soutien aux entreprises pour le développement et l'approvisionnement du réactif (substitut du tétrachlorure de carbone) exigé en vertu de la norme nationale amendée. Cette activité soutiendrait les fabricants dans la mise sur pied d'installations de purification des usines de PERC pour répondre aux demandes d'une nouvelle norme et à la demande du marché;

- d) Formation et renforcement des capacités de supervision et d'application en lien avec les SAO pour les Bureaux de l'écologie et de l'environnement (BEE). Des cours de formation seront offerts périodiquement au personnel des BEE provinciaux, municipaux et de canton sur la gestion, l'inspection, la supervision et l'application des SAO, dans le cadre de cette activité;
- e) Surveillance du marché et collecte d'information sur les ventes de SAO. Les services d'une entreprise de consultation seront retenus afin de recueillir de l'information sur les ventes et le marché des SAO, et de repérer les ventes illégales soupçonnées. L'information sur ces ventes sera communiquée au ministère de l'Écologie et l'Environnement (MEE), afin que des mesures soient prises en conséquence; et
- f) Soutien technique, de politique générale et juridique sur la gestion, l'inspection, la supervision et l'application en rapport avec les SAO, ainsi que leur élimination. Des experts seront embauchés afin d'offrir ce soutien aux institutions concernées.

220. De plus, le gouvernement de la Chine a prévu d'utiliser une part de 250 000 \$US du solde pour un système de gestion en ligne des SAO et 750 000 \$US pour le renforcement des capacités des autorités douanières.

221. Le Secrétariat a pris note de ce qui suit à la 84<sup>e</sup> réunion :

- a) Le système de gestion en ligne des SAO permettra à toutes les entreprises qui utilisent des SAO de présenter une demande, de s'enregistrer comme utilisateur de SAO et de communiquer des données. Bien que le Secrétariat ait appuyé la proposition, il ne connaît pas les détails de ce système de gestion en ligne et a été incapable d'évaluer le niveau de financement de cette activité. De plus, le financement provenant d'autres projets, dont les plans sectoriels sur la production de bromure de méthyle, la réfrigération industrielle et commerciale, et les climatiseurs individuels au titre du plan de gestion de l'élimination des HCFC (PGEH) et du plan de gestion de la production de HCFC (PGEPH) a été utilisé pour renforcer le système de gestion en ligne des SAO; un tel regroupement de ressources constitue assurément une utilisation efficace des ressources, mais il rend le suivi des progrès financiers et de mise en œuvre plus difficile;
- b) Ce même type de financement est proposé pour le renforcement des capacités des autorités douanières concernant le secteur de la production de bromure de méthyle. Le Centre de coopération étrangère pour l'environnement (FECO) a précisé que le contrat pour le secteur de la production de bromure de méthyle porte sur le bromure de méthyle utilisé pour les applications de quarantaine et préalables à l'expédition, tandis que le renforcement des capacités pour le secteur de l'agent de transformation II porte sur les activités de lutte contre la contrebande; et
- c) Les six activités proposées seront utiles, mais le Secrétariat doit encore déterminer le financement à allouer à chaque activité. De plus, le Secrétariat est d'avis que des rapports supplémentaires sur les résultats des activités seraient utiles. Par exemple, l'activité sur la supervision du marché pourrait aider à mieux comprendre comment les installations qui fabriquent du CFC-11 ont pu acheter du tétrachlorure de carbone. Le Secrétariat croit que l'activité de supervision du marché sera encore utile après l'achèvement du projet et estime que le MEE devrait prévoir un budget à ces fins. Le développement et la mise à niveau du système en ligne de suivi de la production de tétrachlorure de carbone favoriseraient cette supervision du marché. Le Secrétariat a suggéré que le gouvernement de la Chine fournisse des renseignements supplémentaires sur les activités proposées, leur budget et un rapport périodique sur leur mise en œuvre à la 85<sup>e</sup> réunion, par l'entremise

de la Banque mondiale, et que le Comité exécutif offre une orientation supplémentaire sur la somme de 1 million \$US allouée au système en ligne de gestion des SAO et le renforcement des capacités des autorités douanières.

222. À l'issue des échanges bilatéraux, le Comité exécutif a demandé au gouvernement de la Chine de remettre, par l'entremise de la Banque mondiale, des renseignements supplémentaires sur les activités proposées dans le cadre du plan sectoriel de l'agent de transformation II et un rapport périodique sur leur mise en œuvre à la 85<sup>e</sup> réunion (décision 84/39 d)).

#### Renseignements supplémentaires fournis à la 85<sup>e</sup> réunion

223. Le budget pour le système de gestion en ligne des SAO a été augmenté à 280 000 \$US; une entreprise de consultation a été retenue et un contrat d'une valeur de 272 238 \$US lui a été octroyé. Un système en ligne avait été mis sur pied à la phase I, par lequel les entreprises devaient faire une demande d'octroi de quotas de consommation et de production de HCFC, enregistrer leurs ventes et l'utilisation comme matière première, et fournir les données demandées en ligne. Cette activité a pour but de créer un système qui étend le mécanisme de communication et de gestion des données des HCFC à toutes les SAO.

224. En ce qui concerne le renforcement des capacités pour les douanes, le FECO et les autorités douanières ont assuré la formation périodique des douaniers des bureaux central et locaux. Le budget de cette activité est demeuré de 750 000 \$US.

225. Le budget de quatre des six activités restantes a été augmenté à 1,26 million \$US en raison des fluctuations du taux de change :

- a) *Construction et mise à niveau du système de suivi en ligne de la production de tétrachlorure de carbone* : Le projet, dont le budget est de 450 000 \$US, améliorera la transmission des données utilisées par le système pour assurer le suivi et la gestion du tétrachlorure de carbone, notamment en utilisant l'Internet pour la transmission de données, en augmentant la capacité des logiciels et de l'équipement du système actuel de suivi en ligne du tétrachlorure de carbone et en créant une page Web pour le système. La plateforme centrale de suivi est une plateforme de suivi des données pour tous les aspects de la production et de l'utilisation du tétrachlorure de carbone, dont la vente, l'élimination et l'inventaire, la facilitation du contrôle dynamique des données de production, l'analyse de données et autres fonctions. Le consultant a été choisi et a commencé à préparer le concept technique, le cadre de travail, l'interface du programme et un protocole de transfert de données compatibles avec les programmes de base de données des producteurs de tétrachlorure de carbone;
- b) *Renforcement des capacités des services douaniers en matière de supervision et de gestion des SAO* : Cette activité de renforcement des capacités, dont le budget est de 650 000 \$US, comprend la suite de la mise en œuvre des programmes de formation outremer du personnel des douanes, la promotion des capacités de gestion des importations et des exportations de la Chine et sa coopération transfrontalière à l'application des lois, l'aide aux autorités douanières pour la mise sur pied d'un système de données de recherche et de jugement sur le commerce illicite, la mise sur pied d'un mécanisme multisectoriel de partage d'information et de renseignements, et le renforcement des capacités d'application conjointe des lois, pour lutter contre les infractions d'importation et d'exportation de SAO et repérer les sources intérieures de production et de ventes illicites. Le FECO et les autorités douanières ont préparé un plan de travail, et le mandat de la mise sur pied d'un système de données de recherche et de jugements sur le commerce illicite a été élaboré;

- c) *Enquêtes sur la production de tétrachlorure de carbone et son utilisation comme matière première, soutien aux entreprises pour le développement et l'approvisionnement du réactif nécessaire (en remplacement du tétrachlorure de carbone) appliqué en vertu de la norme nationale amendée* : Cette activité, dont le budget est de 120 000 \$US, a pour but de poursuivre le suivi de la production de tétrachlorure de carbone et de son utilisation comme matière première. Elle comprend l'enquête sur place et la vérification de la production de tétrachlorure de carbone et de son utilisation comme matière première, ainsi que le soutien aux fabricants de réactifs afin qu'ils puissent aménager les installations de purification nécessaires de perchloroéthylène. Le consultant a été choisi et les études théoriques sur la production de tétrachlorure de carbone et la consommation de matière première ont débuté; par contre, les enquêtes sur place n'ont pas encore commencé à cause des contraintes sur les déplacements imposées à cause de la pandémie de COVID-19. Les échanges se poursuivent avec l'association de l'industrie concernant le soutien à l'approvisionnement de perchloroéthylène de qualité laboratoire; et
- d) *Soutien technique, de politique et législatif à la gestion, l'inspection, la supervision des SAO et de l'élimination définitive des SAO* : Soutien technique, de politique et législatif à la gestion, l'inspection, la supervision et l'application des SAO et leur élimination définitive. Le budget de cette activité est de 40 000 \$US. Le MEE est en voie de mettre au point le mandat et les experts seront choisis et retenus par contrat d'ici la fin juin 2020. L'activité sera menée à terme d'ici la fin de 2020.

### **Observations du Secrétariat**

226. La Banque mondiale a expliqué qu'il existe un solide mécanisme de coopération entre le MEE, les autorités douanières et le ministère du Commerce depuis la création du bureau d'importation/exportation, contrairement à ce qui se passe pour la production de bromure de méthyle, où il y a eu des retards dans la mise au point des modalités de coopération entre le FECO et les autorités douanières, et que celui-ci continuera à être utilisé. Aucun retard n'est prévu avec les autorités douanières dans la mise au point des activités en cours dans le plan sectoriel de l'agent de transformation II.

227. La surveillance du marché et la collecte d'information sur les ventes de SAO proposées à la 84<sup>e</sup> réunion seront effectuées dans le cadre du programme de suivi, de communication des données et de vérification mis en œuvre par le MEE, conformément à la décision 83/41 c) v). Un agent a été nommé pour assurer la liaison avec l'industrie dans le but de suivre les ventes de SAO et de produits à base de SAO. La tâche sera donc retirée du programme de travail pour l'agent de transformation.

228. Quant au lien entre le système de gestion en ligne des SAO (280 000 \$US) et le système de suivi en ligne de la production de tétrachlorure de carbone (145 000 \$US), la Banque mondiale a précisé que le système existant de gestion en ligne des SAO a été conçu pour effectuer le suivi de la production et des ventes de HCFC seulement. Les producteurs sont tenus de déclarer leur production et ventes mensuelles tous les trimestres. Les données sont compilées par le FECO et utilisées comme base pour l'exercice de vérification indépendante de la production et la consommation de HCFC mené par la Banque mondiale. Le FECO a demandé aux consultants d'étendre le système existant en ligne afin d'y inclure les SAO, dont le tétrachlorure de carbone. Cette activité sera achevée d'ici la fin de 2020. Le système de suivi en ligne de la production de tétrachlorure de carbone a pour but de garantir le transfert en temps réel de données sur la production de tétrachlorure de carbone (mesurées par les débitmètres et stockées dans les systèmes de contrôle des procédés des entreprises) de chaque producteur de tétrachlorure de carbone aux autorités gouvernementales. L'information recueillie sera utilisée pour recouper les données mensuelles de production et de ventes soumises tous les trimestres par les entreprises dans un système élargi de gestion en ligne des SAO.

229. Quant à la différence entre le renforcement des capacités des autorités douanières (750 000 \$US) et le renforcement des capacités des douanes pour la supervision et la gestion des SAO (650 000 \$US), la Banque mondiale a expliqué que le renforcement des capacités des autorités douanières visait la formation courante des douaniers des bureaux central et locaux ayant été menée par le FECO et les autorités douanières, tandis que le renforcement des capacités des douanes avait pour but d'aider l'autorité douanière à mettre sur pied un système de données de recherche et de jugements sur le commerce illicite, d'établir un mécanisme multisectoriel de partage d'information et de renseignements, et de renforcer le système conjoint d'application des lois.

230. Le Secrétariat soutient les activités proposées pour le secteur de l'agent de transformation II. Cependant, l'information supplémentaire fournie par le gouvernement de la Chine ne lui a pas permis d'évaluer le coût des activités proposées.

### Recommandation

231. Le Comité exécutif pourrait souhaiter prendre note des renseignements supplémentaires sur les activités proposées pour le secteur de l'agent de transformation II de la Chine, de leur budget et du rapport périodique sur leur mise en œuvre (décision 84/39 d) présentés dans le document UNEP/OzL.Pro/ExCom/85/9.

### Demande de prorogation des activités de facilitation (PNUD, PNUE et ONUDI)

232. Conformément à la décision 81/32 a),<sup>51</sup> les agences bilatérales et d'exécution ont présenté une demande officielle de prorogation des activités de facilitation de la réduction progressive des HFC au nom de neuf pays visés à l'article 5, comme indiqué dans le tableau 10.

**Tableau 10 : Demandes de prorogation des activités habilitantes de la réduction progressive des HFC soumises à la 85<sup>e</sup> réunion**

Pays	Agence d'exécution principale	Date d'achèvement	Date de remise
Bahamas	PNUE	30 juin 2020	30 juin 2021
Bolivia (État plurinational de)	PNUE	30 juin 2020	30 juin 2021
Brunéi Darussalam	PNUE	30 juin 2020	30 juin 2021
Cap-Vert	PNUE	30 juin 2020	30 juin 2021
Îles Cook	PNUE	30 juin 2020	30 juin 2021
Jordanie	ONUDI	30 juin 2020	30 juin 2021
Maurice	PNUE	30 juin 2020	30 juin 2021
Qatar*	ONUDI	30 juin 2020	30 juin 2021
Timor-Leste	PNUE	30 juin 2020	30 juin 2021

\*PNUE en tant qu'agence d'exécution de coopération

### Observations du Secrétariat

233. Plusieurs raisons ont été invoquées dans les demandes de prorogation des activités de facilitation : Il faut plus de temps que prévu pour commencer la mise en œuvre, la coordination entre les Bureaux nationaux de l'ozone, les parties prenantes et le PNUE, et le besoin de mener à terme toutes les activités prévues. Le Secrétariat a pris note que les difficultés qui avaient retardé le début de la mise en œuvre ont été réglées et que des progrès ont été accomplis. Les gouvernements des pays concernés reconnaissent que les activités de facilitation doivent être terminées d'ici au 30 juin 2021 et que les soldes devront être restitués lorsque les activités seront terminées.

<sup>51</sup> Le Comité exécutif a décidé de maintenir la période de 18 mois pour la mise en œuvre des activités de facilitation et de la prolonger d'un maximum de 12 mois, si nécessaire (pour un total de 30 mois depuis l'approbation), lorsque le Secrétariat aura reçu une demande de prorogation officielle.

## Recommandation

234. Le Comité exécutif pourrait souhaiter :

- a) Prendre note des demandes de prorogation des activités de facilitation de la réduction progressive des HFC présentées par les agences d'exécution respectives des neuf pays visés à l'article 5 indiqués dans le tableau 10 du document UNEP/OzL.Pro/ExCom/85/9;
- b) De reporter la date d'achèvement des activités de facilitation de la réduction progressive de HFC au 30 juin 2021 pour les Bahamas, la Bolivie (État plurinational de), le Brunéi Darussalam, le Cap-Vert, les Îles Cook, la Jordanie, Maurice, le Qatar et le Timor-Leste, étant entendu qu'aucune autre période de prorogation ne sera demandée et que les agences d'exécution remettront le rapport final des activités de facilitation réalisées conformément à la décision 81/32 b) six mois après l'achèvement du projet, au plus tard.

## PARTIE III : RAPPORTS SUR LES PROJETS COMPORTANT DES EXIGENCES PARTICULIÈRES DE REMISE DE RAPPORTS PROPOSÉS POUR EXAMEN INDIVIDUEL

### Rapports liés aux PGEH

République populaire démocratique de Corée : Plan de gestion de l'élimination des HCFC (phase I : Rapport périodique sur la mise en œuvre des activités) (ONUDI)

#### Contexte

235. Le Comité exécutif, à sa 73<sup>e</sup> réunion, a approuvé, en principe, la phase I du PGEH pour la République populaire démocratique de Corée, pour laquelle l'ONUDI agirait en qualité d'agence d'exécution principale et le PNUE agirait en qualité d'agence d'exécution de collaboration, afin de réduire la consommation de HCFC à un niveau stable de 66,30 tonnes PAO avant le 1<sup>er</sup> janvier 2018 (c.-à-d., 15 pour cent sous la valeur de référence des HCFC pour la conformité de 78,0 tonnes PAO). L'approbation est entrée en vigueur sur confirmation par les agences d'exécution que la phase I du PGEH pour la République populaire démocratique de Corée serait mise en œuvre conformément aux résolutions du Conseil de sécurité des Nations Unies<sup>52</sup> concernant la République populaire démocratique de Corée.

236. Le Comité exécutif a approuvé trois des quatre tranches de financement depuis l'approbation de la phase I, pour la somme de 808 550 \$US (c.-à-d., 95,3 p. cent de la somme totale de 848 550 \$US approuvée en principe), ainsi que le transfert à l'ONUDI de toutes les activités devant être mises en œuvre par le PNUE. La dernière tranche de la phase I du PGEH, représentant la somme de 40 000 \$US, devait être proposée à la 81<sup>e</sup> réunion, conformément à l'accord entre le gouvernement et le Comité exécutif. L'ONUDI était toujours incapable de soumettre la demande de tranche en date de la 84<sup>e</sup> réunion, à cause des résolutions du Conseil de sécurité des Nations Unies.

#### Rapport périodique

237. L'ONUDI a remis à la 85<sup>e</sup> réunion, un rapport périodique sur la mise en œuvre de la phase I du PGEH, indiquant les activités mises en œuvre à ce jour, le niveau de décaissement réalisé, les difficultés rencontrées dans les tentatives de poursuivre la mise en œuvre des activités en conformité avec les résolutions du Conseil de sécurité, et comprenant une demande d'orientation du Comité exécutif.

---

<sup>52</sup> Le Conseil de sécurité des Nations Unies, établi en vertu de la résolution 1718, a été consulté avant la proposition de la phase I du PGEH afin de déterminer si l'équipement ou tout autre service relevant du PGEH pouvait être fourni au pays.



238. Le rapport révèle que les principales activités suivantes ont été mises en œuvre au cours de la première et de la deuxième tranches, malgré les résolutions du Conseil de sécurité :

- a) Achat de trois identifiants de frigorigènes pour le bureau des douanes du pays;
- b) Achat d'une distributrice de mousse pour l'usine de matériaux de construction Puhung après avoir reçu l'autorisation du Conseil de sécurité en 2015 et préparation d'un contrat pour de l'équipement accessoire permettant l'installation et la mise en service de l'équipement de distribution de la mousse, et expédition de celui-ci;
- c) Achat d'équipement pour la mousse de polyuréthane (formiate de méthyle) autorisé par le Conseil de sécurité, conformément à la procédure établie à la résolution 2270 (2016) du Conseil de sécurité; un contrat a été émis à l'intention des fournisseurs d'équipement; l'équipement a été expédié en passant par la Chine, car il ne pouvait pas être envoyé directement en République populaire démocratique de Corée, mais il a été refusé par les autorités douanières de la Chine et retourné au fournisseur;
- d) Achat d'équipement de formation pour les techniciens d'entretien de l'équipement de réfrigération et de climatisation, après l'autorisation du Conseil de sécurité, qui a été expédié et distribué aux techniciens d'entretien de l'équipement de réfrigération en juin 2016;
- e) Organisation d'un atelier de formation des formateurs de techniciens à l'intention de 35 techniciens en réfrigération et climatisation, présenté en août et septembre 2016;
- f) Achèvement d'une session de formation supplémentaire en meilleures pratiques de réfrigération et climatisation à l'intention de 5 techniciens, présenté en Inde en décembre 2016; et
- g) Présentation du premier atelier de formation des formateurs à 40 douaniers en mai 2017.

*Niveau de décaissement des fonds*

239. La somme totale de 303 313 \$US (36 p. cent) des 808 550 \$US approuvés avait été décaissée au 30 mars 2020, comme indiqué dans le tableau 11.

**Tableau 11 : Rapport financier de la phase I du PGEH pour la République populaire démocratique de Corée (\$US)**

Tranche	Somme approuvée	Somme décaissée	Taux de décaissement (%)
Première	134 003	87 386	65,2
Deuxième	506 680	211 110	41,7
Troisième	167 867	1 817	1,1
<b>Total</b>	<b>808 550</b>	<b>300 313</b>	<b>36,0</b>

*Mise à jour sur la mise en œuvre de la phase I du PGEH*

240. Les activités suivantes n'ont pas encore été mises en œuvre :

- a) Suivi de l'atelier de formation des techniciens d'entretien de l'équipement de réfrigération et de climatisation, et des douaniers;

- b) Levé des centres de régénération et de récupération existants et achat d'équipement supplémentaire;
- c) Mise sur pied du groupe de gestion du projet lorsque le mode de transfert du financement aura été approuvé et sera fonctionnel.

241. De plus, l'équipement retourné au fournisseur par les autorités douanières de la Chine n'a pas pu être réimporté car une autre résolution, la résolution 2397 adoptée en 2017, interdit spécifiquement « toute machinerie industrielle (codes SH 84 et 85), tout véhicule de transport (codes HS 86 à 89), ainsi que le fer, l'acier et tout autre métal (codes HS 72 à 83) ». Après l'adoption de cette résolution, l'ONUDI a été informée de présenter une nouvelle demande de dérogation au Conseil de sécurité, accompagnée d'une liste à jour de l'équipement à importer au pays. L'ONUDI a présenté une demande de dérogation officielle le 8 mai 2019 qui a été refusée par le Conseil de sécurité le 18 juin 2019. Compte tenu de ce qui précède, l'ONUDI n'a pas été en mesure de donner suite à la livraison de l'équipement.

242. L'incapacité de transférer des fonds au pays, situation rendue encore plus difficile par l'imposition de sanctions plus sévères à la suite de l'adoption de la résolution 2397 (2017), a aussi eu des incidences sur les activités ne portant pas sur des investissements.

243. Compte tenu de ce qui précède, l'ONUDI a précisé dans son rapport qu'elle n'était pas en position de poursuivre la mise en œuvre du PGEH de la République populaire démocratique de Corée et demande l'orientation du Comité exécutif.

### **Observations du Secrétariat**

244. Le Secrétariat a pris note que l'ONUDI a continué à faire preuve de diligence raisonnable et à effectuer un suivi tout au long de la mise en œuvre du projet. Elle a présenté une demande de dérogation au titre de la résolution 1718, ainsi qu'une liste à jour de l'équipement à importer au pays, lors de l'adoption d'une résolution supplémentaire du Conseil de sécurité en 2017, et a continué à collaborer étroitement avec les États membres des Nations Unies concernant l'achat et l'exportation d'équipement conçu pour réduire progressivement l'utilisation de substances réglementées au pays.

### **Recommandation**

245. Le Comité exécutif pourrait souhaiter examiner l'information sur la mise en œuvre des activités au titre de la phase I du plan de gestion de l'élimination des HCFC (PGEH) pour la République populaire démocratique de Corée proposée par l'ONUDI.

### **Rapports de vérification financière des secteurs de la production de CFC, des halons, de la mousse de polyuréthane, de l'entretien de l'équipement de réfrigération et des solvants en Chine**

Chine : Rapports de vérification financière des secteurs de la production de CFC, des halons, de la mousse de polyuréthane, de l'agent de transformation II, de l'entretien de l'équipement de réfrigération et des solvants (PNUD, ONUDI et Banque mondiale)

### **Contexte**

246. Le Comité exécutif a examiné à sa 84<sup>e</sup> réunion, les rapports de vérification financière des secteurs de la production des CFC, des halons, de la mousse de polyuréthane, de l'agent de transformation II, de l'entretien de l'équipement de réfrigération et des solvants, pour lesquels une mise à jour des activités mises en œuvre dans chacun des plans sectoriels a également été fournie.<sup>53</sup> Par la suite, le Comité exécutif

<sup>53</sup> Paragraphes 6-105 du document UNEP/OzL.Pro/ExCom/84/22/Add.1

a demandé au gouvernement de la Chine de remettre à la 85<sup>e</sup> réunion, par l'entremise de l'agence d'exécution concernée, les rapports de vérification financière au 31 décembre 2019 pour les secteurs de la production de CFC, des halons, de la mousse de polyuréthane, de l'agent de transformation II, de l'entretien de l'équipement de réfrigération et des solvants, ainsi que les rapports d'achèvement de projet pour les secteurs de la production de CFC, de la mousse de polyuréthane, de l'entretien de l'équipement de réfrigération et des solvants, et de retourner à la 85<sup>e</sup> réunion les soldes au 31 décembre 2019 des projets associés aux secteurs de la production de CFC, de la mousse de polyuréthane, de l'entretien de l'équipement de réfrigération et des solvants (décision 84/49 c) i) et c) ii)).

247. Les agences d'exécution concernées ont remis au nom du gouvernement de la Chine, les rapports financiers vérifiés au 31 décembre 2019 et les rapports d'achèvement de projet pour les secteurs de la production de CFC, de la mousse de polyuréthane, de l'entretien de l'équipement de réfrigération et des solvants, conformément à la décision 84/39 c) i). Des rapports finaux supplémentaires ont été remis pour les secteurs de l'entretien de l'équipement de réfrigération et des solvants. Un compte rendu sur les progrès accomplis dans le secteur de l'agent de transformation II est présenté aux paragraphes 218 à 230 du présent document.

248. Les données financières présentées dans le présent rapport sont basées sur le rapport de vérification remis par le gouvernement de la Chine au 31 décembre 2019, indiquant un solde de 11 309 628 \$US (tableau 12). Le solde des plans sectoriels achevés (c.-à-d., production de CFC, mousse de polyuréthane, entretien de l'équipement de réfrigération et solvants) s'élève à 792 215 \$US (à savoir 311 653 \$US provenant de soldes et 480 561 \$US provenant d'intérêts cumulés). Le solde retourné à la 85<sup>e</sup> réunion, conformément à la décision 84/39 c) ii) s'élève à 792 215 \$US.

**Tableau 12 : Soldes et intérêts restants pour les secteurs de la production de CFC, des halons, de la mousse de polyuréthane, de l'agent de transformation II, de l'entretien de l'équipement de réfrigération et des solvants (\$US)**

Activité	Solde au 30 juin 2019	Solde au 31 décembre 2019	Intérêt cumulé	Date d'achèvement
Production de CFC (Banque mondiale)	179 878	33 907	22 119	Décembre 2019
Secteur des halons (Banque mondiale)	9 154 827	8 913 167		Décembre 2020
Agent de transformation II (Banque mondiale)	3 076 109	2 084 808		Décembre 2020
Mousse de polyuréthane (Banque mondiale)	897 009	280 108		Décembre 2019
Entretien (Japon, PNUE, ONUDI)	735 791	752	99 178	Décembre 2019
Solvants (PNUD)	708 822	*-3 114	*359 265	Décembre 2019
<b>Total</b>	<b>14 752 436</b>	<b>11 309 628</b>	<b>480 561</b>	

\*Le solde total à restituer par le PNUD est de 356 151 \$US.

### Observations du Secrétariat

249. Les plans des secteurs de la production de CFC, de la mousse de polyuréthane, de l'entretien de l'équipement de réfrigération et des solvants ont été menés à terme. Des rapports d'achèvement préliminaires ont été remis, mais ils n'indiquent pas les décaissements finaux versés aux bénéficiaires ni les sommes à retourner à la 85<sup>e</sup> réunion. L'Administrateur principal, Suivi et évaluation collabore avec les agences d'exécution concernées afin que les données financières figurent dans les différents rapports d'achèvement de projet.

250. Les plans des secteurs des halons et de l'agent de transformation II seront achevés au 31 décembre 2020, comme convenu à la 84<sup>e</sup> réunion, et les soldes restants à cette date seront retournés à la 87<sup>e</sup> réunion, conformément à la décision 84/39 b).

## Recommandation

251. Le Comité exécutif pourrait souhaiter :

- a) Prendre note :
  - i) Du rapport de vérification financière des secteurs de la production de CFC, des halons, de la mousse de polyuréthane, de l'agent de transformation II, des solvants et de l'entretien de l'équipement de réfrigération de la Chine, présenté dans le document UNEP/OzL.Pro/ExCom/85/9;
  - ii) Que la Banque mondiale a retourné les soldes des secteurs de la production de CFC et de la mousse de polyuréthane de 314 015 \$US et l'intérêt accumulé de 22 119 \$US à la 85<sup>e</sup> réunion;
  - iii) Que l'ONUDI a retourné le solde du plan du secteur de l'entretien de l'équipement de réfrigération de 752 \$US, plus l'intérêt accumulé de 99 178 \$US, à la 85<sup>e</sup> réunion;
  - iv) Que le PNUD a retourné la somme de 356 151 \$US en intérêt accumulé du plan du secteur des solvants à la 85<sup>e</sup> réunion;
- b) Demander à la Banque mondiale de remettre les rapports de vérification financière des plans des secteurs des halons et de l'agent de transformation II, qui seront achevés le 31 décembre 2020, conformément à la décision 84/39 b), à la 87<sup>e</sup> réunion, avec les rapports d'achèvement de projet correspondants et tout solde restant au 31 décembre 2019; et
- c) Demander à l'Administrateur principal, Suivi et évaluation de collaborer avec les agences d'exécution concernées afin que les rapports d'achèvement de projet associés aux secteurs de la production de CFC, de la mousse de polyuréthane, de l'entretien de l'équipement de réfrigération et des solvants indiquent les décaissements aux bénéficiaires finaux, correspondant à l'information fournie dans les rapports de vérification financière remis à la 85<sup>e</sup> réunion.

## **PARTIE IV : LISTE DES ENTREPRISES FINANCÉES AU TITRE DU PGEH ACCUSANT DU RETARD ET/OU ASSUJETTIES AUX CHANGEMENTS DANS LE PLAN DE MISE EN ŒUVRE ET ENTREPRISES DEVANT RECONVERTIR À DES TECHNOLOGIES À FAIBLE PRG CONNAISSANT DES RETARDS À CAUSE DE PROBLÈMES D'ACCÈS SUR LES MARCHÉS LOCAUX ET/OU DE COÛTS PLUS ÉLEVÉS (décisions 84/27 et 84/42)**

### Contexte

252. Le Comité exécutif, à sa 84<sup>e</sup> réunion, a examiné les rapports sur les projets comportant des exigences particulières pour la remise de rapports.<sup>54</sup> Au cours des échanges, les membres ont souligné l'importance d'examiner les raisons des retards à introduire les substances de remplacement approuvées à faible potentiel de réchauffement de la planète (PRG). Le Comité exécutif a donc demandé au Secrétariat de préparer pour la 85<sup>e</sup> réunion, une liste des entreprises ayant reçu un soutien financier pour reconvertir leurs activités à des technologies à faible PRG dans le cadre de leur plan de gestion de l'élimination des

---

<sup>54</sup> UNEP/OzL.Pro/ExCom/84/22, Add.1, Add.2 et Add.3

HCFC (PGEH) qui connaissaient des retards dans la mise en œuvre des projets liés à la disponibilité des produits sur le marché et/ou des coûts plus élevés (décision 84/27).

253. Le Comité exécutif, à sa 84<sup>e</sup> réunion, a également demandé au Secrétariat de préparer pour la 85<sup>e</sup> réunion, un tableau élémentaire à partir des renseignements puisés dans les rapports périodiques connexes sur les situations des entreprises ayant reçu du soutien financier pour leur PGEH qui connaissaient des retards et/ou dont le plan de mise en œuvre a subi des changements, afin d'avoir accès à de l'information mise à jour régulièrement sur les raisons des changements dans les projets ou de leur annulation (décision 84/42).

#### Mesures prises par le Secrétariat et les agences

254. Le Secrétariat a demandé aux agences bilatérales et d'exécution de lui remettre un compte rendu des projets connaissant des retards et a examiné les rapports périodiques sur la mise en œuvre des PGEH soumis par les agences bilatérales et d'exécution en complément des renseignements fournis par les agences, afin de répondre aux demandes formulées dans les décisions 84/27 et 84/42. La liste de toutes les entreprises connaissant des difficultés en lien avec les décisions 84/27 et 84/42 est jointe à l'annexe VIII au présent document.

255. Le gouvernement de l'Allemagne a fait savoir que sept projets dans le secteur de la mousse connaissaient des retards en lien avec les décisions 84/27 et 84/42. Un projet connaissait un retard car la technologie choisie n'est pas vendue sur le marché et six projets connaissaient des retards à cause de changements dans la mise en œuvre du projet visant, notamment, à obtenir du cofinancement ou à répondre aux sanctions des Nations Unies.

256. Le PNUD a indiqué que 78 projets connaissaient des retards en lien avec les décisions 84/27 et 84/42, dont 22 projets dans le secteur de la mousse, 52 projets dans le secteur de la réfrigération et de la climatisation et quatre projets dans le secteur des solvants. Soixante projets connaissaient des retards à cause de difficultés liées au prix plus élevé et/ou à l'absence de la technologie à faible PRG choisie sur le marché local; plusieurs entreprises se sont retirées du projet à cause des coûts plus élevés et/ou de la non-disponibilité des composants de la technologie de remplacement choisie. Dix-huit projets connaissaient des retards pour d'autres raisons (p. ex., processus administratif d'approbation, signature des documents par le gouvernement, retards dans la signature des accords avec les entreprises concernant le processus de mise en œuvre et les délais plus longs pour faire les essais des substances de remplacement et obtenir l'attestation de sécurité).

257. L'ONUDI a indiqué que 70 projets connaissaient des retards en lien avec les décisions 84/27 et 84/42, à savoir 51 projets du secteur de la mousse et 19 projets dans le secteur de la réfrigération et de la climatisation. Dix projets connaissaient des retards liés à la disponibilité de la technologie de remplacement choisie sur le marché local et/ou à des coûts plus élevés, et 60 projets connaissaient des retards pour d'autres raisons (p. ex., processus administratif d'approbation par le gouvernement, signature des accords avec les entreprises, délais supplémentaires pour l'adoption des réglementations en lien avec les projets, situation politique ou problèmes de sécurité, et sanctions des Nations Unies).

258. La Banque mondiale n'a pas identifié de projets à inclure dans un rapport en lien avec les décisions 84/27 et 84/42.

#### **Observations du Secrétariat**

259. Le Secrétariat a pris note avec satisfaction des renseignements fournis par le gouvernement de l'Allemagne, le PNUD, l'ONUDI et la Banque mondiale concernant les exigences des décisions 84/27 et 84/42.

260. Quatre-vingts des 155 entreprises connaissant des retards sont dans le secteur de la mousse, 71 sont dans le secteur de la réfrigération et de la climatisation et quatre sont dans le secteur des solvants; 71 connaissent des retards en raison de la non-disponibilité de la technologie choisie ou des coûts plus élevés, et 84 projets connaissent des retards pour d'autres raisons. De plus, d'autres projets pourraient connaître des retards pendant la mise en œuvre à cause de facteurs spécifiques liés au projet; ces raisons ont été abordées par les agences en consultation avec les entreprises et les parties prenantes nationales.

261. L'information fournie par les agences révèle que la mise en œuvre des projets connaissait des retards à cause d'une faible acceptation sur le marché des frigorigènes à faible PRG, vendus à meilleur prix et plus éconergétiques, par rapport aux frigorigènes à PRG plus élevé, pour la climatisation, et de l'absence de formules de gonflage de la mousse à base de HFO<sup>55</sup> comparativement aux solutions à base de HCFC-141b/solutions de remplacement à PRG plus élevé, malgré le rôle important que les sociétés de formulation ont joué dans l'essai et l'adaptation de ces formules de remplacement.

262. Le Secrétariat a également pris note que des retards ont été signalés dans les rapports périodiques concernant la mise en œuvre de certains PGEH. Ces retards ont été causés par les changements dans le plan de mise en œuvre non déclarés au titre de cette décision (p. ex., changement de technologie pendant la mise en œuvre du projet de reconversion des climatiseurs résidentiels et dans quatre projets de mousse; ou le coût plus élevé de l'installation et de l'entretien des climatiseurs individuels à base de R-290). Dans leurs réponses, les agences ont indiqué qu'à leur avis, les retards dans la mise en œuvre n'étaient pas attribuables aux raisons soulevées dans les décisions 84/27 et 84/42 et avaient été réglés dans le cadre du processus de gestion régulière et de l'examen du projet.

263. Le processus d'examen des tranches des PGEH et des rapports sur les projets comportant des exigences particulières pour la remise de rapports permet de réaliser une évaluation approfondie des retards dans la mise en œuvre des projets par entreprise, des conséquences de ces retards sur la réalisation des objectifs du PGEH et des mesures proposées pour résoudre les problèmes de mise en œuvre. Les agences ont mentionné que ce processus aide les agences à corriger les retards tout en gardant à l'esprit les situations propres aux projets et aux pays, mais aide aussi le Comité exécutif à fournir l'orientation nécessaire pour accélérer la mise en œuvre du projet. Les agences bilatérales et d'exécution doivent veiller à ce que la mise en œuvre générale des PGEH soit réalisée dans des délais raisonnables, qu'ils atteignent les objectifs de consommation nationaux et que l'élimination réalisée soit durable.

## **Recommandation**

264. Le Comité exécutif pourrait souhaiter prendre note des rapports soumis par le gouvernement de l'Allemagne, le PNUD, l'ONUDI et la Banque mondiale conformément aux décisions 84/27 et 84/42, présentés dans le document UNEP/OzL.Pro/ExCom/85/9.

## **PARTIE V : PROJETS D'INVESTISSEMENT ET ACTIVITÉS DE FACILITATION EN LIEN AVEC LES HFC FINANCÉES AU MOYEN DES CONTRIBUTIONS SUPPLÉMENTAIRES D'UN GROUPE DE 17 PAYS NON VISÉS À L'ARTICLE 5 (DÉCISION 84/12 b))**

### **Contexte**

265. Le Comité exécutif, à sa 84<sup>e</sup> réunion, en examinant le rapport périodique global du Fonds multilatéral au 31 décembre 2018, a chargé le Secrétariat de remettre à la 85<sup>e</sup> réunion, un rapport supplémentaire sur les projets d'investissement sur les HFC et les activités de facilitation financées au

---

<sup>55</sup> Les projets pour lesquels une technologie de gonflage de la mousse à base de pentane a été adoptée n'ont pas connu de retards, car la technologie a fait ses preuves et a été adoptée par d'autres pays depuis l'élimination des CFC.

moyen des contributions supplémentaires d'un groupe de 17 pays non visés à l'article 5, dans lequel il identifierait les pays pour lesquels des projets avaient été approuvés et fournirait un aperçu des objectifs, de l'état de la mise en œuvre, des principales conclusions et des enseignements tirés, des quantités de HFC éliminées, s'il y a lieu, du niveau de financement approuvé et décaissé, et des difficultés possibles pouvant nuire à l'achèvement des projets et des activités, étant entendu que les renseignements seraient fournis individuellement pour les projets d'investissement sur les HFC et globalement pour les activités de facilitation de la réduction progressive des HFC (décision 84/12 b)).

266. Le Secrétariat a élaboré un modèle pour faciliter la collecte d'information<sup>56</sup> et l'a présenté aux agences bilatérales et d'exécution lors de la réunion de coordination interagences.<sup>57</sup>

267. En réponse à la décision 84/12 b), le Secrétariat a remis à la 85<sup>e</sup> réunion, le rapport supplémentaire sur les projets d'investissement sur les HFC et les activités de facilitation en utilisant le modèle actualisé, après y avoir intégré les suggestions pertinentes des agences.

### Rapport sur les projets d'investissement sur les HFC

268. Les agences d'exécution ont remis des rapports de situation détaillés sur la mise en œuvre des projets d'investissement sur les HFC pour l'Argentine, le Bangladesh, la Chine, le Liban, le Mexique et la Thaïlande. Un résumé des projets est proposé dans le tableau 13 et des informations plus détaillées sont fournies à l'annexe IX au présent document.

**Tableau 13. Sommaire des projets d'investissement sur les HFC**

Pays	Agence	Produits	HFC consommés (tm)	Substance de remplacement utilisée	Tm d'éqCO <sub>2</sub>	Somme approuvée (\$US)	Somme décaissée (\$US)
Argentine	ONUDI	Réfrigérateurs domestiques et commerciaux	HFC-134a (96,60 tm)	R-600a/R-290	137 993	1 840 755	1 065 380
Bangladesh	PNUD	Réfrigérateurs domestiques et compresseurs	HFC-134a (230,63 tm)	R-600a	329 372	3 131 610	3 126 415
Chine	PNUD	Mousse isolante pour les réfrigérateurs domestiques	Cyclopentane + HFC-245fa (250,00 tm)	Cyclopentane + HFO-1233zd(E)	256 750	1 275 000	380 000
Liban	ONUDI	Réfrigérateurs domestiques et commerciaux	HFC-134a/R-404A (112,58 tm)	R-600a/R-290	137 993	1 053 858	842 975
Mexique	ONUDI	Réfrigérateurs commerciaux	HFC-134a/R-404A (56,04 tm)	R-600a/R-290	90 793	1 018 123	41
Thaïlande	Banque mondiale	Réfrigérateurs commerciaux	HFC-134a (8,78 tm)	R-600a	12 543	183 514	0
<b>Total</b>			<b>754,64</b>		<b>965 444</b>	<b>8 502 860</b>	<b>5 414 811</b>

269. Un projet (Bangladesh) a été mené à terme et le PNUD a remis un rapport de projet détaillé le concernant. Les cinq autres projets avancent bien, mais la COVID-19 pourrait entraîner des retards dans leur achèvement.

<sup>56</sup> Annexe IV au document MLF/IACM.2020/1/7

<sup>57</sup> Montréal, 25-27 février 2020.

## Rapport sur les activités de facilitation de la réduction progressive des HFC

270. La liste des pays ayant reçu un soutien financier pour les activités de facilitation de la réduction progressive des HFC est jointe à l'annexe X au présent document. Plusieurs raisons justifient les demandes de financement des activités de facilitation, à savoir le soutien à la ratification hâtive de l'Amendement de Kigali, la mise en œuvre des activités mentionnées au paragraphe 20 de la décision XXVIII/2 visant à entreprendre des arrangements institutionnels de soutien, l'examen des programmes d'octroi de permis, la communication de données sur la consommation et la production de HFC et la démonstration d'activités ne portant pas sur des investissements telles que la formation et la diffusion d'information. Le tableau 14 propose un aperçu de l'état de la mise en œuvre des principaux éléments des activités de facilitation en voie d'être mises en œuvre.

**Tableau 14. Aperçu des principales activités mises en œuvre dans le cadre des activités de facilitation de la réduction progressive des HFC**

Agence	Nombre de pays	Ratification de l'Amendement de Kigali (*)		Programme d'octroi de permis et de quotas		Système de collecte de données et de suivi		Démonstration d'activités ne portant pas sur des investissements	
		Oui	Non	Oui	Non	Oui	Non	Oui	Non
PNUD	11	5	6	2	9	5	6	2	9
PNUE	79	30	49	21	58	18	61	15	64
ONUDI	28	13	15	12	16	11	17	7	21
Banque mondiale	3	0	3	0	3	1	2	1	2
Allemagne	3	1	2	1	2	3	0	0	3
Italie	4	3	1	3	1	3	1	3	1
<b>Total</b>	<b>128</b>	<b>52</b>	<b>76</b>	<b>39</b>	<b>89</b>	<b>41</b>	<b>87</b>	<b>28</b>	<b>100</b>

(\*) L'information changera au fil du temps.

### Aperçu des progrès accomplis dans la mise en œuvre des projets

271. Les activités de facilitation vont bon train dans presque tous les pays. Le PNUE<sup>58</sup> et l'ONUDI<sup>59</sup> ont achevé les activités de facilitation dans trois pays chacun, à ce jour.

272. Voici un sommaire des activités :

- a) Ratification de l'Amendement de Kigali : Plusieurs activités ont été mises en œuvre, dont les consultations avec les parties prenantes; l'élaboration de documents légaux avec l'appui de consultants, dans certains cas; les rapports d'évaluation des pays concernant les tendances dans la consommation de HFC et les conséquences de l'Amendement de Kigali sur les parties prenantes; l'évaluation des besoins de formation sur l'introduction de technologies sans HFC dans le secteur de l'entretien; et la participation à l'atelier régional sur la ratification de l'Amendement de Kigali;
- b) Développement et mise en application d'un programme d'octroi de permis et de quotas : Plusieurs activités ont été mises en œuvre, dont l'examen et/ou la révision des lois et des réglementations afin d'inclure les dispositions de l'Amendement de Kigali au programme d'octroi de permis et de quotas; des ateliers de consultation sur l'élaboration d'un programme d'octroi de permis et de quotas; et des consultations sur les mécanismes de

<sup>58</sup> Cambodge, Kirghizistan et Tonga.

<sup>59</sup> Albanie, Monténégro et Viet Nam.



suivi de l'approvisionnement et de l'utilisation de HFC en collaboration avec les douanes et autres parties prenantes;

- c) Soutien à l'application du système de collecte de données et de suivi : Plusieurs activités ont été mises en œuvre, dont l'élaboration d'un système de collecte de données sur les HFC; les consultations des parties prenantes avec les importateurs, commerçants et autres parties prenantes sur la collecte de données sur les HFC et les mélanges de HFC; les exigences de remise de rapports et de suivi; la mise à jour des codes du Système harmonisé (SH) de suivi des HFC et des mélanges de HFC; l'achat d'équipement pour identifier les frigorigènes à base de HFC;
- d) Mise en œuvre d'autres activités, dont la démonstration et la formation : Plusieurs activités ont été mises en œuvre dont le programme de formation sur les substances de remplacement à faible PRG, y compris les frigorigènes inflammables, avec un soutien technique; des programmes de proximité pour sensibiliser le public à l'Amendement de Kigali, aux HFC et aux substances de remplacement sans HFC dans différentes applications, l'adoption de technologies à faible PRG; une réglementation et un suivi à l'intention du secteur de la fabrication/entretien de l'équipement de réfrigération, des institutions gouvernementales et techniques et du public; des conditions fiscales préférentielles fondées sur le PRG des frigorigènes; et
- e) Activités en lien avec l'efficacité énergétique : Plusieurs activités ont été mises en œuvre dont la coordination avec les institutions d'efficacité énergétique afin d'inclure les dispositions de l'Amendement de Kigali tout en mettant en œuvre les mesures d'efficacité énergétique (p. ex., normes minimales de rendement énergétique, programmes d'étiquetage, amélioration de l'efficacité énergétique de l'équipement de réfrigération et de climatisation, participation aux programmes de refroidissement pour promouvoir les technologies éconergétiques à faible PRG, contributions à l'élaboration de normes régionales sur l'adoption de technologies éconergétiques<sup>60</sup>); l'encouragement de la participation des parties prenantes de l'efficacité énergétique aux réunions sur l'Amendement de Kigali; la promotion de l'efficacité énergétique en lien avec le refroidissement dans les mesures sectorielles de l'efficacité énergétique; la formation sur les technologies éconergétiques de réfrigération et climatisation; la démonstration des économies réalisées par l'adoption d'équipement éconergétique à l'intention des utilisateurs; et la conception d'équipement de réfrigération et climatisation éconergétique et l'élaboration de mesures pour améliorer l'adoption de technologies éconergétiques.

### Principales conclusions et enseignements tirés

273. Les pays ont acquis de l'expérience concernant le processus de ratification de l'Amendement de Kigali et la mise en œuvre des activités de facilitation de la réduction progressive des HFC au cours de la mise en œuvre des activités de facilitation. Elle est résumée ci-dessous :

- a) Le rapport d'évaluation du pays permettant de comprendre les tendances dans la consommation de HFC aide les parties prenantes à définir les mesures à prendre et leurs responsabilités dans l'application de ces mesures; les lignes directrices sur les méthodologies de collecte de données et des questionnaires structurés/modèles de rapports ont été préparés et communiqués à toutes les parties prenantes concernées; et les liaisons avec les activités existantes et prévues des plans de gestion de l'élimination des

---

<sup>60</sup> Plusieurs nouvelles activités sur l'amélioration de l'efficacité énergétique ont été mises en œuvre dans les pays. Ainsi, l'information sur les types de projet est illustrative et non exhaustive.

HCFC ont été adoptées à l'interne en analysant les niveaux de consommation de HCFC et de HFC, et en consultant les parties prenantes de l'industrie;

- b) Le renforcement des programmes d'octroi de permis et de quotas afin d'y inclure les HFC et les mélanges de HFC est une priorité en ce qui concerne le suivi et l'établissement de rapports et exige des consultations détaillées avec les institutions concernées; les douaniers et les importateurs aiment les programmes en ligne car ils leur permettent d'économiser du temps et des efforts; le renforcement supplémentaire des capacités et la formation des officiels responsables de la collecte de données et du suivi sont aussi des priorités; la formation des douaniers et des agents responsables de l'application et le renforcement des points de contrôle douanier grâce à de l'équipement d'identification sont essentiels afin de prévenir le commerce illicite des HFC;
- c) Suivi continu par les Bureaux nationaux de l'ozone auprès des autorités responsables de l'élaboration, de la mise au point et de l'approbation des politiques et réglementations sur les HFC;
- d) D'importants efforts sont requis pour approuver la réglementation sur l'adoption mesures de sécurité s'appliquant aux frigorigènes à faible PRG; le renforcement des capacités, dont la formation et la diffusion d'information, est essentiel aux fins d'adoption durable de frigorigènes à faible PRG inflammables, toxiques et exigeant des pressions élevées, et le renforcement des capacités pour la formation et les institutions techniques, la certification des techniciens d'entretien sur la manipulation des frigorigènes à faible PRG et les programmes de formation des formateurs sont essentiels;
- e) L'introduction de normes minimales de rendement énergétique et d'un système d'impôt/taxes progressif fondé sur l'efficacité énergétique de l'équipement de réfrigération et climatisation sans HFC encourage l'industrie à faire la transition à de l'équipement à faible PRG et éconergétique; et l'importation d'équipement de réfrigération et climatisation usagé ayant un plus faible niveau d'efficacité énergétique influence la mise en œuvre de mesures pour améliorer l'efficacité énergétique;
- f) L'identification de l'expertise locale pour entreprendre les activités exige le soutien continu des Bureaux nationaux de l'ozone et le renforcement des capacités; et
- g) Les activités de sensibilisation et de rayonnement par le biais de consultations et de communications régulières sont essentielles afin que les parties prenantes comprennent les conséquences de l'Amendement de Kigali.

#### Difficultés possibles

274. Certaines difficultés propres aux projets (à savoir les changements dans la structure institutionnelle du gouvernement à la suite de retards dans l'approbation et de la mise en œuvre de certains éléments du projet, la situation politique qui influence la mise en œuvre) peuvent retarder certains projets; elles seront abordées séparément dans les rapports périodiques qui seront soumis à la 86<sup>e</sup> réunion et inclus dans les rapports finaux sur les activités de facilitation.

#### Sommes approuvées et décaissées

275. La somme totale approuvée pour les projets d'investissement sur les HFC et les activités de facilitation provenant des contributions supplémentaires d'un groupe de 17 pays donateurs s'élevait à 23 687 811 \$US et une somme de 13 114 664 \$US avait été décaissée en date de mars 2020.

**Observations du Secrétariat**

276. Le Secrétariat a pris note que les projets d'investissement sur les HFC et les activités de facilitation de la réduction progressive des HFC avançaient bien; un projet d'investissement sur les HFC et des activités de facilitation pour six pays sont terminés. La situation entourant la COVID-19 aura assurément des conséquences sur l'achèvement prévu de certains projets.

**Recommandation**

277. Le Comité exécutif pourrait souhaiter prendre note de l'information sur les projets d'investissement sur les HFC et les activités de facilitation soumise par les agences bilatérales et d'exécution conformément à la décision 84/12 b), présentée dans le document UNEP/OzL.Pro/ExCom/85/9.



**Annexe I**

**PROJETS DANS LESQUELS « CERTAINS PROGRÈS » ONT ÉTÉ ACCOMPLIS ET POUR  
LESQUELS LE MAINTIEN DU SUIVI EST RECOMMANDÉ**

<b>Pays</b>	<b>Code</b>	<b>Titre du projet</b>	<b>Agence</b>
Chine	CPR/ARS/56/INV/473	Plan sectoriel pour l'élimination de la consommation de CFC dans le secteur des inhalateurs à doseur	ONUDI
Égypte	EGY/ARS/50/INV/92	Élimination de la consommation de CFC dans la fabrication d'inhalateurs à doseur	ONUDI
Iraq	IRQ/REF/57/INV/07	Remplacement du frigorigène CFC-12 par l'isobutane et de l'agent de gonflage CFC-11 par le cyclopentane dans la fabrication de réfrigérateurs domestiques chez Light Industries Company	ONUDI
Saint-Vincent-et-les-Grenadines	STV/PHA/77/TAS/24	Rapport de vérification sur la mise en œuvre du plan de gestion de l'élimination des HCFC	PNUE
République arabe syrienne	SYR/REF/62/INV/103	Élimination du HCFC-22 et du HCFC-141b dans la fabrication de climatiseurs individuels et de panneaux isolants en mousse de polyuréthane rigide chez Al Hafez Group	ONUDI



**Annexe II**

**PROJETS POUR LESQUELS DES RAPPORTS DE SITUATION SUPPLÉMENTAIRES ONT ÉTÉ DEMANDÉS**

<b>Pays</b>	<b>Code</b>	<b>Titre du projet</b>	<b>Agence</b>	<b>Recommandation</b>
Algérie	ALG/SEV/73/INS/81	Prorogation du projet de renforcement des institutions (phase VI : décembre 2014 - novembre 2016)	PNUE	Demander un rapport de situation sur le niveau de décaissement des fonds, à remettre à la 86 <sup>e</sup> réunion
Botswana	BOT/SEV/76/INS/19	Prorogation du projet de renforcement des institutions (phase V : juin 2016 – juillet 2018)	PNUE	Demander un rapport de situation sur le niveau de décaissement des fonds et la signature de l'accord de financement à petite échelle (SSFA), à remettre à la 86 <sup>e</sup> réunion
République centrafricaine	CAF/SEV/68/INS/23	Prorogation du projet de renforcement des institutions (phase VI : janvier 2013 – décembre 2014)	PNUE	Demander un rapport de situation sur le niveau de décaissement des fonds, la signature de l'accord de financement à petite échelle (SSFA) et les progrès dans la mise en œuvre, à remettre à la 86 <sup>e</sup> réunion
République démocratique du Congo	DRC/PHA/79/PRP/42	Préparation d'un plan de gestion de l'élimination des HCFC (phase II)	PNUD	Demander un rapport de situation sur le niveau de décaissement des fonds et l'état de la soumission de la phase II du PGEH, à remettre à la 86 <sup>e</sup> réunion
République démocratique du Congo	DRC/PHA/79/PRP/43	Préparation d'un plan de gestion de l'élimination des HCFC (phase II)	PNUE	Demander un rapport de situation sur le niveau de décaissement des fonds et la soumission de la phase II du PGEH, à remettre à la 86 <sup>e</sup> réunion
Dominique	DMI/SEV/80/INS/23	Assistance d'urgence supplémentaire pour le renforcement des institutions	PNUE	Demander un rapport de situation sur le niveau de décaissement des fonds et la signature de l'accord de financement à petite échelle (SSFA), à remettre à la 86 <sup>e</sup> réunion
Dominique	DMI/SEV/80/TAS/01+	Activités de facilitation de la réduction progressive des HFC	PNUE	Demander un rapport de situation sur le niveau de décaissement des fonds et sur la mise en œuvre du projet, à remettre à la 86 <sup>e</sup> réunion
Dominique	DMI/SEV/81/INS/24	Prorogation du projet de renforcement des institutions (phase VII : juin 2018 – mai 2020)	PNUE	Demander un rapport de situation sur le niveau de décaissement des fonds et la signature de l'accord de financement à petite échelle (SSFA), à remettre à la

Pays	Code	Titre du projet	Agence	Recommandation
				86 <sup>e</sup> réunion
Haïti	HAI/PHA/76/TAS/21	Plan de gestion de l'élimination des HCFC (phase I, deuxième tranche)	PNUE	Demander un rapport de situation sur les progrès dans la mise en œuvre, à remettre à la 86 <sup>e</sup> réunion
Haïti	HAI/SEV/75/INS/20	Prorogation du projet de renforcement des institutions (phase IV : novembre 2015 – octobre 2017)	PNUE	Demander un rapport de situation sur les progrès dans la mise en œuvre, à remettre à la 86 <sup>e</sup> réunion
Liban	LEB/DES/73/DEM/83	Projet de démonstration pilote sur la gestion et l'élimination définitive des résidus de SAO	ONUDI	Exhorter l'ONUDI de remettre le rapport d'achèvement de projet, conformément à la décision 82/15 c)
Libye	LIB/FOA/82/PRP/41	Préparation des activités d'investissement pour l'élimination des HCFC (phase II) (secteur de la mousse)	ONUDI	Demander un rapport de situation sur les progrès dans la préparation de la phase II du PGEH, à remettre à la 86 <sup>e</sup> réunion
Libye	LIB/PHA/82/PRP/43	Préparation d'un plan de gestion de l'élimination des HCFC (phase II)	ONUDI	Demander un rapport de situation sur les progrès dans la préparation de la phase II du PGEH, à remettre à la 86 <sup>e</sup> réunion
Pérou	PER/SEV/80/INS/56	Prorogation du projet de renforcement des institutions (phase V : janvier 2018 – décembre 2019)	PNUE	Demander un rapport de situation sur le niveau de décaissement des fonds et les progrès dans la mise en œuvre, à remettre à la 86 <sup>e</sup> réunion
Qatar	QAT/PHA/65/TAS/17	Plan de gestion de l'élimination des HCFC (phase I, première tranche) (secteur de l'entretien de l'équipement de réfrigération)	PNUE	Demander une mise à jour sur l'état du retour des soldes, à remettre à la 86 <sup>e</sup> réunion
Qatar	QAT/PHA/73/PRP/20	Préparation d'un plan de gestion de l'élimination des HCFC (phase II)	PNUE	Demander un rapport de situation sur le niveau de décaissement des fonds et la soumission de la phase II, à remettre à la 86 <sup>e</sup> réunion
Qatar	QAT/PHA/73/PRP/21	Préparation du plan de gestion de l'élimination des HCFC (phase II)	ONUDI	Demander un rapport de situation sur les progrès accomplis dans la préparation et la soumission de la phase II, à remettre à la 86 <sup>e</sup> réunion
Arabie saoudite	SAU/FOA/62/INV/13	Élimination du HCFC-22 et du HCFC-141b dans la fabrication de panneaux de polystyrène extrudé chez Al-Watania Plastics	ONUDI	Demander un rapport de situation sur l'achèvement du processus d'encan, à remettre à la 86 <sup>e</sup> réunion
Arabie saoudite	SAU/SEV/67/INS/15	Prorogation du projet de renforcement des	PNUE	Demander un rapport de situation sur le niveau de



<b>Pays</b>	<b>Code</b>	<b>Titre du projet</b>	<b>Agence</b>	<b>Recommandation</b>
		institutions (phase II : juillet 2012 – juin 2014)		décaissement des fonds et la signature de l'accord de financement à petite échelle (SSFA), à remettre à la 86 <sup>e</sup> réunion
Soudan du Sud	SSD/PHA/77/TAS/04	Plan de gestion de l'élimination des HCFC (phase I, première tranche)	PNUE	Demander un rapport de situation sur le niveau de décaissement des fonds et la signature de l'accord de financement à petite échelle (SSFA), à remettre à la 86 <sup>e</sup> réunion
Soudan du Sud	SSD/SEV/76/INS/03	Projet de renforcement des institutions (phase I : mai 2016 – avril 2018)	PNUE	Demander un rapport de situation sur le niveau de décaissement des fonds et la signature de l'accord de financement à petite échelle (SSFA), à remettre à la 86 <sup>e</sup> réunion
Suriname	SUR/PHA/81/TAS/26	Plan de gestion de l'élimination des HCFC (phase I, troisième tranche)	PNUE	Demander un rapport de situation sur le niveau de décaissement des fonds et la signature de l'accord de financement à petite échelle (SSFA), à remettre à la 86 <sup>e</sup> réunion
République arabe syrienne	SYR/FOA/61/PRP/102	Préparation des activités d'investissement pour l'élimination des HCFC (secteur de la mousse)	ONUDI	Demander un rapport de situation sur la préparation du projet et la date proposée pour la soumission du PGEH, à remettre à la 86 <sup>e</sup> réunion
République arabe syrienne	SYR/PHA/55/PRP/97	Préparation d'un plan de gestion de l'élimination des HCFC	ONUDI	Demander un rapport de situation sur la préparation du projet et la date proposée pour la soumission du PGEH, à remettre à la 86 <sup>e</sup> réunion
République arabe syrienne	SYR/SEV/73/INS/104	Prorogation du projet de renforcement des institutions (phase V : janvier 2015 – décembre 2016)	ONUDI	Demander un rapport de situation sur les progrès dans la mise en œuvre et le niveau de décaissement des fonds, à remettre à la 86 <sup>e</sup> réunion
Yémen	YEM/SEV/73/INS/43	Prorogation du projet de renforcement des institutions (phase VIII : janvier 2015 – décembre 2016)	PNUE	Demander un rapport de situation sur les progrès dans la mise en œuvre, à remettre à la 86 <sup>e</sup> réunion



# FINAL REPORT

PROJECT TITLE: Demonstration project for the introduction of trans-critical CO<sub>2</sub> refrigeration technology for supermarkets (Argentina and Tunisia)

PROJECT NUMBER: GLO/REF/76/DEM/335

## Table of Contents

Background .....	2
The supermarket sector in Argentina .....	2
Refrigerants used in the food chain.....	3
Environmental impact of supermarket systems.....	3
The demonstration project.....	4
Objective.....	4
Project Budget.....	4
Methodology used in the project.....	5
Determination of baseline data .....	6
Post project data .....	6
Sustainability and barriers.....	6
Location and Baseline Situation.....	7
Selection of CO <sub>2</sub> commercial refrigeration technology.....	9
Project Implementation .....	13
Timeframe .....	13
Installation and start-up of the new equipment.....	13
Lessons Learnt.....	16
Equipment related issues.....	16
Electricity consumption.....	18
Environmental impact.....	21
Sustainability .....	24
Budget and expenditures.....	27



## BACKGROUND

On its 76th Meeting, the Executive Committee decided:

- (a) To approve the demonstration project in Argentina and Tunisia for the introduction of trans-critical CO<sub>2</sub> refrigeration technology for supermarkets, in the amount of US \$846,300, plus agency support costs of US \$59,241 for UNIDO, in line with decision 72/40; and
- (b) To request the Governments of Argentina and Tunisia, and UNIDO, to complete the projects within 30 months of its approval, and to submit a comprehensive final report soon after project completion. **(Decision 76/27)**

The subproject designed for Tunisia was not implemented due to lack of interest. The project funds approved for Tunisia amounts to **USD 319,131**. The remaining funds available will be returned as per decision.

The project funds approved for Argentina amounts to **USD 527,169** plus agency support cost.

This document is prepared for the information of the members of the Executive Committee and takes account of the background, the implementation process and the results achieved as well as the experience gathered through the subject demonstration project.

### [The supermarket sector in Argentina](#)

Between 2010 to 2016, the five largest Argentine supermarket chains had grown by 63%. The total estimated points of sale were of 8,672 in 2010<sup>1</sup>, reaching around 13,000 in 2016<sup>2</sup> and a future growth<sup>3</sup> had been expected.


The growth was boosted by the opening of proximity small self-service markets by the big players of the sector.

---

<sup>1</sup> Informe Relevamiento sobre Supermercados en Argentina. 2011. Federación Argentina de Empleados de Comercio y Servicios.

<sup>2</sup> Informe de Actualización: Evolución del Sector Supermercadista. 2016 Federación Argentina de Empleados de Comercio y Servicios.

<sup>3</sup> Encuesta de Supermercados. Informes Técnicos vol. 1 n° 65, Comercio vol. 1 n° 9. INDEC, Febrero de 2017.



### Refrigerants used in the food chain

Synthetic refrigerants have been typically used in retail food refrigeration. At the beginning CFCs were used; later they were replaced by HCFCs.

HCFC-22 has been the most popular refrigerant over the past decades for retail food refrigeration systems and it is still widely used in the supermarket sector. Therefore, consumption of HCFC-22 in this sector is still very relevant in Argentina; it is estimated at around 750-800 MT. Leakage rates are very high ranging from 35% for big and medium size installations to above 70% for small installations. This is caused by inadequate maintenance and sometimes bad quality installations.

When HCFCs phase-out gathered momentum, it became a priority to replace HCFC refrigerants used in the supermarkets. As a result, HFCs have started replacing HCFCs. Natural refrigerant technologies had not been commonly used in this sector in Argentina.

The Kigali amendment is imposing limitations on the use of HFCs refrigerants with high GWP. As a result, the refrigerant manufacturing chemical industry as well as the end users of their products have been compelled to find new low GWP alternatives. In view of the growing concern about climate change, new technologies with very low GWP alternatives have been developed, matured and put into the market. These are spreading fast in many A2<sup>4</sup> countries. Among these low GWP refrigerants CO<sub>2</sub> is gaining popularity.

### Environmental impact of supermarket systems

The environmental impact of the supermarket sector is caused by its

- i. High energy consumption, and
- ii. Significant consumption of ozone depleting refrigerants, and

---

<sup>4</sup> Article 2 countries under Montreal Protocol



iii. Increased use of high GWP refrigerants.

Among the commercial outlets, supermarkets have the highest specific energy consumption, typically in the range of 400-600 kWh/m<sup>2</sup> annually. The largest energy consumers in a supermarket are the refrigeration equipment (30%-50%), which is followed by ventilation, heating and cooling of the store and its lighting.

The generation of electricity used by the supermarkets is associated with CO<sub>2</sub> emission in various degree depending on the energy mix. The effect of this type of CO<sub>2</sub> emission is called indirect impact.

## THE DEMONSTRATION PROJECT

### Objective

The primary objective of the project was to evaluate the performance and energy efficiency of trans-critical CO<sub>2</sub> technology in a real case scenario: a carefully selected representative supermarket located in moderately warm climatic conditions

The other objective was to identify incentives and barriers related to an upgraded to trans-critical CO<sub>2</sub> technology, by phasing out HCFCs and leapfrogging the HFC conversion step.

When successful, the project is expected to be replicated in countries of the region thereby promoting the use of low-GWP refrigerants in the sector.

### Project Budget

The project was approved by the Executive Committee of the MLF in May 2016 with a budget of U\$527,169, with UNIDO as implementing agency and an implementing period of 30 months.

The details of the budget are shown in the table below:

TABLE 1. PROJECT COST

Item	USD
<b><i>Refrigeration plant</i></b>	
Transcritical plant	117,497
Condenser / gas cooler	19,299
Subcooler (Option 2 R-290 refrigerant)	41,060
8 x evaporators	12,675
Refrigeration installation and materials	115,632
Electrical installation	54,828
Electrical panels and electronics	28,875



<b>Total refrigeration system</b>	<b>389,866</b>
<i><b>Food display cabinets</b></i>	
8 fresh food cabinets with doors and led model	66,754
5 frozen food islands	35,722
2 semi-cabinets for frozen food	25,630
6 Fresh food cabinets	34,197
Less cost sharing	-60,000
<b>Total cabinets</b>	<b>102,303</b>
<b>Subtotal equipment cost (incl. installation)</b>	<b>492,169</b>
<i><b>Engineering and transport</b></i>	
Engineering	10,000
Transportation, 3%	11,451
Cost sharing	-6,451
<b>Total services</b>	<b>15,000</b>
<b>Total cost of equipment and services</b>	<b>507,169</b>
Demonstration project for 20 participants	20,000
<b><u>TOTAL COST OF SUB-PROJECT 1: ARGENTINA</u></b>	<b>527,169</b>

### Methodology used in the project

The main barrier for introducing low GWP alternatives, especially CO<sub>2</sub> in the supermarket sector in Article 5 countries is the lack of knowledge and experience as well as the limited availability of equipment components and know-how related to the new technology as well as the still high initial cost implication.

For these reasons, even when the end users decide to phase out HCFCs in their installations, the likelihood that they would opt for an HFC well-known technology is rather high. Furthermore, such conversions require less modifications and thus it will be the less costly solution.

At the time the project was formulated, there was only one supermarket in Argentina using a transcritical CO<sub>2</sub> centralized refrigeration system. This is operated in the south of Argentina (Patagonia region) - a location with a very cold climate condition.

Therefore, Argentina decided to implement a project to address the issues and barriers related to as well as the feasibility of CO<sub>2</sub> technology in warmer climatic conditions where the CO<sub>2</sub> transcritical technology had not yet been used.



### Determination of baseline data

In the past, the electricity consumption of the refrigeration equipment was neither measured, nor monitored. Thus, in order to quantify the impact of the project on the energy consumption of the technological equipment La Anonima separated the electrical supply of the refrigeration systems from the air conditioning and lighting. They also installed separate power meters with data loggers.

The electricity consumption of refrigeration equipment had been meticulously measured during the first year of the project, when only the bidding, manufacturing and delivery of equipment took place. The data collected in the pre-startup year was used to determine the baseline electrical consumption level.

Temperatures, as well as, general climate condition information were taken for all the measuring period from the nearest meteorological station.

The consumption of refrigerants was not strictly monitored by the supermarket. After approval of the project the supermarket started strict monitoring of the actual use of refrigerants and the causes of leaks.

### Post project data

During the one-year post conversion period the measurements of electricity consumption of the refrigeration equipment as well as refrigerant continued, and the data were compiled.

Thus, we were able to compare the pre- and post-conversion energy consumption based on real data.

### Sustainability and barriers

To identify potential barriers, the long-term sustainability, as well as the impact of this demonstration project, we assessed various aspects, such as:

- Technical viability,
- Investment and relevant operating costs,
- Environmental benefits,
- Impact of energy consumption
- Availability of components,
- Installation and servicing skill requirements,
- Other possible advantages and disadvantages.

These factors are also important to assess the opportunities for replication at country level, regionally and/or globally.

During the project we organized several meetings with the supermarket's maintenance management and staff, as well as with the vendor of the equipment and technology, in order



to investigate and collect cost data, maintenance requirements and other financial and technical matters.

### Location and Baseline Situation

OPROZ contacted several nationally owned supermarket chains to select the supermarket ready and capable to implement the demonstration project in a timely manner. In order to enhance the demonstration value of the project it was important to find a supermarket located in one of the warmest locations of the country, which could serve as a model for other supermarkets in moderately hot A5 countries. It was also important to find a company with appropriate financial means and technical expertise required to complement the resources and technical inputs granted through the project.

The selection was narrowed down to a supermarket in the town of Lincoln, Buenos Aires Province. It is part of a large Argentine supermarket chain, which belongs to Sociedad Anónima Importadora y Exportadora de la Patagonia, in short La Anónima. This supermarket is located in a moderately warm climatic zone (GPS coordinates: Latitude: -34.8637778 (34° 51' 49.6" S), Longitude: -61.528350 (61° 31' 42.062" W). The chain had been in healthy financial situation, possess highly trained technical and maintenance staff and has been eager to participate in the demonstration project. So, it had complied with all criteria of the demonstration project.



*Figure 1 La Anonima, Lincoln Branch*

Ú



TABLE 2. AREA OF THE SUPERMARKET

Area	m <sup>2</sup>
Total sales area	1,258
a. Cold food cabinets	49
b. Frozen food cabinets	6
c. Frozen food aisles	16
Total storage area	449
a. Cold storage	108
b. Walk-in freezers	14




Figure 2 Layout of the LaAnonima Supermarket in Lincoln

Figure 2 depicts the layout of the supermarket with the location of the refrigerated and frozen food sections and the roof with the machine room.

In the baseline, the supermarket had two central refrigeration systems, one for low and another for medium temperature.



*Figure 3 Baseline machine room*

The refrigerant used in the central systems was **HCFC-22**.

Furthermore, there were a number of self-contained freezer units (islands and upright reach-in cabinets) working with **HFC-404A**.



*Figure 4 Baseline Cabinets and Freezer Aisles*



*Figure 5 Baseline Dairy Cold room*

### [Selection of CO<sub>2</sub> commercial refrigeration technology](#)

In the last 15 years, as environmental considerations gradually came to the forefront, CO<sub>2</sub> technology was “reinvented” as an environmentally friendly solution in commercial refrigeration, based on the low Global Warming Potential (GWP) of CO<sub>2</sub> resulting in lower Total Equivalent Warming Impact (TEWI) compared with HFC refrigerants. Today, in A2 countries there is no difficulty in sourcing all the necessary equipment for CO<sub>2</sub> technology. However, in A5 countries this technology is still new and rarely used in areas of warm climate.

Booster systems have been the preferred option due to their relative simplicity and lower initial cost compared to cascade systems. At the time of the preparation of the project there were already some

4,000 systems, mainly in supermarkets, which use the traditional booster system shown below. According to Danfoss there is a 100% market growth on year on year basis for these systems and it seems that in moderate climate countries booster system is now the market standard. The trend is now to move the market towards warmer regions.

However, at higher ambient temperatures the inherent properties of R-744 lead to loss of efficiency and elevated equipment costs. The efficiency of systems with CO<sub>2</sub> depends more on the application and the climate conditions prevailing on the site of installation than in the case of other refrigerants. For all refrigerants there is a decline in system efficiency with increasing condensing temperatures, and CO<sub>2</sub> is among the refrigerants with the steepest drop. The good thermo-physical properties of CO<sub>2</sub> can compensate to some extent, but there is a limit.

The problem with transcritical CO<sub>2</sub> systems in warm climate is not that they will not work, but more that there is a significant loss of capacity and efficiency.

In cold climates like the Nordic climate we see 10% lower energy consumption, but going to warm climates like Asia, South Europe, Southern part of North America, Latin America and Africa is a challenge for CO<sub>2</sub> systems. The extra cost of compressors and loss of efficiency could make the technology less attractive.

The traditional booster system is illustrated on [Figure 6](#).




Figure 6 Traditional Booster System




Figure 7 Booster System with Parallel Compression




Figure 8 Booster System with Parallel Compression and Subcooling

[Figure 7](#). shows that the traditional booster system is complemented with a compressor, which compresses the flash gas from the refrigerant valve that regulates the pressure in the liquid receiver (flash tank) and associated pipe work. The advantages of this solution are:

- a. Solution is mature and well proven,
- b. 5-10% energy improvement in warm climates,
- c. Approximately 25% saving on installed capacity,
- d. Can be combined with other features to enhance the system.



The system shown on Figure 8 includes an additional heat exchanger – so called subcooler. The advantages of this solution are:

- a. Solution is ready
- b. 5-10% energy improvement in warm climates
- c. Up to 50% saving on compressor capacity, but the capacity is needed on the auxiliary cooling unit.

In warm climates, when the system works in transcritical cycle the amount of flash gas inside the liquid receiver increases.

In a transcritical system the receiver pressure is controlled by expanding the vapor released through connection of a by-pass Flash Valve to the medium temperature suction header.

The parallel compressor in the system the result is a better performance due to a reduction in the compression work between the intermediate pressure in the receiver and the common discharge pressure.

For example, under external temperature of 40 °C, the system develops increased amount of flash gas. Medium temperature compressors will work with a COP of 1.34 and the parallel compressor will have a COP=2. Without parallel compressor all the flash gas will pass through the medium temperature compressors.

Other component added to the system to save energy is an external subcooler installed before the transcritical valve. It is a plate heat exchanger, which works with a dedicated chiller. This subcooler reduces the gas's enthalpy and reduces the amount of flash gas.

Figure 9 shows the actually installed system and provides additional explanations.

With the aim of increasing energy efficiency during the warm periods of the year when there are excessive room temperatures in the supermarket, a Subcooler was installed.

UNIDO and the counterpart decided to reduce the climate impact of the new system by using only natural low GWP refrigerants. We succeeded to convince the supplier to design a subcooler with a refrigeration system using R-290 refrigerant. R-290 is refrigerant grade propane, a natural refrigerant widely used in a wide range of refrigeration and air conditioning applications with smaller charge size. The use of R-290 in various applications is increasing due to its low environmental impact and excellent thermodynamic performance. It is non-toxic with zero ODP (Ozone Depletion Potential) and very low GWP (Global Warming Potential).

However, R-290 is a flammable refrigerant so it is vital to take appropriate safety measures at the installation site. R-290 may react violently with oxidants, air, oxidizers. It was necessary to study carefully the national safety rules and designate a suitable outside location for the machine. In view of the charge size. It is important to demarcate the area around the subcooler, where heat, sparks, open flames, hot surfaces, and no smoking is allowed. In our case the sub-cooler was installed on the roof where good natural ventilation is prevailing, so there was no need to install special sensors

The subcooler includes an inertia module with CO<sub>2</sub> - Glycol plate heat exchanger.




Figure 9 Booster System with Parallel Compression and Subcooling

The latest development is the so-called Ejector Compression System. At the time of the development of the project, this technology had been still under development and had not yet come out on the market.

Further energy savings could have been achieved by utilization of waste heat developed in the refrigeration system. Such integrated systems combining the energy requirements of cooling, heating and air-conditioning are extremely attractive under cool or moderate climate condition but could bring benefits also in warmer countries e.g. to produce hot water. The applicability is to be evaluated based on the cost-benefit ratio. This combination was not considered in the subject demonstration project.



Thus, after thorough review of the available technological options in 2015 suitable for supermarkets located in warm climate conditions, it was decided to introduce a transcritical CO<sub>2</sub> booster system with parallel compression and subcooling. In order to use natural refrigerants for all the system it was decided to incorporate a R290 subcooler.

## PROJECT IMPLEMENTATION

### Timeframe

After the approval of the project in May 2016 the implementation was organized by OPROZ and UNIDO in close cooperation with the beneficiary company.

The Terms of Reference was prepared, and the bidding was initiated by the end of 2016. After the contract award, the equipment was manufactured in Argentina by EPTA and in Italy by EPTA's mother company and delivered to the site in 2017. The installation was completed in December 2017. The supermarket has been operated with the new technology as of January 2018 and the monitoring of energy consumption was undertaken throughout all the year of 2018.

Thus, the actual implementation took about 1.5 years, the remaining time of the project duration was spent to study and monitor the post-conversion situation and to assess the project performance.

According to the Project Document the duration of the physical implementation (bidding, purchase, delivery of equipment, its installation and start up) of the project was projected for 2 years.

To gain a true picture of the long-term reliability of operation, maintenance requirement, leakage rate and also of the energy efficiency the originally planned 6-month project evaluation was extended to 12 months. It was necessary, because the energy consumption is fluctuating during the year depending, inter alia, on the climate/temperature fconditions. Thus, it was decided to measure the energy consumption for an entire year prior conversion and also an entire year after conversion and compare the results. Thus, the project was not delayed, but more information has been obtained than expected.

### Installation and start-up of the new equipment

The CO<sub>2</sub> transcritical system design was developed in Argentina by EPTA with the assistance from their design headquarters in Italy and UK following UNIDO and OPROZ national and international consultants' technical requirements.

A critical point was the design, calculation and manufacturing of the R290 subcooler. This work was undertaken by the equipment manufacturer. The refrigeration system was built



by EPTA using a subcooler of an Italian manufacturer. All piping calculations were adjusted locally

The conversion did not affect the layout of the supermarket.

The arrangement, number, configuration and temperature set points of the new display cases, cold rooms and walk-in coolers are nearly identical to the baseline too.

The stand-alone R404A units of the baseline installation were replaced and the new ones were integrated into the CO<sub>2</sub> centralized system.

The refrigeration capacity of the medium temperature circuit is 68,79 kW and the same of the low-temperature side 9,53 kW. This is smaller than in the baseline: 72,09 kW for the HCFC-22 positive temperature cabinets and cold room, and 10,05 kW for the HFC-404A low-temperature cabinets and cold rooms.

In order to supply the refrigeration needs of all supermarket's refrigeration equipment a multi compressor refrigeration central has been installed. A parallel compressor was incorporated into the refrigeration plant and mounted on the refrigeration plant's frame.



*Figure 10 The CO<sub>2</sub> Transcritical Refrigeration Machinery*



*Figure 11 Walk-in Vegetable Cooler and its CO<sub>2</sub> Evaporator*

The installation's condensation is achieved by using a Condenser/Gas Cooler designed to withstand a pressure of 120 bar pressure. To avoid accidents the installation is protected by safety pressure valves, which release the refrigerant pressure in the event of exceeding the said 120 bar.

In a CO<sub>2</sub> transcritical installation, it is necessary to use a correctly dimensioned Condenser/Gas Cooler to ensure that the heat dissipation requirements of the discharge of the compressors are met even in extreme heat conditions.



The cold rooms remained unchanged; however, their evaporators had to be replaced. All evaporators for the positive temperature cold rooms, the working rooms and the negative temperature cold rooms are compact and equipped with integrated ventilators and electronic expansion valves.



*Figure 12 New CO<sub>2</sub> Freezer Cabinets and Aisles*

With the aim of increasing the energy efficiency during the warm periods of the year, a R290 subcooler was installed. The subcooler is a R290 (Propane) chiller and propilenglycol is the recirculated fluid. The R290 charge size (1,7 kilograms) is small and the device is located in the open air. Anyway, it is important to demarcate the area around the subcooler where heat, sparks, open flames, hot surfaces, and smoking are not allowed.

The application of CO<sub>2</sub> in the loop required the change of the pipes to harmonize the system to the lower charge and also to withstand the very high operating pressures.

A system for continuous display of the refrigeration parameters in both the cold rooms and display cabinets was installed. This display system allows easy observation of the working parameters on a screen incorporated into the electronics module.

Other important safety devices are the leak detectors and alarms installed in the cold rooms. In the case of excessive refrigerant gas (R-744) leak this detector closes the electronic valves of the CO<sub>2</sub> supply side of the circuit to avoid suffocation hazard through build-up of CO<sub>2</sub> concentration.

During the implementation of the conversion process the smooth operation of the supermarket was maintained, thus the operation of the baseline machinery had been in operation until the new took over their role. The old machinery was dismantled only after successful start-up and trial runs of the new system.





Figure 13 CO<sub>2</sub> Leak Detector



Figure 14 Display of the Electronic Control System

## LESSONS LEARNT

The project was approved for the introduction of transcritical CO<sub>2</sub> system to replace the medium and low temperature refrigeration system of a supermarket working with HCFC-22 and HFC-404A refrigerant, respectively. No funds were approved to convert a similar supermarket to HFC (R-404A or R-134a) refrigerants. Thus, we could only compare the performance of base-line pre-project and the post-project scenarios (transcritical CO<sub>2</sub> equipment).

### Equipment related issues

1. Since HCFC-22 is being phased out, the most important competitor of transcritical CO<sub>2</sub> equipment in Latin America is HFC-404A. In view of lack of direct information on the cost of conversion to HFC of a similar supermarket, we estimated the difference between the investment cost of the traditional HFC 404A and the transcritical system using indirect investment cost information collected from the industry and the technical literature.

The initial cost of a CO<sub>2</sub> transcritical system used to be substantially higher than a conventional HFC 404A system. A study prepared for the US Department of Energy<sup>5</sup> in 2015 stated: “Given the nascence of transcritical CO<sub>2</sub> technology in the US market, these systems currently have an upfront cost that is 40-50% higher than that of conventional systems at the time of this study”. Lately the price difference has been decreasing due to the standardization of several components. Today, according the information received from a large equipment manufacturer the price of an HFC-404A



installation is about 20% lower the equivalent CO<sub>2</sub> one in case of a direct cooling system and around 10-13% lower in case of an HFC/glycol system in the Latin American Region depending on the size and characteristics of the systems. The reason of this price difference is related to the substantially higher pressure used in the CO<sub>2</sub> installations. Thus, they require the use of stronger piping, better welding of the circuit and also several controls and monitoring devices that are normally not part of an HFC systems.

2. Cost of installation of CO<sub>2</sub> system due to the high-pressure requirements is still very high in Argentina. TIG brazing is made by specialized companies so the price is much higher than standard brazing. Availability of specialized brazing companies is lacking in some locations of the country. Two of such specialized brazing companies have been employed during Lincoln installation.
3. The installed CO<sub>2</sub> transcritical system did not leak from the start up until now and, if leaks would occur in the future, the recharge would be done at a low price due to the much lower price of CO<sub>2</sub> compared to the current prices of synthetic refrigerants.
4. The refrigeration systems are optimized for the designed refrigerant charge. Leaks would lead to suboptimal conditions loss of refrigeration capacity, increased energy consumption. Such systems will cause damages to the perishable goods, so losses could be quite significant. Thus, low leakage rates of the new system is advantageous from several points of view.
5. The first charge of CO<sub>2</sub> was supplied by EPTA. Industrial gas vendors like Praxair and Air Liquide are located in Argentina and offer CO<sub>2</sub> with 20 ppm humidity and since it is used for sparkling beverages, it is easily available. This CO<sub>2</sub> is also used for some other refrigeration systems in Argentina.
6. R290 has been supplied to EPTA by a local refrigerant importer and EPTA maintains a stock for emergencies.
7. Frequency of preventive maintenance is similar to HCFC/HFC systems and the only is the adequate training of the service staff. The equipment of La Anonima Lincoln is maintained by its own staff, they have been properly trained by EPTA, as part of the project.
8. The selected vendor had the necessary expertise to provide assistance during installation and start up as well as after sales maintenance. During the procurement process this was a condition required from the bidders. Vendor was also required to train the maintenance staff of the Lincoln supermarket on the following:
  - Procedures to intervene on a CO<sub>2</sub> system under pressure
  - Maintenance procedures like filters and oil replacement, sight glass control.



- Management of electronic controls of the refrigeration rack and system
  - Operation of monitoring system
9. OPROZ also offered during 2017 and 2018 all over the country trainings for more than 700 technicians on Good Practices in Handling Low GWP refrigerants which included CO<sub>2</sub>.
  10. Parts to be replaced most frequently are manometers and valves. These devices are now available in Argentina. As previously stated, several components, like valves, are standardized today for several refrigerants and their working pressures are adequate even for CO<sub>2</sub>.
  11. Availability of CO<sub>2</sub> transcritical system vendors in the local market is low. CO<sub>2</sub> central refrigeration systems as well as the evaporators and subcooler were manufactured in Italy by EPTA Italy. The size of the market is still not sufficient for manufacturing it locally.
  12. Compressors in this case were manufactured by Bitzer and the service center for these compressors is located in Brazil, so the project vendor has a reduced stock for emergency. Because of this, the capacity of the CO<sub>2</sub> central was calculated with a slight reserve so it could work even if one of the compressors fails.
  13. Display cabinets are manufactured by EPTA Argentina locally at their Rosario manufacturing plant but some of the components are imported.
  14. Most electrical components are available locally but some cables as well as special connectors are imported.
  15. The Control system is manufactured by Carel, which is based in Brazil and has distributors in Argentina. Carel control systems for CO<sub>2</sub> transcritical installations are manufactured in Italy so the project vendor maintains a complete control system in stock as well as pressure transducers to be able to assist in case of emergency.

### [Electricity consumption](#)

As expected with any refrigeration system, the electricity consumption of the CO<sub>2</sub> transcritical booster refrigeration system showed correlation with the ambient temperatures. In the summer period from December to March the average maximum temperature was 32 °C, and most of the time over 30°C, as shown in the following figure.



FINAL REPORT  
DEMONSTRATION PROJECT: CO<sub>2</sub> REFRIGERATION EQUIPMENT IN SUPERMARKETS




Figure 15 Average maximum temperature between December 2017 and March 2018

Year 2018<sup>6</sup> showed more extreme temperatures than the baseline year 2017<sup>7</sup>, with an increase of almost 2 Celsius degrees in the maximum temperatures during several days.

Prior to the project the supermarket had only one meter to measure all electrical consumption of the shop. Thus, the supermarket did not have any information on the consumption of the refrigeration equipment. In order to be able to assess the impact of the project, the first thing was to install of a separate meter to delineate the measurement of the electrical power consumption of the cooling equipment only. In the following figure and table, the monthly electricity consumption of the new CO<sub>2</sub> transcritical system is presented versus the baseline registered during the test period from January to November.




Figure 16 Energy consumption of refrigeration equipment

<sup>6</sup> Monitoreo Regional de la Temperatura 2018. Servicio Meteorológico Nacional

<sup>7</sup> Monitoreo Regional de la Temperatura 2017. Servicio Meteorológico Nacional

During the first 11 month of the trial period, the cumulative electric consumption of the CO<sub>2</sub> transcritical system in the first year of its operation was 27.64% lower compared to the pre-project annual electric consumption of the baseline equipment. The annual energy consumption was extrapolated based on the power-meter measurements of the first 11 months and the results are shown on the following graph.




Figure 17 Annual electrical energy consumption of refrigeration equipment

The annual electricity bills (including non-technological energy use) showed a 27% year saving of pesos \$343,673 (US\$ 9,200).

The following graph shows energy cost comparison based on electricity bills of 2017 and 2018.




Figure 18 Electricity cost of the supermarket



## Refrigerant leaks

The refrigerant charge amounts and leakage data are shown in Table 3.

TABLE 3. REFRIGERANT CHARGES AND LEAKS, SUPERMARKET IN LINCOLN

Year	HCFC-22 (kg)			HFC-404A		
	Charge [kg]	Leak	%	Charge [kg]	Leak	%
<b>2011</b>	400	244	61%		N/A	-
<b>2012</b>	400	593	148%		N/A	-
<b>2013</b>	400	312	78%		N/A	-
<b>2014</b>	400	517	129%	10.6	27.2	<b>257%</b>
<b>2015</b>	400	272	68%	10.6	40.8	<b>385%</b>
<b>Average</b>	<b>400</b>	<b>387.6</b>	<b>97%</b>	<b>10.6</b>	<b>34.0</b>	<b>321%</b>

The baseline annual consumption of refrigerants at the Lincoln La Anónima supermarket amounted to 398.2 kg. The associated refrigerant cost amounted to 5,700 USD.

The new system is filled with 300 kg CO<sub>2</sub>.

In view of the high pressure of the CO<sub>2</sub>, high quality pipes are used. Special attention and qualified/certified technicians and welders were employed for the connections and installation of the circuits and equipment. Rigorous testing of all joints and of the entire circuit was carried out prior commissioning and start-up. In view of the high quality of the equipment and installation work, almost no leaks occurred during the first year of operation. Thus, the cost of the refrigerants is now saved and also the labour cost of replacements and repairs associated with it. The loss of perishable goods was not quantified.

### Environmental impact

The following table shows the impact of direct and indirect green-house gas emissions during the monitoring period. As shown in Table 4 the direct green-house gas emission reduction is 834.9 TCO<sub>2eq</sub> due to the high GWP of R-22 refrigerant as well as the extensive baseline annual leakage average amounting to 97% of the total charge compared to the GWP and leakage of R744 and R290 of the new system.



In 2019, during the generation of 1 kWh electrical energy in Argentina 310 g of CO<sub>2</sub> eq greenhouse gas was emitted<sup>8</sup>. Even if this figure is not too excessive compared to other countries (e.g. EU- 269 g<sub>CO<sub>2</sub>eq</sub>/kWh<sup>9</sup>, USA – 401 g<sub>CO<sub>2</sub>eq</sub>/kWh<sup>10</sup>, China 555g<sub>CO<sub>2</sub>eq</sub>/kWh<sup>11</sup>) the energy saving results in substantial greenhouse gas savings amounting to 21.43 tCO<sub>2</sub>eq. Even though this is quite low compared to the direct emission saving, but it is recurring annually during the entire lifetime of the machinery.

TABLE 4 CALCULATION OF CLIMATE IMPACT OF THE PROJECT

DIRECT EMISSION			
Chemicals	Average leakage (kg)	GWP	Direct emission (tCO <sub>2</sub> eq)
Prior to conversion			
R-404A	34	3,922	133.35
HCFC-22	387.6	1,810	701.56
Total			834.90
After conversion			
R-290	0	5	0
CO <sub>2</sub>	0	1	0
<b>Saving</b>			<b>834.90</b>
INDIRECT EMISSION			
	Electricity consumption	Intensity of power generation (gCO <sub>2</sub> eq/kWh)	Indirect emission (tCO <sub>2</sub> eq)
Prior to conversion	247,616	313	77.50
After conversion	179,163	313	56.08
<b>Saving</b>			<b><u>21.43</u></b>
CLIMATE IMPACT			
<b>Total emission saving</b>			<b>856.33</b>

The climate impact is illustrated on the following graphs.

<sup>8</sup> [https://www.climate-transparency.org/wp-content/uploads/2019/11/B2G\\_2019\\_Argentina.pdf](https://www.climate-transparency.org/wp-content/uploads/2019/11/B2G_2019_Argentina.pdf)

<sup>9</sup> [https://www.climate-transparency.org/wp-content/uploads/2019/11/B2G\\_2019\\_EU.pdf](https://www.climate-transparency.org/wp-content/uploads/2019/11/B2G_2019_EU.pdf)

<sup>10</sup> [https://www.climate-transparency.org/wp-content/uploads/2019/11/B2G\\_2019\\_USA.pdf](https://www.climate-transparency.org/wp-content/uploads/2019/11/B2G_2019_USA.pdf)

<sup>11</sup> [https://www.climate-transparency.org/wp-content/uploads/2019/11/B2G\\_2019\\_China.pdf](https://www.climate-transparency.org/wp-content/uploads/2019/11/B2G_2019_China.pdf)




Figure 19 Overall climate impact of the project




Figure 20 Climate impact of the project by emission types

The total annual reduction of climate impact in the year after the conversion amounted to approximately 856 metric tons CO<sub>2</sub> equivalent. For illustration, this number is equivalent to the annual CO<sub>2</sub> release of approx. 420 passenger cars running 15,000 km in a year! (A currently used mid-size car releases 110 - 160 g CO<sub>2</sub> per km.)





The strong commitment of the recipient company as well as of OPROZ, the vendor and of the skills and hard work of the national and international consultants' of UNIDO contributed to the successful completion of the project and laid the foundation for its long-term sustainability and replicability in the country.

Based on the good results obtained in the project, the recipient company La Anónima, has adopted transcritical CO<sub>2</sub> as the default technology for its new branches as well as for updating or refurbishing of current ones, whenever it is feasible.

The project helped to create confidence in the technology. It demonstrated its feasibility, removed many barriers and accelerated the adoption of this technology even for warmer climate zones of this country (e.g. Córdoba, Santa Fe, Salta and Tucuman). As of the date of this report, the number of supermarkets using CO<sub>2</sub> transcritical systems in Argentina increased to a total of 20, belonging to eight different supermarket chains.

At regional level, the same vendor has installed 3 more systems in Chile, 1 in Colombia and 12 in Ecuador from 2017 up to now.

## SUSTAINABILITY

The strong commitment of the recipient company as well as of OPROZ, the vendor and of the skills and hard work of the national and international consultants of UNIDO contributed to the successful completion of the project and laid the foundation for its long-term sustainability and replicability in the country.

Based on the good results obtained in the project, the recipient company La Anónima, has adopted transcritical CO<sub>2</sub> as the default technology for its new branches as well as for updating or refurbishing of current ones, whenever it is feasible.

The project helped to create confidence in the technology. It demonstrated its feasibility, removed many barriers and accelerated the adoption of this technology even for warmer climate zones of this country (e.g. Córdoba, Santa Fe, Salta and Tucuman). The number of supermarkets using CO<sub>2</sub> transcritical systems in Argentina increased to a total of 13 belonging to seven different supermarket chains.

At regional level, the same vendor has installed 3 more systems in Chile and 9 in Ecuador from 2017 up to now.

The following e-mail represents a true testimony of the success of the project:

**De:** Gil Nestor - Epta Argentina <[Nestor.Gil@epta-argentina.com](mailto:Nestor.Gil@epta-argentina.com)>

**Enviado el:** miércoles, 26 de febrero de 2020 04:03 p.m.

**Para:** Laura Estela Berón <[lberon@ambiente.gob.ar](mailto:lberon@ambiente.gob.ar)>

**Asunto:** Buenas nuevas



*Hola Laura, tenemos buenas noticias !*

*A partir de los resultados de Lincoln, La Anonima y Epta firmamos un acuerdo estratégico para comenzar a reemplazar gases sintéticos por CO<sub>2</sub> en sus tiendas existentes. Es una excelente noticia ya que fue anunciada en el marco de EuroShop en Alemania.*

*Pensábamos que estaría bueno distinguir a La Anonima como primera cadena en instalar Transcritico y también en tomar una decisión de esta característica.*

*Que opinas ?*

Translation:

Hi Laura, we have good news!

Based on the results of Lincoln, La Anonima and Epta, we signed a strategic agreement to begin replacing synthetic gases with CO<sub>2</sub> in their existing stores. This is excellent news as it was announced within the framework of EuroShop in Germany.

We thought it would be good to distinguish La Anonima as the first chain to install transcritical equipment and also of having taken a decision accordingly. What do you think ?

Thank you and regards,

Nestor



## SUB-PROJECT: TUNISIA

The project funds approved for the Tunisia component amounts to **USD 319,131**.

UNIDO has been working closely with the NOU on the introduction of trans-critical CO<sub>2</sub> refrigeration technology at Monoprix supermarket within the framework of the contract “Demonstration project for the introduction of trans-critical CO<sub>2</sub> refrigeration technology for supermarkets in Tunisia”. Technical experts were mobilized and the needed ToRs have been prepared and approved by all partners. Unfortunately, the beneficiary decided to withdraw and the project was on hold.

In June 2019, a meeting was held with the NOU and it was decided to look for an alternative beneficiary that can participate in the project. Carrefour was identified as a potential partner. UNIDO mobilized an international expert and a meeting was held with the representative of Carrefour and the Manager of the Technical Department. Carrefour confirmed the plan to build a new supermarket by February 2020 that will be opened by March 2020. No delay on these dates will be allowed given to profitability reasons. The company is present in Tunisia as a franchise of the French firm. This means that the ownership is from Tunisia; there are no French capitals.

The planned cooling capacity is 53,188 W for the positive temperature and 4,700 W for negative temperature. The original plan was to install a system based on R404A. Carrefour representatives committed their agreement to installing a CO<sub>2</sub> trans-critical system in the new supermarket.

After further consultations with the MLF Secretariat, it was decided not to proceed with the installation as the initial intention was to replace an existing technology with the CO<sub>2</sub> trans-critical system rather than performing a new installation. The NOU and the beneficiary have been notified accordingly.

The remaining funds after financial completion will be returned as per decision.



## FINAL REPORT

DEMONSTRATION PROJECT: CO<sub>2</sub> REFRIGERATION EQUIPMENT IN SUPERMARKETS**BUDGET AND EXPENDITURES**

The financial status of the Project is summarized in Table 3 overleaf.

Item as per Approved Proposal	Budget as per Approved Proposal (US\$)	Disbursements So Far (US\$)	Remaining Obligations (US\$)	Balance (US\$)	Comments
<b>Argentina</b>					
New refrigerating equipment	389,866	484,372 (*)			
Food display cabinets	102,303	Included in (*)			
Engineering and transport	15,000	Included in (*)			
Workshops to disseminate results of the project	20,000	23,763			
<b>Subtotal Argentina</b>	<b>527,169</b>	<b>508,135</b>			
<b>Tunisia</b>					
New refrigerating equipment	245,347	0			
Food display cabinets	43,784	0			
Engineering and transport	10,000	0			
Workshops to disseminate results of the project (intern. consultant, meetings, traveling**)	20,000	20,000 **			
<b>Subtotal Tunisia</b>	<b>319,131</b>	<b>20,000</b>			
<b>Totals (Argentina + Tunisia)</b>	<b>846,300</b>	<b>528,135</b>		<b>318,165</b>	The remaining funds from the project will be returned to the MLF upon financial closure.

Annex IV

**DEMONSTRATION PROJECT ON REFRIGERANT QUALITY, CONTAINMENT AND  
INTRODUCTION OF LOW-GLOBAL-WARMING POTENTIAL (GWP) ALTERNATIVES**



**Final Report**

*85<sup>th</sup> meeting of the Executive Committee for the Implementation of the Montreal Protocol*

March 2020

**CARIBBEAN SUB-COMPONENT**

**Countries:** the Bahamas, Grenada, Saint Lucia, Saint Vincent and the Grenadines, Suriname

**Title:** Safe handling of low-GWP flammable refrigerants

**Project Budget:** USD 234,584

**Implementing Agency:** UNIDO

**National Counterparts:** National Ozone Units, National Refrigerant Associations, Vocational Schools

## Table of content

I. Background.....	1
II. Project objectives.....	2
III. Implementation plan.....	2
IV. Implementation report.....	2
<i>Activity 1: Design of training curriculum preparation and monitoring of training</i> .....	2
<i>Activity 2: Upgrading Training Centre</i> .....	3
<i>Activity 3: Train the trainers Regional Workshop</i> .....	4
<i>Activity 4: Training sessions for technicians</i> .....	5
<i>Activity 5: Workshop and exhibition</i> .....	9
<i>Activity 6: Regional expert group meeting and dissemination of results</i> .....	10
V. Financial status.....	12
VI. Lessons learned and recommendations for the sustainability of the project.....	12
Annexes.....	14



## **I. Background**

The phase-out of hydrochlorofluorocarbons (HCFCs), specifically in the refrigeration and air-conditioning sector, brought about a broader discussion on suitable long-term alternatives. Readily available refrigerant alternatives, which are hydrofluorocarbons (HFCs), have however high global warming potentials (GWPs) and contribute to global warming. The refrigeration and air-conditioning manufacturing sectors worldwide, are thus gearing towards the use of low-GWP alternatives, such as hydrocarbons (HCs) and novel refrigerant formulations of HFO and HFC blends, which are designed to have short atmospheric lifetimes.

It has been established that refrigeration service technicians in countries with large service sectors need to be well trained and equipped to cope with the installation and maintenance demands of next-generation appliances. HCs and HFOs have zero-ODP and low-GWP properties, but are flammable. HCs, such as propane, are classed as “A3 - highly flammable”. HFOs and HFC blends are classified with “A2L – mild flammability” with slow propagation. Countries are steadily beginning to take up hydrocarbons as an alternative to HCFCs in air-conditioning although few technicians are trained to handle the alternatives effectively. It is anticipated that as old installations near decommissioning, more end-users will opt for hydrocarbon-based appliances.

However, specialised training for technicians on flammability needs to be done to ensure that only well-trained technicians service hydrocarbon-based equipment. Hydrocarbons such as propane, LPG and hydrocarbon mixtures have been used during service operations, where the risks associated with the flammability and the thermodynamically properties of the refrigerants has not always been taken into account. Hence it is important to increase the know-how and confidence of technicians with regard to using flammable low-GWP refrigerants when installing new units or servicing old units.

To address these barriers, the Executive Committee for the Implementation of the Montreal Protocol approved at its 76<sup>th</sup> in May 2016 a demonstration project on refrigerant quality, containment and introduction of low-global-warming potential (GWP) alternatives. The project was implemented through two components, one in the Caribbean, and one in Eastern African, by UNIDO (lead implementing agency) and UNEP (co-operating implementing agency).

The Caribbean component was implemented by UNIDO in the Bahamas, Grenada, Saint Lucia, Saint Vincent and the Grenadines, and Suriname for a total funding of USD 234,584.

## II. Project objectives

In order to facilitate the introduction of low-GWP refrigerants in the servicing sector, the demonstration project aimed to:

- Enhance the expertise of technicians and train specialized trainers;
- Upgrade the training curricula at vocational centers;
- Augment the equipment at the regional training center;
- Expose stakeholders to the latest HC-based equipment and components on the market.

The activities planned under the project were linked to the countries' respective HPMPs. The use of flammable refrigerant alternatives is covered to varying extents in the HPMPs. However, the funding levels of the HPMPs could not adequately cover the issue of flammability. Therefore, regional, as well as country-specific activities were required to bring about a more comprehensive approach that would enable the countries to transition to flammable low-GWP refrigerants in a safe manner, as proposed in the project and described in more details below. Moreover, it was vital that these activities were carried out as soon as possible, so that current HC service practices are conducted safely, in light of the concerns pointed out under decision 72/17 of the Executive Committee.

## III. Implementation plan

Activities	Budget (USD)	Countries
1. Design of training curriculum preparation and monitoring of training	30,000	All
2. Upgrading training centre	72,417	Grenada
3. Train the trainers regional workshop	42,792	All
4. Training sessions for technicians	49,375	All
5. Workshop and exhibition	5,000	Grenada
6. Regional expert group meeting and dissemination of results	35,000	All
<b>Total</b>	<b>234,584</b>	

## IV. Implementation report

### *Activity 1: Design of training curriculum preparation and monitoring of training*

A regional workshop for policy makers and curriculum developers was held in May 2017, where representatives from national ozone units and training providers were trained on preparing a training course and operational and organisational activities featuring the essential aspects of the training organisation. In addition, various types of certification schemes from different regions were introduced and discussed to serve as a platform to selecting the right components for a scheme for the Caribbean region.



*The National Ozone Officers, their alternates, national consultants and training provider during the regional workshop*

A regional training curriculum was designed to ensure that only qualified technicians are handling and servicing equipment and flammable fluids. This curriculum encompasses theoretical knowledge as well as specifies practical expertise that must be achieved to get the necessary skills to safely handle low-GWP alternatives and flammable refrigerants. It includes a list of the appropriate equipment and materials for training of technicians. In addition, the competence and requirements for an adequate assessor and venue requirements are also provided. This curriculum should be adapted by each country for their respective schemes, but it is already in use at the regional training center in Grenada, together with a training programme developed by the GIZ. The complete curriculum is provided in annex 1.

### ***Activity 2: Upgrading Training Centre***

In order to facilitate the introduction and the safe use of low-GWP refrigerants, the regional training centre in Grenada at the T.A. Marryshow Community College (TAMCC), St. George's was upgraded in 2017 with equipment, tools and materials suitable for low-GWP flammable refrigerants.

The list of items was established in consultation with the National Ozone Officer of Grenada, and other National Ozone Officers of the region, based on needs identified at the regional level and following the recommendations contained in the training and certification curriculum on flammable refrigerants developed as part of the project and the "Guidelines for the safe use of hydrocarbon refrigerants" developed by the GTZ Proklima in 2010.

Items delivered included manifolds with gauge for hydrocarbons, electronic leak detectors for flammable refrigerants, portable charging stations for hydrocarbons, propane and butane gas cylinders, and other tools and material for use of low-GWP refrigerants in air-conditioning. The complete list of equipment, tools and materials delivered is provided in annex 2.

In 2019, the regional training center was operating fully for the RAC technicians of Grenada, and will open to technicians of other countries of the region in 2020. The training center has the capacity to train up to 20 technicians per session, and it is envisaged that once open to other neighbouring and participating countries, up to 10 technicians could come from outside Grenada at each session. Participation of technicians from all countries in the training remains subject to availability of

financing. Countries are therefore invited to consider possible source of funding such as the national HPMPs or other ozone or climate related projects.

### ***Activity 3: Train the trainers Regional Workshop***

A regional train-the-trainers workshop was organised in Grenada on 22-25 August 2017. 20 RAC technicians, four from each of the participating countries, were trained as trainers on theoretical and practical aspects of refrigeration servicing, in particular on the safe handling of refrigerants and alternatives. Technicians who participated in the workshop already possessed consistent knowledge and practical skills on HFCs and other traditional refrigerants. The full list of technicians who attended the workshop is provided in annex 3.

The objectives of the workshop were more specifically to:

- Disseminate technical knowledge on the flammable refrigerants necessary to operate with these types of refrigerants;
- Showcase the reduction of direct and indirect global warming emissions that it is possible to obtain with systems using flammable refrigerants thanks to their better energy efficiency;
- Present the safety aspects, as mandatory knowledge required when dealing with the flammable refrigerants;
- Provide practical and technical skills, which would allow technicians to maintain and repair flammable refrigerant-systems in safe conditions;
- Provide a consistent theoretical and practical knowledge (train-the-trainers) for future training of other technicians in their area;
- Activate a life long learning process, which students could further develop for a life project of continuous learning.

The workshop consisted of both theory and practice sessions, preparing for the final assessment. The training took place at the TAMCC, recently upgraded with equipment, tools and materials suitable for low-GWP flammable refrigerants. Part of the theoretical lessons were prepared based on the REAL alternatives learning material, and on guidelines on F-gas refrigerants. Furthermore, additional material was prepared specifically by the trainer, based on European laws.

The theoretical topics presented during the workshop included:

- Information on HCFC-free technologies available or HCFC alternative substances in servicing including training on the safe handling of refrigerants and alternatives, mainly those with high toxicity, flammability or pressure;
- Refrigeration principles and fundamentals, refrigerants, temperature-pressure relation and diagrams, refrigerant properties;
- Thermodynamic principles, basic components of the refrigeration cycle;
- Applications with a choice of components, compressors, evaporators, condensers, calculations and sizing;
- Refrigerating plant: efficiency and refrigerating capacity, maintenance, disadvantages, correct installation, component functionality control (compressor, condenser, evaporator, valves), main electrical problems, different types of refrigerants, lubricants and problems connected with their utilisation, faulty functioning of refrigerating plants;
- Presentations of hydrocarbon applications in window and split type air-conditioners, chiller, etc.;
- Methodology for conducting risk assessments for systems and equipment using

hydrocarbon/flammable refrigerants, e.g. electrical components.



*Participants during the theoretical session*

The practical session covered the following aspects:

- Introduce good practices to avoid the refrigerant emissions during servicing, troubleshooting and maintenance, including refrigerant containment;
- Vacuum, charge. regulation, tools, recovery, retrofit, drop-in, manometer reading, pressure gauge;
- Research and damage detection, leak detection, valves, filters, oil and liquid separators;
- Practical applications of hydrocarbons in the refrigeration-servicing sector;
- Safe handling of flammable refrigerants.

At the end of the training course, an assessment was carried out and successful participants received the F-gas and the REAL alternatives certifications. These certifications are recognised worldwide and certify the competence level of technicians for handling refrigerant gases- in this case, F-gases and flammable refrigerants. An example of the REAL alternatives certificate is provided as annex 4.

#### ***Activity 4: Training sessions for technicians***

Two hydrocarbon-based air-conditioning units were delivered to each country (apart from Grenada, which received units earlier for the regional training centre) to organise their in-country training sessions. This activity met with difficulties as manufacturers of hydrocarbon-based air-conditioners are still reluctant to sell small quantities commercially. Based on consultations with National Ozone Officers, additional purchases of materials were made in all countries but Grenada to ensure that each country is well equipped for their in-country training. The complete lists are provided as annex 5.

As of March 2020, 85 air-conditioning technicians have already been trained during the country training sessions organised since the train-the-trainers regional workshop which took place in August 2017 in Grenada. An additional 40 to 70 technicians will be trained before August 2020. When possible, the trainers trained during the workshop have been carrying out the country training sessions. The detail of the training sessions by country is provided hereafter.

### The Bahamas:

A three-evening training course was organised on 20-22 August 2019 for 9 technicians. One local RAC trainer and the National Ozone Officer conducted the training. The full list of participants to the training is provided in annex 6.

The topics covered included: properties of hydrocarbons, toxicity, flammability restrictions on use of hydrocarbons, availability of hydrocarbons, design characteristics of appliances using hydrocarbons, leakage issues and leak detection, maintenance and repairs of appliances using hydrocarbons.

### Grenada:

A two-day training course was organised on 8-9 May 2019 for 32 technicians. Two local RAC trainers and the National Ozone Officer (NOO) conducted the training. The technicians were required to have at least three years working experience in the field of RAC to participate in the training. The full list of participants to the training is provided in annex 6.

Major topics covered in the training included but were not limited to: properties of hydrocarbons, risk assessment, legislation, policy and standards, fire and electrical safety, charge limitation and room size calculations, personal protective equipment and specialise tools and equipment required for installation and servicing, leak detection, installation, servicing and maintenance practices, and brazing and pipe connections. The methodology used included a combination of power point presentations, lectures, handouts and multi-media.



*Participants during the theoretical session*

During the practical training, the participants were required to demonstrate their competence in brazing, flare joint connections, leak and pressure testing, evacuation, venting and charging of refrigerants.



### *Participants during the practical work*

During the evaluation participants were asked to give their overall rating of the training. Out of 27 respondents, 18 rated the training as been excellent, eight as very good and one as good. At the end of the training, certificates of participation were awarded to all the participants.



### *Participants receiving their certificate*

#### Saint Lucia:

A two-day training session was organised on 4-5 February 2020 for 11 air-conditioning technicians. The facilitators of the training were two refrigeration technicians who underwent training in flammable refrigerants and their technology under the “train the trainer” component of the project. The full list of participants to the training is provided in annex 6.





### *Participants during the theoretical session*

The first day was dedicated to theoretical aspects, including a presentation of the Montreal Protocol and of the HPMP for Saint Lucia, descriptions of the most common types of refrigerants, measures for the safe handling of flammable refrigerants and good servicing practices for flammable refrigerants, and a reminder of thermodynamic notions relevant to refrigeration and air-conditioning. At the end of the first day, participants were given an examination to assess their knowledge and understanding on the subjects covered during the theoretical component. The second one consisted of practical sessions and hands-on exercise.

Overall, the technicians found the training to be very useful and informative. The recommendations which were made by participants included the organisation of longer training sessions and the possibility for RAC technicians to purchase HC-based servicing tools to familiarise themselves with the technology.

#### *Saint Vincent and the Grenadines:*

A four-day training course was organised on 10-13 February 2020 for 11 technicians on the safe handling of low-global warming potential flammable refrigerants. Two local RAC trainers and the National Ozone Officer conducted the training. The full list of participants to the training is provided in annex 6.

The range of topics selected for the training session were geared towards ensuring that technicians are adequately prepared for the introduction and use of flammable refrigerants. These topics included: refrigeration cooling system, hydrocarbon refrigerants, flammable refrigerant safety, GIZ cool training programme and overview of training, safe design and general criteria for hydrocarbon refrigerants, hydrocarbons vs hydrochloroflourocarbons.



*Participants during the theoretical session*

The training also included practical work and hands-on exercise on the following topics: brazing project, testing and evaluation, demonstration of brazing with and without nitrogen, fabrication according to best practice, installations of hydrocarbon air conditioner, collection of data and system's analysis, requirements for data recording and labelling of systems, leak testing.



*Participants during the practical work*

Full day sessions were well attended by all registered participants. Theoretical sessions not only created an opportunity for technicians to have a better understanding of the use of hydrocarbon refrigerants, but also created a forum where participants were able to interact and network with other personnel within the industry to share their experiences. The practical exercises were successfully completed by all technicians. Participants indicated their appreciation for the training workshop and expressed a desire to be involved in similar sessions.

#### Suriname:

22 technicians were trained following the train-the-trainers workshop in Grenada in August 2017. All the technicians are members of the Air-conditioning, Refrigeration & Ventilation Association Suriname (ARVAS).

This training programme is now being extended, with multiple sessions taking place from March to August 2020, for an additional 40 to 70 technicians, in particular non-ARVAS members technicians and technicians from the informal sector. Each session will last four days, with two days of theory on topics such as basic thermodynamics, the cooling system, refrigerants, alternative refrigerants (hydrocarbons, carbon dioxide), differences between alternative refrigerants and HCFC, safety aspects, and compressor replacement and instalment. The two following days will be dedicated to practical sessions.

#### ***Activity 5: Workshop and exhibition***

The workshop and exhibition was intended to showcase the offer of appliances using low-GWP alternative and servicing equipment offered by regional and international suppliers. Representatives from these suppliers would have participated to present their offers and answer questions from workshop participants. It was in particular envisaged to organise the exhibition back to back with the regional expert group meeting to create synergies between the discussions with the suppliers' representatives, and those on the success and challenges of the project among shareholders.

As international suppliers expressed the desire to understand better regional market conditions and trends, market surveys for each country have been considered and started, but the lack of data

available, both in the countries and from public sources, did not allow to draw any certain and conclusive results. More generally, the lack of data on the market remains a challenge to encourage international suppliers of HC equipment to increase their presence in the region. The geographical distance from markets which are more mature in terms of natural refrigerants is also seen as a barrier to the growth of trade between the region and international suppliers or manufactures. Hence, only documentation and catalogues were collected from international suppliers and no representative participated in the event.

Regarding regional suppliers, a representative from Grenz concept, a reseller of R290 appliances and RAC equipment participated remotely in the regional expert group which took place in Paramaribo, Suriname, on 5 October 2019. The representative gave on this occasion a presentation on its offer and business model, and answered the questions from participants. He indicated in particular that the recent end of the production of the 12,000 BTU units by Godrej is an issue as these models are the most popular in the country. It is supposed that Godrej stopped the production of these units due to the dynamics of its domestic market, India, where the 18,000 and 24,000 BTU units are preferred because of the very high ambient temperature.

The representative of Grenz concept further indicated that warranty is not offered by the company to customers if the appliances are not maintained by trained technicians. The manufacturer on its side guarantee the compressor for 10 years, and five years for the rest of the unit. Grenz concept currently sells in Guyana and Trinidad and Tobago, and estimates that there is a potentially large market in the Caribbean for R290 appliances. Shipping time from India is three months, therefore Grenz concept mostly operates based on stocks. The 12,000 BTU units are sold nationally for USD 900, and the 18,000 BTU for USD 1,300, both excluding transportation. The supplier's representative indicated that it would be ready to supply other countries, as the the representative from Saint Lucia in particular demonstrated strong interest.

#### ***Activity 6: Regional expert group meeting and dissemination of results***

The regional expert group meeting took place in Paramaribo, Suriname, on 5 October 2019. 11 persons, including National Ozone Officers or their alternate representatives, attended the event. Two additional persons joined the meeting remotely. The attendance per country or organisation is as follows: the Bahamas (1), Grenada (2), Saint Lucia (2), Saint Vincent and the Grenadines (2), Suriname (3), Grenz concept, a supplier of R290 appliances in Grenada (1), and UNIDO (2). The topics discussed during the expert group meeting included among others the barriers to the introduction of low-GWP alternative, the curriculum and national training programs, as well as the



lessons learned of the project. The full list of participants to the regional expert group meeting is provided as annex 7.

### *Participants during a working session*

#### *Persistent Barriers to the introduction of low-GWP alternative:*

In Suriname, R290 appliances and maintenance equipment are not present in the country to date. However, R32 equipment are available as well as R600a ones to a lesser extent. There are only two suppliers of refrigerants in the country, but they do not supply R290 gas. The main problem to the uptake of natural refrigerant in the country is the cost of the appliances, which is a complex issue to address due to the low consumption of the country.

In Saint Lucia, R290 appliances, maintenance equipment and gases are also not present in the country to date, except some R290 chillers. For the phase-out of CFCs, the government played an instrumental role in bringing alternative equipment in the country by developing collaboration with suppliers, but similar actions are still to be implemented for natural refrigerants. A majority of technicians still refuse to use R290 as a refrigerant, due to safety concerns, and even ignore that some chillers operating with R290 exist in the country.

In Saint Vincent and the Grenadines, R290 appliances, maintenance equipment and gases are as well not present. Further, there is a fatigue with regard to HC training and sensitisation. There are only three RAC maintenance companies in the country. Out of the four trainers trained during the train-the-trainers workshop, only one is ready to train technicians. The lack of availability of trainers locally remains an issue in organising more training sessions. The high number of private islands in the Grenadines is an additional challenge to control the equipment and technologies entering the country.

In Grenada, there is a lack of institutional and technical capacity to deal with natural refrigerants, in particular economic and fiscal barriers. The government could take further appropriate measures in this regard. Regarding availability of equipment, the situation in Grenada is different from the one in other countries. There are two suppliers of R290 appliances, all manufactured by Godrej. There are few suppliers of gases, different from the resellers of equipment. However, R290 specific maintenance equipment are not available in the country. All these suppliers embarked on alternative refrigerants supply following business recommendations and support from the National Ozone Office. There is also a need for additional awareness raising, as HC suffers from bad press and create fears among technicians. Additionally, standards and codes (in particular regarding charging procedures, room. size, brazing methods, venting, etc.) are not yet well known by the whole technician community. This should improve as training sessions are extended to more technicians. Specific technical topics, such as moisture prevention on equipment operating with R290 or R600a, are to be better addressed by the continuous training programme as technicians are not familiar with the specificities of hydrocarbons.

In the Bahamas, most if not all technicians in the country still ignore hydrocarbon use. The main barrier is the lack of equipment in the country since the market is mainly dependent on the US market. The country does not have any supplier of R290 appliances, maintenance equipment or gas.

#### *Curriculum and subsequent training:*

The curriculum is not yet officially adopted by individual countries, but it has already integrated the

body of reference material available in the region to design training on the safe handling of low-global warming potential flammable refrigerants. At the regional training centre at TAMCC in Grenada, it is used in combination with training material developed as part of a project with the GIZ.

In Suriname, 22 technicians were trained following the train-the-trainers workshop in Grenada in August 2017. In Saint Vincent and the Grenadines, the training of technicians following the train-the-trainers workshop did increase their confidence in alternative technologies.

The group agreed together with UNIDO that the curriculum will be further discussed.

Other discussions:

The group had extensive discussion on the voltage and frequency for the operation of R290 air-conditioners. Currently no equipment are available for countries using 110V/60Hz mains electricity. Technicians from Suriname, Grenada and Saint Lucia further indicated that countries with 60Hz frequency cannot use appliances made for 50Hz. This is a major limitation to the intake of R290 in the Caribbean and elsewhere. Using appliances designed to operate at a frequency of 50Hz in countries having 60Hz was deemed as counterproductive, as it increases energy consumption, reduces appliance lifetime, and leads to early malfunctioning. However, it was noted that technical assessments could be carried out with R290 appliances to examine how they operate under 110V/60Hz mains electricity, and if local alternatives could be developed. Finally, it was indicated that no appliances operating at 110V/60Hz is to be expected to be developed as long as .

The group also exchanged views on the risks associated with brazing and retrofitting appliances for use with R290. Grenada indicated that the GIZ developed a step-by-step guide on retrofitting, and that if correctly done, with all the necessary safety measures to prevent ignition, retrofitting can be consider as a viable option in absence of R290 appliances in the countries. Grenada explained that, in the national training, one full day is dedicated to brazing and safety measures while brazing. Grenada however strongly discouraged against using 290 as a drop-in replacement in appliances designed for the other refrigerants. It was further noted that the MLF and UNIDO strongly advise against the retrofitting of appliances or drop-in replacement, due to the safety risks and lack of awareness on dangers of hydrocarbon use in both scenarios.

Finally, tools available to promote good servicing practices were discussed by the group. Grenada in particular presented how to use the Android application “Good Servicing: Flammable Refrigerants Quick Guide”. Grenada showed for example how to calculate the minimum floor area based on refrigerant charge, and vice versa. Grenada encouraged the group to promote the mobile application among their national technician community.

**V. Financial status**

<b>Activities</b>	<b>Budget (USD)</b>	<b>Total expenditures (USD)</b>
1. Design of training curriculum preparation and monitoring of training	30,000	28,701
2. Upgrading training centre	72,417	77,874
3. Train the trainers’ regional workshop	42,792	42,769

4. Training sessions for technicians	49,375	62,643
5. Workshop and exhibition	5,000	0
6. Regional expert group meeting and dissemination of results	35,000	21,989
<b>Total</b>	<b>234,584</b>	<b>233,976</b>

## **VI. Lessons learned and recommendations for the sustainability of the project**

Some of the following recommendations were made during the expert group meeting held in Paramaribo in October 2019 and after observations from project implementation:

- Individual countries to consider legally adopting the curriculum with small adaptations for country specificity where needed;
- Take appropriate measures to ensure that the regional training center in Grenada opens to RAC training technicians of other participating countries in 2020;
- Assess on a regular basis the capacity of the regional training center in Grenada and consider the need for a second regional training center in another country if capacities are not sufficient;
- Develop appropriate mechanisms and partnerships to encourage international suppliers or manufacturers of HC equipment and tools to offer a stronger presence in the region;
- Collect and analyse RAC market data with the view to encourage international suppliers or manufacturers to offer a stronger presence in the region;
- Develop appropriate mechanisms to encourage local suppliers to distribute HC equipment and tools;
- Envisage group purchases at the regional level of HC equipment and tools for distribution to local resellers with the view to limit the impact of transportation costs;
- Consider the opportunity to create a regional refrigeration association;
- Formulate monitoring and incentive mechanisms to encourage trainers and trained technicians to increase their participation in awareness raising and capacity building exercises conducted at the national and regional levels;
- Attract additional financial support from international funding bodies for the introduction of low-GWP alternatives refrigerants, in particular to fund capacity building programmes for technicians in the region (through the regional training center in Grenada or at the national level);
- Consider developing eco-labeling schemes for cooling appliances and/or reward schemes when consumers buy green cooling appliances;
- Increase in public tenders the minimum COP required for RAC appliances so as to encourage other users to switch to more energy efficient and modern equipment such as those using low-GWP refrigerants;
- Consider the opportunity to impose fees on appliances which use high GWP refrigerants;
- Consider compulsory technical requirements for designing, constructing or retrofitting civil

buildings (offices, hotels, hospitals, schools, apartment blocks, or trade and service facilities, etc. ) with a floor space above a certain size;

- Carry out technical assessments with R290 appliances to examine how they operate under 110V/60Hz mains electricity (as found in the Bahamas among others);
- Develop platforms in each country (e.g. social media, mobile messaging applications) for information sharing among technicians. Such solutions have been implemented in Grenada, and have been facilitating the dissemination of information (e.g. event, training, technical information) by the National Ozone Office and favored mutual assistance by technicians;
- Reinforce presence of RAC technicians in regional meetings, in particular in the Caribbean Network Meeting of the National Ozone Officers. In the past, RAC technicians used to participate in regional meetings. Their involvement in the Regional Expert group provided valuable technical inputs, and participants expressed the wish to benefit from their expertise on technical issues on a more frequent basis.

**Annex 1: training curriculum**

*See next page.*



# **CURRICULUM TRAINING** **ON FLAMMABLE REFRIGERANTS**

## **“Refrigeration and Air conditioning using Flammable Refrigerants”**

### **Summary**

Scope .....	18
Training curricula and necessary equipment .....	18
Skills to be assessed .....	19
Structure .....	19
Structure of the Exam, tests multiple choice, written or online (also oral will be considered) with bank of questions, papers for the practical session, Open Book.....	19
Assessment: practical organization issues .....	20
Theoretical assessment – examination session .....	20
Practical Exam and Exercises .....	20
Practical assessment: .....	20
Training Material .....	21
Assessor competence.....	21
Annex 1 Venue requirements for training and assessment .....	22
Annex 2 Bank of questions (#40).....	22
References .....	33

**Disclaimer:** The principles contained in this Guide are not legally binding, and following them gives no legal guarantee. A binding interpretation of legislation is the exclusive competence of the European Court of Justice. CSG also recommends to readers, when using this Guide, to always refer to the national legislation, and guidance if any, of the State they are dealing with.

## ***Curriculum Training on flammable refrigerants***

### Scope

Design of a regional training curriculum for Refrigeration and A/C technicians working with HC A3 (HydroCarbon - HC) and A2L refrigerants. Training curriculum intends to provide the appropriate and practical knowledge and skills to safely and efficiently install, maintain, repair and dismantle refrigeration systems that utilize HC and to a lesser extend A2L refrigerants.

Training is to be devised with a maximum of practical skills and with the minimum of required theoretical content.

### Training curricula and necessary equipment

#### ***Course details***

- 1) Major (safety / environmental) differences between non- flammable, HC and “ A2L” refrigerants
- 2) Thermodynamic characteristic of Hydrocarbons as refrigerant - p/h diagram
- 3) Specific components for Hydrocarbons – difference between conventional components and HC specific components
- 4) Electronic components suitable for flammable refrigerants
- 5) Refrigeration and Air conditioning applications with HC refrigerants
- 6) Recovery or Venting of HC refrigerants
- 7) Recovery of A2L refrigerants
- 8) Vacuum-Charging procedures for HC refrigerants – accuracy / repercussions for over-undercharging
- 9) Leak testing
- 10) Mechanical/compression joint connections – avoid brazing
- 11) Flammability and safety issues
- 12) Review of Local (if any) guidelines for HC refrigerants – gases
- 13) Review of International guidelines for the use of HC refrigerants – practical and basic
- 14) Transport and storage requirements
- 15) Documentation

#### ***Venue requirements and necessary equipment details***

See Annex 1

## *Curriculum Training on flammable refrigerants*

### Learning / assessment components

T – Theoretical      P – Practical	<b>HC</b>
<b>BASIC THERMODYNAMICS AND PHYSICS</b>	
Thermodynamic properties of HC refrigerant: temperature, pressure, density, thermal capacity, log p/h diagram	T/P
Differences between HC refrigerants and HFCs	T
Characteristic of flammability of the substances, velocity of propagation, LFL, UFL, occupancy	T
Specific components for HC / A2L refrigerant in the refrigeration cycle	T/P
Oil compatibility, oil safety, requirements and oil return	T
<b>REGULATIONS AND STANDARDS</b>	
If available; review of local guidelines for HC (refrigerants) as well as review of international safety guidelines	T
Storage and transportation of HC refrigerant	T
Instructions to end user / customer	P
<b>GOOD PRACTICE<sup>1</sup></b>	
State and identify the commonly used refrigerants' designation	P
How to label HC refrigerant RAC systems <sup>6</sup>	P
Identify appropriate tools, equipment and PPE for work on HC RAC systems	P
Recovery of A2L refrigerant (when / when not – precautions)	P
Safely removing (venting) HC refrigerant from Refrigeration or A/C system	P
Calculate the max fill weight for a refrigerant recovery cylinder for (A2L) refrigerants	P
Pressure test check direct assessment using appropriate techniques	P
Vacuuming the refrigerant circuit – purpose, process	P
Charging of an HC refrigerant system without refrigerant loss (emission) – accuracy / procedure	P
Make a connection without brazing with alternative connections	P
Check the correct functioning of the safety ventilation system	P
Check the correct functioning of the safety system controls	P
<b>HEALTH AND SAFETY REQUIREMENTS</b>	
Safe system shutdown and isolation <sup>6</sup>	P
Extinguish a fire, identify the appropriate fire extinguisher	P
First aid treatment for frostbite	P
First aid treatment for fire burn	P
First aid treatment for suffocation due to breathing problems	P
Safety issues related to high pressures	T
Calculate LFL (confined space)	T
Calculate confined space risk for asphyxiation (heavier than air)	T
Check that Health and Safety rules in the refrigeration system location are respected (emergency exits, fire alarms, leak detectors...)	T
Correct use of Personal Protective Equipment	P

### Assessment Structure

Structure of the Exam, tests multiple choice, written (also oral will be considered) with bank of questions, papers for the practical session, Open Book.

In Annex 2 a bank of questions is listed for flammable refrigerants (Certifications on Real Alternatives flammable refrigerants Category HC)

<sup>1</sup> All practical trainings should include theoretical training

## Curriculum Training on flammable refrigerants

### Assessment: practical organization issues

It is recommended that the following guidance is followed for the organization of Assessments:

- 1) The assessment should last 1 day and the candidate will be informed on the same day if they passed. The certificate will be printed and sent after approximately 2 weeks

Theoretical assessment	60 minutes i.e. 9 am – 10 am
Practical assessment	Start just after the theoretical assessment i.e. starting from 10 am .  Each candidate in max 2.5 hours should perform all the activities

### Theoretical assessment – examination session

- 2) The candidate should arrive 30 minutes before the scheduled exam time
- 3) Each candidate MUST have a photo ID to present to the assessor. No one will be allowed to take the exam without it.
- 4) All electronic devices should be turned off and left in a safe area designated
- 5) Maximum 20-25 candidates per class dependent on number of assessors (1 assessor/assistant every 10 candidates)
- 6) Multiple answers tests, 30 questions for 60 minutes duration
- 7) The same test among candidates with variation of questions to prevent predictability among candidates
- 8) Open books and specific technical tools such as calculator and pressure-temperature comparator should be available
- 9) NO! mobile phones or cameras
- 10) NO! copying or communication between candidates
- 11) YES! speaking to the assessor for clarification; many candidates use different words and vocabulary to identify the same concept (eg. Valves)
- 12) Theoretical assessment: Pass mark above 60% correct answers
- 13) The test could be performed orally if the candidate has asked prior to the beginning of the exam and the assessor has agreed to this arrangement

### Practical Exam and Tasks

#### Practical assessment:

In Annex 3 there are papers to complete during the Practical session and in Annex 4 there are the Instructions

- 14) The laboratory should be properly equipped for performing the practical test (see Annex 1 for Venue Requirements). Measuring instruments should be calibrated.
- 15) There are 3 stages of assessment (1. thermodynamic parameter reading, 2. Pressure test, Vacuum, Charge, Recovery, 3. Brazing) for assessing 3 candidates at time, divided by the practical activities to speed up the process. An alternative is to combine “ thermodynamic exercise” (P/T, Superheat,

## ***Curriculum Training on flammable refrigerants***

Subcool, comments) and pressure test, vacuum, recovery in one exercise and brazing in another.

Increase the difficulty on brazing by adding an expansion valve, check valve or rotalock fitting.

- 16) Pass if candidate proves competence in performing all (100%) main RAC service technicians activities without or with only small hesitations (remember candidates could be knowledgeable but be nervous!):
- B)** Thermodynamic parameters reading through gauges and devices, temperature, pressure, subcooling, superheating,
  - C)** Parameters interpretation, troubleshooting
  - D)** Perform a pressure/leak test
  - E)** Vacuum, charge, recovery with minimum emissions
  - F)** System Logbook reading, understanding and completing
  - G)** Brazing leak tight joints with proper capillary flow.

### Training Material and Real Alternatives

Training material can be found at the following link which is a project financed by EU and to which Centro Studi Galileo, the Italian Association of Refrigeration and the European Association AREA has worked for Blended Learning on Alternative Refrigerants. Free of charge but with Licences to use it for commercial purposes (Enquire Licencing modalities to [buoni@centrogalileo.it](mailto:buoni@centrogalileo.it) ).

[www.realalternatives.eu](http://www.realalternatives.eu)

### Assessor Qualification and competence

Assessors and Trainers should be sufficiently skilled in the curriculum

Assessors should be unbiased in trainees' evaluation

## ***Curriculum Training on flammable refrigerants***

### Annex 1 Venue requirements for training and assessment

A Venue is required both for the training and assessment sessions. It is of paramount importance that safety of teacher, students and staff is warranted.

For the theoretical section, technical teaching aids such as beamer/LCD screen, PC/Laptop and white or chalkboard are required. Adequate seating arrangements as well as air conditioning / heating and sufficient light must be provided.

As for the practical section; the venue must be well ventilated, lit and have sturdy workbenches.

#### ***Necessary equipment and components (minimum)***

- 1) Training model HC a/c and refrigerator unit
- 2) Nitrogen Regulator - Cylinder of High Purity Nitrogen
- 3) Electronic Weighing Platform (accuracy 1 gram)
- 4) Electronic Vacuum gauge
- 5) Manifold set - Hoses with ball valves
- 6) Vacuum Pumps and Hose
- 7) Recovery Unit
- 8) Recovery Cylinder
- 9) Electronic Leak Detector
- 10) Proprietary Leak Spray
- 11) Temperature meter
- 12) Ammeter
- 13) Tools, Pipe Cutters, Pipe Deburring Tool, Pipework Expanders, Hacksaws, Brazing Rods
- 14) Flaring Tool
- 15) Personal protective equipment PPE

## **Curriculum Training on flammable refrigerants**

### Annex 2 Bank of questions (#40)

#### Question 1 A2L

Mod 3 Eff leak test	Which system is not as suitable for a fluorescent additive leak detection system	One with a coalescing oil separator
		A trans critical system
		A cascade system
		A two stage system

#### Question 2 A2L

Mod 3 Eff leak test	How frequently should a hand-held electronic leak detector used for R32 be checked?	At least once per year
		There is no requirement for leak detection of R32
		The frequency depends on the charge size
		After every 100 hours of operation

#### Question 3 A2L

Mod 3 Press testing	What is the benefit of using hydrogen as a trace gas with nitrogen for pressure testing	It has a small molecule and diffuses more readily
		It is easily detectable
		It has an odour
		It is non flammable

#### Question 4 A2L

Mod 3 Leak test regime	Under the revised F Gas regulation (from 01.01.2015) how frequently would a system containing a charge of 60 tonnes CO <sub>2</sub> -equivalent of	Twice per year
		Once per year
		Four times per year
		Leak testing is not required

## **Curriculum Training on flammable refrigerants**

	refrigerant need to be leak tested?	
--	-------------------------------------	--

Question 5 A2L

Mod 3 Indirect leak testing	What is the effect on the high pressure side of a system (with no head pressure control) if it is short of refrigerant?	The discharge pressure will be lower and the degree of subcooling will be lower
		The discharge pressure will be higher and the degree of subcooling will be lower
		The discharge pressure will be higher and the degree of subcooling will be higher
		The discharge pressure will be lower and the degree of subcooling will be higher

Question 6 A2L

Mod 4 Flam refs	Why should you not use an HFC recovery machine on R1234ze?	It contains sources of ignition
		The recovery machine oil is not miscible with R1234ze
		The recovery machine will not withstand the operating pressure of R1234ze
		The low pressure switch setting will not be suitable for R600a because of its lower operating pressure

Question 7 A2L

Mod 4 Flam refs	How do you make sure it is safe to switch on a vacuum pump to evacuate an R32 system?	Use an R32 gas detector to ensure there is no flammable refrigerant in the area
		Recover the system down onto a slight vacuum before fully evacuating the system with the vacuum pump
		Flush the area with nitrogen before switching on the pump
		Fit a long hose on the outlet of the vacuum pump to discharge the R32 away from the work area

Question 8 A2L



## **Curriculum Training on flammable refrigerants**

Mod 4 Flam refs	How do you remove as much refrigerant as possible from a condensing unit system with a charge of 800 g R1234ze?	Recover the R1234ze so the system is on a vacuum, break the vacuum with oxygen free nitrogen to pressure of 0.1 bar g
		Recover the R1234ze so the system is on a vacuum
		Vent the R1234ze outside and evacuate the system
		Vent the R1234ze outside; fill the system with oxygen free nitrogen to a positive pressure, vent and evacuate twice, fill the system with nitrogen for a third time and vent

### Question 9 A2L

Mod 2 R32	What is the typical PS for the low side of an R32 system with an air cooled condenser in a 32°C ambient?	19.3 bar g
		14.3 bar g
		34.2 bar g
		65 bar g

### Question 10 A2L

Mod 3 Leak Points	Which document provides torque values for manually made flared joints	EN378
		The F Gas regulation
		The Pressure Equipment Directive
		EN60079

### Question 11 A2L

Mod 3 Indirect leak testing	What is the effect on the low pressure side of a system (with no suction pressure control) if it is short of refrigerant?	The suction pressure will be lower and the useful superheat will be higher
		The suction pressure will be higher and the useful superheat will be higher
		The suction pressure will be lower and the useful superheat will be lower

## *Curriculum Training on flammable refrigerants*

		The suction pressure will be higher and the useful superheat will be lower
--	--	--

### Question 12 A2L

Mod 2 R32	What is the typical PS for the high side of an R32 system with an air cooled condenser in a 32°C ambient?	34.2 bar g
		24.8 bar g
		19.3 bar g
		120 bar g

### Question 13 A2L

Mod 2 R1234ze	What is the typical PS for the high side of an R1234ze system with an air cooled condenser in a 32°C ambient?	10.3 bar g
		19.3 bar g
		24.8 bar g
		120 bar g

### Question 14 A2L

Mod 3 Leak Points	Why are flare solder adaptors used	They have a factory machined face
		They are brazed onto the pipe work
		They cannot be disconnected once fitted
		They only need to be hand tight

### Question 15 A2L

Mod 3 Press testing	What is the approximate rise in nitrogen pressure if its temperature increases by 5°C?	0.7 bar
		There is no change in pressure
		7 bar
		4.75 bar

## *Curriculum Training on flammable refrigerants*

### Question 16 A2L

Mod 1 Intro, Safety	The hazards of R32 include:	Mild flammability
		High flammability
		High toxicity
		Mild toxicity

### Question 17 A2L

Mod 3 Leak test regime	According to the latest F Gas regulation (EU517/2014) how frequently must an R1234ze system with a charge of 300kg and no fixed leak detection system be checked?.	It does not need to be leak tested
		Once per year
		Twice per year
		Four times per year

### Question 18 A2L

Mod 1 Intro, Safety	The hazards of R1234ze include:	Mild flammability
		High flammability
		High toxicity
		Highly corrosive

### Question 19 A2L

Mod 1 Intro	R32 is used in systems which traditionally use ...	R410A
		R134a
		R404A
		R290

### Question 20 A2L

## **Curriculum Training on flammable refrigerants**

Mod 1 Intro	What type of refrigerant is R1234ze?	An HFC which has unsaturated carbon
		A hydrocarbon
		Carbon dioxide
		An HFC which has saturated carbon

### **HC**

#### Question 1 HC

Mod 1 Restr on use HC	What is the maximum charge of R1270 that can be used on a supermarket shop floor (occupancy category A)	1.5 kg
		150 g
		It cannot be used in this application
		There is no limit

#### Question 2 HC

Mod 1 Intro HC	What is the predominant application for R600a?	Domestic refrigerators and freezers
		Car air conditioning systems
		Glycol chillers for process cooling
		Central plant retail systems

#### Question 3 HC

Mod 1 Perf HC	What compressor displacement is required for R1270 compared to that used for R404A?	Similar
		50%
		150%
		600%

#### Question 4 HC

Mod 2		To disperse the refrigerant safely in the event of a leak
-------	--	---

## *Curriculum Training on flammable refrigerants*

R717 R32 R1234ze HCs	On some systems which use a flammable refrigerant, why does the condenser fan run constantly?	To avoid a build up of contamination on the condenser
		To ensure the head pressure is never excessively high
		To reduce energy consumption

### Question 5 HC

Mod 4 Intro HC	Why is the charge weight accuracy more important on critically charged R1270 systems compared to HFC systems?	Because the density is less so the charge weight is less compared to a similar HFC system
		Because these systems never have liquid receivers
		Because R1270 is only used in systems with less than 150 g charge weight
		Because of the lower operating pressures

### Question 6 HC

Mod 4 Flam refs HC	What is the safe R290 fill weight for a recovery cylinder which has a safe fill weight of 10 kg for R404A?	4.5 kg
		10 kg
		15.4 kg
		22 kg

### Question 7 HC

Mod 4 Flam refs HC	Why should you not use an HFC recovery machine on R600a?	It contains sources of ignition
		The recovery machine oil is not miscible with R600a
		The recovery machine will not withstand the operating pressure of R600a
		The low pressure switch setting will not be suitable for R600a because of its lower operating pressure

### Question 8 HC

## *Curriculum Training on flammable refrigerants*

Mod 4 Flam Refs HC	How do you avoid the risk associated with the on/off switch on a standard vacuum pump when evacuating an HC system?	Use the vacuum pump in a well ventilated area and switch on at least 3 m away from the pump
		Fit a long hose to the pump's outlet to discharge the HC away from the system
		Position the vacuum pump 3 m above the floor
		Position the pump outside

### Question 9 HC

Mod 4 Flam refs HC	How do you make sure it is safe to light a brazing torch to un braze a joint on a system which operates on a flammable refrigerant?	Ensure the area is well ventilated and use a flammable gas detector to check the area
		You must not un braze connections on a flammable refrigerant system, they should be cut using a pipe cutter
		Work outside
		Purge with oxygen free nitrogen

### Question 10 HC

Mod 1 Safety HC	A refrigerant which is classified in refrigerant safety group A3 has which hazards?	High flammability, lower toxicity
		Mild flammability, lower toxicity
		High toxicity, no flame propagation
		Lower toxicity, no flame propagation

### Question 11 HC

Mod 1 Intro HC	What is the GWP of R600a (according to EN378)?	3
		550
		0
		6

### Question 12 HC

## Curriculum Training on flammable refrigerants

Mod 1 Intro R290	R290 is	Propane
		Propene
		Propylene
		Iso butane

### Question 13 HC

Mod 1 Restr on use HC	Which factors are used to determine the maximum charge in a comfort cooling / heating application?  HC	Lower flammability level, height of the indoor unit, floor area
		Practical limit, height of the indoor unit, floor area
		Practical limit, room volume
		Lower flammability level, room volume

### Question 14 HC

Mod 2 HCs	What is the approximate cooling capacity of R1270 compared to R404A?	100%
		50%
		200%
		7 times

### Question 15 HC

Mod 2 R717 R32 R1234ze HCs	What is area classification (with regard to the application of flammable refrigerants)	Testing which determines the extent of a flammable zone in the event of a leak of flammable refrigerant
		Zoning of an area where invasive work on a system containing a flammable gas is to be carried out
		Determining where flammable warning diamonds should be located
		Erection of safety barriers while working on systems which use a flammable refrigerant

### Question 16 HC

## **Curriculum Training on flammable refrigerants**

Mod 2 R717 R32 R1234ze HCs	Which of these devices will not ignite a leak of flammable refrigerant?	An EX “n” rated device
		An EC evaporator fan motor
		A high pressure switch
		A thermostat

### Question 17 HC

Mod 4 Intro HC	What implication does the density difference between HC and HFC have?	The HC refrigerant charge weight is lower
		The system must be evacuated for longer
		The HC system must be charged with gas not liquid
		The system must be charged very slowly to prevent damage to the compressor

### Question 18 HC

Mod 4 Flam refs HC	How do you make sure it is safe to light a brazing torch when working on an HC system?	Ensure the area is well ventilated and use a flammable gas detector to check the area
		You must not un braze connections on an HC system, they should be cut using a pipe cutter
		Work outside
		Purge with oxygen free nitrogen

### Question 19 HC

Mod 2 HCs	What is the typical PS for the high side of an R600a system with an air cooled condenser in a 32°C ambient?	6.8 bar g
		10.3 bar g
		19.3 bar g
		24.8 bar g

### Question 20 HC



## ***Curriculum Training on flammable refrigerants***

Mod 2 R717 R32 R1234ze HCs	What is ATEX?	A European directive which covers equipment intended for use in a potentially explosive atmosphere
		A type of enclosure which can be safely used on a system which operates with a flammable refrigerant
		An electrical device which can be safely used on a system which operates with a flammable refrigerant
		A type of system which uses a flammable refrigerant


**Annex 2: list of equipment, tools and material provided to the regional training centre in Grenada**

<b>Item</b>	<b>Quantity</b>	<b>Item</b>	<b>Quantity</b>
4 way manifold gauge set	20	Steel brush	20
Electronic leak detector for halogenated refrigerants and blends	5	Wire stripper	20
Electronic leak detector for HC refrigerants	20	Mains tester with LED	20
Double stage vacuum pump	10	Oxy/Acetylene brazing unit	5
Digital scale	10	Metallic tool box	20
Portable charging station for R600a and HC blends	5	Cylinder with HC refrigerant R290	20
Refrigerant reclaim unit	2	HC refrigerant R600a	20
Advanced refrigerant identifier ID Pro	2	Cans HC blend refrigerant	20
Split air conditioning unit (R-22)	2	Refillable refrigerant recovery cylinders	20
Precise Electronic Thermometer	4	Set of copper tube rolls	10
Nitrogen cylinder with valve and cap	5	Packet of brazing rods	40
Nitrogen cylinder pressure regulator	5	Box of Flux	20
Set of 7 screw drivers	20	Set of filter drier for HC refrigerant	40
Set of 4 pliers	20	Set of adapters, fitting, flare nuts	20
Piercing pliers	20	Portable CO2 Fire extinguishers	5
Set of tubing tools	20	Portable Dry powder extinguishers	5
Cable reel	10	Refrigerant recovery unit with external recycling module	10
Combination wrenches set	20	Gallon of compressor mineral lubricant	10
Adjustable wrench	20	Gallon of compressor synthetic lubricant	10
Ratchet wrench	20	Pair of safety gloves refrigerant handling	20
Safety goggle	20	Pair of safety gloves for mechanical work	20
Cable knife	20	Pipe wrench 35 mm.	20
Hack saw and extra blades	20	Folding rule 2 m	20
Hammer	20		

**Annex 3: list of participants to the train the trainer workshop**

<b>Name</b>	<b>Surname</b>
Giltan	Baptiste
Frederick Perceival Philip	Beausoleil
Michael	Cadore
Alexander	Darville Jr
Ells	Breuno
Lance	Simpson
Henry	Frederick
Wayne	Grant
Earl Michael	Harte
Vincent	Lorde
Andrew	Miller
Alfred Tyrone	Paul
Gary	Peters
David	Ramsey
Satiesh	Sardjoe
Curtis	James
Stanley	Sovan
Milton	Spier
William	Sturup
Jerry	Van Ommeren

## Annex 4: REAL alternatives certificate




**Name Surname**  
From Country

has successfully completed the assessment for

# REAL ALTERNATIVES (Flammable Refrigerants)







properties • design • maintenance • safety • legal obligations


Assessment carried out by the Authorised Training Provider



Certificate number I0001  
2017, August 25th

Certificate issued on behalf of  
The Institute of Refrigeration



 REAL Alternatives is a blended learning programme for low GWP refrigerants for refrigeration, air conditioning and heat pump technicians. Created by international co-operation of partners and co-funded by the EU Leonardo Life Long Learning Programme.

**Annex 5: list of tools and material provided to National Ozone Units, National Refrigerant Associations, Vocational Schools to support the in-country training sessions**

***The Bahamas***

<b>Item</b>	<b>Quantity</b>
Leak Detector D-400 (UN)	2
Manifold Set 4 valve UNIDO	2
Refrigerant Control Valve 1/4" flare	2
1/4" Charging Hose Gasket 10 pcs	2
3/8" hose gasket K10	2
Gauge HD R-600a,R-290, R22, B/PSI, C/F 80mm T-line	4
Gauge LD R-600a,R-290, R22, B/PSI, C/F 80mm T-line	4
Gauge HP R-134a,404A,410A,407C B/PSI, C/F 80mm T-line	4
Gauge HP R-134a,404A,410A,407C B/PSI, C/F 80mm T-line	4
Fieldpiece dual input thermometer ST4	2
Fieldpiece K-Type thermocoupler Bead Tip ATB1	4
Compact Clamp Meter w/Temp SC240 Fieldpiece	2
Filter copper capillair SM-20M Metric	5
Cylinder refrigerant 12.5 ltr.	2
Pair of safety gloves	10
Portable Charging unit HC, K-PGTB-A3	1
Charging Scale 0-5000 gr P&M	2
Oil 1 liter ISO32 (3GS)	5
Label Flammable Gas 100 x 100 (roll 1,000 pcs)	5

***Saint Lucia***

<b>Item</b>	<b>Quantity</b>
Leak Detector D-400 (UN)	2
Manifold Set 4 valve UNIDO	2
Refrigerant Control Valve 1/4" flare	2
1/4" Charging Hose Gasket 10 pcs	2
3/8" hose gasket K10	2
Gauge HD R-600a,R-290, R22, B/PSI, C/F 80mm T-line	2
Gauge LD R-600a,R-290, R22, B/PSI, C/F 80mm T-line	2
Gauge HP R-134a,404A,410A,407C B/PSI, C/F 80mm T-line	2
Gauge HP R-134a,404A,410A,407C B/PSI, C/F 80mm T-line	2
Fieldpiece dual input thermometer ST4	2
Fieldpiece K-Type thermocoupler Bead Tip ATB1	4
Compact Clamp Meter w/Temp SC240 Fieldpiece	2
Filter copper capillair SM-20M Metric	4
Cylinder refrigerant 12.5 ltr.	6
Pair of safety gloves	10

Portable Charging unit HC, K-PGTB-A3	1
Charging Scale 0-5000 gr P&M	2
Oil 1 liter ISO32 (3GS)	2
Label Flammable Gas 100 x 100 (roll 1,000 pcs)	5

***Saint Vincent and the Grenadines***

<b>Item</b>	<b>Quantity</b>
Manifold Set four way	10
Portable Charging unit for HC, K-PGTB-A3	5
Leak Detector for HC's D-400	10
Fieldpiece dual input thermometer ST4 including: 2 x Fieldpiece K-Type thermoc. Bead Tip ATB1	10
Compact Clamp Meter w/Temp SC240 Fieldpiece	10
Filter copper capillair SM-20M Metric	20
Flammable Gas Label	2500
Pair of safety gloves	20
Charging Scale 0-5000 gr P&M	10
Oil 1 liter ISO32 (3GS)	10

***Suriname***

<b>Item</b>	<b>Quantity</b>
Fridges (R600a)	2
Flammable Gas Label (set of 30)	2

## Annex 6: lists of participants to training sessions for technicians

### *The Bahamas (20-22 August 2019)*

The names of the technicians that participated in the training exercise are;

- Mr. Jerry Josey
- Mr. Deon Ferguson
- Mr. Keno Munroe
- Mr. Maurice Knowles
- Mr. Robert McKinney Jr.
- Mr. Dwight Forbes
- Mr. Refshinko Stubbs
- Mr. Kevin Gibbs
- Mr. Kashmir Colebrooke

### *Grenada (8-9 May 2019)*

<b>List of participants</b>					
<b>Natural Refrigerants Workshop</b>					
T A Marrayshow Community College (TAMMCC)					
May 8th and 9th, 2019					
ATTENDANCE REGISTER					
#	Name	Company	Gender	Tel #	email
1	Amanaki Millette	Phillip's AC & Refrigeration	M	4101454	<a href="mailto:amanakimillette123@gmail.com">amanakimillette123@gmail.com</a>
2	Allen Rick Lyons	Rapid Cool	M	4109620	<a href="mailto:rapdcoolgda@gmail.com">rapdcoolgda@gmail.com</a>
3	Nicholas Joseph	BL International	M	4072531	
4	Chad Walcott	Total Engineering Co. Ltd	M	4560413	<a href="mailto:cwalcott@totalengineeringgd.com">cwalcott@totalengineeringgd.com</a>
5	Razzum Baptiste	Viking Engineering Co Ltd	M	4222849	
6	Everton Connor	ELCICS	M	4065068	<a href="mailto:evertonconnor3113@gmail.com">evertonconnor3113@gmail.com</a>
7	Ian Benoit	ELCICS	M	4160616	
8	Glendon Regis	ELCICS	M	5340331	
9	Javid Mitchell	Modem Electrical Solutions	M	4232364	<a href="mailto:javidmitchell@techie.com">javidmitchell@techie.com</a>
10	Shane Roberts	Modem Electrical Solutions	M	4141931	<a href="mailto:shane.roberts01@gmail.com">shane.roberts01@gmail.com</a>
11	Arnold Fraser	Grenada Airports Authority	M	4155555160	<a href="mailto:arnoldfraser1@gmail.com">arnoldfraser1@gmail.com</a>
12	Kwesi Hamlet	LA Purcell/ Courts	M	5383431	<a href="mailto:ultrakool82@gmail.com">ultrakool82@gmail.com</a>
13	Devon Fraser	Courts	M	5373971	<a href="mailto:ultrakool82@gmail.com">ultrakool82@gmail.com</a>
14	Godfrey Debellotte	General Hospital	M	4495250	<a href="mailto:desmondg1691@hotmail.com">desmondg1691@hotmail.com</a>
15	Ronald Mark	General Hospital	M		
16	Levon Philbert	General Hospital	M	4220975	
17	Kelly Ann Telesford	Self Employed	F	4178838	<a href="mailto:kellyanntelesford@gmail.com">kellyanntelesford@gmail.com</a>
18	Kenneth Stephen	STE-TECH	M	4590150	<a href="mailto:propertygrenada@gmail.com">propertygrenada@gmail.com</a>
19	David Ganpot	Ganpot's Technical Services	M	4202823	<a href="mailto:davidganpot@hotmail.com">davidganpot@hotmail.com</a>
20	Vonnet John	NEWLO	F	5342455 4236154	<a href="mailto:vonnetjohn24@gmail.com">vonnetjohn24@gmail.com</a>
21	Jade Pursue	NEWLO	M	4207966	<a href="mailto:jpersue@gmail.com">jpersue@gmail.com</a>
22	Trevor Andrew	Spice Island Beach Resort	M	4060507	
23	Karvin Johnson	Spice Island Beach Resort	M	5367077	
24	Ramesh Patrick	Grenada Electrical/Franks Refrigeration	M	4578758	<a href="mailto:rameshpatrick917@hotmail.com">rameshpatrick917@hotmail.com</a>
25	Jordan Paredes	Cool Breeze	M	4102192	<a href="mailto:oldwester28@outlook.com">oldwester28@outlook.com</a>
26	Presley Thomas	Cool Breeze	M	4195246	<a href="mailto:presleythomas@hotmail.com">presleythomas@hotmail.com</a>
27	Jerry Coutain	Self Employed	M	5358284	<a href="mailto:jerrycoutain@hotmail.com">jerrycoutain@hotmail.com</a>
28	Aldrin Cox	James Refrigeration Services	M	4208769	<a href="mailto:aldrincox90@gmail.com">aldrincox90@gmail.com</a>
29	Britnay Frank	Grenada Electrical/ Franks Refrigeration	F	4584297	
30	Dondre Sandy	Ultra Kool	M	4199293	<a href="mailto:dondre473@gmail.com">dondre473@gmail.com</a>
31	Meril Fraser	Courts	F		
32	John Campbell	SGU (Observer)		4052718	<a href="mailto:icampbell@sgu.edu">icampbell@sgu.edu</a>
36					
37					
38					
39					
40					

**List of Facilitators**

<b>Name</b>	<b>Company/Institution</b>	<b>Telephone</b>	<b>email</b>
<b>Mr. Lance Simpson</b>	<b>Cooling Tech Limited</b>	<b>534 6423</b>	<b>lsimpson@coolingtech.gd</b>
<b>Mr. Henry Frederick</b>	<b>Maurice Bishop International Airport</b>	<b>415 1198</b>	<b>hfrederick@mbiagrenada.com</b>
<b>Mr. Leslie Smith</b>	<b>National Ozone Unit</b>	<b>409 8128</b>	<b>Smithld31@gmail.com</b>

*Saint Lucia (4-5 February 2020)*

<b>Name of participants</b>
Lambert Calixte
Brandon Mathurin
Keisha Lansiquot
Clemence Charlemagne
Archibald Anderson
Rudolph Felix
Sherwin Joseph
Collin Mondesir
David Charles
Daniel Jn Baptiste
Aaron Doxilly
<b>Facilitators</b>
Michael harte
Percival Beausoliel
<b>National Ozone Unit</b>
Kasha Jn Baptiste
Shanna Scott

*Saint Vincent and the Grenadines (10-13 February 2020)*



## ATTENDANCE SHEET


1) Ronald Jessop	East Caribbean Metal Industry	Technician	<a href="mailto:wayneip@yahoo.com">wayneip@yahoo.com</a>	593-2855
2) Cameron Julian Conliffe	AIW Fish Market	Technician	<a href="mailto:cameron.conliffe@gmail.com">cameron.conliffe@gmail.com</a>	530-8228
3) Lou-Anne Dover	Thompson Cooling & Electrical	Office manager	<a href="mailto:louloupeng@gmail.com">louloupeng@gmail.com</a>	497-3060
4) Vondon Herbert	Thompson Cooling & Electrical	Technician	<a href="mailto:vondonherbert@live.com">vondonherbert@live.com</a>	434-9327
5) Bernard Celestine	Mustique Company	Technician	<a href="mailto:Juiceberryxs60@gmail.com">Juiceberryxs60@gmail.com</a>	530-0138
6) Jason Raguette	AIW Fish Market	Technician	<a href="mailto:Jason24783@hotmail.com">Jason24783@hotmail.com</a>	530-4555
7) Kenny Campbell	Self Employed	Technician	<a href="mailto:Jjken21@hotmail.com">Jjken21@hotmail.com</a>	532-2181
8) Clyde Gurley	JAD	Technician	<a href="mailto:Docgurley32@gmail.com">Docgurley32@gmail.com</a>	531-3222
9) Damien Hinds	JAD	Technician	<a href="mailto:dodley@gmail.com">dodley@gmail.com</a>	531-6946
10) Arthur A. Matthews Jr.	Self Employed	Technician	<a href="mailto:Mathur1318@gmail.com">Mathur1318@gmail.com</a>	431-6980
11) Zoanie Bailey	OSV	Technician	<a href="mailto:doaniebailey@gmail.com">doaniebailey@gmail.com</a>	492-7920

**Annex 7: list of participants to the regional expert group meeting (Paramaribo, Suriname, on October 5, 2019)**

<b>Participant name</b>	<b>Participant function</b>	<b>Country</b>
Ryan PERPALL	National Ozone Officer	the Bahamas
Leslie SMITH	National Ozone Officer	Grenada
Henry FREDERICK	Technician, consultant with National Ozone Office	Grenada
Kelly CYRUS (remote)	CEO from Grenz concept, RAC and R290 appliances supplier	Grenada
Shanna SCOTT	Alternate to the National Ozone Officer	Saint Lucia
Frederick BEAUSOLEIL	Technician and national supplier, consultant with National Ozone Office	Saint Lucia
Janeel MILLER	National Ozone Officer	Saint Vincent and the Grenadines
Brentin QUAMMIE	Alternate to the National Ozone Officer	Saint Vincent and the Grenadines
Cedric NELOM	National Ozone Officer	Suriname
Jerry VAN OMMEREN	Technician, consultant with National Ozone Office	Suriname
Satiesh SARDJOE	Technician, consultant with National Ozone Office	Suriname
Ozunimi ITI (remote)	Project manager, Industrial development officer	UNIDO
Guillaume CAZOR	Consultant	UNIDO

**EASTERN AFRICA SUB-COMPONENT**

# Contents

EXECUTIVE SUMMARY .....	3
I. CONTEXT AND BACKGROUND .....	5
II. PROJECT OBJECTIVE .....	7
III. ACTIVITIES AND ACHIEVEMENTS.....	8
<b>Component 1: Policy incl. actual National Policy Frameworks and Gap Analysis .....</b>	<b>8</b>
<b>Component 2: Technical assistance through provision of tools and equipment.....</b>	<b>14</b>
<b>Component 3: Awareness Raising including Information Dissemination .....</b>	<b>22</b>
IV. FINANCIAL REPORT .....	23
V. CONCLUSIONS AND RECOMMENDATIONS.....	24
Conclusions .....	24
Recommendations.....	26
ANNEXES.....	28
Annex I. Agreed Work Plan for the project implementation. ....	28
Annex III. Reports of: .....	28
Standards and Market Availability of Quality Refrigerants in Tanzania, Kenya, Uganda and Zambia)	
 Tanzania_UNIDO Assignment_DEMO I .....	28
Standards and market availability of Quality Refrigerants in Kenya .....	28
Country program Kenya.....	28
Annex IV. Reports on gap analysis .....	28
Reports on gap analysis .....	28
Annex V. UNIDO Brochures .....	29
Refrigerant can be Counterfeit! English version.....	29
!Los refrigerantes también los falsifican! Spanish version .....	29

## Executive Summary

The project “Demonstration project on refrigerant quality, containment and introduction of low-global warming potential alternatives (Eastern Africa and Caribbean regions)” was planned to be implemented by UNIDO, as lead agency, and UNEP on behalf of the Governments of Eritrea, Kenya, Tanzania, Uganda, and Zambia. The demonstration project was approved at a funding level of USD 369,150 including PSC for UNIDO and USD 56,500 plus PSC for UNEP – in total USD 425,650.

It was approved in May 2016 at the 76<sup>th</sup> Meeting of the Executive Committee (ExCom) of the Multilateral Fund of the Montreal Protocol, at the funding level of USD 345,000 for UNIDO, and USD 50,000 for UNEP (excluding Project Support Cost (PSC)). For the refrigerant quality component, UNIDO allocate USD < 110,415 > and for the Caribbean component USD < 234,584 >. Preliminary project expenditures are USD < 110,181 > related to UNIDO, and USD < 0 > related to UNEP. Thus, the overall expenditure of the project is USD < 110,181 >.

The project aimed to demonstrate the availability of fake refrigerant; the lack of awareness of stakeholders; gaps in customs and legislation; and propose ways to ensure refrigerant quality in the market in Eritrea, Kenya, Uganda, Tanzania, and Zambia. The United Republic of Tanzania was selected as the lead pilot country for leading the implementation of the project due to its geographical location and the biggest by size and population among target countries.

The project included a series of activities:

i) carrying out surveys on refrigerant availability in the markets; ii) conducting a regional train-the-trainer workshop for refrigeration technicians; iii) training national for customs officers, environmental inspectors, importers, and staff from the Tanzanian Bureau of Standards in Tanzania and Eritrea; iv) equipping project stakeholders; v) establishing testing centres and; vi) supporting awareness raising among refrigeration technicians and all stakeholders.

Results of the activities are described within the report.

The project achieved all the goals as follows:

- 1) Availability: Through the surveys, it was clear that counterfake refrigerant is available in the majority of shops in project countries. Even there are shops where there are two prices for the same refrigerant, meaning better or lower quality. Also that for National Ozone Units, it is complete unknown fact, ‘in this country there is no fake refrigerant’.
- 2) Availability mimetic: Refrigerant packed as R-22 were found containing several non-standard blends, expanded refrigerants, recovered refrigerant and more. The same for HFC, blends of refrigerants, hydrocarbons etc. The main source were cans and small cylinders. In general the counterfake refrigerants can be detected due to misleading information in the labels, colours of cylinder, trade names, mistakes in nomenclature, etc.
- 3) Lack of awareness: It is clear the fact that stakeholders e.g. technicians, importers, custom officers, government officers (including NOU) were not aware of counterfake refrigerant, consequences, extra costs generated – refrigerant consumption, more energy, potential compressor damage, reduce efficiency etc.
- 4) Gaps in policy: No legislation regarding refrigerant quality is available. Customs ensure that control substances are regulated, there is lack of awareness on counterfake. Since stakeholders are not aware, there is no legislation or standards for refrigerants.
- 5) Quality assurance: To ensure refrigerant quality, demonstration on the opposite was the first step. A workshop for trainers to demonstrate fake refrigerant and consequences; workshop for stakeholders, customs, bureau of standards, etc. Establishment of testing centers through the provision of tools and equipment including Ultima ID – HVAC Refrigerant Identifiers.

- 6) Quality assurance awareness: The project raised awareness on counterfeit refrigerants taking into account mislabelling, consequences of using fake refrigerants, potential safety risks and dangers including tips for indentifying fake refrigerants. Brochurs were developed and distributed to the technicians and other stakeholders.

## Recommendations

- 16) The counterfake refrigerant are not only present in countries included in this Demo Project. UNIDO staff member has surveyed the situation and found the same cases in many countries. In general the same situation, lack of awareness, cheap prices offered, gaps in customs and legislation. The subject should be included in the HPMP and Enabling Activities since the consequences – more refrigerant leaking, more consumption, extra energy, etc – were demonstrated.
- 17) This issue needs to be tackled because refrigerant being phase out from some countries, ends in other countries under the label ‘new’. This became excellent business, just collecting recovered refrigerant, bottling and deliver. In some cases, the blends tested shows the right composition but not percentages, blends recovered and repacked in original cylinders.
- 18) It is required to establish testing centres, work in standards and public awareness. The counterfake refrigerant will likely be vented and more refrigerant consumed since, due to lack of awareness, the technicians blame the equipment.
- 19) It is important also to work with the importers and create awareness, it is clear that some of them are not aware of fake refrigerants.

## I. Context and background

### **Context**

Refrigerant supply is growing in line with the demand due to the increasing number of comfort, industrial and commercial equipment. However, low quality refrigerants of various sources and origins are finding their ways to the domestic market. This negatively affects not only the whole refrigerant market, but it also has become one of the major concerns and a serious obstacle to the development of the refrigeration-servicing sector. Contaminated, mixed or recovered refrigerants can lead to decreased cooling capacity and energy efficiency, reduced lifetime, increased servicing needs, they can damage the compressor of the equipment and end up being vented to the atmosphere.

All of the target countries are Low-Volume Consuming Article 5 countries, where the refrigerant market is small with loose standards, so low-quality substances can easily and quickly spread. Moreover, since the countries of the region have strong economic and commercial connections, refrigerants can easily cross borders. It is particularly true for Kenya, Tanzania and Uganda.

The predominant HCFC consumed in the region is HCFC-22 which is solely used in the refrigeration and air-conditioning servicing sector. The complex issue of low-quality refrigerants (contaminated, recovered, mixed) should be addressed in the first place in order to enhance the technical level of the servicing sector. For this, it is necessary to use policy instruments, monitoring mechanisms and raising awareness of dealers, technicians and end-users.

The root of the problem is that the purity of virgin refrigerant is questioned neither by the importers nor by the end-users. Most technicians assume that the refrigerant in the cylinder is "good enough" until the RAC system develops failures or cooling problems. Furthermore, even if a technician suspects the refrigerant is somehow contaminated, there is no proper mechanism/strategy to detect or avoid low-quality refrigerants.

The present proposal fits into the concept of the ongoing HPMPs: it would benefit from the established network of stakeholders and the experience gained so far. At the same time, it would give new impetus to improve efficiency and impact of the HPMP by extending its scope of activities and widening the group of stakeholders.

It should be noted that the project has an enormous relevance not only for the phase out of HCFCs but also for the phase down of HFCs. It is clear that counterfake refrigerant are available for all kind of refrigerants, including hydrocarbons. The presence of counterfake in article V countries is directly linked with the increase of consumption due to failure in the refrigeration systems and consequent recharge.

The lack of awareness at all levels, - service technicians, importers, trainers, custom officers – standards, policies and testing options are increasing the potential for more availability of fake. As mentioned before, fake refrigerant includes also 'refrigerant phased out' in other countries, recovered and mixed or expanded. In all cases, the refrigerant will end vented generating more ozone depletion, global warming and consumption.

### **Background**

The quality of refrigerants available on the market in many developing countries is of major concern in relation to the development of the refrigeration servicing sector and the proper adoption of best practices. The main problems and challenges identified are mixed refrigerants on the market, fake refrigerants, i.e. substances sold as refrigerant but not in conformity with the requirements and specification related to any classified standard refrigerant, improper drop-ins i.e. some refrigerants sold as drop-ins but incapable of fulfilling the technical requirements and performing the task required, and incorrect labelling i.e. by mistake or on purpose. These discrepancies are driven by economic interests, deficiencies of the regulatory framework, insufficient and inefficient control mechanisms, and lack of technical knowledge.

The objective of the project was to demonstrate: i) the availability of fake refrigerant; ii) the lack of awareness of stakeholders; iii) gaps in customs and legislation; and iv) propose ways to ensure refrigerant quality in the domestic market in Eritrea, Kenya, Uganda, Tanzania and Zambia.

For this purpose, the project began with surveys of refrigerant available in project countries. It was clear that the counterfeit refrigerants are available in different forms. It was also clear that stakeholders were not aware of the fact.

Among other activities: surveys on quality of refrigerant; train-the-trainer workshop; training for customs officers, environmental inspectors, importers, etc; establishing testing centres; gap analysis; and awareness raising.

All the activities were completed, but more public awareness and workshops for stakeholders were missing and should be carried out in line with other projects activities.

### **Approval and cancellation**

The project was approved for ‘Demonstration project on refrigerant quality, containment and introduction of low-global warming potential alternatives (Eastern Africa and Caribbean regions)’. Despite that, the two components are related to refrigeration service and HPMP the implementation activities were split due to regional execution and different activities and therefore the funds were also divided internally in UNIDO.

The project “Demonstration project on refrigerant quality, containment and introduction of low-global warming potential alternatives (Eastern Africa and Caribbean regions)” was submitted jointly by UNIDO, as lead agency, and UNEP on behalf of the Governments of Eritrea, Kenya, Uganda, Tanzania and Zambia. It was approved at the 76<sup>th</sup> Meeting of the ExCom of the Multilateral Fund in May 2016 (UNEP/OzL.Pro/ExCom/76/66, Decision 76/36).

UNIDO’s component (GLO/REF/76/DEM/336) was approved at USD 369,150 including PSC. From this amount, US\$ 110,415 were destined for ‘Demonstration project on refrigerant quality, containment’ to be implemented in Eastern Africa region. UNEP’s component (GLO/REF/76/DEM/334) was approved at USD 56,500 including PSC. Since UNEP was not able to implement their component of the project, this was cancelled and funds returned at 82<sup>nd</sup> ExCom Meeting held in Montreal in December 2018.

*“UNEP/OzL.Pro/ExCom/82/72*

*115. Concerning the cancellation of the UNEP component of the global demonstration project in the Eastern Africa and Caribbean regions, the representative of the Secretariat said that, despite the best efforts of UNEP, the project had not yet been initiated, although the part being implemented by UNIDO was in its final stages. After consultations with UNEP, the*



*recommendation to the Committee was to cancel the part of the project being implemented by UNEP.*

*(c) Regarding the global demonstration project on refrigerant quality, containment and introduction of low-GWP refrigerants in the Eastern Africa and Caribbean regions implemented by UNEP and UNIDO:*

*(i) To cancel the component implemented by UNEP (GLO/REF/76/DEM/334), and to note that US \$50,000, plus agency support costs of US \$6,500 for UNEP had already been returned at the 82nd meeting;*

*(ii) To extend to 31 July 2019 the project completion date for the component implemented by UNIDO (GLO/REF/76/DEM/333), on the understanding that no further extension would be requested, and to request UNIDO to submit the final report no later than the 84th meeting;”*

### **Project components and implementation strategy**

The demonstration project on refrigerant quality, containment and introduction of low-global warming potential alternatives was divided into three components:

**Component 1:** Policy review including detailed assessment of the current national policy frameworks. Certifying the presence of fake, mixed and/or recovered refrigerants. Detailed gap analysis on control mechanisms at the local and regional level and provision of technical advice.

**Component 2:** Technical assistance through provision of tools and equipment. Training of stakeholders on the importance of refrigerant quality and establishing testing centres to provide free service of identification to ensure quality and providing information on potential fake based on labelling.

**Component 3:** Awareness raising among stakeholders regarding the importance of refrigerant quality, related costs of using fake (operational, energy consumption, redo jobs, etc) and its relationship with the efficiency of equipment.

### **Strategy**

The project concept included the following strategy and implementation plan. In the report it can be found that in general the project was well planned, due to different circumstances some activities were replaced.

Due to the nature of the demonstration project and the common characteristics of the target countries, Tanzania was selected as lead pilot country. While most of the activities targeted all beneficiary countries, many of the activities were implemented in the pilot country. This allowed the demonstration and monitoring of the project results at the country level, while ensuring that the experience and lessons learned are shared at a regional level offering the potential for regional replications.

## **II. Project objective**

The objective of the project is to facilitate safer and more efficient operation of equipment in the RAC sector through the improved availability of appropriate quality refrigerants.

The objectives were slightly adapted to the needs of the project during the project implementation it may differ with those planned in the Project Concept.

- Demonstrate that fake refrigerant is widely available in the markets and the lack of awareness on the stakeholders including NOUs, service technicians, importers;
- Increase the awareness among technicians and end-users of the benefits to the RAC performances from the use of high-quality refrigerants;
- Identify the gaps in customs and legislation.
- Establish strategy to reduce the availability of fake refrigerant and provide means to test refrigerant quality;
- Foster the market availability of high-quality refrigerant;

### III. Activities and Achievements

#### **General approach**

The project was planned with Tanzania as main country for the implementation activities due to the geographical location (borders with three countries included in the project), the port in Dar es Salam, the results of HPMP implementation in the country at the time. Based on that, a Tanzanian coordinator, Mr. Japhet Nidja, former Ozone Officer was selected and the project launched.

Having selected the project coordinator the implementation plan was decided and a brief mission to Kenya, Tanzania and Zambia undertaken. For the other two countries in the project, the project manager was informed and coordinated the activities. A copy of the project implementation plan can be found attached in Annex I.

The first activity was visiting the respective National Ozone Units of Kenya, Uganda, Tanzania, and Zambia. The project activities, approach and goals were defined during the visits. In addition, some refrigerant dealers were visited and a first approach for the market situation was obtained. In general, fake refrigerant, based on the packing, labels, codes and names, among others, is widely available. In some cases, they have a different price level. A copy of the mission report can be found attached in the Annex II.

#### **Component 1: Policy incl. actual National Policy Frameworks and Gap Analysis**

The project implementing activities includes the three components, the report will be focussed on the activities related to each component rather than chronological or logical order.

#### **Context**

This component was focused on the non-investment component. The planned activities were achieved with some changes but the results are considered satisfactory. The following paragraphs include the activities, the results and reports can be found in the annexes.

#### **Activities**

1. Assessments of the actual situation of the refrigerant supply chain including the quality of refrigerants available on the domestic market. Assessments of national policy frameworks were carried out for Kenya, Uganda, Tanzania, and Zambia.

2. National experts were hired in each country and survey assessments of the actual situation of the refrigerant supply chain, including the quality of refrigerants available on the domestic market were carried out. All reports were received and information shared with respective NOUs. The activity was coordinated by Mr. Japhet Kanizius, project coordinator and the report is attached as Annex III. The annex also includes a special report and country program from Kenya.

3. Samples of R-22, R-134a were randomly picked from refrigerant selling shops and tested for their qualities using refrigerant identifiers. Consequently, a general impression of the quality reliability of the supplied refrigerants in the local market was obtained. The results showed that counterfeit refrigerants are available especially for HCFC-22 and HFC-134a. Detailed information on the standards and market availability of quality refrigerants is included in the mentioned report Annex III.

4. For the gap analysis, it was planned to contract Tanzanian Bureau of Standards - TBS. Some visits were paid to Ms. Agnes NJAU and the aim of the project agreed. UNIDO requested the services through the Terms of Reference, copy attached in Annex IV. The offer was received by UNIDO with budget beyond the available funding.

5. At the time of negotiation, UNIDO found out that UNEP was cancelling their participation in the project and decided to cancel the proposal. Since the gap analysis was a pillar for the project implementation, it was decided to contract national experts in Kenya and Uganda. The most relevant and accurate information had been received before from both countries.

6. The activity was carried out by Ms. Selelah OKOTH in Nairobi; Mr. Reuben LANGART in Mombasa and Mr. Paulo ODU in Kampala. A sample of the Terms of Reference for the consultant is attached in Annex IV.

7. The reports from the three experts were received and analysed. So far, the information was only shared with the respective National Ozone Units of the countries under the Demonstration Project. The socialization of the information was a component of the activities to be implemented by the cooperation agency UNEP.

8. The most relevant findings, comments and conclusions are summarized below. Table includes Gap Analysis, after proposed counter measures, conclusion and recommendations applicable to all countries under the demo project and other not only in the region.

### Summary of Gap Analysis

No	Thematic Area	Gap(s) Identified
1	Policy and Legal Framework	<p>The existing policy has inadequate statements relating to the RAC sector. This therefore fails in providing a strong guiding framework towards the growth of the sector</p> <p>The Controlled Substances Regulations has no provisions on use of spectrophotometer analyzer which would be essential in quality assurance</p> <p>The Regulations have no stringent punitive measures upon ODS/RAC gases importers in the event of shipment of fake refrigerants</p> <p>The Regulations have no framework for tracking movement of RAC gases once cleared at the port of entry. This makes it difficult to ascertain the end point for RAC gases declared as on transit.</p>

2	Licensing and Licensing Conditions	While the accessed licenses show that all refrigerants are regulated, the aspect of quality control is not emphasized beyond the provision that only licensed refrigerants are allowed. There is no provision instructing the importer to ensure that certificate of conformance (CoC) is obtained prior to shipment. The use of the licensing system that has no linkage with the upcoming Integrated Customs Management System (ICMS) raises a gap in quality control as some refrigerants may easily pass the border point if due diligence is not undertaken by the Customs officials.
3	Standards	There are no easily accessible standards relating to the quality of refrigerants.
4	Enforcement	Inadequate presence of <i>environmental inspectors</i> at the border points.
5	Interagency coordination	No clearly documented framework is in place regarding working relationship among the various stakeholders more specifically the regulators in the RAC sector

### **Proposed counter measures to prevent counterfeit/contaminated refrigerants from entry to local market**

The counter measures that can be put in place include:

- i. Encouraging collaboration between all the stakeholders involved thus; Anti-Counterfeit Agency, Customs, Bureau of Standards, NOUs and RAC importers Association to come up with the strategy to counter and minimize the influx of the contaminated/ counterfeit refrigerants into the local market.
- ii. Encourage all importers who have not been using the Electronic Single Window Licensing System (or equivalent) to procure their goods through the system for transparency and accountability.
- iii. As for lack of awareness on newly manufactured equipment containing fake / contaminated refrigerant, public awareness creation campaign to be conducted on use of quality refrigerants, on reviewed cylinder general appearance in terms of colour, labels and specifications according to UN numbers including testing of the refrigerants.
- iv. Entry through illegal routes and diversion of transit counterfeits should be controlled by the sharing of intelligence information by all the relevant enforcement authorities by tracking the illegal routes and prosecuting those involved in diversion of goods on transit.
- v. The dishonest importers/traders who request repackaging/refilling of contaminated refrigerants from the exporting countries should be prosecuted upon conviction. This can be done through government to government collaboration/agreement on the enforcement of the policies, standards and laws relating to prevention of contaminated refrigerants getting into the market. Both Governments could arrange meetings for the importers and exporters from the two countries to strategize on how to minimize circulation of the contaminated refrigerants in the local market. This effort will address the loopholes due to refilling /repackaging of contaminated refrigerants from country of origin by dishonest traders, as a result of requests made by importers.
- vi. The NOUs to review their database of compliant RAC Importers from time to time and blacklist those that sneak contaminated refrigerants into the country.

## **Conclusion**

Countries should put strategies in place to prevent or minimize the importation of contaminated /counterfeit refrigerants which include the enforcement of use of the *Electronic Single Window Licensing System* by all validated RAC importers.

However, there is a challenge in enforcement due to the activities of traders who import contaminated refrigerants through illegal entry ports and hence are not easy to prosecute. RAC importers reported that Contaminated / counterfeit refrigerants are popular to some traders because they are cheap, require low investment and guarantee them maximum profits.

During the process of survey, some RAC importers disclosed that some travel abroad to the source of refrigerants and influence them to refill/ repackage the contaminated/counterfeit in genuine popular branded cylinders and import them through either illegal routes/ entry points to avoid paying taxes or comprise by means of negligence/deceit of the control points and legally import.

In order to control this, there should be a Government to Government agreement /policy on standards of the export refrigerants meant for export by enforcing quality. Further this framework should explore convening of regular meetings of all RAC importers and Exporters of the countries concerned. This will call for training of the customs officers, and other inspectors involved in law enforcement. The customs officials should immediately alert the NOUs inspectors on imports of counterfeit refrigerants through illegal ports of entry.

Adequate human capacity and analyser equipment to be available in all entry points for use to test for any contamination of the refrigerants. These efforts require that any illegal entry points must be monitored through collaboration of all the regulatory agencies by deploying more personnel to man them.

To further strengthen compliance and enforcement there is a need to raise awareness among the stakeholders, the RAC Sector, Customs, NOUs, ACA, including the public on the relevant regulatory requirements on quality refrigerants.

A combination of all these efforts of regulatory, capacity building, awareness campaigns will minimize consumption of the contaminated refrigerants because the equipment owners and end users will be aware of the risk that can cause damage to their equipment.

These strategies will eventually reduce demand for these refrigerants in the local market.

## **Recommendations**

This report was prepared by the consultants with the input of the relevant stakeholders through one to one interviews, telephone calls interviews and review of the existing legislation in coming up with the following recommendations:

- i. The National Ozone Office (NOU) should ensure that it is always in touch with refrigerant importers so that trust could be developed, and hence transparency is seen to prevail and sharing of information on how to identify counterfeits refrigerants.
- ii. There is need for continuous capacity building programmes for customs officers and NOUs officers. This should be well mapped out to include new officers based at border points. There is a need to include the Anti-counterfeit agency as currently their role in the RAC sector is not clear.

- iii. NOUs and Customs must strengthen enforcement of refrigerants on transit. One possible solution is to consider a tracking system that must be endorsed by the importer and NOUs as well as Customs upon entry and exit of the refrigerants on transit.
- iv. The inter agency Collaboration between NOU, Standard offices, Customs Department, Ports Authority and other enforcement officials needs to be strengthened in order to eliminate or minimize influx of illegal imports of contaminated/counterfeit refrigerants.
- v. The NOU should ensure that refrigerant identifiers are functional, distributed and regularly provide trainings to customs officers at all entry points to increase efficiency in the identification of counterfeit refrigerants.
- vi. The Anti-Counterfeit Authority should build human capacity through training among all the counterfeit inspectors.
- vii. A harmonized Coding system should be embraced by Customs including use of UN number, chemical formula and ASHRAE number among others.
- viii. ODS regulations should be reviewed to include all refrigerants and ensure that counterfeits refrigerants are not imported.
- ix. The refrigeration and air conditioning sectors importers Association and technicians should be more involved in awareness campaign to minimize counterfeit refrigerants being imported into the local market.
- x. NOU or Environment Authorities must ensure that the refrigerants are specified before endorsing the importing permits. This could be done by creating awareness of possibilities of repackaging of refrigerants, brand identification, labelling and colour codes.
- xi. Provide enforcement officers with the necessary skills and equipment to identify, monitor and control imports of contaminated refrigerants. Incentives/awards to customs officers who manage to seize counterfeit refrigerants should be given incentives by way of rewards for their seriousness in work
- xii. Develop brochures and flyers that should be displayed at all border points that can guide Customs and NOUs on chemical composition of the various refrigerants during analysis.
- xiii. Strengthen the network for RAC technicians that would make it possible to avail information on quality of refrigerants to the regulators since they have direct contact with these refrigerants during servicing and maintenance works.
- xiv.

Please note that the reports were shared with NOUs from Eritrea, Kenya, Uganda, Tanzania and Zambia. Since project funds were reduced and this activity was intended by the Cooperating Agency, UNIDO could only share the reports and advice to find the best way to implement in their own countries.



**Training on refrigerant quality**

## Component 2: Technical assistance through provision of tools and equipment.

This component was focused on the investment component. The results reached mainly the trainers in project countries and, in some cases, refrigeration technicians. The planned activities were achieved with interesting results and an innovative approach. The results are satisfactory for UNIDO and, based on received comments, for the involved NOUs. The following paragraphs include the activities, the results and reports can be found in the Annex V.

### **Context**

1. There are two main reasons for the wide availability of counterfeit refrigerants in the market, not only in those countries under the present project. The first is the absence of awareness among stakeholders on the availability of fake refrigerants in the market and, the second, the lack of testing methods for the technicians.

2. Lack of awareness is an asset for *fake refrigerant dealers* and the consequences were demonstrated during project implementing activities. Good refrigeration practices and procedures with the best available tools can be applied, however, the fake refrigerant spoil the efforts. At the end, more refrigerant is released, efficiency is reduced and energy consumption increased, among other potential consequences. Refrigeration technicians, in general, consider that the refrigerant is ‘good enough’ even if they have paid for ‘cheap gases’.

3. In line with the absence of awareness, once the issue is addressed, it is required to deal with the lack of testing facilities or tools. This is a challenge since refrigerant identifiers are expensive and delicate tools and to establish a testing centre is also difficult.

4. Prior to the project approval, a testing centre had been established in Asmara, Eritrea. At the time, one of the main issues in the country was the availability of contaminated refrigerant in the country and lack of testing centre. As HPMP component, the service for testing refrigerant was offered in the National Ozone Unit office. The results at the time were remarkable and fake refrigerant was drastically reduced.

5. Once the testing centre was operating, before purchasing refrigerants the condition of previous testing in some cases was established. Since this is an LVC country and the number of stakeholders is manageable, the refrigerant tested as contaminated was returned to the supplier.

6. As a consequence, after some meetings, the importers in Eritrea decided to request ‘certificate of origin’ and some quality assurance documents for the refrigerant.

### **Activities**

1. The first activity was to provide all countries with Refrigerant Identifiers Ultima id. Pro. The quantity of identifiers were decided based on the size of the country and the needs as per agreement with respective NOUs. The table below was used for the supplier at the delivery time.

Component 2. Table 1. Distribution of refrigerant identifiers.



Country	# of Units	Contact person	Email	Address	Telephone
Eritrea	1	Kibrom WELDEGEBRIEL National Ozone Officer	kibromaw@gmail.com	Ministry of Land, Water & Environment Asmara Eritrea	290.0049525
Kenya	2	<i>To be delivered to UNIDO office in Kenya.</i> Emmanuel KALENZI (UNIDO Representative)	E.Kalenzi@unido.org	P.O. Box 41609 United Nations Avenue Nairobi KENYA	+254 207624369
Tanzania	2	Zainabu KUHANWA National Ozone Officer	zaikuhanwa@yahoo.com	Vice President's Office P.O. Box 5380, Dar-es-Salaam Tanzania	+ 255 222113857
Uganda	1	Margaret AANYU National Ozone Officer	maanyu@nemaug.org	National Environment Management Authority (NEMA), NEMA-House, Kampala. Uganda.	256 (0)414 251064 /5 /8
Zambia	2	Mathias BANDA National Ozone Officer	mbanda@zema.org.zm	Environmental Management Agency, Corner Suez and Church Road, Lusaka 10101, ZAMBIA.	260 211254023 /59

2. Following the success case in Eritrea, it was agreed with all NOUs involved in the project that a testing centre was required. In each country the conditions differ and based on that, centres were created in Training Centres, NOU offices, Refrigeration Technicians Associations or even refrigeration dealers. The testing service was agreed to be provided for free. In some countries like Kenya and Tanzania, two testing centres were established.

3. A workshop for training of trainers and government officials in refrigerant quality was held in Tanzania in February 2017. For this training, 20 participants, in the main trainers from seven countries attended. The participants from non-demo project countries were financed by the respective HPMPs. A list of participants, including the trainers can be found below.

	Name	Country	Comment
1	Kamthunzi Marvin	Malawi	Trainer
2	Peter Kiarie Nyagah	Kenya	
3	Joseph Kibet Rugut	Kenya	
4	Stephen Kanyoni K	Kenya	
5	Raymond Sichembe	Zambia	
6	Kelvin Kwila	Zambia	
7	Stephen Ngoma	Zambia	
8	Paulo Odu	Uganda	Associate trainer
9	Mohammed Kanyike	Uganda	
10	Basile Sebulikoko	Rwanda	
11	Alphonse Dushimimana	Rwanda	
12	Wabi Marcos	Benin	

13	Codjo Dedji	Benin	
14	Robinson Swai	Tanzania	
15	Scholastica Mbena	Tanzania	
16	Daudi Kadinda	Tanzania	
17	Said Mziwanda	Tanzania	
18	Haji Maalim Sinani	Tanzania	Local participant (Kibaha)
19	Victor A. Ngowi	Tanzania	Local participant (Kibaha)
20	Japhet Kanizius	Tanzania	UNIDO national expert

4. The aim of the training was to demonstrate the availability and consequences of contaminated or fake refrigerant in the system. For this purpose, the training started with the concept of good practices, good refrigerant management and introduction of alternatives. A copy of the Agenda and certificate can be found in the annex V.

5. Since the core of the workshop was to demonstrate the consequences of the fake refrigerant, three kinds of refrigerant were used in three HCFC based brand new mini spilt air conditioners of 12,000 BTU. For this First HCFC-22 original from the system, which was tested and approved. The second was charged with R-290 after recovery of HCFC-22 and the third was charged with contaminated HCFC-22 purchased locally, as pure HCFC-22, for the training. *(It should be noted that as a component of the training of trainers, the safety use and introduction of hydrocarbon as refrigerant was also included. The activity included good refrigeration practices, demonstration of HC as refrigerant using HC based equipment and fake refrigerant and its consequences). (It was also cleared that retrofit from HCFC-22 to HC is not recommended, and if the case, it will be under the responsibility of the user).*

6. Based on the refrigerant identifier, the contaminated HCFC-22 contained 80% HCFC-409A (R-22/R-124/R-142b) with (60%/25%/15%) and 10% air and 10% other gases. As it can be seen in the table below, taken from Honeywell refrigerants, the liquid density and boiling point of R-22 and R-409A are quite similar, therefore it can be easily mimetized. It is to be noted that the lubricant type differs, for HCFC-22 mineral oil is recommended and for HCFC-409A Alkylbenzene.

Genetron® Product	ASHRAE Number	Refrigerant Type	Refrigerant Class	Typical Lubricant Used*	Liquid Density (lbs/ft <sup>3</sup> )**		Boiling Point °F
					0 °F	80 °F	
Genetron 11†	11	Single Component	CFC	MO	98.2	91.9	74.7
Genetron 12†	12	Single Component	CFC	MO	90.6	81.5	-21.6
Genetron 13†	13	Single Component	CFC	MO	76.9	49.0	-114.7
Genetron 22	22	Single Component	HCFC	MO	83.6	73.9	-41.5
Genetron 23	23	Single Component	HFC	POE	72.0	–	-115.6
Genetron 123	123	Single Component	HCFC	AB	97.9	91.1	82.1
Genetron 134a	134a	Single Component	HFC	POE	84.4	74.9	-14.9
Genetron 422D	422D	Blend	HFC	MO	82.2	70.9	-45.7
Genetron MP39	401A	Blend	HCFC	AB	82.8	73.9	-27.3
Genetron MP66	401B	Blend	HCFC	AB	82.8	73.8	-30.2
Genetron HP80	402A	Blend	HCFC	AB	82.7	71.0	-56.1
Genetron HP81	402B	Blend	HCFC	AB	82.1	71.3	-52.6
Genetron 404A	404A	Blend	HFC	POE	75.8	64.7	-51.2
Genetron 407C	407C	Blend	HFC	POE	81.0	70.6	-46.5
Genetron LT	407F	Blend	HFC	POE	79.9	69.2	-50.9
Genetron 409A	409A	Blend	HCFC	AB	84.3	75.4	-30.0
Genetron AZ-20®	410A	Azeotropic Mixture	HFC	POE	77.2	65.6	-60.6
Genetron 500†	500	Azeotrope	CFC	MO	79.6	70.9	-28.5
Genetron 502†	502	Azeotrope	CFC	MO	86.9	75.4	-49.3
Genetron 503†	503	Azeotrope	CFC	MO	73.6	–	-126.0
Genetron AZ-50®	507	Azeotrope	HFC	POE	76.3	64.9	-52.1
Genetron 508B	508B	Azeotrope	HFC/PFC	POE	72.1	–	-125.3

7. The parameters were verified once the units were commissioned and several times, as can be seen in the report for trainers and some experts in the Annex V. After ca. 2 hours working, the conditions of the first and second units were stable as expected. The performance with HC-290 can be stated as little better and in this case was just to demonstrate how to operate this kind of refrigerant.

8. The third unit was consuming ca. 35% more energy based on the design, the efficiency of the system drop ca. 30%. Most importantly, the compressor became so hot that it was decided to stop the system and recover the refrigerant. After the procedure, the system was cleaned without using HCFC-141b, in this case with high efficient filters.

9. From the report of the main trainer, Mr. Marvin Kamthunzi, the conclusions and some technical comments were extracted for the present report:

**Practical session:** *Practical covered three days of the workshop interspaced with theory presentations. There were 3 new min-split units designed for use with R22. The participants were then divided in 3 groups.*

- *Group 1: install and operate pure R22*
- *Group 2: use unknown and assumed R22 (fake)*
- *Group 3: replace R22 with R290 (refrigerant grade)*

*Refrigerant charging:*

- *Unit design and pre-charged R22 – 583 gm;*
- *Fake refrigerant unit – as R22 – 583 gm;*
- *Unit for R290 (42% of R22 charge) 203 gm.*

*Outcome: After several readings of various parameters, results were as follow:*

- *Unit charged with fake refrigerant depicted highest temperature (82°C)*
- *R22 unit registered 62°C*
- *R290 unit had discharge temp of only 41°C*

*It was also observed that:*

- *R290 unit had lowest evaporator off coil temp of 14.3°C followed by R22 unit at 15°C and fake at 18°C.*
- *Overall power consumption was lowest for R290 unit at 974 watts followed by R22 at 1339 watts and fake at 1935 watts.*
- *The capacity (output) of the units was 12000 Btu/hr. this shows that on Energy Efficiency Ratio:*

*R22 gives 8.96, Fake gives 6.20 while R290 is at 12.32 BTU per H per watt input. The fake refrigerant was later identified to contain about 80% R409A, 10% air and 10% some unknown trace gases. Air in a system is considered a contaminant and results in high compressor head pressure resulting in high power consumption. Running for a long time on this refrigerant would eventually damage the system. Besides, R409A is HFC and could not work with mineral oil (lubricant) that is used in HCFC systems like the one with R22.*

### Conclusion

*At the end of the 'Train-the-Trainer workshop (4 days for technicians and 2 days for non-technical (back to back)) the participants assured UNIDO, Demo Project coordinator that they would use the knowledge gained and would also share with those they work with in order to positively and effectively contribute to their respective countries' efforts to phase out HCFCs and promote environmentally friendly technologies including Carbon Dioxide, Hydrocarbons, Ammonia etc.*

*On fake refrigerants, the participants found it very useful and informative as a few countries in the region reported to have experienced unexplained equipment failures that were never thought to have been caused by use of fake and or contaminated refrigerants. In this regard, the Refrigerant Identifier has become an invaluable tool to counter fake refrigerants. There are also a number of falsely labelled refrigerants in order to conceal the real type of chemical contained.*

*Participants further reiterated their desire to build capacity within their respective fields through training so as to keep pace with the changing technologies.*

*The two day Non-technical group also requested training to last at least three days. After using the refrigerant identifier they felt UNIDO should assist Tanzania Bureau of Standards and Customs with similar equipment for use in strategic locations to effectively control fake refrigerants as a means of refrigerant quality control.*

10. In addition, a training for Customs Officers, Border Police, Ministry of Environment staff, Tanzania Bureau of Standards, importers and other relevant staff was held back to back with the training of trainers. The report from Mr. Kamthunzi includes the results of this workshop.

11. The same activity, training of trainers including test of fake refrigerants was carried out in Eritrea in June 2019. The results do not differ much from those from the demonstration in Tanzania. The report from the trainer, Mr. Kamthunzi, is attached in the annex V. Some comments and conclusion extracted from the report are below:

*Practical session: Practical was for one day of the workshop period in each location interspaced with theory presentations. There were 2 new min-split units designed for use with R22. The participants were then divided in 2 groups.*

- *Group 1: install and operate pure R22*
- *Group 2: install and operate with unknown and assumed R22 (fake)*

#### *Refrigerant charging:*

- *Unit design and pre-charged R22 – 910 gm;*
- *Fake refrigerant unit – (as R22) – 910 gm;*

#### *Comments:*

- *Unit charged with fake refrigerant depicted highest compressor temperature (109 and 95°C)*
- *R22 unit registered compressor temperature of 84 to 92°C*
- *R22 split unit was run for a longer period than the one with assumed fake. This was due to the fact that group 2 had to recover original refrigerant, weigh and recharge with different refrigerant.*
- *The assumed contaminated/fake refrigerant was actually mixture of R22, R134a and 409a (50%, 45%, and 5%) since the available cylinders had pure refrigerant composition, though contaminated/fake refrigerants are available in certain places in the country.*
- *HFC 134a, 409a are not compatible with mineral oil used with HCFC 22. This may explain the rise in compressor casing temperature. Running this system for longer period, say full day, would have resulted in oil degradation and compressor failure.*
- *R 134a, though not suitable as retrofit alternative to R 22, is a low pressure refrigerant and therefore the other recorded parameters cannot be used for comparison. Fake refrigerant would have showed the high pressures and temperatures associated with characteristics and therefore corresponding higher energy consumption.*
- *Availability of suitable alternative to R22, for example R 290 would have shown favourable (lower) pressures/temperatures and therefore lower energy use.*

#### *Conclusion*

*At the end of workshop in both Asmara and Massawa, Stakeholders and technicians, the participants assured NOU that they would use the knowledge gained and would also share with those they work with in order to positively and effectively contribute to efforts to phase out HCFCs and where available and cost effective, promote environmentally friendly technologies including Carbon Dioxide, Hydrocarbons, Ammonia and other L-GWP alternatives.*

*On fake refrigerants, the participants found it very useful and informative. Some reported unexplained equipment failures that could not have been linked to use of fake and or contaminated refrigerants. The pamphlet provided by UNIDO, **'REFRIGERANT CAN BE COUNTERFEIT!'** came at the right time as well.*

*In this regard, the Refrigerant Identifier has become an invaluable tool to counter fake refrigerants. There are also a number of falsely labelled refrigerants in order to conceal the real type of chemical contained. However, for Eritrea, they only have two working units and therefore more would be required.*

#### *Follow up action*

*For continuation of the training objectives the NOU should ensure that trainers have access to equipment and specialized tools, so as to provide meaningful and effective training in a professional manner. It is encouraging though, to UNIDO to note, that those trained last year,*

*have been able to conduct training workshops, to train others, at least twice locally to date already.*

*Measures are to be taken for effective public awareness involving government agencies, importers, end users and technicians on influx of counterfeits. It is through government involvement that suitable registration and regulations can be enacted and implemented in order for those with lawful authority to enforce compliance.*

Some of the participants deliver reports with lessons learned and recommendation. The following summarized of some of the reports:

*Peter Nyagah - Kenya*

*I wish to express my appreciation for the chance to take part in the regional training in Tanzania starting on the 20-2-2017 to 24 -2-2017. The training was very helpful. We learnt several things such as:-*

- how to detect fake refrigerants*
  - measuring performance parameters using pure and fake refrigerants*
  - how to use the refrigerant analyzer*
- exchange of experiences from various countries.*

*I look forward to participating in more of such trainings in the future*

*Too I would request that one of those analyzers be stationed at NITA Mombasa because it is more strategic and has the most interaction with the refrigeration industry.*

*Regards*

*Mr. Rugut – Kenya*

- 1. The demonstration through practical means for the use of fake/wrong type of refrigerant in a designated system affect the sector adversely.*
- 2. Awareness of the presence of impure gases in the market.*
- 3. We need to pass this knowledge as fast as possible.*
- 4. Availability of testing and proving equipment is paramount.*
- 5. A follow up in how to place control systems especially views from the RAC techs is the way to speed this up.*

#### **RECOMMENDATION**

*I take this opportunity firstly to give my sincere thanks to Vice President's Office and UNIDO for my nomination to attend this workshop; I have acquired new knowledge and skills towards my career. It is therefore, this workshop has prepared me to share acquired knowledge, skills and experience with my fellow RAC Technicians and Artisans.*

*Secondly, the workshop duration was not enough for the participants to cover the materials given; therefore, I am laying a special request that the preparations of this kind of workshop(s) should consider the adequate time to meet the planned contents.*

*Prepared By: Said Mziwanda, Tanzania*

#### **RECOMMENDATIONS**

*To be in a good position the authority concerned should be provided:*

- standby generator before*
- adequate time of training which is relevant with the materials provided*


- adequate tools and equipment for recovery, recycling, reclamation, and refrigerant handling containment etc
- several workshops be completed within a short time

#### IMPLEMENTATION PLAN IN MY DAILY WORK

The phase-out of unwanted refrigerant like R22 and introduces (in the market) new refrigerant, like R290, is a global strategies and the aim is to protect the ozone layer. The following is the implementation plan which I thought will work

- to inform or educate the Centre Management to be aware of the refrigerant quality
- to prepare / purchase new refrigerants
- to involve other staff and trainees concerning protection of ozone layer
- to prepare schedule of removing unwanted refrigerant and charging new refrigerant

Mr. Kadinda, Tanzania



'Dupont' Suva and R-134A

## Component 3: Awareness Raising including Information Dissemination


This component was planned to be implemented by the Cooperating Agency. Unfortunately, it was not possible to carry out the activities and UNIDO took over and redistribute the funds and activities to complete the project in the best possible way.

### Context

The awareness and information dissemination is as relevant as the previous components. One of the main conclusions of the present report is the need of public awareness for the stakeholders. A second important final step is sharing information with not only the National Ozone Units but other institutions and policy makers. The report includes only the activities undertaken by UNIDO which unfortunately could not fulfil the plan.

### Activities

1. The main activity carried out for public awareness was the design and print a brochure with information related to Counterfeit Refrigerants. The design was shared with some of the Ozone Officers, trainers and stakeholders involved in Demo Project and other.
2. Below the English version of the brochure, a Spanish version was also completed. In the Annex VI copies of the brochures can be find.



3. Copies were delivered to the respective NOUs Eritrea, Kenia, Tanzania, Uganda and Zambia for distribution. More than 200 copies and file to be reprinted if required were sent. Each country has the right to distribute the brochures as per they own criteria.



4. The complementary activities related to this component are included in the report of trainings held in Tanzania and Eritrea. Unfortunately, this component could not be completed.



**Replace for R-134a and R-600**

#### IV. Financial report

The demonstration project was approved at a funding level of USD 369,150 including PSC for UNIDO and USD 56,500 plus PSC for UNEP – in total USD 425,650.

The project “Demonstration project on refrigerant quality, containment and introduction of low-global warming potential alternatives (Eastern Africa and Caribbean regions)” was approved as Global including two regions. Based on that, the funds received by UNIDO were divided as follows:

1. Demonstration project on refrigerant quality and containment - Eastern Africa region. US\$ 110,415
2. Demonstration project on introduction of low-global warming potential alternatives Caribbean region US\$ 134,585

The present report includes only information related to the first component related

Upon project completion, the estimated project expenditures are USD <110,181> related to UNIDO’s component, it is to be noted that UNEP’s component was returned with balance of expenditures equal zero USD <0>. Thus, the overall cost estimate of the project is USD <110,181>. Any balances will be returned to the Multilateral Fund after financial completion.

At the time of presenting this report almost 100% of the funds approved for UNIDO - East Africa component have been committed and spent and 98% delivered. The table below shows the budget and actual expenses.

Activity	Planned Expenditures (US \$)	Actual Expenditures	Disbursement	Funds available
		As of Sep 2019 (US \$)	As of Sep 2019 (US \$)	As of Sep 2019 (US\$)

a. International experts	12,000	12,289	12,289	-289
b. Project management	5,000	2,031	2,031	2,969
c. National experts	25,000	24,886	24,620	114
c. Workshops	30,000	30,947	28,919	-947
d. Equipment	35,000	37,633	37,633	-2,633
e. Subcontract public awareness	3,000	2,395	2,395	605
f. Contingencies	415			415
<b>TOTAL</b>	<b>110,415</b>	<b>110,181</b>	<b>107,888</b>	<b>234</b>

The funds spent in equipment were used to purchase the refrigerant identifiers and room air conditioners used for the workshops as indicated in component 2 of the present report. A total of 8 identifiers Ultima Id Pro were purchased and delivered as per table 1 in Component 2. It also includes 5 mini-split units of 12,000 BTU, fake refrigerant and other materials and tools purchased for workshops.

## V. Conclusions and recommendations

This paragraph does not include the conclusions already inserted above from the national and international experts. The present conclusions are from the project findings and implementation activities.

### Conclusions

1. The first conclusion is that lack of knowledge from all stakeholders, even Implementing Agencies, on the fact that Counterfake or contaminated refrigerant is widely available in the market. It cannot be stated that 'all over the world' but it is more and more available.
2. Nowadays, the web commercial pages increased the availability of this kind of refrigerant. It is possible to find and purchase many kind of refrigerants at different prices without any restriction.
3. The project was implemented in direct cooperation with the experts in the countries, the involvement of NOU and local technicians was the main factor for the success. In cooperation with the project manager, many local refrigeration dealers were visited and different kind of refrigerants with misleading labeling and packing were found.
4. The demonstration carried out during workshops was one of the most important activities. With this, the technicians understood the consequences they can expect using the counterfake refrigerant. It was clear that the good refrigeration practices and proper use of tools are useless if the refrigerant has not standard quality.
5. Among the consequences of fake refrigerant can be listed the following:
  - a) More energy consumption, indirect CO<sub>2</sub> emissions.
  - b) Damage of components, compressor burnout, equipment to be cleaned.
  - c) Reduce of equipment life span.
  - d) Lost of efficiency in the system.
  - e) Can be flammable or toxic.

- f) Cannot be recycled or reclaimed.
- g) Potential increase in refrigerant consumption due to recharge.
- h) Potential increase of leaks, if higher pressure refrigerant charged.
- i) Unreliable, the job may have to be repeated. Loss of credibility for the technicians.
- j) Counterfake refrigerant will end vented releasing ODS and GWP gases.

6. The counterfake refrigerant are widely available among other due to the following reasons.

- a) It is a profitable business.
  - In some cases it is matter just of bottling recovered refrigerant. This include all kind of pure of blend refrigerants that can be contaminated by particles, other gases, acidity etc. or unbalanced blends.
  - It is also possible to expand pure refrigerants with no-standard gases like R-40.
  - Just recovered phase-out gases bottled and reselled.
  - More and more examples can be found in the market.
- b) Difficult to track and prosecute.
  - As per the results of surveys included in the present report. In some cases, customs allow refrigerants which are not banned. For customs, the quality is not a requirement.
  - Refrigerant are not entering the countries through the regular ways.
  - Refrigerant are not properly declared in customs
  - No country of origin, no proper import licences.
  - More and more examples
- c) Lack of awareness
  - This can be the most important conclusion. In general, the concept is that there is only one quality, even if refrigerant of the same denomination is available at quite different prices in the same market.
  - Even importers, seems to be, are not aware on the refrigerant quality.
  - Stakeholders are unaware of quality and consequences.
  - Good refrigeration practices and, in general, training does not include the refrigerant quality as subject.
- d) Attractive due to low price
  - Price drive market.
  - It is repacked in some countries and distributed in low quantities
- e) Difficult and expensive to verify authenticity
  - One of the first activities implemented in the project.
  - Refrigerant identifiers should be also provided to training centres

7. The refrigerant identifiers are very expensive but delicate tools. So many units have been distributed all over the article 5 countries and are damaged. The refrigerant identifiers are designed to be used for gas and includes a device to be used for liquid. One of the issues is that if counterfake refrigerant is being tested, the identifier can be used with liquid refrigerant and the consequences are well known after some uses. It is recommended to emphasize the uses to use always the identifier with the liquid testing device and also with the small 'capillary valve' included and seldom used.

8. As per the brochure prepared by UNIDO, there are some tips on how to identify counterfake refrigerants:

- a) Lower or upper case: E.g. R-134a is different to R-134A or R-141b to R-141B, and R-410A to R-410a, inclusive R-600 is not R-600a and R-600A does not exist.
- b) Small letter is used for single refrigerant to indicate change in chemical composition. R-134 is different than R-134a.


- c) Capital letter is use to indicate the composition of the blend R-410A, R-508B or R-401C. Eg. R-409A (60% R-22/25% R-124/15%R-142b) and R-409B (65% R-22/25% R-124/10%R-142b)
  - d) Brand names: Dupont can be found in some cylinders and it is DuPont. Genatron is used instead of Genetron.
  - e) General appearance of the cylinders: Some cylinders or cans are scrapped, repainted, soiled or damaged. Some are out of dimension or even renamed.
  - f) AHRI colour code: The colour code is a good guidance, sometimes same refrigerant is available in cylinders of two different colours.
  - g) Misleading advertising: from R-600a or R-290 non-flammable to ‘replace for’ can be found in the market.
  - h) The brochure include some tips on how to recognize genuine refrigerants. It is to be noted that not all should be included, but it can be used as guidance. Some tips are: manufacturers name; trade name; ASHRAE refrigerant number; chemical name; UN number; CS number; country of origin; net weight.
9. The lack of knowledge on the refrigerant quality is also found in the custom officers. In general, the training is focused in the substances and licensing systems but the general aspects of the packing and labeling is not included.
10. The best way to stop the counterfeit refrigerants is through the training of technicians and public awareness. The brochure also includes some tips on this issue: - Check the packing or cylinder based on described; if possible, test the refrigerant; report counterfeit refrigerant to enforcement agencies, refrigeration service technicians association, relevant authorities; do not accept counterfeit (it is for your own safety); no demand, no offer; public awareness, spread the word; low enforcement, policy and standards.
11. Project manager have found counterfake refrigerant in many countries beyond those included in the present demonstration project. Even, in some countries, the refrigerant available in the training centres was first externally verified and then tested, the results showed that there is clear relation between packing and containment. In many cases contaminated refrigerant was found and good examples to teach on ways to identify potential fake refrigerants based on the label.
12. Conclusion of the project implementation:
- a) Due to geographical distribution, the project was indirectly implemented in two parts. The main was for the neighbor countries Kenia, Uganda, Tanzania and Zambia and the second for Eritrea. In both cases the same activities were implemented and the results are summarized in the present report.
  - b) The support received from the National Ozone Units from Kenia and Uganda was very valuable for the project implementation.
  - c) The lack of funds for public awareness and information dissemination jeopardize the project implementation plan. Since the activities from UNIDO side were well advanced, the project was redirected and completed in the best possible way.

## Recommendations

The recommendations given are intended to be applicable and not a wish list which would require big investment and impossible activities.

1. In the training activities for trainers and technicians, is should be included the subject of fake refrigerants. The basic tips for identification, the testing options with or without identifiers and the demonstration with refrigeration units, hopefully new refrigerant identifiers should be included.

2. Wherever possible, a testing centre should be established. It should provide the service for free and have statistic information on counterfake refrigerant available in the country. At least one testing centre should be located in the main city and second in a port city if the case. Training centre is a good option, however, every country can find the best venue for this purpose.
3. Public awareness at all levels is the most important tool to combat the counterfake refrigerants. Since so many environmental treats are included in the fact that counterfake refrigerant is entering the markets, it is a good opportunity to join national public awareness campaigns to protect the environment.
4. It is required to include the basic information and provide brochures, like the one designed by UNIDO, to the custom officers. It will be necessary to include the requirements in the check lists.
5. The brochures were design in English and Spanish language. Some copies have been delivered to countries were UNIDO is implementing projects. It can be distributed in other countries or at least copied and adapted to the local requirements.
6. It is time to work on standards for refrigeration, as already included in the Enabling Activities for the Kigali Amendment. The standard should not be only for HFC but for all kind of refrigerant, labeling and packing.



**Composition for R-22 and R-134A and R-134a**

**Final Report**

**Demonstration project on refrigerant quality, containment and introduction of low-global warming potential alternatives (Eastern Africa and Caribbean regions)**

**Annex I. Agreed Work Plan for the project implementation.**



Tanzania\_Workplan  
\_UNIDO Assignment

**Annex II. Report of joint mission Project Manager and Project leader.**



Mission report  
Zam-Kan-Tan JN Sep

**Annex III. Reports of:**

**Standards and Market Availability of Quality Refrigerants in Tanzania, Kenya, Uganda**



Tanzania\_UNIDO  
Assignment\_DEMO I

**and Zambia)**



Standards and  
Market Availability o

**Standards and market availability of Quality Refrigerants in Kenya**



Country program  
Kenya Oct 16 -.docx

**Country program Kenya**

**Annex IV. Reports on gap analysis**

**Reports on gap analysis**



UNIDO FINAL  
SURVEYREPORT.doc



ODU's Survey June  
19.docx



Refrigerant  
Survey\_Gap Analysis



REFRIGERANTS  
SURVEY IN NAIROBI

## Annex V. UNIDO Brochures

### Refrigerant can be Counterfeit! English version



Brochure\_Gas\_En.pdf

### !Los refrigerantes también los falsifican! Spanish version



Brochure\_Gas\_Sp.pdf

Annex V

## **Final Report on the Project**

**Decision 76/35 of THE EXECUTIVE COMMITTEE OF THE  
MULTILATERAL FUND FOR THE IMPLEMENTATION OF THE MONTREAL PROTOCOL**

# **Development of Regional center of excellence for training and certification and demonstration of low-global warming potential alternative refrigerants in Eastern Europe and Central Asia**

**Submitted by the Russian Federation**

**As of December 2019**



# CONTENT

<b>Introduction</b> .....	3
<b>Objectives of the Project and deliverables</b> .....	3
<b>Financial statement as of 31 December 2019</b> .....	5
<b>Main activities and key outcomes</b> .....	5
<b><u>Description of outcomes</u></b> .....	
OUTCOME 1: Center of Excellence is established and put into operation with fully equipped training and assessment facilities. ....	7
OUTCOME 2: Training and certification programs and technical advisory services of the Regional Center are developed and accredited under Real Alternatives certification system. ....	9
OUTCOME 3: A common draft F-gas regulation harmonized with (EU) No. 517/2014 was developed and published as e-version in Russian and English languages for dissemination among partner countries of the Region ...	10
OUTCOME 4: Demonstration Project showing utilization of low-GWP refrigerants and energy efficient design is in place and accessible for conducting study tours and analysis.....	11
OUTCOME 5: Common curriculum was developed for providing vocational and academic studies covering refrigeration and air-conditioning service practices. ....	14
<b>Gender issues</b> .....	16
<b>PR activities and cooperation with other projects</b> .....	16
<b>Project implementation delays</b> .....	17
<b>Project sustainability evidence</b> .....	18
Development concept .....	18
Governmental support and official partners .....	18
Trainings held in the Regional Center .....	18
Initiation of F-gas certification for participants from the countries of the Region ...	20
<b>Recommendations</b> .....	21

## Introduction

EXECUTIVE COMMITTEE OF THE MULTILATERAL FUND FOR IMPLEMENTATION OF MONTREAL PROTOCOL at its Seventy-sixth Meeting (Montreal, 9-13 May 2016) approved (Decision 76/35) the demonstration project for the Eastern Europe and Central Asia region on development of a Regional center of excellence for training and certification and demonstration of alternative refrigerants with low-global warming potential (hereinafter referred to as Regional Center), with allocation of funds in amount of US \$591,600, plus agency support costs of US \$75,076 (total amount US \$666,676.00).

In line with Decision 72/40 the allocated funds came from the annual contribution of the Government of the Russian Federation to MLF for 2016 (against the MLF invoice in amount of US \$5,290,344.00). The Executive Committee of MLF requested the Government of the Russian Federation to complete the Project within 36 months of its approval (May 2016) and accordingly submit the final report. As a matter of fact the money was wired by MLF to the Implementing agency in July 2017.

According to the Trust Fund agreement between the United Nations Industrial Development Organization (UNIDO) and the Government of the Russian Federation dated 31 August 2017 UNIDO has been implementing the Project in 2017 – 2019.

## Objectives of the Project and deliverables

The overall objective of the project is to improve the technical capacity of the refrigeration and air-conditioning sectors in the countries of the Region (Eastern Europe and Central Asia) and consequently facilitate:

- overcoming the barriers on the way to introduction of low-GWP refrigerants;
- improving service practices used on the national level, and
- reducing the level of F-gas emission from the existing refrigeration and air-conditioning equipment.

As result the trained national technicians and designers will enhance their awareness, understanding and promoting introduction of new approaches to energy efficient design and operation on their national market in domestic, commercial and industrial refrigeration and air-conditioning systems.

This project sets up the training and assessment facilities at the Regional Center for the benefit of the countries of the Region, on the basis of using of curriculum document and certification program for the national level corporate employees performing maintenance, servicing or manufacturing of products and equipment relying on or containing F-gases and/or low-GWP refrigerants in line with the requirements of article 10 of (EU) N° 517/2014, Directive 2006/40/EC; Regulations (EC) N° 303/2008, (EC) N° 306/2008 and Regulation (EC) N° 307/2008. The Regional Center acts also as a demonstration hub and knowledge base for alternative

refrigerant technology especially for safe handling, application and related systems design using low-GWP refrigerants.

The main deliverables of the Project are as follows:

1. Center of Excellence is established and put into operation with fully equipped training and assessment facilities.
2. Training and certification programs and technical advisory services of the Regional Center are developed and accredited under Real Alternatives certification system.
3. A common draft F-gas regulation harmonized with (EU) No. 517/2014 was developed and published as e-version in Russian and English languages for dissemination among partner countries of the Region.
4. Demonstration Project showing utilization of low-GWP refrigerants and energy efficient design is in place and accessible for conducting study tours and analysis.
5. Common curriculum was developed for providing vocational and academic studies covering refrigeration and air-conditioning service practices.

By collocating the practical training and job certification with the development of expertise in design and systems operation, the Regional Center will be able to provide excellent opportunities for private and public organizations to demonstrate new and innovative technology and the latest refrigeration and air-conditioning systems, components, controls and operating practices. The operating model is therefore based on public-private partnerships where mutual benefit can be derived to achieve the common objectives of improving current practices, performance, energy efficiency and climate impact of refrigeration and air-conditioning systems.

## Financial statement as of December 2019

	<b>Component</b>	<b>Funds approved, USD</b>	<b>Disbursement, USD</b>
1	Infrastructure of the Regional Center	128,500	138,697
2	Operation of the Center	39,600	45,347
3	Adaptation and Printing of UNIDO Programmes and Manuals (English and Russian)	51,500	55,500
4	Development of Online Interactive Courses (English and Russian)	58,500	62,500
5	Pilot Refrigeration Plant Based on Natural Refrigerants	214,000	188,261
6	PR Activities	8,500	8,500
7	Internet-portal of the Project (in Russian and English)	28,500	30,295
8	Management, Office	62,500	62,500
<b>Total:</b>		<b>591,600</b>	<b>591,600</b>

## Main activities and key outcomes

<b>Planning Activity (as per initial project document)</b>	<b>Outputs or service delivered</b>	<b>Outcomes observed</b>
<p><u>Deliverable 1:</u></p> <p>Center of Excellence is established and put into operation with fully equipped training and assessment facilities</p>	<ul style="list-style-type: none"> <li>- With support from the Russian Federation the host side (Ministry of Nature Protection of the Republic of Armenia) nominated the beneficiary for location and establishment of the Regional center of excellence;</li> <li>- Bidding procedures implemented to choose the Contractor/ Service Provider;</li> <li>- The instructors of the Regional center of excellence received training in Moscow on stands operation;</li> <li>- Works completed on production,</li> </ul>	<p>Regional center of excellence with training and assessment facilities was put into operation.</p>

<b>Planning Activity (as per initial project document)</b>	<b>Outputs or service delivered</b>	<b>Outcomes observed</b>
	<p>delivery and installation of equipment at the Regional Center of excellence;</p> <ul style="list-style-type: none"> <li>- The launching ceremony was held on September 18, 2019. It was a part of the session of the Interstate Ecological Council of the Commonwealth of Independent States (CIS) which was attended by representatives of Environmental ministries, UNIDO, RAC associations and NOUs representatives, technical experts communities and Lyceum students;</li> <li>- 5 trainings were conducted; a new contract was signed to conduct trainings in the Regional Center for 45 technicians representing the Eastern Europe and Central Asia countries.</li> </ul>	
<p><u>Deliverable 2:</u></p> <p>Training and certification programs and technical advisory services of the Regional Center are developed and accredited under Real Alternatives certification system.</p>	<ul style="list-style-type: none"> <li>- Bidding procedures implemented to choose the Contractor;</li> <li>- Major part of work on developing training programs and technical advisory services were carried out before December 31, 2018;</li> <li>- Website <a href="http://hvacceneter.am/">http://hvacceneter.am/</a> was created for remote online learning;</li> <li>- 5 trainers were certified (F-gas + Real Alternatives);</li> <li>- The Regional Center was accredited under the Real Alternatives certification system.</li> </ul>	<p>Training Center is accredited under the internationally recognized EU certification system of Real Alternatives.</p>
<p><u>Deliverable 3:</u></p> <p>A common draft F-gas regulation harmonized with (EU) № 517/2014 was developed and published as e-version in Russian and English languages for dissemination among partner countries of the Region.</p>	<ul style="list-style-type: none"> <li>- A set of documents on F-gas regulation was translated into Russian (working language in the Regional Center);</li> <li>- Proposal based on F-gas regulation for simplification of certification reasonable for the countries of the Region was developed;</li> <li>- Each country of the Region is expected to consider national regulations harmonization after ratification of the Kigali Amendment.</li> </ul>	<p>A set of useful documents was compiled and then translated into Russian language to facilitate development of national regulation and certification systems in the countries of the Region.</p>
<p><u>Deliverable 4:</u></p> <p>Demonstration Project showing utilization of low-GWP refrigerants and energy efficient design is in place and accessible for conducting study tours and analysis.</p>	<ul style="list-style-type: none"> <li>-</li> <li>- The host side (Ministry of Nature Protection of the Republic of Armenia) defined the beneficiary for development of demonstration project;</li> <li>- UNIDO carried out tender procedures to choose the Contractor/ Service Provider;</li> <li>- Works on production, supply and installation were carried out;</li> <li>- The Regional Center launching</li> </ul>	<p>Implementation of this Demonstration Project resulted in presenting real benefits from using hydrocarbon refrigeration system to enhance safety</p>


Planning Activity (as per initial project document)	Outputs or service delivered	Outcomes observed
	ceremony was held on September 18, 2019; - Demo-project "Hydrocarbon refrigeration system for typical fruits and vegetables storages" is aimed at improvements in the field of safety, energy efficiency (by 34% on the demo-project site). - The information events were held in September 2019 for Armenian HVAC&R representatives and government officials and in December 2019 for technicians from Turkmenistan.	and energy efficiency with aim to spread replication widely.
<u>Deliverable 5:</u>  Common curriculum is developed for providing vocational and academic studies covering refrigeration and air-conditioning service practices.	- Bidding procedures implemented to choose the Contractor/ Service Provider; - All procedures and works under the Contract were completed.	Common curriculum of the Regional Center is developed for providing vocational and academic studies.

## Description of outcomes

### OUTCOME 1: Center of Excellence is established and put into operation with fully equipped training and assessment facilities.

The Ministry of Nature Protection of the Republic of Armenia nominated the International Scientific-Educational Complex of "Shirakatsy Lyceum" for location and functioning of the Regional center of Excellence.

"Shirakatsy Lyceum" was founded in 1990 to reveal gifted children, manage their education and study their gift problems. Since October 2009 the "Shirakatsy Lyceum" has been officially recognized as a regional one, and since 2010, it has been a sound member of the World Association of International Schools «Round Square» (network of 150 innovative schools located in 40 countries on five continents). More than 300 graduates from "Shirakatsy Lyceum" continued their studies at leading world universities such as Harvard, Cambridge, Sorbonne, Oxford, Stanford, Lomonosov, Massachusetts, Tokyo, Beijing, and London universities.



The Regional center of Excellence is equipped with the following training simulators and equipment:

- CO<sub>2</sub>-based refrigeration machine;
- HC-based refrigeration machine (“HC-based refrigeration machine” and “Retrofit to HC refrigerants”);
- Training simulator “Welding and soldering. Supply and exhaust ventilation”;
- Training simulator “Principles of refrigeration machine operation. Azeotropic refrigerants”;
- Training simulator “Principles of refrigeration machine operation. Zeotropic refrigerants”;
- Training simulator “Refrigerants. Types. Identification. Recovery and regeneration”;
- Training simulator “Refrigeration machine. VRF”;
- Training simulator «Refrigeration machine. Chiller & fan coil unit»;
- The furniture and office equipment have been supplied in the following scope: desks for students and a trainer, chairs for students and a trainer, desk for a trainer, lap tops, interactive whiteboard, racks for the back office, safety and warning signs, first-aid kits, consumables and tools;
- Training courses and software installed on the laptops to enable simultaneous training of 15 HVAC system specialists.



Fig. 1 Main class-room equipped with the state-of-the art training simulators

The Regional Center was launched in September 18, 2019. The launching ceremony was a part of the session of the Interstate Ecological Council of the Commonwealth of Independent States (CIS) countries. It was attended by more than 50 participants: ministers and deputy ministers of CIS countries, representatives of UNIDO, HVAC&R associations and companies, technical experts and students.



Fig. 2 Participants of the launching ceremony



Fig. 3 A ribbon-cutting ceremony  
(from left: Erik Grigoryan, Minister of Environment of the Republic of Armenia, and Sergey Yastrebov, Deputy Minister of Natural Resources and Environment of the Russian Federation)

**OUTCOME 2:** Training and certification programs and technical advisory services of the Regional Center are developed and accredited under Real Alternatives certification system.

The Regional Center was accredited under the internationally recognized certification schemes (Real Alternatives) and accessed to the learning programs for technicians working in the refrigeration, air conditioning and heat pump sector, designed to improve skills and knowledge in safety, efficiency, reliability and containment of alternative refrigerants in English and Russian languages.



Fig. 4-6 Training process and handing of certificates



The accreditation scope of supply includes the following:

- learning booklets for individual self-study delivered as pdf downloads;
- e-learning modules that mirror the learning booklets;
- practical training course design;
- assessments and certification for individuals;
- a train the trainer programme and licensing of training providers;
- programme website.

5 trainers were trained and certified under F-gas and Real Alternatives certification systems.

The National Lead agreement was signed. The Regional Center as a National Lead will provide learners with access to the Real Alternatives materials, conduct trainings and assessment exams.

The level of equipment in the Regional Center was highly praised by the Centro Studi Galileo (Italy), which conducted the accreditation assessments with following remarks:

- The HVACR training center is very well equipped with several RAC didactical units (e.g. AC split, unit with f-gases, equipment with CO<sub>2</sub> and with HCs, etc). The technological relevance of the equipment is high. The disposition of the training equipment in the center allows the best task performance. There is also a vast, up-to-date and useful stock of reserve equipment, tools, and consumables.
- The five participants were motivated, very well prepared and highly skilled. They possess a remarkable theoretical knowledge and the motivation to perform the practical tasks; this allowed carrying out the training and assessments smoothly and rapidly. Many questions and comments raised by the participants allowed for a stimulating debate at the end of each session. The younger participants demonstrated a promising attitude and interest for the activity. All participants passed the three assessments with remarkable grades, higher than average.

Additionally, the Regional Center signed a special agreement on cooperation with the related Moscow training Center. So now the Regional Center can provide additional training courses for learners and grant them with safety and skills certificates (such as electrical safety, works at heights, pressure receptacles and soldering skills) valid on the territory of Russia and Eurasian Economic Union states.

**OUTCOME 3:** A common draft F-gas regulation harmonized with (EU) №517/2014 was developed and published as e-version in Russian and English languages for dissemination among partner countries of the Region.

The set of F-gas documents directly related to the training and certification issues were translated into Russian:

- Regulation (EU) N° 517/2014 of the European Parliament and of the Council dated 16 April 2014 on fluorinated greenhouse gases and repealing Regulation (EC) N° 842/2006 Text with EEA relevance;
- Commission Regulation (EC) N° 1516/2007 dated 19 December 2007 establishing, pursuant to Regulation (EC) N° 842/2006 of the European Parliament and of the Council, standard leakage checking requirements for stationary refrigeration, air conditioning and heat pump equipment containing certain fluorinated greenhouse gases (Text with EEA relevance);
- Commission Implementing Regulation (EU) 2015/2067 dated 17 November 2015 establishing, pursuant to Regulation (EU) N° 517/2014 of the European Parliament and of the Council, minimum requirements and the conditions for mutual recognition for the certification of natural persons as regards stationary refrigeration, air conditioning and heat pump equipment, and refrigeration units of refrigerated trucks and trailers, containing fluorinated greenhouse gases and for the certification of companies as regards stationary refrigeration, air conditioning and heat pump equipment, containing fluorinated greenhouse gases (Text with EEA relevance);

These documents were taken into account when certification training courses had been developed and introduced.

The countries of the Region will consider the process of harmonization of national legislation and regulation after their ratification of the Kigali Amendment. The Regional Center is now ready to provide advisory services and technical assistance regarding implementation of needed harmonization of legislation and regulation on a request of any country of the Region. The Interstate Technical Council of National Refrigeration Associations has been established to accelerate this process.

**OUTCOME 4:** Demonstration Project showing utilization of low-GWP refrigerants and energy efficient design is in place and accessible for conducting study tours and analysis.



Demo-project «Hydrocarbon refrigeration system for typical fruits and vegetables storages» was implemented in Province of Kotayk, Armenia. Old-fashioned cooling system using CFC-12 as refrigerant was replaced with secondary refrigeration system using R290 (propane).

Fig. 7 Hydrocarbon refrigeration system installed in Province of Kotayk, Armenia

The new cooling system installation provided benefits in terms of safety, energy efficiency, reduction of life-cycle costs and opportunity for wide spreading replication. Description of benefits considered while conducting study tours are as follows.

**Safety**

Refrigerant charge is 6 kg. Considering the fact that R290 is a highly flammable matter, the following fire safety measures have to be taken:

- all spark-hazardous electrical components are located beyond protecting casing and are installed in a separate control switchboard;
- all components installed in a protecting casing are explosion-proof;
- a protecting case has an internal alarm system with R290 leakage detector, which in case of refrigerant leakage isolates the refrigeration plant;
- new unit is installed outdoor as specified by fire safety requirements.





Fig. 8 Example of safety location of equipment

**Energy efficiency**



High energy efficiency is ensured by lower refrigeration load through enhanced heat insulation, condenser of larger size and automation system maintaining minimum condensing pressure. As result energy efficiency has improved by 34%.

Fig. 9 Comparison of energy efficiency between new and old-fashioned systems

**Reduction of life-cycle costs**

The life-cycle costs include initial (capital) expenditures, cost of electrical energy and repair and maintenance costs. Average operation time before overhaul is taken as 10 years.


Solution	Initial expenditures, USD	Electrical energy		Repair and maintenance cost, USD/y	Total in 10 years, USD
		kWh/y	USD/y		
Old equipment*	0	52 000	9 360	112 000	213 600
R404a central system	105 000	43 545	7 838	3 000	213 381
Proposed solution	125 000	34 525	6 215	500	192 145

\*Cost of operation of old equipment includes overhaul with possible purchase of R12 in future.

Fig. 10 Sample calculations and comparison of life-cycle cost

10 years later the proposed solution will enable to save USD 21,236 as compared to R404a central system and USD 21,445 as compared to the “old-fashioned” equipment.

### Opportunities for wide spreading replication



This demo-project has some technological advantages: factory assembly, easy for installation, parameters are maintained without service personnel, materials are available and maintenance costs are low. Up to 500 new installations per year can be replaced by using this solution in the countries of the Region (Eastern Europe and Central Asia).

Fig. 11 Opportunities for replication of this solution

All visitors of the Regional Center and potentially interested parties in the countries of the Region are invited to undertake site visit and see an example of successfully implemented project showing safety and energy efficiency of the proposed solution on the basis of natural refrigerants.

The system operation parameters are transmitted in real time and recorded for further analysis and studies. Thus, the Demonstration Project serves as a platform for promoting natural refrigerants solutions in the countries of the Region.

**OUTCOME 5:** Common curriculum was developed for providing vocational and academic studies covering refrigeration and air-conditioning service practices.

The common curriculum for vocational and academic studies covering refrigeration and air-conditioning practices is based on use of internationally recognized programs.

## Forms of education




Fig. 12 A scheme used in the Regional Center for development of common curriculum

The forms of education include first e-learning: theory + testing, then coming to Armenia and in-depth study of theory, practice and testing at the Regional Center. The final process of consolidation of knowledge includes undertaking practice on site of demo-project or/and at the training centers of equipment manufacturers and partners facilities.

The Regional Center provides a wide range of training programs for different target audience given in the table below:

Title of program	Forms of education	Target audience	Trainers	Certificate
Real Alternatives learning program	E-learning on <a href="https://www.realalternatives.eu">https://www.realalternatives.eu</a> , theory, practice, assessments and certification for individuals	HVAC&R specialists	Certified Regional Center Trainers	Real Alternatives
F-gas certification course (4 category)	E-learning on <a href="http://hvaccenter.am">hvaccenter.am</a> , theory, practice, assessments	Technicians and other	Certified Regional	European F-gas, if

	and certification for individuals	HVAC&R specialists	Center Trainers + independent assessment procedure	necessary
Use of natural refrigerants in various sectors	E-learning on hvaccenter.am, theory, practice and advisory services	Customers and HVAC&R specialists	Certified Regional Center Trainers, Regional Center partners	Not applicable
Safe use of ammonia refrigeration systems	E-learning on hvaccenter.am, theory, practice at Regional Center and advisory services	Customers and HVAC&R specialists	Certified Regional Center Trainers, Regional Center partners	Not applicable
Safe use of hydrocarbon refrigeration systems	E-learning on hvaccenter.am, theory, practice at Regional Center and demo-project and advisory services	Customers and HVAC&R specialists	Certified Regional Center Trainers, Regional Center partners	Not applicable
Safe use of carbon dioxide (CO <sub>2</sub> ) refrigeration systems	E-learning on hvaccenter.am, theory, practice at Regional Center and demo-project and advisory services	Customers and HVAC&R specialists	Certified Regional Center Trainers, Regional Center partners	Not applicable
Ozone layer protection and climate change legislation	E-learning on hvaccenter.am, theory, practice at Regional Center	Customers, government officials and HVAC&R specialists	Certified Regional Center Trainers, NOU experts	Not applicable
Design and operation of carbon dioxide (CO <sub>2</sub> ) refrigeration systems	Theory and practice at Regional Center	Customers and HVAC&R specialists	Regional Center partners	Not applicable
Danfoss training courses: 1) Refrigeration fundamentals 2) Danfoss compressors 3) Danfoss automation systems 4) Industrial refrigeration 5) Commercial refrigeration	Theory and practice at Regional Center	HVAC&R specialists	Regional Center partners	Danfoss certificates

The training package includes:

- Curriculum of training courses;
- Online training course;
- Training manual;

- Training presentations for theoretical classes of the course;
- Practical training course design;
- Assessments and certification for individuals (where applicable).

## Gender issues

The equal rights of women and men were provided through the whole project cycle.

A key role in the project implementation was played by UNIDO Country Representative and Head of Ozone office, National Ozone Focal Point for Armenia.

The percentage of women-managers in the beneficiary institution has increased to 50% and it is higher than in average in an ordinary organization in Armenia.

The Regional Center ensures equal rights and equal access to its services for women and men. It encourages women's participation in trainings by popularizing women in Trades and Technology together with the Regional Ozone Network for A 5 Countries in the Region of Eastern Europe and Central Asia.

## PR activities and cooperation with other projects

The PR activities of the project included arrangement of special events, participation in relevant meetings and information dissemination.

The Project participants repeatedly discussed issues related to development of the Regional Center of excellence at the meetings of Ozone Officers Network for the region of Eastern Europe, Caucasus and Central Asia and community events held in Moldova, Georgia, Belorussia and Turkey in 2017-2018. The issues related to the Regional center of excellence vision and training programs under development, as well as the unified concept of the regional certification system were under discussion.

Representatives of refrigeration associations and working groups also met in Moscow (more information can be found on website:

[http://www.ozoneprogram.ru/eng/news/refrigeration\\_associations\\_in\\_moscow/](http://www.ozoneprogram.ru/eng/news/refrigeration_associations_in_moscow/)) to discuss among other issues the development of a regional certification structure and certification concept.

The Project participants held numerous meetings with representatives of the Ministry of Nature Protection of the Republic of Armenia, project`s beneficiaries, local stakeholders and Armenian RAC Association.

The Interim Project report was submitted for consideration at a workshop on activities of the Russian Federation in area of International Development held at the Russian Embassy in Yerevan on January 30, 2019.

The launching ceremony was a very important PR-event and organized as a part of the session of the Interstate Ecological Council of the Commonwealth of Independent States (CIS). It was the important event for Armenia, Russia and other CIS countries and was widely covered by mass media including TV and governmental and HVAC association websites, e.g.:

- [http://www.mnr.gov.ru/press/news/v\\_armenii\\_po\\_initsiative\\_i\\_pri\\_finansovoy\\_podde\\_rzhke\\_rf\\_otkrylsya\\_regionalnyy\\_tsentr\\_povysheniya\\_kva/](http://www.mnr.gov.ru/press/news/v_armenii_po_initsiative_i_pri_finansovoy_podde_rzhke_rf_otkrylsya_regionalnyy_tsentr_povysheniya_kva/)
- <http://www.mnp.am/en/post/4185>
- <https://www.youtube.com/watch?t=4s&v=3IE3M1tEfdY&app=desktop>
- [http://www.rshp.ru/index.php?option=com\\_content&view=article&id=673:2019-09-25-04-15-51&catid=62:2009-08-28-05-54-21&Itemid=2](http://www.rshp.ru/index.php?option=com_content&view=article&id=673:2019-09-25-04-15-51&catid=62:2009-08-28-05-54-21&Itemid=2)
- <https://armenpress.am/arm/amp/988505>
- <https://news.am/arm/news/534091.html>
- <https://168.am/2019/09/18/1175278.html>
- <https://enews.am/news/5d821d110a975a6f105e8c84>
- <https://www.tert.am/am/news/2019/09/18/mnp/3096706>
- <https://assets.danfoss.com/documents/DOC320841040091/DOC320841040091.pdf>  
(page 10)

The Regional Center was also presented at Europe and Central Asia (ECA) network meeting held in Kiev on 24-25 September, 2019.

## Project implementation delays

The project was approved in May 2016. The implementation period was expected to be 36 months after the project approval therefore it should have been completed by June 2019. But funds were allocated to the Implementing Agency (UNIDO) in September 2017. So actually financing of the Project activity was commenced with delay of one year. Therefore December 2019 can be considered as early estimated completion of the Project (36 months will expire in September 2020). It means the project is completed faster than planned.

Other factors causing minor delays of the Project commencement and accomplishment are as follows: delays in defining beneficiaries for the Regional Center of Excellence (till 23.04.2018) and in implementation of the Demonstration project (till 18.07.2018) were caused on the host side (Ministry of Nature Protection of the Republic of Armenia), mostly due to replacement of beneficiary for the Demonstration project (till 02.11.2018), resulting in rescheduling of bidding procedures terms and bidding tasks adjustment.

Long-lasting repair works in the premises of the Regional Center were carried out by the beneficiary to prepare the required classrooms and make installation of training stands (all works were completed only in February 2019). These delays were caused mostly due to some political reforms and decision maker replacements in the Republic of Armenia.



## Project sustainability evidence

### Development concept

The Development concept for the Regional Center provides its management with important information on the educational market in the countries of the Region, the promising directions of development of the Regional Center, its partners, training programs, potential customers, pricing, staff and other important issues. The development concept was under discussion as one of key issues with the Regional Center management.

### Governmental support and official partners

The Regional Center is supported by the Ministry of Environment of the Republic of Armenia and the National Ozone Unit of the Republic of Armenia. The Regional Center has five partners and cooperation with them on the basis of signed partnership agreements as follows:

- The Danfoss Group manufactures products and provides services used in cooling food, air conditioning, heating buildings, variable frequency drives, gas compressors and powering mobile machinery.
- NORD is a Russian manufacturer of CO<sub>2</sub> and Hydrocarbons systems.
- Rossoyuzkholodprom is a Russian HVAC association working closely with the Russian government.
- Vercont-service is a Russian HVAC training-center, established with technical assistance of UNIDO. It works successfully without governmental support, that is important for success in exchange of experience.
- IMEI helps the Regional Center to get safety certificates valid on the territory of Russia and other Eurasian Economic Union states.

The Center provides an open platform for potential partners to contribute to operation of the Regional Center in return to fair exposure of their goods and services and testing and demonstration of products and systems. They are also interested in supporting the HVAC sector globally and fostering research activities, including practical application of testing results (environmentally-safe techniques of handling refrigerants), energy-efficiency performance, and many other issues incorporated into certified academic programs.

### Trainings held in the Regional Center

A few trainings have been conducted since the establishment of the Regional Center.

The first training event for trainers started immediately after the launching ceremony. Five trainers were trained and certified under F-gas and Real Alternatives (CO<sub>2</sub>, HC) program.



Fig. 13 Training process



Fig. 14 Training course in class and on site

The second training course was held with the partners of the Center. It was dedicated to its development and the demo-project key features. More than 30 participants, including partners of the Regional Center, HVAC specialists and Regional Center representatives attended the second training event.

The third training event was carried out in October 2019 immediately after the Prom Expo exhibition held in Yerevan, with assistance of Danfoss company (official partner of the Regional Center). A group of 17 participants represented HVAC&R specialists and trainers from Armenian technical colleges and universities.



Fig. 15 Course leavers with certificates handed

The fourth training course was held in November and December 2019 for technicians from Turkmenistan in amount of 15 participants. They received Regional Centre certificates and safety certificates valid on the territory of CIS countries (electrical safety, work at heights, pressure receptacles, soldering).



Fig. 16 A group of course leavers from Turkmenistan with certificates handed

The fifth training course was carried out in December 2019 for Armenian technicians in amount of 15 participants representing Armenian RAC. All of them received Real Alternatives certificates.



Fig. 17 Training process in a classroom

As result of the Regional Centre activity it was contracted in the end of 2019 to conduct training courses in early 2020 for minimum 45 technicians representing the countries of the Region of Eastern Europe and Central Asia.

### Initiation of F-gas certification for participants from the countries of the Region

The Interstate Ecological Council of the Commonwealth of Independent States (CIS) addressed this issue of F-gas certification for the countries of the Region at its session in Yerevan in September 2019. The states of the Region which are not yet a Party of the Kigali amendment to the Montreal Protocol including the Russian Federation will initiate F-gas certification after ratification of the Kigali Amendment.

## Recommendations

- Additional funds to be allocated to continue and develop the Project success and enable the countries of the Region to direct their technicians to the Regional center in Yerevan for certified training

The original Project budget was proposed by the Russian Federation in amount of USD 852,600 excluding 13 % of Agency Support Costs. The budget was expected to cover expenses for both development of the Regional center and further conducting training and certification of expected and considerable number of technicians from the countries of the Region.

The originally proposed budget of the Project was reduced more than by 30 % and the budget approved amounted to USD 591,600 excluding 13% Agency Support Costs. Nevertheless the main tasks of the Project have been performed but substantial reducing of the budget resulted in considerable cutting-down of total number of trained technicians representing the countries of the Region.

Therefore the Russian Federation suggests that some needed additional funds to be allocated to complete the Project component related to enabling the countries of the Region to direct their technicians to the Regional center in Yerevan. The funds can be allocated as Phase 2 of the Project and covered from the Russian Federation contribution to MLF for 2020 paid and wired in full amount of USD 7,782,333.00 in December 2019.

- Customers training is a key target

The refrigeration systems owners and potential customers are real decision-makers on the local markets. They make a final decision what to “buy” and “which system to install”. It is strongly recommended to concentrate efforts on customers training in similar future projects implementation.

- Commencing Project implementation shall be provided by timely allocation of funding in order to avoid any delays

The Project implementation period should be determined from a moment of receiving sufficient funds by Implementing Agency.

- Country situation assessment shall be a subject of proper investigation

There is a need in more proper assessment of the country situation. For example, a lack of vocational schools and universities, qualified specialists, co-financing sources as well as temporary political instability in Armenia at the period of implementation of the Project (obviously this factor cannot be predicted or expected) can result in delays in the schedule of implementation.

---



# **Final Report**

DEMONSTRATION PROJECT FOR THE PHASE-OUT OF HCFCs BY  
USING HFO AS FOAM BLOWING AGENT IN THE SPRAY FOAM  
APPLICATIONS IN HIGH AMBIENT TEMPERATURES  
SAU/REF/76/DEM/27

2020

## Table of contents

1. Objective .....	2
2. Companies selected (background/application).....	3
3. Technologies Considered and selected .....	3
3.1. Alternative technologies considered .....	3
3.2. Commercially Available Options .....	4
3.3. Emerging Options .....	4
3.4. Assessment of criteria for commercially available options .....	5
3.5. Assessment of criteria for Emerging Technology options .....	5
3.6. IOC comparison between major alternatives during demonstration project formulation .....	6
3.7. Selection of alternative technology for the Demonstration project .....	6
4. Modification of production .....	7
5. Technical evaluation .....	8
Table 5-1. Test Results from the first samples in March 2017 .....	8
Table 5-2. Thermal conductivity at 10°C .....	8
Table 5-3. Thermal conductivity at 35°C measured two weeks after production .....	9
Table 5- 4. Physical properties measured after 18 months from applying the foam on the roof. The samples were stored next to the test roof for easier testing purpose .....	10
Table 5-5. Following characteristics were studied due to high ambient temperature .....	11
6. Commercial Evaluation .....	12
Table 6-1 – Commercial Evaluation / IOC.....	12
7. Environmental impact.....	13
Table 7-1 – Environmental impact .....	13
8. Additional information.....	14
Table 8-1 – List of chemicals.....	14
Table 8-2 – Demo project results were presented at Foam Sector workshops during 22-25 June 2019 at Jeddah, Riyadh and Damman / Al Khobar .....	14
9. Conclusion.....	15
10. Other notes.....	17

## 1. Objective

Demonstrate benefits from the use of the HFO-1233zd(E) and HFO-1336mzz(Z), which have very low GWP in replacement of HCFC-141b with water, in terms of lower GWP and CO<sub>2</sub> release and insulation properties in the PU spray foam insulation sector;

Demonstrate the easy applicability of the technology and, consequently, the replicability of the results;

Demonstrate that lower cost structure as compared to other alternatives can be obtained by means of lower foam density and lower thermal conductivity;

Objectively analyze, if the incremental operating cost could be reduced overall in similar future projects by means of using optimized water / physical foam blowing agent applied in the foaming process;

Objectively analyze, if the incremental capital cost at the System Houses can be utilized by means of lesser focus on the flammable gas detection and ventilation. In particular, the extensive exhaust ventilation in the countries with hot climate may result in unexpected costs in the air-conditioning production area during the hot summer periods.

Table 1-1 – HFO Foaming agent

Common Name	HCFC-141b	Formacel® 1100	Solstice Liquid BA™	Forane® 1233zd
		1336mzz(Z)	1233zd(E)	1233zd(E)
Chemical Formula	CH <sub>3</sub> CFCl <sub>3</sub>	Cis-CF <sub>3</sub> -CH=CH-CF <sub>3</sub>	Trans-CICH=CH-CF <sub>3</sub>	Trans-CICH=CH-CF <sub>3</sub>
Molecular Weight	117	164	130.5	130.5
Boling Point (°C)	31.9	33	19	19
Gas thermal conductivity (W/mk)	8.8	10.7	9.52	9
Foam Properties	Good	Very good	Very good	Very good
Flammable Limits in air (Vol %)	5.6-17.7 (Effectively none-flammable)	None	None	None
GWP (100 years ITH)	725	2	1	1
TLV (ppm)	500	500	800	Not disclosed



<b>Price (US\$/kg)</b>	2.0 – 4.0	?	USD 9 - 13	?
<b>Manufacturer</b>		Chemours (Formerly DuPont and Dow)	Honeywell	Arkema

## 2. Companies selected (background/application)

HCFC-141b is used by Sham Najd International in in-situ formed sprayed rigid polyurethane (PUR) and polyisocyanurate foam (PIR) for insulating and water proofing walls, ceilings, roofs, suspended ceilings and floors at the construction sites and industrial sites in the Kingdom of Saudi Arabia. Thus, Sham Najd was solely selected to phase-out HCFC-141b within this demonstration project by converting to HFO foaming agent technology due to its willingness and availability to act simultaneously as a demonstration project. The chosen technology is a non-ozone depleting and low GWP foaming agent. This HFO technology, which is a definitive alternative under the Montreal Protocol and additionally has a positive impact on climate, is in compliance with Decision XIX/6.

Replacing HCFC-141b in spray foam in the Kingdom of Saudi Arabia (KSA) presents an opportunity and technical challenge, making it worthy of a demonstration project. The preliminary 2014 HCFC consumption estimates show that 600 MT of HCFC-141b or 66 ODP tonnes were consumed in 2014 for spray foam in the Kingdom of Saudi-Arabia (these figures include import of pre-blended polyurethane systems). Also, in 2014, the Ministry of Municipal and Rural Affairs of KSA has made thermal insulation compulsory for all new buildings in the 24 districts of the country covering 80% of the populations. The addition of thermal insulation in new building is expected to reduce 40% of energy use in air conditioning. Today, air conditioners account for 70% of electricity consumption in the region and with 1.5 Million new homes needed to keep up with the population growth, energy demand is anticipated to double by 2030 if energy conservation measures are not put in place.

## 3. Technologies Considered and selected

### 3.1. Alternative technologies considered

In accordance with the 2014 report of the rigid and flexible foams technical options committee, there are numbers of alternatives that are available to replace the use of HCFC 141b in rigid polyurethane foam. Several foaming technologies, including the following, are used as alternate technology:

- Cyclopentane
- HFC-245fa
- HFC-365mfc/227ea

- HFC-134a
- Methyl formate
- CO2 (Water)
- u-HFC
- Liquid unsaturated HFC/HCFC (HFOs) as emerging technology (subject for this demonstration project)

### 3.2. Commercially Available Options

Option	Pros	Cons	Comments
Cyclopentane & n-Pentane	Low GWP	Highly flammable	High incremental capital cost, may be uneconomic for SMEs
	Low operating costs		
	Good foam properties		
HFC-245fa, HFC-365mfc/227ea, HFC-134a	Non-flammable	High GWP	Low incremental Capital Cost
	Good foam properties	High Operating Cost	Improved insulation (cf. HC)
CO2 (water)	Low GWP	Moderate foam properties -high thermal conductivity-	Low incremental Capital Cost
	Non-flammable		
Methyl Formate/Methylal	Low GWP	Moderate foam properties -high thermal conductivity-	Moderate incremental capital cost (corrosion protection recommended)
	Flammable although blends with polyols may not be flammable		

### 3.3. Emerging Options

Option	Pros	Cons	Comments
Liquid Unsaturated HFC/HCFC (HFOs)	Low GWP	High operating costs	First expected commercialization in 2013
	Non-flammable	Moderate operating costs	Trials in progress
			Low incremental capital cost

The Indicative assessment of criteria for commercially available options as well as emerging alternatives in PU foam is provided in the table below:

### 3.4. Assessment of criteria for commercially available options

	c-pentane	i-pentane n-pentane	HFC-245fa	HFC365mfc/ 227ea	CO <sub>2</sub> (water)	Methyl Formate
Proof of performance	+	++	++	++	++	+
Flammability	---	---	++	+(+)	+++	--
Other Health & Safety	0	0	+	+	-	0
Global Warming	+++	+++	--	---	++	++
Other Environmental	-	-	0	0	++	-
Cost Effectiveness (C)	--	---	++	++	++	0
Cost Effectiveness (O)	++	+++	--	--	+	+
Process Versatility	++	++	+	++	+	+

### Assessment of criteria for Emerging Technology options

	HFO-1234ze(E)	HFO-1336mzzm(Z)	HFO-1233zd(E)
	Gaseous	liquid	Liquid
Proof of performance	0	+	+
Flammability	++	+++	+++
Other Health & Safety	+	+	+
Global Warming	+++	+++	+++
Other Environmental	+	+	+
Cost Effectiveness (C)	++	++	++
Cost Effectiveness (O)	--	--	--
Process Versatility	+	+	+

### 3.5. IOC comparison between major alternatives during demonstration project formulation

IOC	HCFC-141b			HFO-1233zd			Methyl Formate			Water-blown / Formic Acid		
	Formula	%	Cost/kg	Formula	%	Cost/kg	Formula	%	Cost/kg	Formula	%	Cost/kg
Polyol	100	44,29%	2,70	100	46,08%	2,70	100	37,88%	2,70	100	37,95%	2,70
B.A	15,8	7,00%	2,70	7	3,23%	11,00	9	3,41%	2,70	3,5	1,33%	2,70
MDI	110	48,72%	2,70	110	50,69%	2,70	155	58,71%	2,70	160	60,72%	2,50
<b>Total</b>	<b>225,8</b>	<b>100,00%</b>	<b>2,70</b>	<b>217</b>	<b>100,00%</b>	<b>2,97</b>	<b>264</b>	<b>100,00%</b>	<b>2,70</b>	<b>263,5</b>	<b>100,00%</b>	<b>2,58</b>
Thermal conductivity mW/mK	21			21			23			31		
Foam density	42			42			42			42		
Equivalent cost USD	2,70			2,97			2,96			3,81		
Total PU consumption 2015	400000	27,99	1080000	400000		1187097	400000		1182857	400000		1522577
IOC / year USD				107097			102857			442577		

### 3.6. Selection of alternative technology for the Demonstration project

The technology chosen has been HFOs due to the following:

Spray foam is used to insulate, provide air sealing and improve structural strength in buildings. The insulation potential of spray foam is dependent upon the insulating gas in the cells of the polyurethane foam. In addition to the insulation performance, polyurethane foams used for the insulation purpose require inherently superior dimensional stability and resistance to fire.

The current zero ODP options for replacement of HCFC-141b in foam applications include hydrofluorocarbons (HFCs) and hydrocarbons. Both HFCs and hydrocarbons are characterized by increased thermal conductivities compared to the HCFC, resulting in inferior insulation performance.


Few alternatives exist for replacing 141b in spray foam. Hydrocarbons are not a viable alternative for spray foam, and HFC-245fa and HFC-365, while viable, have high global warming potential (GWP). Also, the low boiling point of HFC-245fa and the flammability of hydrocarbons and HFC-365mfc present significant challenges to refrigerants processing and handling that are critically important in spray foam applications. On the other hand, foam blowing agents HFO-1233zd(E) and HFO-1336mzz(Z) have very low GWP, both less than 5, and HFO-1233zd (E) is claimed to be even less than 1. These molecules are also non-flammable and stable liquids at ambient temperatures. The HFO-1233zd(E) is already commercialized and HFO-1336mzz(Z) was expected to be commercially available from the year 2016. However, during the project implementation it was found out impossible to obtain it in such quantities which would have facilitated full-scale demonstration project. Thus, only blowing agent HFO-1233zd(E) has been tested in this demonstration project.

#### 4. Modification of production

The foaming agent technology did not require new foaming equipment. All testing was performed with Sham Najd existing equipment (Graco E-XP1 Applicator).



*Graco E-XP1 Applicator*



## 5. Technical evaluation

Testing of the spray foam system SHPU 45 FSSL-50 from Covestro, UAE. The testing took place at Sham Najd's Labor camp & Warehouse area on 13 through 15 March 2017.

The spray foam testing operation was conducted by means of Sham Najd's existing Graco Reactor E-XP1 spray foaming machine and using the Fusion Air Purge Plural-Component Spray Gun.

The testing started on 13 March 2017 by means of spraying the standard non-fire rated spray foam system PS 105 H 40 Winter from KSA local system house SUCCO. The test results are provided in the table 1 and 2.

Testing was continued on 14 March 2017 with Covestro's HFO-1233zd blown SHPU 45 FSSL-50 fire retarded foam system. The test results are provided in table 1 and 2. All tests were conducted as follows:

**Table 5-1. Test Results from the first samples in March 2017**

Density	Approx. 43-47	ASTM D1622
Compressive strength	> 0.1 MPa	ASTM D 1621
Fire rating (DIN4102-1)	B2	DIN 4102
Fire rating Butler Chimney	Above 50%	ASTM 3014
Thermal Conductivity	≤0.024 W/m <sup>2</sup> K (10°C) ≤0.029 W/m <sup>2</sup> K (35°C)	ASTM C518
Dimensional Stability -20°C/+70°C, 48 hrs	Max 1%	ASTM D2126

**Table 5-2. Thermal conductivity at 10°C**

System	Density kg/m <sup>3</sup>	Compressive strength MPa	Dim. Stability % Max allowable 1%	Thermal conductivity W/mK @ 10°C	Aged thermal conductivity 21 days @70°C W/mK	Butler Chimney test ASTM 3014
SHPU45FSSL- 50 (HFO- 1233zd)	40.8	0,298	0.85	0.0210	0.0267	81.9%
PS 105 H 40 (HCFC-141b)	57.8	0,406	0.81	0.0248	0.0296	52.0%

Table 5-3. Thermal conductivity at 35°C measured two weeks after production

System	Density kg/m <sup>3</sup>	Compressive strength MPa	Dim. Stability % Max allowable 1%	Thermal conductivity W/mK @ 10°C	Aged thermal conductivity 21 days @70°C W/mK	Butler Chimney test ASTM 3014
SHPU45FSSL-50 (HFO-1233zd)	44.5	0,350	0.85	0.0246	0.0273	81.9%
PS 105 H 40 (HCFC-141b)	57.8	0,406	0.81	0.0275	0.0298	52.0%

**Table 5- 4. Physical properties measured after 18 months from applying the foam on the roof.  
The samples were stored next to the test roof for easier testing purpose**

Property		Unit	Average	Typical	Assessment of 18 months foam
Foam Density	EN 1602	kg/m <sup>3</sup>	48,7	47	Typical value for roof insulation
Thermal Conductivity $\lambda_{10}$ (+10°C)	EN 13165	mW/mk	26,1	26	Increased from 21 to 26.1, but understandable due to 18 months ageing at the construction site
Aged Thermal Conductivity (21days +70°C) $\lambda_{10}$ (+10°C)	EN 13165	mW/mK	26,8	27	Shows that foam has kept insulation well
Thermal Conductivity $\lambda_{35}$ (+35°C)	EN 13165	mW/mk	28,2	28	Increased from 24.6 to 28.2, but understandable due to 18 months ageing at the construction site
Aged Thermal Conductivity (21days +70°C) $\lambda_{10}$ (+35°C)	EN 13165	mW/MK	28,9	29	Shows that foam has kept insulation well
Compression Behavior	EN 826	kPa	352	300	Similar to original 298 kPa -> 352 kPa (improved), which is typical that physical foam properties improve during the first months, upon all foam has after polymerized. The compression strength of PUR/PIR products remains constant with time if there is no air diffusing into the cells (ageing). If air diffusion is characteristic of the product then the compression strength will increase with time. The level of this increase will increase with the level of closed cells present, i.e. this increase will be the highest with level CCC4 (>90%) and least with level CCC1 (<20%).
Tensile Strength	EN 1602	kPa	183	150-200	This is typical for sprayfoam
Dimensional stability ( 3 days +70°C)	EN 1605	%	+0,66	±1	Excellent
Dimensional stability ( 10 days +70°C)	EN 1605	%	+0,69	±1	Excellent
Reaction to Fire Butler Chimney Test	ASTM 3014	%	91,1	80-90	Very good, practically IMPROVED FROM 81.9% to 91.1%
Reaction to Fire B2 Test	DIN 4102	cm	10,5	10-11	Has kept the fire rating well (15 cm max)
Water Vapor Resistance	ISO 12572	(m <sup>2</sup> s Pa/kg)	10,5*10 <sup>9</sup>	8-12*10 <sup>9</sup>	This is a typical value, and means that about 10 g water vapor goes through the 2 cm thick foam within 24 hrs, when there is 50 RH% humidity difference at 20 deg centigrade
Closed Cell Content	ISO 4590	%	93,3	90	Similar to HCFC-141b based foams
Closed Cell Content Corrected	ISO 4590	%	97,4	95	Similar to HCFC-141b based foams



**Table 5-5. Following characteristics were studied due to high ambient temperature**

Characteristic	Observations
The maximum concentration of HFO in the polyol to be used without pressurization of polyol vessel	12%
Impact to surfactants and catalysts	It was noticed that special package was to be introduced. Honeywell, the foaming agent supplier, was able to provide necessary package.
Pre-mixed polyol storage at the System House or Enduser's own storage	Five months during November 2016 to March 2017 did not cause any reactivity changes
Surface of the polyurethane as a product	The surface had somewhat more of pinholes compared to baseline foam formulation. However, it is meeting the customer expectations
Dimensional stability of sprayed foam	The tested foam system's dimensional stability in regard to baseline was somewhat reduced, however acceptable and meeting the spray foam standards. In regard to the most important direction against rise, the stability was good
Evaluate the correct timing for laying the protective coating for surface	The protective layer was sprayed on the foam just like on the baseline case (1.5 cm per pass)
Evaluate the performance of existing standard coating spray materials' applicability for the new product	Performance is the same

## 6. Commercial Evaluation

Commercial evaluation has been prepared basing on actual foaming results. If considering the thermal conductivity remains the same with HCFC-141b and HFO-1233zd the phase-out cost of HCFC-141b with present foaming agent prices the phase-out of HCFC-141b will cost USD 3.18/kg HCFC-141b. The actual laboratory tests displayed better results for HFO-1233zd based foam and in such case the phase-out cost of HCFC-141b were USD 0.52/kg.

**Table 6-1 – Commercial Evaluation / IOC**

Commercial Evaluation / IOC	HCFC-141b			HFO-1233zd			Water-blown / Formic Acid		
	Formula	%	Cost/kg	Formula	%	Cost/kg	Formula	%	Cost/kg
Polyol	100	38,46 %	2,46	100	38,17 %	2,70	100	37,95 %	2,80
B.A	20	7,69 %	4,00	12	4,58 %	9,50	3,50	1,33 %	2,46
MDI	140	53,85 %	3,50	150	57,25 %	3,50	160	60,72 %	3,50
Total	260	100,00 %	3,14	262	100,00 %	3,47	263,50	100,00 %	3,22
Aged Thermal conductivity mW/mK	29.8			28.2			31		
Required foam density			45			45			52
Equivalent cost USD			3.14			3.47			3.87
IOC (USD/kg HCFC 141b)						4,30			1,07
IOC (USD/kg HCFC 141b) considering change in thermal conductivity and foam density						0.33			9,53

## 7. Environmental impact

The project impact on the environment was studied for both chemicals i.e. HCFC-141b and HFOs. The CO<sub>2</sub> emission before conversion (using HCFC-141b as blowing agent with Global Warming Potential of 725) is expected as 20,282.68 metric ton per year whereas after conversion to HFO with GWP 1, it is estimated 17.32 metric ton per year. The net impact on the environment is positive. The CO<sub>2</sub> emission is expected to be reduced by 20,282.68 MT after implementing the new technology at Sham Najd. In whole KSA respectively the impact will be 434,643.00 CO<sub>2</sub> MT/ year. The ODP phase-out at Sham Najd is 3.08 ODP tonnes and respectively in KSA 66 ODP tonnes. The net effect calculation is provided in the table below:

**Table 7-1 – Environmental impact**

Name of Industry	Substance	GWP	Phase out amount MT/ year	Total equivalent warming impact CO <sub>2</sub> eq. MT/ year	ODP HCFC-141b	Total ODP
Sham Najd						
Before Conversion						
Total CO <sub>2</sub> emission in M tonnes	HCFC-141b	725	28	20,300.00	0.11	3.08
After Conversion						
Total CO <sub>2</sub> emission in M tonnes	HFO-1233zd	1	17,32	17.32	0	0
Net Impact				20,282.68		3.08
Before conversion Kingdom of Saudi Arabia						
Total CO <sub>2</sub> emission in M tonnes	HCFC-141b	725	600	435,000.00	0.11	66
After Conversion		1	357	357	0	0
Total CO <sub>2</sub> emission in M tonnes				434,643.00		66

## 8. Additional information

**Table 8-1 – List of chemicals**

Product	Supplier	Price USD / Kg
HFO-1233zd - Solistice LBA	Honeywell	9.50-15.00
Dabco 2040	Evonik	27.95
Dabco 203	Evonik	13.75
Tegostab B84711	Evonik	8.70
MDI	Sadara (Dow Chemicals' joint venture in KSA)	6.75 SAR USD 1.80

Since the spray foam systems are now available locally in KSA, there will be further local spray foam system use by Sham Najd and other spray foam applicators like Al-Babtain and customers of SUCCO and Saptex.

The SUCCO's actual field testing was conducted during early 2018 with Al-Babtain spray foam applicator for roofing of Honeywell's store area roofing. This testing was not actually connected to this Demo project but demonstrating the local Foam System Houses availability to provide foam systems, which facilitate phase-out of HCFC-141b.

Workshop with all results was held in June 2019. This workshop provided detailed information from the results in Jeddah, Riyadh and Damman.

**Table 8-2 – Demo project results were presented at Foam Sector workshops during 22-25 June 2019 at Jeddah, Riyadh and Damman / Al Khobar**

Place of venue	Presentations	Subjects	Audience
Jeddah Riyadh Damman	Saptex System House	Alternative foaming agent for spray and pour-in-place applications	Spray applicators 15 Construction consultants 4
	Succo System House	Foaming results and challenges experienced in the foam formulations and expectations with PU spray foam	National Ozone Unit UNEP
	Sham Najd - Spray Applicator	Comments on the Demo Project	
	Jundi – System House	Experience in the use of natural and flammable foam blowing agent	

	UNIDO International Consultant	1 <sup>st</sup> : Foaming with HFO foaming agents- Solstice LBA and Opteon 1100 2 <sup>nd</sup> : Foaming results with hydrocarbons and other blowing agents 3 <sup>rd</sup> : Foam cost calculations	
	Momentive	Foam formulations	
	Honeywell	4th Generation Blowing Agents	

## 9. Conclusion

The phase-out of HCFC-141b in Sham Najd will reduce the total CO<sub>2</sub> emission and ODP emissions by a significant margin. The conversion will facilitate the phase-out cost-effectively. The same approach can be applied to the whole KSA and the surrounding region respectively.

Spray foam for roofing in the KSA where the insulation demand is growing will require superior insulating and water-proofing properties and ability to be monolithically apply to all shapes and types of surfaces.

According to the field testing and resulting laboratory testing, the spray foam formulation with HFO-1233zd foaming agent appears to have a high potential to replace HCFCs and HFCs as it has very similar technical and physical attributes and has a very low GWP and zero ODP factor.

Following conclusive characteristics can be noted:

1. The end spray product is matching HCFC-141b blown spray foam in many aspects, such as adhesion, thermal conductivity, dimensional stability, paint-ability, overall foam density and compression strength;
2. Lesser amount of HFO-1233zd can be mixed due to the boiling point of polyol mix will also be lower than boiling point of HCFC-141b blown foam;
3. Storage of mixed polyol needs to be kept at max 28 degrees of centigrade - > needs upgrade of polyol mix storage room air-conditioning;
4. On construction sites, the drum storing of polyol by the spray foam applicators require shelters;
5. HFO-1233zd needs to be kept in pressure vessels;
6. HFO-1233zd needs to be mixed in the temperature-controlled mixing vessel (reactor), temperature less than 18 °C, or to use in-line pre-mixer unit;
7. HFO-based foam system needs special additives in order to avoid deterioration of ageing performance of the polyol mix, see the chemicals to be purchased.

8. Cost of foam system is presently higher than HCFC-141b blown foam. However, it is expected to be balanced within few years.

**Advantages:**

1. Better foam performance in the cold weather period season (lower boiling point);
2. HFO-1233zd provides future foam formulation without concern of use limitations;
3. Very low Global Warming Potential (GWP) of 1;
4. Non-ozone depleting;
5. Nonflammable (ASTM E-681), VOC exempt (per U.S. EPA) and
6. Facilitate required improved energy efficiency for the future constructions and buildings and can be used for improving old buildings to meet present insulation requirements.

**Budget**

**Total budget approved 96,250 USD**

Expenditures: **94,000 USD** (2019), which contains of:

Consultancy services and travels -	28,000 USD
Equipment/Chemicals –	48,000 USD
Workshop and laboratory test -	18,000 USD

## Response to MFS comments on Interim Report of HFO demonstration project in PU foam Saudi Arabia

1. At the 80<sup>th</sup> meeting, the Executive Committee agreed to extend the project completion date to 31 December 2018, on the understanding that no further extension of project implementation would be requested, and to request UNIDO to submit the final report no later than the 83rd meeting (decision 80/26(i)). The Secretariat notes from the present report that substantial progress has been achieved in the implementation of the demonstration, but that some activities (i.e., scale field testing and dissemination workshop) have not taken place yet. We would appreciate the following clarifications on the remaining activities to finalize the project:

- (a) Please provide the characteristics of the scale field testing planned (specific tests planned, how many tests in how many enterprises, formulations to be used, duration of these tests and additional information expected);

**Response:** It is tentatively, and as per the project document intention to conduct the field testing only by the company Sham Najd. Intention is to obtain foam systems from KSA SHs SUCCO and Saptex. In the project document it was foreseen only Saptex, but during implementation of this project and System House projects, SUCCO appears to have the most experience in the foam formulation development. The laboratory formulations are already in place, and those are to be field tested.

- (b) Please confirm estimated date of completion of all pending activities;

**Response:** It is foreseen that testing would be completed and results available by October 2019.

- (c) Given that these reports are going to be used by other Article 5 countries as reference when implementing projects, we would appreciate that the final detailed report of the demonstration is presented to the 84<sup>th</sup> meeting, including the result of the remaining tests, any conclusions or additional information emerging from the workshop, and additional details requested the comments below.

**Response:** The final report is projected to be available by October 2019.

### Formulations

2. Please clarify the origin of the formulation used to test HFO-1233zd(E). Was it developed by Covestro for the demonstration project, or is it a commercially formulation available to any systems house?

**Response:** All foam formulations details are always System Houses' own developments and secrets and based on their polyols in use. However, the additive suppliers (for instance Evonik and Momentive) and the foaming agent suppliers (Honeywell and Chemours) have R&D support available, and they actively provide their experience to the formulators at System Houses. In the case of the Spray Demo project first phase the formulation was fully developed by Covestro, and not available to any other source.

3. Kindly inform if all the tests were done with a formulation containing pure HFO-1233zd(E) or if there were also tests with formulations reduced with water. If that was the case, please also provide the results and how the foam with reduced formulations compare with pure HFO-1233zd and HCFC-141b-foam?

**Response:** The HFO-1233zd formulations are always substantially reduced with water. The HFO-1233zd content as foaming agent is from 8 to 12 % in polyol formulation high ambient temperature countries. Due to HFO-1233zd's low boiling point, it is not really possible to formulate cost-effectively polyol mixture, which could keep blowing agent fully soluble. The testing has shown that blowing agent start boiling strongly, and the hot climate conditions preclude this kind of high content HFO-1233zd formulations.

The below tables are providing information from the laboratory test. It is to be noted that the HCFC-141b foam was not most suitable for the comparison. However, it was only available.

System	Density kg/m <sup>3</sup>	Compressive strength MPa	Dim. Stability % Max allowable 1%	Thermal conductivity W/mK @ 10°C	Aged thermal conductivity 21 days @70°C W/mK	Butler Chimney test ASTM 3014
SHPU45FSSL-50 (HFO-1233zd)	40.8	0,298	0.85	0.0210	0.0267	81.9%
PS 105 H 40 (HCFC-141b)	57.8	0,406	0.81	0.0248	0.0296	52.0%

System	Density kg/m <sup>3</sup>	Compressive strength MPa	Dim. Stability % Max allowable 1%	Thermal conductivity W/mK @ 35°C	Aged thermal conductivity 21 days @70°C W/mK	Butler Chimney test ASTM 3014
SHPU45FSSL-50 (HFO-1233zd)	44.5	0,350	0.85	0.0246	0.0273	81.9%
PS 105 H 40 (HCFC-141b)	57.8	0,406	0.81	0.0275	0.0298	52.0%

### Tests undertaken and results

4. Thank you very much for Table 1 listing the tests undertaken. Kindly inform why other typical tests such as adhesion strength (ASTM D-1623), water absorption or closed cell content (ASTM D-2856) were not included. Could they be included in the next measurements?

**Response:** These above-mentioned tests were to be conducted, but misunderstanding with the UAE Test laboratory, they were not able to conduct all tests. These tests will be conducted for the next test.

5. Table 2 can be considered a clear summary of the results. However, it does not contain all the information that other Article 5 countries will need as reference. We would appreciate if for the final report you could include for each of the tests listed, a brief description on how the test was done (how many times, at what temperature,



relative humidity and other conditions) and how you interpret the results found. Please feel free to include Annexes for additional tables, where necessary.

**Response:** The following testing will be included:

- European in-situ formed sprayed PU foam standard EN 14315;
- Thermal resistance and thermal conductivity
- Measurement of lambda values (thermal conductivity W/mK)
- Ageing of lambda value
- Reaction to fire of the products
- The reaction to fire classification of the products shall be determined in accordance with EN-13501-1 and using data obtained from tests carried out according to procedures EN ISO 11925-2 and EN 13823
- Dimensional stability under specified temperature and humidity conditions
- Dimensional stability under specified temperature and humidity conditions shall be determined in accordance with EN 1604
- Reaction profile and free-rise density
- Durability characteristics
- Durability of reaction to fire against ageing/degradation
- Durability of thermal resistance against ageing/degradation
- Durability of compression strength against ageing/degradation
- Closed cell content
- Short-term water absorption by partial immersion
- Compressive stress or compressive strength

All tests above will be conducted according to EN 14315 (Thermal insulating products for buildings — In-situ formed sprayed rigid polyurethane (PUR) and polyisocyanurate (PIR) foam products)

6. Kindly inform if the characteristics of the foam were measured again several weeks after, in order to obtain information on aging. It has been observed in several of the demonstration projects that some of the characteristics of the alternative foam may vary over time in a different way than HCFC-141b-foam. If this was measured, please include it in the final report. If this was not done, please explain the reasons and kindly consider undertaken additional measurements.

**Response:** We understand this need, and it is foreseen.

7. It is understood from the demonstration that no modifications were required to the foam dispenser for the application of HFO-1233zd(E) in spray foam applications. Is there any instance in which a modification to the spray foam equipment would be needed or it can be inferred that in general no changes are needed?

**Response:** The evaluation was done with relatively new Graco Spray foam unit, which has very good control on the pressure, mixing and heating of hoses. Thus, it can be used as such.

8. The conclusion section indicates that mixed polyols needs to be stored at maximum 28 degrees Celsius. The reasons are not explained in the report.

**Response:** Boiling point of the HFO-1233zd is so low that it will cause evaporation / boiling of the chemical. It is not azeotropic mixture with polyol.

9. The conclusions also indicate that HFO-1233zd should be mixed in the reactor at a temperature lower than 18 degrees Celsius. The reasons are not explained in the report.

**Response:** Boiling point of HFO-1233zd is 19.5 °C, and in order to avoid loss of the blowing agent during mixing process, it needs to be mixed preferable at 15°C

10. What have been identified as the main challenges to introduce HFO-1233zd(E) in spray foam application in Saudi Arabia?

**Response:** Ambient temperature, shelf-life of the polyol mixture, high price and motivation to the SH's due to the availability of HCFC-141b formulations and bulk.

11. Kindly include in the final report an independent technical review.

**Response:** Will be budgeted and included as requested.

### Cost

12. What is the cost of the additional surfactants and catalysts required for the application of HFO-1233zd(E)? Please also provide an explanation on why they are required.

**Response:** The Evonik catalyst – emulsifier - silicone surfactant package, having the commercial product names;

- Dabco 203
- Dabco 2040 and
- Tegostab B8471

This optimized catalyst package through extensive and multi-year testing is recommended by Evonik and HFO-1223zd supplier Honeywell for spray foam formulators, when using HFO-1233zd as foam blowing agent, and this catalyst package provide self-life for polyol blend for more than 8 months. Thus, UNIDO Demonstration project needs to follow these recommendations.

Name of chemical	kg	USD/ kg	One drum	Description	Other information
Dabco 2040	200	27,50	5 500,00	Dabco 2040 catalyst is a low odor amine used to enhance cure and adhesion to substrate in HFO-blown spray foams.	
Dabco 203	200	13,20	2 640,00	Dabco 204 catalyst can help customers achieve between 6 to 8 months of polyol blend stability when used with HFO-1233zd(E). Dabco 203 catalyst performs similarly to Polycat 204 catalyst, but brings the added advantage of having a low water content, providing additional flexibility to formulators.	Typical uses levels of Dabco 203 catalyst / Dabco 204 catalyst are 2-4% by weight on the polyol side. The product can be used in conjunction with other catalysts to optimize system stability, overall reactivity as well as back-end cure speed. Recommended co-catalysts for HFO based systems include: Dabco® 2039 catalyst, Dabco® 2040 catalyst.
Tegostab B8471	200	8,25	1 650,00	TEGOSTAB® B 8471 acts as a silicone surfactant. Offers foam stabilization. Used in polyurethane rigid foam for construction applications.	Improves stability in formulation.

Momentive package is including following.

- Silicone L5107
- DMEA
- DMCHA
- Catalyst A-1 (Momentive)
- Potassium Octoate from Momentive

13. Is the formulation in Table 5 the one used in the demonstration project (Covestro HFC-1233zd blown SHPU 45 FSSL-50)?

**Response:** Yes.

14. Is the price of pure HFO-1233zd(E) in Saudi Arabia US \$9.50/kg as indicated in Table 5?

**Response:** Seems to be that price in smaller quantities is USD 15,000 / MT. So, price has not been reduced as expected. In the case of Demo material from Covestro, UNIDO purchased foam as a system, and foam individual chemical prices were not revealed.

15. Kindly explain how the IOC value of US \$0.52/kg was obtained?

**Response:** From the calculation below, foam cost USD /kg difference is USD 0,04/kg. However, when thermal conductivity is considered, the HFO-1233zd foam USD 0.52/kg lower in cost.

Commercial Evaluation / IOC	HCFC-141b			HFO-1233zd			Water-blown / Formic Acid		
	Formula	%	Cost/kg	Formula	%	Cost/kg	Formula	%	Cost/kg
Polyol	100	38,46 %	2,46	100	38,17 %	2,70	100	37,95 %	2,80
B.A	20	7,69 %	4,00	12	4,58 %	9,50	3,50	1,33 %	2,46
MDI	140	53,85 %	3,50	150	57,25 %	3,50	160	60,72 %	3,50
Total	260	100,00 %	3,14	262	100,00 %	3,47	263,50	100,00 %	3,22
Aged Thermal conductivity mW/mK	29,8			27,3			31		
Required foam density			45			45			52
Equivalent cost USD			3,14			3,18			3,87
IOC (USD/kg HCFC 141b)						4,30			1,07
IOC (USD/kg HCFC 141b) considering change in thermal conductivity and foam density						0,52			9,53

# RATES OY

Construction Product Testing Laboratory

August 21<sup>th</sup> 2019

UNIDO UNITED NATIONS INDUSTRIAL DEVELOPMENT ORGANISATION

Yuri SOROKIN

Industrial Development Officer Montreal

Protocol Division VAGRAMERSTR. 5 VIENNA

AUSTRIA

## TEST REPORT

Physical Properties of Sprayed PIR Foam							Typical value
Property		Unit	1.	2.	3.	Average	
Foam Density	EN 1602	kg/m <sup>3</sup>	48,9	48,4	48,9	48,7	47
Thermal Conductivity $\lambda_{10}$ (+10°C)	EN 13165	mW/mk	26,1	26,0	26,1	26,1	26
Aged Thermal Conductivity (21days +70°C) $\lambda_{10}$ (+10°C)	EN 13165	mW/mK	26,7	26,4	27,3	26,8	27
Thermal Conductivity $\lambda_{35}$ (+35°C)	EN 13165	mW/mk	27,3	28,6	28,7	28,2	28
Compression Behaviour	EN 826	kPa	351	345	359	352	300
Tensile Strength	EN 1602	kPa	172	229	149	183	150-200
Dimensional stability ( 3 days +70°C)	EN 1605	%	+0,60	+0,63	+0,74	+0,66	±1
Dimensional stability ( 10 days +70°C)	EN 1605	%	+0,68	+0,63	+0,76	+0,69	±1
Reaction to Fire Butler Chimney Test	ASTM 3014	%	88,7 93,8	88,5 93,9	93,8 88,1	91,1	80-90
Reaction to Fire B2 Test	DIN 4102	cm	10 11	11 10	11 10	10,5	10-11
Water Vapour Resistance	ISO 12572	(m <sup>2</sup> s Pa/kg)	10,7*10 <sup>9</sup>	9,8*10 <sup>9</sup>	11,0*10 <sup>9</sup>	10,5*10 <sup>9</sup>	8-12*10 <sup>9</sup>
Closed Cell Content	ISO 4590	%	93,6	92,8	93,4	93,3	90
Closed Cell Content Corrected	ISO 4590	%	97,6	97,1	97,5	97,4	95

RATES OY



Heikki Tolonen

Laboratory Manager

+358 40 5322350 Rates Oy VAT-CODE

Huvijärventie 3

2535453-4

12100 OITTI  
FINLAND

# Promoting Low-GWP Refrigerants for Air-Conditioning Sectors in High Ambient temperature Countries Phase II (PRAHA-II)

2019

---

## Project Report

Project supported by the Multilateral Fund of the Montreal Protocol



**UNITED NATIONS ENVIRONMENT - UNEP**



**UNITED NATIONS INDUSTRIAL DEVELOPMENT ORGANIZATION - UNIDO**

## Disclaimer

This report may be reproduced in whole or in part and in any form for educational or non-profit purposes without special permission from United Nations Industrial Development Organization (UNIDO) and United Nations Environment (UNEP), provided acknowledgement of the source is made. UNIDO and UNEP would appreciate receiving a copy of any publication that uses this publication as a source. No use of this publication may be made for resale or for any other commercial purpose whatsoever without prior permission in writing from UNIDO and UNEP.

While the information contained herein is believed to be accurate, it is of necessity presented in a summary and general fashion. The decision to implement one of the options presented in this document requires careful consideration of a wide range of situation-specific parameters, many of which may not be addressed by this document. Responsibility for this decision and all its resulting impacts rests exclusively with the individual or entity choosing to implement the option. UNIDO, UNEP, their consultants and the reviewers and their employees do not make any warranty or representation, either expressed or implied, with respect to the accuracy, completeness or utility of this document; nor do they assume any liability for events resulting from the use of, or reliance upon, any information, material or procedure described herein, including but not limited to any claims regarding health, safety, environmental effects, efficacy, performance, or cost made by the source of information.

## Acknowledgments

The project team would like to acknowledge the assistance given by the governments and the National Ozone Units of the countries participating in the PRAHA project for their support in the implementation of the project phases and their assistance in facilitating communication with the different stakeholders.

We also acknowledge the independent International Technical Review Team that assist the project team in reviewing the project report. The team includes:

- Dr. Abdelaziz, Omar (Zewail City of Science and Technology, Egypt);
- Eng. Almatouq, Yaqoub (Environment Public Authority - Kuwait);
- Prof. Chakroun, Walid (University of Kuwait);
- Dr. Olama, Alaa (Independent Consultant - Egypt);
- Prof. Peixoto, Roberto (MAUA University - Brazil);
- Mr. Wang, Xudong (Air Conditioning, Heating and Refrigerating Institute - USA); and
- JRAIA team of experts

We acknowledge the contribution of the Air Conditioning, Heating, and Refrigeration technical Institute (AHRTI) and the Japan Refrigeration and Air Conditioning Industry Association (JRAIA) for their cooperation in the conduction of the optimization and risk assessment elements of the project.

Acknowledgement also goes to the “Technology Providers” for providing components and advice

Refrigerant Providers: Chemours, Daikin, and Honeywell.

Compressor providers: Emerson.

We recognize the efforts by Optimized Thermal System (OTS) in the optimization elements and the AHRI members who were part of the optimization project monitoring team. We also recognize the efforts of the JRAIA members in their assistance and especially in conducting teleconferences at late hours.

Special thanks to Prof. Chakroun, Walid who supported PRAHA-II in the designing and evaluating the content of the optimization element of the project.

## Project Team

### **Project Managers:**

Mr. Eltalouny, Ayman - Coordinator International Partnerships, OzonAction, Law Division (UNEP)

Mr. Nielsen, Ole - Chief of Montreal Protocol Division (UNIDO)

### **Project Consultant and Report Lead Author:**

Mr. Elassaad, Bassam - P.Eng. – HVAC Expert

# Table of Contents

Disclaimer.....	2
List of Tables .....	6
List of Figures .....	6
ACRONYMS .....	7
Executive Summary.....	8
<b>1. Background and Project Main Elements .....</b>	<b>10</b>
<b>2. Capacity Building through Knowledge Sharing and developing a Technical Platform .....</b>	<b>14</b>
<b>2.1. Track-I: Capacity Building for the Manufacturers of PRAHA-I .....</b>	<b>14</b>
<b>2.2. Track-II: Sharing with the different stakeholders at regional and global events.....</b>	<b>17</b>
<b>2.3. Conclusion from the Capacity Building Element .....</b>	<b>18</b>
<b>3. Optimization of PRAHA-I Prototypes.....</b>	<b>19</b>
<b>3.1. Contracting the Activities.....</b>	<b>19</b>
<b>3.2. Scope of Work .....</b>	<b>20</b>
<b>3.3. Deliverables .....</b>	<b>21</b>
<b>3.4. Matrix .....</b>	<b>21</b>
<b>3.5. Project Monitoring .....</b>	<b>22</b>
<b>3.6. Challenges and Modifications .....</b>	<b>23</b>
<b>3.7. Project Implementation and Findings .....</b>	<b>23</b>
<b>3.7.1. Activity 1 – Analyzing the Design of PRAHA-I Prototypes .....</b>	<b>23</b>
<b>3.7.2. Activity 2 – Design Improvements .....</b>	<b>27</b>
<b>3.7.3. Activities 3, 4, and 5 .....</b>	<b>35</b>
<b>3.8. Conclusion and Recommendations from the Optimization Element .....</b>	<b>40</b>
<b>4. Risk Assessment .....</b>	<b>44</b>
<b>4.1. Background on Risk Assessment.....</b>	<b>44</b>
<b>4.1.1. Flammability Definition and Classes.....</b>	<b>44</b>
<b>4.1.2. Concept of Risk Assessment.....</b>	<b>45</b>
<b>4.1.3. Approach of a Risk Assessment Model.....</b>	<b>46</b>
<b>4.1.4. Outline of a Risk Assessment Model .....</b>	<b>47</b>
<b>4.1.5. Global Risk Assessment Efforts.....</b>	<b>48</b>
<b>4.2. Process of a Risk Assessment Model .....</b>	<b>50</b>
<b>4.3. Example of a Risk Assessment Model .....</b>	<b>58</b>



4.3.1.	Simulation of Time Factor and Space factor During Usage Stage.....	60
4.3.2.	Simulation of Time Factor and Space factor During Servicing Stage.....	62
4.4.	Conclusions and Recommendations from the Risk Assessment Element.....	63
5.	Overall Conclusions and Recommendations .....	65
	Annex I – Examples of Risk Assessment Model Data Tables filled .....	67
	Annex II - Safety .....	69
	ANNEX-III: AHRTI Final Report .....	71

## List of Tables

Table 1: PRAHA Participation in International Events .....	17
Table 2: Matrix of Activities for the Prototype Optimization Element of PRAHA-II .....	22
Table 3: Matrix of units and new refrigerants to be tested.....	24
Table 4: Components for units 1, 4, 6, and 10.....	25
Table 5: Compressor models .....	31
Table 6: Activity 2 Results.....	34
Table 7: Prototype Units for Component Modification and Further Testing .....	35
Table 8: Unit 6 Modifications for Testing.....	37
Table 9: Unit 6 - Performance Test Summary for R32 Baseline (OTS) @ 35°C.....	37
Table 10: Unit 6 - Performance Test Summary for R32 Baseline (OTS) @ 46°C.....	37
Table 11: Unit 10 Modification for Tetsing.....	38
Table 12: Unit 10 - Performance Test Summary at 35°C.....	38
Table 13 : Unit 10 -Performance test Summary at 46°C.....	39
Table 14: Unit 10 – R447B Leak Test Summary Results.....	40
Table 15: Flammability Classification for Refrigerants .....	45
Table 16 Risk Matrix - Frequency vs. Severity (source JRAIA) .....	51
Table 17: Determination of tolerable risk levels .....	52
Table 18: Information for the risk assessment model used by PRAHA team .....	58
Table 19: Data for the calculation of risk for Usage Stage.....	60
Table 20: Data for calculation of Risk for Service Stage .....	62

## List of Figures

Figure 1: Main findings from PRAHA-I .....	11
Figure 2: Outline of PRAHA-II.....	12
Figure 3: Heat Exchanger First Order Analysis (FOA).....	26
Figure 4: P-h and T-s diagrams for HCFC-22 alternatives .....	28
Figure 5: P-h and T-s diagrams for R-410A alternatives .....	28
Figure 6: Profiles of refrigerants.....	29
Figure 7: Illustrative T-s diagram for baseline and improved cycle .....	30
Figure 8: Diagram illustrating COP Improvement a) Real Cycle, b) Ideal Cycle (Carnot) .....	30
Figure 9: System design framework .....	31
Figure 10. Condenser Forms: Unit 1 (left), Unit 10 (center), Unit 6 Cabinet (right). .....	33
Figure 11. HX Form Examples: L-shape (left), Flat (right). .....	33
Figure 12: Factors and Probability of Ignition.....	44
Figure 13: Tolerable vs. Acceptable risk (source: UL) .....	46
Figure 14: Procedure of Risk Evaluation according to ISO/IEC 51 (source: JRAIA) .....	48
Figure 15: Selection of equipment and life stage for the risk assessment model .....	50
Figure 16: Life Cycle range for assessment.....	52
Figure 17: Risk Map .....	53
Figure 18: Fault Tree Analysis (FTA) model .....	55
Figure 19: Probability of Ignition FTA .....	55
Figure 20: FTA reiterative process .....	57
Figure 21: FTA for usage stage.....	61
Figure 22: FTA for servicing stage.....	63

## ACRONYMS

AC	Air Conditioning
AHRI	Air Conditioning, Heating, and Refrigeration Institute
AHRTI	Air Conditioning, Heating, and Refrigeration Technical Institute
ASHRAE	American Society of Heating, Refrigerating, and Air Conditioning Engineers
BTU/hr	British Thermal Unit per Hour
CHEAA	China Home and Electrical Appliance Association
EGYPRA	Promotion of Low-GWP Refrigerants for the AC Industry in Egypt
ETA	Event Tree Analysis
EVX	Electronic Expansion Device
FMEA	Fault Measurement and Effects Analysis
FOA	First Order Analysis
FTA	Fault Tree Analysis
GWP	Global Warming Potential
HAT	High Ambient temperature
HC	Hydrocarbon
HCFC	Hydro Chloro Fluoro Carbon
HFC	Hydro Fluoro Carbon
HFO	Hydro Fluoro Olefin
HOC	Heat of Combustion
HX	Heat Exchanger
IPR	Intellectual Property Rights
JRAIA	Japan Refrigeration and Air Conditioning Industry Association
kW	Kilowatt
lbs	Pounds
LFL	Lower Flammability Limit
MCHX	Micro Channel Heat Exchanger
MOP	Meeting of the Parties
OEWG	Open-Ended Working Group
RACHP	Refrigeration, Air-Conditioning, and Heat Pumps
TFHX	Tube Fin Heat Exchanger
TXV	Thermal Expansion Valve
UA	Thermal Conductance
UFL	Upper Flammability Level

## Executive Summary

### **PRAHA Has Turned into a Process!**

PRAHA-I created an awareness about the challenges faced by high ambient temperature (HAT) countries and offered stakeholders in HAT countries support in building their technical knowledge of the alternatives technologies as well as practical support through the building and testing of several prototypes using lower-GWP refrigerants.

PRAHA-I concept of testing prototypes at high ambient temperatures pioneered other testing and research programs which eventually tested more alternative refrigerants than the few refrigerants that were still in the development stage when PRAHA-I was launched. In Addition, PRAHA-I also helped component manufacturers, especially compressors, to start building and testing dedicated compressors for the new alternative refrigerants that are capable of delivering sustained energy efficiency levels at HAT conditions.

The main result of PRAHA is that it went beyond the level of being an individual project with specific planned outcomes and outputs, PRAHA turned to be a **PROCESS** at different levels: governmental, local industry, institutional as well as for the international technology providers.

PRAHA-II is a continuation of the process with specific goals that are aligned with the findings of PRAHA-I. The two main findings of PRAHA-I are that, 1) there are viable alternatives at HAT conditions which need optimized equipment design to perform and deliver the energy efficiency minimum requirements, and 2) that there is a concern about safety of the mostly flammable alternative refrigerants that calls for a special risk assessment model for the HAT countries.

### **PRAHA-II Elements**

PRAHA-II had three main elements: 1) to build the capacity of the local industry in designing and testing products using efficient lower-GWP flammable refrigerants; 2) to evaluate and optimize the prototype built for PRAHA-I; and 3) To build a risk assessment model for the high ambient temperature countries.

Each element has its components and events and was designed to give maximum exposure to the stakeholders, both the industry as well as research institutions and the government, on the latest technology and the developments that are happening worldwide. All three elements were designed to benefit the maximum number of stakeholders.

### **PRAHA-II Main Findings**

PRAHA-II delivered tangible and beneficial results on all three main elements.

- **Capacity Building:** The capacity building element was successful in providing a platform of cooperation between governments, research institutes, industry associations, and the industry in general and became a process for the sharing of information and results among the different stakeholders. The experience of working on PRAHA-I gave UN Environment and UNIDO the confidence that international stakeholders support the goals of the project and that the

outcome will be beneficial to all and beyond economic gains. Simultaneous to the efforts by the PRAHA project to create awareness about HAT challenges and the work done through the different symposia held in the HAT countries that were participating in the PRAHA project, the local industry themselves started to directly evaluate and examine long term alternatives which reflect the level of built awareness and attention gained to the wise selection of alternatives.

- **Design Optimization:** The original scope and schedule were modified during the project as new findings and challenges surfaced. The original baseline test data was used for comparison with tests done on the optimized units built according to the modeling work done even though the latter tests included measurements and metrics not typically performed in energy certification tests of the type done under PRAHA-I.

A resume of the conclusions:

- For systems operating in considerably higher temperatures (greater than 46°C), the resultant impact on performance must be considered since performance will degrade as compared to operating under more temperate conditions.
  - The design assessment through modeling provided good insights on adequate component design and/or selection for proper system functioning when using novel refrigerants;
  - Rebuilt and tested units exhibited a considerable reduction in power consumption at the high ambient test condition (46°C) as compared to the original test data. This indicates the importance of proper compressor selection.
  - Because of the differences in saturation curves from the simulation analysis, refrigerant with wider saturation curves tend to result in systems with higher efficiency and less charge when no modifications to the hardware are made. The results showed however, that by making appropriate component selection, such as compressors with larger displacement volumes and higher mass flow rate, the cooling capacities and overall performance of the other refrigerants were of the same order of magnitude.
  - Refrigerant fractionation as evidenced by the leak tests, does not appear to be a great concern since less than 2% change in cooling capacity was observed after the system's re-charge.
- **Risk Assessment:** The work on risk assessment required resources beyond the traditional RACHP expertise that is allocated for typical conversion/demo projects. The different usage and servicing practices used in the region needed to be considered in order to assess the risk of using flammable refrigerants. The initial concern about the effect of high ambient temperature on the increased risk of ignition was removed and the main focus is on actual practices. The recommendation is for HAT countries to continue the risk assessment based on actual situations and reduce the risk by implementing various measures that are verified such as minimizing ignition probability. In addition, the risk assessments of other stages matching cultural and lifestyle aspects should be studied.

## The Way Forward

In general, PRAHA-II outcomes will be of benefit to all 35 countries defined by the Montreal Protocol Parties at the OEWG-37, 2016 as "High Ambient Temperature Countries". A HAT symposium scheduled for March 2020 will convey these results to representatives from those countries. UN Environment and UNIDO intend to transform the PRAHA initiative into a live process with continuous feedback and support to HAT countries.

# 1. Background and Project Main Elements

## Background

The 69<sup>th</sup> meeting of ExCom approved PRAHA-I with the aim to support assessing the feasibility of lower-GWP refrigerants suitable for high-ambient temperature countries and in particular for air-conditioning applications. UN Environment and UNIDO worked with local industries, international technology providers and national ozone units in these countries to do such assessment through an agreeable independent process that included in its core component building and testing 18 different prototypes and comparing them with respective baseline units which are available from the local industry using mainly HCFC and high-GWP HFC such as R-410A. The process of building and testing the prototypes was completed in 2015 and the final report was released in January 2016. PRAHA included additional components for assessing the technology transfer barriers, energy efficiency implications and economics of alternatives in addition to assessment of district cooling opportunities to reduce dependency on high-GWP alternatives and technologies.

The key finding of PRAHA-I show the potentials and challenges to promote the use of lower-GWP alternatives. Furthermore, many of the non-testing components under PRAHA, like assessing standards and codes and promoting technology transfer, were not thoroughly completed due to two main reasons; the commercial availability of the lower-GWP alternatives in the high-ambient markets and limited resources available to complete the work needed. The findings also pose important queries about what is left to be done in order to make the deployment of low-GWP alternatives possible at high-ambient temperature countries.


## PRAHA-I Key Findings

The non-testing components under PRAHA-I assessed technological, economic and energy efficiency aspects in conjunction with high ambient temperature with the following key findings:

- I. There are potential alternative refrigerants that are close, or in some cases better, in performance and efficiency compared to baseline refrigerants (HCFC<sub>22</sub> and R-410A) that are worth further investigation. With further product engineering (design and optimization) those alternatives can be strong candidates for replacement of HCFC-22;
- II. There is a need to develop the R&D capacity of the local air-conditioning industry in high ambient temperature countries in terms of the design and optimization of products using lower-GWP alternatives with their specific characteristics, such as flammability, higher operating pressures, temperature glide, etc.;
- III. Economic and technology transfer barriers Intellectual Property Rights (IPR) will continue to be issues for some time before international and regional markets stabilize on a limited group of candidates that are sustainable compared to the current long list of options being examined;

- IV. Due to the nature of those alternatives and the consequent safety issues, a comprehensive risk assessment model needs to be tailored to the needs of A5 countries, in particular for high ambient temperature conditions. Such a model needs to address manufacturing, placing into market, servicing and the end-of-life of the equipment;
- V. There is a lack of institutional programs that address alternative technologies to reduce the dependency on high-GWP alternatives in high ambient temperature countries. This is clearly reflected by the market directions during the phase-out of HCFCs;
- VI. The process of improving energy efficiency (EE) standards for air-conditioning application in high ambient temperature countries is progressing at a much quicker pace compared to the process of assessing and selecting alternative refrigerants. A smart approach is needed to jointly consider addressing EE and lower-GWP alternatives in order to avoid promoting higher-GWP alternatives that are commercially available at this stage of time.

Figure 1 summarizes the main findings from PRAHA-I.




**FIGURE 1: MAIN FINDINGS FROM PRAHA-I**

## The Project

UN Environment and UNIDO approached the Multilateral Fund seeking support for stage-II of PRAHA which is designed to address the priority areas identified in PRAHA-I. The Executive Committee of the Multilateral Fund of Montreal Protocol approved, in its 76th meeting in May 2016, stage-II of the project which is now called PRAHA-II.

The main objective of the project is to maintain the momentum generated by PRAHA-I and advance the technical capacities of stakeholders to enable the adoption and use of lower-GWP sustainable technologies for high ambient temperature countries by supporting the decision-making process related to the acceptance and promotion of lower-GWP refrigerants and advancing the technological capabilities of the local industry to design with those refrigerants.

In consultation with the project stakeholders, several areas were identified that would require further work in order to ensure putting the process of alternative refrigerants' deployment on the right track and address all technical, technological and economic concerns of both industry and policy makers. The areas identified and envisaged to be part of PRAHA-II fall under two components with three distinct elements as shown in **Error! Reference source not found.**. The three elements of PRAHA-II are detailed below.



**FIGURE 2: OUTLINE OF PRAHA-II**

Under Component A, Capacity Building, there are two elements:

**I. Building the capacity of R&D sectors in designing with low-GWP alternatives through knowledge sharing and developing a technical platform**

There are three technology schools when it comes to design air-conditioning units, excluding chiller systems, with low-GWP alternatives:

- Designing with HFC-32, which is quite established by the Japanese industry;
- Designing with HC-290, which is at an acceptable level of maturity in China and in other countries;



- Designing with HFO/HFC blends which is just starting to be implemented in different places around the globe.
- II. Optimizing the designs of PRAHA-I prototypes to meet/exceed the baseline designs:** This includes several elements using prototypes of PRAHA-I that had good results and candidate refrigerants that are promising. Prototypes showing unexpectedly poor results will also be evaluated to identify shortcomings.

**Component B aims at developing a comprehensive Risk Assessment Model:** This includes designing, developing and examining a risk assessment model suitable for use pattern and operating conditions for high ambient conditions and in particular for the GCC region.

## **2. Capacity Building through Knowledge Sharing and developing a Technical Platform**

The concept behind this element is to benefit from the experience of the most advanced industry for each technology in building the capacity of the local R&D in high ambient temperature countries. This includes attending special courses, workshops and conferences discussing these technologies, as well as field visits to manufacturing centers in countries pioneering the technologies.

The three centers of technology for the three main types of lower-GWP refrigerants are Japan, China, and the United States. The Japanese industry is leading in HFC-32 technology for the residential air conditioning sector (apart from Variable Refrigerant Flow -VRF) and is the most proliferated technology in terms of market penetration even though it does not have the lowest GWP. The Japanese market is fully transitioned into using this technology and all Japanese manufacturers are currently producing products using HFC-32. These companies, and other, are building HFC-32 products outside Japan and are marketing them in other markets including some of the HAT countries. The HFC-32 program was conducted in cooperation with Japan Refrigeration and Air Conditioning Industry Association (JRAIA) with input from the Japan Society of Refrigeration and Air Conditioning Engineers (JSRAE) and the industry.

The Chinese industry have an established HC-290 technology and have successfully implemented several conversion projects under UNIDO/UNEP. . Even though the products are not widely available globally, the potential for this technology is very promising due to the many advantages that HC-290 offers in terms of energy efficiency and low-GWP characteristics. The draw-back of high flammability was the main concentration of the capacity building efforts for the stakeholders. The HC-290 program was conducted in cooperation with the Chinese Household and Electrical Appliances Association (CHEAA) and the Chinese industry

The North American industry is leading in the field of unsaturated HFC technology, also referred to a Hydrofluoroolefin (HFO) technology. Although most of the lower-GWP HFO refrigerants are still not widely available globally, test results have shown some promising alternatives with good performance. The HFO training program which was designed in cooperation with the Air Conditioning, Heating, and Refrigeration Institute (AHRI) which represents the industry in the US with involvement from and the technology providers, i.e., refrigerant and compressor manufacturers.

The capacity building efforts had two tracks: TRACK-I capacity building for the manufacturers of PRAHA-I, and TRACK-II knowledge sharing with different stakeholders at regional and global events

### **2.1. Track-I: Capacity Building for the Manufacturers of PRAHA-I**

The objective of this track is to expose the manufacturers of PRAHA-I to the three technologies through factory visits, study tours, specialized courses, and special events. The purpose is to see firsthand how the technologies have developed in the three centers and how to apply them locally in terms of design, production capabilities, and after sales support.

This track included two study tours, one to Japan and one to China which also included events that were specially designed for PRAHA. In Japan, a risk assessment workshop to explain the Japanese

model for A2L refrigerants and the data needed for building the model; and in China a special workshop on A3 refrigerants that attracted input from local and international resources and included participants from other HAT countries.

**The HFC-32 study tour objective** was to provide participants with a good background about designing and working with lower-GWP refrigerants with A2L low-flammability characteristics. The tour included plants visits, the risk assessment workshop, as well as attending the JRAIA International Symposium on “New Refrigerants and Environmental Technology”.

The plant visits took place at Daikin facility in Shiga and the Mitsubishi plant in Shizuoka. Both plants produce HFC-32 based units and have been in production for a couple of years with hundreds of thousands of units installed. The plant visit included explanation of the charging and testing facilities where special precautions are needed. Participants were able to view the special measures taken for the safe handling of flammable refrigerants including storage.

The one-day workshop was conducted by JRAIA at their premises in Tokyo. The subject was risk assessment of A2L refrigerants for residential and commercial equipment. The information provided was detailed and included a review of the risk assessment work conducted by JRAIA; a presentation of key requirements for design; risk assessment for residential & commercial split type air conditioners and VRF during installation and maintenance; and safety guidelines during charging and servicing. Presenters were from Daikin, Panasonic, and Mitsubishi.

The symposium took place in Kobe Dec 1 & 2, 2016: The program provided in-depth information about global efforts to transition to lower-GWP refrigerants including research, regulation, design, safety, components, and energy conservation. The symposium also included a session on new refrigerants and their systems.

**The HC-290 study tour objective** was to provide in-depth knowledge of HC-290 with visit to a production plant, a building with an HC-290 installation, a special workshop, plus visit to China Refrigeration Expo to attend a one-day roundtable organized by UN Environment and other associations billed as Ozone2Climate Industry Roundtable (O2C).

The visit to AUX factory near Ningbo allowed the participants to view the special measures taken to manufacture equipment working with A3 flammable refrigerants. Factory personnel provided an overview of the R&D work and planning as well as sharing some information on the availability of products and their comparison to those operating with high-GWP refrigerants.

A visit to a facility with more than 1,100 units running on HC-290 was also arranged. The facility is a student dormitory for over 2,000 students in several buildings and all rooms are fitted with mini-splits running on HC-290. The units have been in operation for over two years and no incidents or major problems were reported. Participants were given a presentation by the management and maintenance staff and had the chance to interact with students and gauge their experience living in a facility with units running with an A3 refrigerant.

Workshop on Designing, Production and Installation with HC-290 in the Air Conditioning Industry was organized for PRAHA in collaboration with the Chinese association CHEAA and the Ozone

authority of China, FECO. The workshop was enlarged to include other participants from China who joined the expanded PRAHA team. The expanded team included participants from Egypt, Tunisia and Vietnam. The agenda of the two-day workshop included presentations by research facilities, universities, and Refrigeration, Air Conditioning and Heat Pump (RACHP) component and equipment manufacturers.

The workshop focused on risk assessment and other measures related to hydrocarbons and HC-290 in particular. Presentations included a review of international standards and what is needed to enable the new flammable technologies to be adopted by the residential and commercial AC sector; conversion of a production line for the manufacturing of R290-based RAC equipment; and the performance of HC-290 in high ambient conditions. Other presentations discussed the installation and servicing of equipment with flammable refrigerants; reducing charge amount; and a review of R&D work by the manufacturers on A3 refrigerants.

The O2C Roundtable was organized by UN Environment, UNDP, FECO, and CHEAA and covered subjects on policy to promote alternative technologies, global trends, challenges and opportunities for the industry, and solutions for the cold chain and logistics. The PRAHA team presented the challenges in phasing out HCFCs in the countries with higher ambient temperature. Participants had the chance to visit the China Refrigeration Expo in Shanghai, one of the largest for RAC equipment.

**The HFO experience in the United States** included a course on “*New ASHRAE-Classified Refrigerants to Meet Society’s Changing Needs*” by the ASHRAE Learning Institute (ALI) was offered to several PRAHA stakeholders who were attending the ASHRAE conference and AHR expo. The course discussed the properties of refrigerants and the history of development of synthetic refrigerants and delved into a detailed discussion on flammability and the safe uses of refrigerants. International standards and agreements governing refrigerants and flammability were discussed.

The participants were also invited to a one-day workshop by the Climate and Clean Air Coalition to Reduce Short-Lived Climate Pollutants (CCAC) on “*Sustainable Technologies for Stationary Air Conditioning*” which aimed to familiarize participants with climate-friendly and cost-effective air conditioning technologies which have proven their applicability to replace high-GWP HFCs.

PRAHA-II team presented on “Challenges at High Ambient Temperature” with discussions on the effect of high ambient on the design and operation of air conditioning systems, energy efficiency of refrigerant alternatives, and safety when using flammable refrigerants. The presentation also included highlights from the four research projects testing low-GWP refrigerant alternatives at different temperatures and a comparison of the results. The presentation concluded with a brief description of the work done on PRAHA-II.

The key outcomes from this element of PRAHA-II were in providing information on risk assessment work for both A2L and A3 refrigerants; informing on the availability of new components and new products running with lower-GWP refrigerants; viewing of operating production lines handling A2L and A3 flammable refrigerant; experiencing an actual installation with more than 1,100 HC-290 units installed; and acquiring information from specially designed workshops, seminars, and courses.

## 2.2. Track-II: Sharing with the different stakeholders at regional and global events

PRAHA-II expanded beyond the original PRAHA-I participants. PRAHA started by inviting members from EGYPRA, the Egyptian Project for Testing Low-GWP Refrigerant Alternatives, to events and study tours. The addition of EGYPRA was a natural one as both projects have similar goals in testing alternative refrigerants on prototypes built by the local industry. EGYPRA participants joined the study tour to Japan in November 2016. The study tour to China in April 2017 was joined by participants from Tunisia and Vietnam; Pakistan was also invited but could not join.

The workshop in Japan was built for the PRAHA and EGYPRA participants. In China, the workshop included, other than EGYPRA, Tunisia, and Vietnam, many participants from China. It also included NGOs, and global researchers. There were close to a hundred participants and the workshop turned into a large forum on the research and development of A3 refrigerants.

Awareness building about HAT and the PRAHA project has been a constant element of PRAHA. The PRAHA-I final report lists the programs and the events which PRAHA launched or participated in. The HAT series of symposia is but one example of the awareness building achievements of PRAHA.

With PRAHA-II, the campaign continued with PRAHA taking advantage of the presence of its managers or consultants to continue the message and update stakeholders, the industry, and the Parties on the developments and the latest technological information related to HAT or to the research at HAT.

PRAHA appears in websites both by UN Environment and UNIDO. Some examples:

<https://www.unido.org/our-focus/safeguarding-environment/implementation-multilateral-environmental-agreements/montreal-protocol/finding-climate-friendly-ways-cool-down>

PRAHA has truly helped in spreading awareness on HAT challenges and opportunities. The continuous awareness of the challenges and the opportunities of the HAT regions has made HAT a permanent subject to be added to the Decisions of the Parties and is a part of every Task Force study and report. HAT now is a full chapter of the 2018 RTOC Assessment Report.

Table 1 shows events and functions where PRAHA either organized special/program in their margins, joined as keynote presentation or organized a dedicated event about the subject.

**TABLE 1: PRAHA PARTICIPATION IN INTERNATIONAL EVENTS**

#	Date	Event
1	Jan 2016	Special Session at ASHRAE Winter Conference
2	Mar 2016	Special Session at West Asia/Africa Joint Network Meeting
3	July 2016	Special Session at OEWG-38
4	Aug 2016	Training Course at IIR Gustav Lorentzen Conference
5	Sept 2016	Special Session ASHRAE-AUB Efficient Building Design Conference
6	Dec 2016	Special Workshop on Designing with A2L Refrigerants

#	Date	Event
7	Jan 2017	ASHRAE Winter Conference and AHR expo
8	Jan 2017	CCAC Sustainable Technologies for Stationary AC Workshop
9	April 2017	Special Workshop on Designing with A3 Refrigerants
10	Oct 2017	International Workshop on Risk Assessment for HAT
11	Nov 2017	Special Session at CCAC Workshop at MOP-30 on Opportunities, Challenges, and Experiences with Transitioning to Low-GWP Alternatives
12	Jan 2018	Special Session at OzonAction First Interregional Networks' Meeting
	Oct 2018	Flammable Refrigerant Research and Planning Conference
13	Jan 2019	ASHRAE Winter Conference
14	Feb 2019	Special Session at OzonAction Second Interregional Networks' Meetings
15	March 2020 <i>(Planned)</i>	6th International Symposium on Alternative Refrigerants for High Ambient Temperature Countries

### 2.3. Conclusion from the Capacity Building Element

The experience of working on PRAHA gave UN Environment and UNIDO the confidence that international stakeholders support the goals of the project and that the outcome will be beneficial to all beyond economic gains. On the other hand, and simultaneous to the efforts by the PRAHA project to create awareness about HAT challenges and the work done through the different symposia held in the HAT countries that were participating in the PRAHA project, the HAT countries themselves were bringing up the issues at the different meetings of the Parties whether at the Open-Ended Working Group (OEWG) meetings or the Meeting of the Parties (MOP).

The capacity building element was successful in providing a platform of cooperation between governments, research institutes, industry associations, and the industry in general and became a process for the sharing of information and results among the different stakeholders.

### **3. Optimization of PRAHA-I Prototypes**

This component includes several elements using prototypes of PRAHA-I that had promising results. Prototypes that showed unexpectedly poor results will also be examined to identify shortcomings. The exercise includes mainly three stages of work on the prototypes, plus a leak analysis stage:

- a. Analyzing the design of PRAHA-I prototypes: a physical inspection and analysis of prior experimental results, plus a first order assessment of component and refrigerant performance.
- b. Design optimization of PRAHA-I prototypes including: acquiring performance maps for components (compressors, fans) that are more suitable for the application; evaluating alternate heat exchanger design configurations; performing detailed engineering optimization to match or exceed the baseline unit performance within an acceptable design space set forth by an expert committee. This may include installing new upgraded compressors, for same refrigerants used in PRAHA-I, and which were not available at the time PRAHA-I prototypes were built; or compressors for refrigerants not tested under PRAHA-I; if so required.
- c. Testing new refrigerants emerging since PRAHA-I using prototypes of PRAHA-I with change/upgrade of compressors.
- d. Analyzing leak-recharge effect on performance for high glide alternatives.

#### **3.1. Contracting the Activities**

PRAHA first contact was with Oak Ridge National Laboratory (ORNL) who had performed their own testing at HAT conditions on two units with two different baseline refrigerants.

Unfortunately, due to legality issues and differences in the contractual practices commonly followed by UNEP, the contract between UNEP and ORNL did not materialize in spite of several attempts to find out solutions.

PRAHA team managed to negotiate and contract with The Air Conditioning, Heating and Refrigeration Technology Institute (AHRTI), the research arm of (AHRI) to take over the task as an internationally independent institute with relevant experience in conducting similar work i.e. AREP project (Alternative Refrigerants Evaluation Programme) and having access to several reputable testing and research centers within North America where the prototypes from PRAHA-I were being stored since end of PRAHA-I project. AHRTI, finally, selected Optimized Thermal Systems (OTS) as the most capable and sound research center for completing the planned work within the required timeline and budget.

## 3.2. Scope of Work

The scope of work that is covered by AHRTI's contractor OTS includes five activities as follows:

### ***Activity 1: Analyzing the Design of PRAHA-I Prototypes***

This task involved the following:

- Physical inspection
- Prior experimental results assessment
- First order assessment of component and refrigerant performance
- Development of validated model
- Detailed assessment of why the performance is "good, i.e. as designed" or "bad, why it did not perform as designed"

### ***Activity 2: Design Optimization***

Design optimization study for select units using the heat pump design model for available prototype units. This entailed:

- Acquiring performance maps for components (compressors, fans) that are more suitable for the application
- Evaluating alternate heat exchanger design configurations
- Performing detailed engineering optimization to match or exceed the baseline unit performance within acceptable design space set forth by an expert committee. This may include installing new upgraded compressors, for same refrigerants used in PRAHA-I that were not available at the time PRAHA-I prototypes were built; or compressors for refrigerants not tested under PRAHA-I; if so required.

### ***Activity 3: Prototype Units Fabrication***

AHRTI, in coordination with UN Environment, selected a subset of prototype units and modify them as per the design optimization study. This involved heat exchanger modification, compressor replacement, expansion valve fine-tuning, fans and blower replacements, etc. All components were from standard production lines.

### ***Activity 4: Evaluation of the Optimized Prototypes***

Optimized prototypes were tested in the multi-zone environmental chamber to evaluate their performance according to ASHRAE Standard 37 at relevant indoor and outdoor conditions (AHRI 210/240 "A" condition, ISO 5151 "T3" condition, hot and extreme conditions)

### ***Activity 5: Analyzing Leak-Recharge Effect for High Glide Alternatives***

The impact of leak-recharge effect on the performance of alternative refrigerants with high glide was experimentally evaluated.



### **Activity 6: Reporting and Data Management**

AHRI submitted a peer-reviewed project report prepared by OTS.

#### **3.3. Deliverables**

The key deliverables/results to be achieved are:

- a) Evaluation of prototypes tested under PRAHA-I
- b) Optimized PRAHA-I prototypes: three units chosen
- c) Analysis of leak-recharge of high glide alternatives on system performance
- d) Report summarizing the project findings.

#### **3.4. Matrix**

The work to be done is shown in the matrix Table 2. The work is in five phases:

- Evaluation of the prototypes;
- Optimization of selected prototypes;
- Building some of the units per the optimized design;
- Testing for a number of refrigerants;
- Leakage assessment.

The selection of units for the various activities as well as that of the refrigerants was done the PRAHA team in coordination with the AHRTI based on:

- For Activity 1, all units needed to be evaluated.
- For Activity 2 for the modeling activity of optimization, the team chose one unit from each application, i.e. window, decorative split, and ducted split. An extra decorative split unit running with HC-290 was also added since decorative splits are the most abundant in the market and the team felt it important to have two splits optimized, one with HC-290 and one with alternatives to R-410A. The team also tried to balance the refrigerants choosing both alternatives to HCFC-22 as well as R-410A. At the time of selection, there was no clear trend or indication from the industry as to which refrigerants would be commercialized. One of the refrigerants originally selected had to be dropped at the request of the supplier.
- For Activities 3 & 4, the window unit with HC-290 was chosen to be re-built and tested. These activities for the window unit had to be dropped for reasons mentioned under **Challenges and Modifications**. For the decorative and ducted splits units 6 and 10, the team chose to work with the same refrigerant alternatives as in Activity 2. Activities 3 and 4 finally worked on one decorative split (unit 6) and one ducted split (unit 10).
- For Activity 4, leak analysis, all the zeotropic blends used in activities 3 and 4 were planned to be tested.

For the unit numbering system, units 1 to 3 are window units, units 4 to 9 are decorative splits and units 10 to 12 are ducted splits.

**TABLE 2: MATRIX OF ACTIVITIES FOR THE PROTOTYPE OPTIMIZATION ELEMENT OF PRAHA-II**

		Activity 1	Activity 2	Activity 3	Activity 4	Activity 5
Unit	Type	Phase I data analysis	Optimization	Build per optimization	Test per build	Leak analysis
1	Window	L-20 (R-444B)	R-444B			
			R-454C			
			R-290	HC-290*	HC-290*	
			R-457A			
6	Decorative Split	HFC-32	HFC-32	HFC-32	HFC-32	
			R-454B	R-454B	R-454B	R-454B
10	Ducted	HCC-32	R-447B	R-447B	R-447B	R-447B
			R-452B	R-452B	R-452B	R-452B
4	Split	HC-290	HC-290			
2	Window	R-444B				
3	Window	DR-3 (R-454C)				
5	Split	HFC-32				
7	Split	L-41 (R-447A)				
8	Split	R-444B				
9	Split	R-454C				
11	Ducted	R-444B				
12	Ducted	R-454C				

\* Could not be completed due to 1) not fitting the timeline, and 2) the limitation of testing A3 packaged (window)

### 3.5. Project Monitoring

AHRTI assembled a project committee made up of AHRI members to help monitor and guide the project and set-up biweekly conference calls with OTS and the PRAHA management team. The calls, which started in November 2018, are normally held on the first and third Thursday of every month. As part of the bi-weekly update, OTS reports both on the progress as well as the technical aspects of the project and solving any possible problems that may arise

On such example is the participation of an additional refrigerant supplier in the project through the supply of information and quantities of refrigerant R-459A to test in one of the optimized and rebuilt prototypes. The problem of receiving response from the supplier was raised in one of the calls and the supplier was contacted by the PRAHA team. The supplier advised of its inability to provide R-459A timely and asked to withdraw from the project. R-459A was replaced by R-454B which has been gaining acceptance by the industry lately.

### **3.6. Challenges and Modifications**

The implementation of this portion of the PRAHA-II project came up with some challenges:

The tests that were carried out for PRAHA-I, while sufficient for the purpose of measuring capacity and energy efficiency for the purposes of PRAHA-I, did not have enough essential data to enable a complete cycle evaluation for optimization purposes.

Some key components and specifications, such as compressors and/or compressor maps for HC-290 and heat exchangers, were not readily available to fit in the project timeline.

The scheduling mechanism of the lab for PRAHA I (fixed test window) and testing logistics was not suited for completing of the project within the budget and required timeline. Therefore equipment performance testing was carried out in-house at OTS facility; however, its lab was not equipped to test the window unit of unit 1 working with A3 flammable refrigerant HC-290 (propane) due to safety concerns and requirements. Testing Unit 1 had to be dropped. Alternatively, the optimization of window unit was carried out using modeling approach.

Overall, the analyses presented by the design assessment through modeling provided good insights on adequate component design and/or selection for proper system functioning when using novel refrigerants. The tests in activities 3-5 partially served as validation for the models developed, and as check for previous test data from PRAHA I.

### **3.7. Project Implementation and Findings**

The full AHRTI report is an annex to this report. The summary of findings per activity are given below

#### **3.7.1. Activity 1 – Analyzing the Design of PRAHA-I Prototypes**

Activity 1 was comprised of three major tasks including: a) reception of 12 physical units at the OTS facility followed by visual inspection and parts identification; b) review of performance test reports from PRAHA I tests; and c), analysis of data and identification, for units of interest, opportunities for improvement targeting higher performance and minimal charge.

The twelve units are shown in Table 3 with the PRAHA-I test results and the new refrigerants to be used.

**TABLE 3: MATRIX OF UNITS AND NEW REFRIGERANTS TO BE TESTED**

Category	Unit #	Ref.	Designed Capacity Btu/h	Measured Cap. Btu/h	Voltage	Ref. (New designs)	Ref. (Tests)
Window	1	L-20 (R-444B)	18,000	19,104	208-230/60/1	R-444B, R-454C, HC-290, R-457A	HC-290
	2	L-20 (R-444B)	18,000	16,924	208-230/60/1		
	3	DR-3 (R-454C)	18,000	18,063	208-230/60/1		
Decorative splits	4	HC-290	24000 (18,000)	19,000	208-230/60/1	HC-290	HC-290
	5	HFC-32	24000 (18,000)	19,328	208-230/60/1		
	6	HFC-32	24,000	25,456	208-230/60/1	HFC-32, R-454B	HFC-32, R-454B
	7	L-41 (R-447A)	24,000	24,830	208-230/60/1		
	8	L-20 (R-444B)	24,000	22,740	208-230/60/1		
	9	R-454C	24,000	14,638	208-230/60/1		
Ducted splits	10	HFC-32	36,000	35,500	220-240/50/1	R-447B, R-452B	R-447B, R-452B
	11	R-444B	36,000	36,553	220-240/50/1		
	12	DR-3 (R-454C)	36,000	33,032	220-240/50/1		

Following is a summary of findings from Activity I

**A. Analysis of PRAHA-I Test Results:**

- **For the window units:** *Evaporator:* The inlet refrigerant temperature and pressure were not measured. The outlet pressure was estimated from suction pressure, a reasonable assumption given the short distance between the evaporator and compressor. The outlet temperature was measured so the superheat was computed. *Condenser:* The inlet refrigerant temperature and pressure were measured. The outlet pressure was not measured, but the outlet temperature was measured.
- **For the decorative splits:** *Evaporator:* The "Inlet Pressure" is the value measured at the service port at the exit of the outdoor unit, after the expansion device (capillary tubes). So, there is significant, but unmeasured pressure and saturation temperature drop between the measurement location and the actual inlet of the evaporator as abovementioned. The "Outlet Pressure" was measured at the service port before entering the outdoor unit. There was an unmeasured pressure drop in the suction line from the evaporator outlet to that measurement location. The inlet and outlet temperature measurements seem like reasonable numbers for the actual inlet and outlet. *Condenser:* The inlet pressure was not measured, the inlet temperature was measured, and the outlet pressure was only measured for Unit 4. The outlet liquid temperature was not measured, rather, the "OD Liq" temperature measurement was likely taken at the liquid service port, near the pressure

measurement. The temperature was much too low to be the actual condenser outlet, but not cold enough to be the evaporator inlet.

- **For the ducted splits:** *Evaporator:* The "Inlet Liquid" temperatures and pressures were taken before the TXV, so they were not actual measurements of the evaporator inlet condition. The outlet temperature and pressure measurements were available so the superheat could be calculated (lab used the compressor suction temperature rather than evaporator outlet temperature to compute superheat.) *Condenser:* The inlet temperature was measured, but the pressure was not. The outlet temperature and pressure were measured, so the sub-cooling was calculated. The sub-cooling computed by the lab ranged between 17 to 18°F, which doesn't correspond to the measured conditions. The calculated sub-cooling for Unit 11, however, was negative for all three tests; as such, it is possible that there was a two-phase refrigerant at the condenser outlet.

### B. Hardware Improvement Assessment

This section defines a first order analysis of the effect of hardware assessment for units 1, 4, 6, and 10. A first order analysis is structural analysis that is performed without taking the unit apart or making any changes to. The analysis is made for the different components.

#### Unit Component Modification Potential

Table 4 shows the detailed existing components for the units of interest for modification.

**TABLE 4: COMPONENTS FOR UNITS 1, 4, 6, AND 10**

System	Unit 1	Unit 4	Unit 6	Unit 10
Refrigerant	R444B	R290	R32	R32
Compressor	HIGHLY SL260DG-C8EU	HIGHLY PSH356DG-C8DU3	GMCC KSG226N1UMT	Copeland ZP42K5E-PFJ-XXX
Condenser	5mm Louver TFHX	9.5mm Wavy TFHX	7mm Louver TFHX	9.5mm Louver TFHX
Expansion Device	Capillary Tube	Capillary Tube	Capillary Tube	Capillary Tube
Evaporator	9.5mm Louver TFHX	7mm Louver TFHX	7mm Slit TFHX	9.5mm Louver TFHX

- **Heat Exchangers (HX):** OTS put as an objective to improve performance while minimizing charge. One way of addressing both objectives is by reducing the tube/channel diameter since heat transfer coefficients are inversely proportional to tube diameters. Pressure drop is also inversely proportional to tube diameter so smaller tubes result in reduced size and reduced internal volume but higher pressure drop.

A qualitative analysis using values from literature was carried out to demonstrate the relative impact of diameter over abovementioned metrics, specifically: heat transfer coefficient, compactness and overall thermal conductance (UA). The left-hand side plot in Figure 3 shows three curves inversely proportional to the diameter; a 5mm tube can achieve, in this example, 70% greater UA than a conventional 9.5mm, within the same cabinet.

These are further explored to illustrate the impact on a system level. Systems respond to UA of both condenser and evaporators, but for the purposes of this analysis, the condenser is only considered. UA represents the overall thermal conductance, which will impact the approach temperatures in the system ( $\Delta T_{app}$ ). If the heat of rejection is kept constant, the higher the UA, the smaller are the  $\Delta T_{app}$ 's, thus allowing the condenser to operate in lower pressure levels, which will consequently increase the system performance. An example using a hypothetical HFC-32 cycle with an EER of 12 as base is shown in the right-hand side plot in Figure 3. Performance improvement is limited by the Second Law, when the approach temperatures near zero. In this illustration, the EER has the potential to increase by over 20% with better condenser design alone.

It is imperative to note that the results presented in this section are first order analysis for illustration purposes only. Further in this report it is presented in more detail a re-design framework, applied to the units of interest in this project, using the metrics outlined in this section.

Unit 1 already had a 5mm condenser, which limits the options for HX re-design. Unit 6 had a 7mm HX on both the indoor and outdoor units, which allows some room for improvement if reducing to 5mm. Lastly, both coils for Unit 10 had 9.5mm tubes, thus there is greater potential for charge reduction and performance improvement for that unit in particular.




FIGURE 3: HEAT EXCHANGER FIRST ORDER ANALYSIS (FOA)

- **Compressors:** The existing units mostly use compressors sized specifically for R-410A or HCFC-22 and in some cases custom made for the particular application. This presents an opportunity for a better compressor selection when migrating to other refrigerants such as R454B or R447B on Units 6 and 10, respectively. A compressor designed for a particular refrigerant having a higher efficiency rating will result in better energy efficiency performance of the same unit.
- **Expansion Devices:** Expansion devices such as TXV's and EXV's may allow for better control and reduced losses in connecting pipes if located near the evaporator. Some units, such as 6 and 10, have a capillary tube in the outdoor unit, which forces the refrigerant to travel in two-phase

along the connecting pipes, and at lower temperatures, thus increasing pressure drop and heat gain. In some regions, expansion devices are installed in the outdoor units for noise control purposes.

- **Fans and Blowers:** Replacing the fan and blower may be necessary if newly designed HXs offer considerable change in pressure drop over the baseline since the flow rates are kept constant. The lack of test data on pressure drop forces us to rely on predicted values only.

### 3.7.2. Activity 2 – Design Improvements

OTS developed improved designs for some units, including use with additional refrigerants. The main goals were to maintain capacity while minimizing internal volume (refrigerant charge) and maximizing performance (COP). The exercise in optimizing the improved designs is subject to limitation in component availability from pre-established vendors. The activity involved:

- Developing a cycle simulation model for each of the baseline systems.
- Calibrating the models using the data provided in Activity 1 (relying on the performance test data for the three ambient conditions).
- For each system, evaluating whether the existing compressor and fans are the best fit, or if alternate designs would be preferred.
- Evaluating heat exchanger design options and suppliers for alternative off-the-shelf solutions. As appropriate, conduct a thorough parametric analysis study for the air-to-refrigerant heat exchangers for use with the alternative refrigerants. In addition to heat exchanger type and/or tube diameter and fin pattern, this may include revised circuitry.
- For each of the targeted design cases/refrigerants, evaluating the performance of optimum component selections and quantifying any anticipated performance gains.

Following is a summary of findings from modeling and simulation:

- A. Hardware:** A first order analysis in Activity 1 showed that moving towards smaller hydraulic diameter tubes can be beneficial from a charge reduction standpoint. Units 4 and 10 use conventional 9.5mm diameter tube condensers making them good candidates for condenser replacement with either a smaller tube diameter or a microchannel heat exchanger (MCHX). The compressors used on Units 1, 4 and 6 do not have available performance maps making it difficult to assess their fitness for the system. The focus of this study is on proper compressor selection and condenser re-design.
- B. Refrigerant:** HC-290 and HFC-32 have wider saturation regions, as can be seen from Figure 4 and Figure 5 for P/h and T/s, putting them at an advantage since they may operate with smaller superheat and sub-cooling, while benefiting from two-phase heat transfer. Their cycles may get closer to that of the ideal Carnot cycle compared to refrigerants with narrower saturation. Although this appears to be the case, this is not universally true for mixtures since they can exhibit other properties that make them suitable for certain designs.




FIGURE 4: P-H AND T-S DIAGRAMS FOR HCFC-22 ALTERNATIVES





FIGURE 5: P-H AND T-S DIAGRAMS FOR R-410A ALTERNATIVES

Amongst the blends investigated for Unit 1, R-444B has the widest saturation region while also having the highest temperature glide Figure 6 .The latter is typically not beneficial, in particular for evaporators, but it may help the condenser. The glide enables the refrigerant temperature profile to get closer to the air temperature profile without crossing (Figure 6). From a thermodynamic perspective, this means R-444B can have its condensing pressure reduced further, resulting in higher theoretical COP.





**FIGURE 6: PROFILES OF REFRIGERANTS**

For Units 6 and 10, the investigated blends, although having narrower saturation than the baseline R32, have similar thermophysical characteristics (Figure 4) with lower temperature glides (Figure 6/Figure 7) making them more competitive from a capacity and performance perspective.

**C. System Design Optimization / Modification Framework:** The framework consists of a retrofit of the existing units by properly designing and selecting components that can be replaced with no modification of the cabinets. In other words, any component replaced must occupy the same envelope as the baseline component. The focus of the re-design is on:

- Compressor
- Condenser, and
- Expansion valve

The evaporator designs were not changed for two main reasons: a) some are custom-made wrap-around the blower units, such as in Unit 6, making it hard to quickly find an off-the-shelf option; and, b) the goal is to deliver the same cooling capacity while improving efficiency. For the latter, there is more room for improvement in the condenser by reducing condensing pressure, assuming the evaporator can already deliver the expected capacity.

The fans and blowers were also not considered for change, in part due to the lack of information on the performance curves from the baseline models, but also due to potential high cost and lead time for replacement with secondary impact on performance since 80-90% of the power consumed comes from the compressor.

The first step to assess the level of performance required for each component is to investigate an improved theoretical cycle, which will indicate how much COP improvement can be expected, as well as refrigerant flow rate needs and HX size (UA). To improve the performance of a vapor compression cycle, the pressure lift between evaporating and condensing pressures must be reduced. Consequently, the approach temperatures between air and refrigerant will be reduced as well (Figure 7), thus the thermal capacitance of the heat exchangers must increase. Furthermore, the closer to the saturation region, the closer the cycle reaches the ideal Carnot efficiency (Figure 8).




FIGURE 7: ILLUSTRATIVE T-S DIAGRAM FOR BASELINE AND IMPROVED CYCLE




FIGURE 8: DIAGRAM ILLUSTRATING COP IMPROVEMENT A) REAL CYCLE, B) IDEAL CYCLE (CARNOT)

The system design framework is performed according to Figure 9




FIGURE 9: SYSTEM DESIGN FRAMEWORK

C. **Compressors:** Modeling compressors are handled in two possible ways, as suggested previously: using performance maps when available or using fixed isentropic efficiency and effective displacement volume. For the larger capacity units (6 and 10), performance maps were provided. Although these compressors were originally designed for R410A refrigerant they may operate – not necessarily optimally – with other refrigerants. Compressor manufacturers supporting this project used proprietary simulation tools, with aid from available empirical data (tests with other refrigerants), to develop theoretical maps for the various refrigerants of interest (Table 5) and made them available to OTS for modeling purposes. It is understood that the predictions are for reference only, and the compressor manufacturer does not guarantee performance for any refrigerants for which the compressors haven't been fully tested.

TABLE 5: COMPRESSOR MODELS

Model	Capacity (BTU/hr)	Frequency (Hz)	Refrigerants
ZP20K5E-PFV	24,000	60	HFC-32, R-454B, R-410A
ZP21K5E-PFV	24,000		
ZP31K6E-PFV	36,000	50/60	R-447B, R-452B, R-454B, R-410A
ZP34K6E-PFV	36,000		

For the smaller units (1 and 4), which were re-designed using HC-290 (Propane), compressor performance maps were not available. The approach for these units then was to set a target isentropic efficiency of 0.7 (baseline data suggests that the compressor efficiencies ranged from 0.55 to 0.65). The required mass flow rate is calculated based on capacity in the theoretical cycle model described above. From there, the effective displacement volume can be determined by the

equation below<sup>1</sup>. The latter serves to determine whether a system can use the same compressors for different refrigerants.

$$V_{eff} = \eta_{vol} \cdot V_{disp} = \frac{\dot{m}_{required}}{f \cdot \rho_{suction}}$$

D. **Heat Exchangers:** The condensers design procedure takes into consideration the following:

- **Face area:** baseline face area must be preserved or at most reduced. Furthermore, the aspect ratio must also match that of the baseline so the HX can be drop-in replaced in the same cabinet.
  - o Find the number of tube rows and tube length to match as closely as possible to tube face area and aspect ratio
- **Airside pressure drop and flow rate:** the test data from reports contain only air flow rate measurements, while no information on pressure drop is provided. Additionally, the fan performance curves are also not available, which limits the ability to find the exact operating condition. The baseline models provide an estimate prediction for the pressure drop, which is used as reference.
- **Thermal performance:** this step must be iteratively conducted with the previous step, as such for each design change the air flow rate and capacity are evaluated under the new conditions found in the theoretical cycle re-design.
  - o Gradually increment the condensing pressure until attainable performance is achieved. This process is done iteratively using the theoretical cycle model, to find new expected operating conditions for evaporating pressure, superheat, sub-cooling and refrigerant flow rate.
- **HX Form:** as indicated previously, the HX design is constrained by cabinet dimensions as well as form. In the case of units 1 and 4, the condensers are flat coils placed 90° inside the cabinet (Figure 10), which makes it simpler for drop-in replacement as long as new designs have the same overall dimensions. For units 6 and 10, however, the condensers are L-shaped inside the cabinet (Figure 10). Forming coils is widely done, however, for custom coils it may be a challenge, in particular for MCHX. For this reason, the MCHX designs for units 6 and 10 are sized for a full-face area, assuming the coil can be formed, and a second design that is a single flat slab placed in longer side of the “L” shape (Figure 11).

---

<sup>1</sup> See Nomenclature at the end of this chapter



FIGURE 10. CONDENSER FORMS: UNIT 1 (LEFT), UNIT 10 (CENTER), UNIT 6 CABINET (RIGHT).




FIGURE 11. HX FORM EXAMPLES: L-SHAPE (LEFT), FLAT (RIGHT).

## Summary of Results for Activity 2

Table 6 shows the summary from the design simulation activity

**TABLE 6: ACTIVITY 2 RESULTS.**

System	General Information			Hardware					Performance	
	Rated Capacity (@35°C)	System Configuration	Refrigerant	Compressor		Condenser		Exp Device	CC @ 46°C	EER @ 46°C
-	BTU/hr	-	-	Effective Disp. Vol. (cm <sup>3</sup> )*	Efficiency (-)	Type	Effectiveness (-)	Type	%	%
Unit 1	18000	Baseline	R-444B	19.8	0.66	Tube-Fin (5mm Tube)	0.20	Passive	0.00%	0.00%
		Alternate 1	HC-290	25.9	0.70	Same as Baseline	0.35	Active (EXV)	1.40%	8.20%
		Alternate 2	R-454C	24.8	0.69		0.26		4.00%	-1.30%
		Alternate 3	R-444B	19.6	0.70		0.23		4.20%	9.90%
		Alternate 4	R-457A	25.3	0.68	MCHX	0.24	2.00%	3.10%	
Unit 4	24000	Baseline	HC-290	26.4	0.61	Tube-Fin (9.5mm Tube)	0.24	Passive	0.00%	0.00%
		Alternate 1	HC-290	26.3	0.70	Tube-Fin (5mm Tube)	0.26	Active (EXV)	1.20%	21.40%
		Alternate 2	HC-290	37.9	0.70		0.20		34.40%	-10.60%
Unit 6	24000	Baseline	HFC-32	16.0	0.60	Tube-Fin (7mm Tube)	0.12	Passive	0.00%	0.00%
		Alternate 1	HFC-32	16.9	0.65	Tube-Fin (5mm Tube)	0.15	Active (EXV)	3.00%	11.20%
		Alternate 2	R-454B	18.4	0.67		0.19		-1.00%	14.80%
		Alternate 3	R-452B	19.0	0.70		0.17		2.50%	13.50%
Unit 10	36000	Baseline	HFC-32	19.6	0.44	Tube-Fin (9.5mm Tube)	0.13	Passive	0.00%	0.00%
		Alternate 1	R-447B	22.3	0.65	Tube-Fin (5mm Tube)	0.25	Active (EXV)	5.10%	47.50%
		Alternate 2	R-452B	23.0	0.67		0.25		6.20%	60.70%
		Alternate 3	R-454B	23.3	0.67		0.25		6.20%	56.50%

\* Product of displacement volume and volumetric efficiency

The General Information describes the baseline unit with the alternate refrigerants used, while the Hardware describes the Compressor, Condenser and the Exp. (expansion) Device for each alternative.

The performance at 46°C is given as a percentage of the baseline performance for the cooling capacity (CC) and Efficiency (EER).

For unit 1 (window unit), the optimized design with the same refrigerant as the baseline can improve EER by 9.9% and using HC-290 can lead to an improvement in the EER by up to 8%.

For unit 4 (decorative split with HC-290), the baseline unit which was supposed to be a true 24,000 Btuh unit had an 18,000 Btuh (26.4 cm<sup>3</sup> effective displacement) compressor with a 24,000 Btuh coils. Optimizing the unit with an 18,000 Btuh compressor would lead to 21.4% improvement in EER, while if a 24,000 Btuh compressor (37.9 cm<sup>3</sup> effective displacement) is used, the EER drops by 10.6%.

The other decorative split (unit 6) running with HFC-32 shows an improvement in EER for all alternative refrigerants.

The unusual results for unit 10 (ducted split) showing a 50% increase in EER is due to using bigger condensers (0.25 effectiveness vs 0.13 for the baseline).

### 3.7.3. Activities 3, 4, and 5

#### A. Scope and Implementation of activities

##### Activity 3: Prototype Units Fabrication

Using design decisions made in Activity 2, OTS constructed two prototypes out of the three that were targeted (see section 4.6 Challenges and Changes). The two units are outlined in Table 7.

**TABLE 7: PROTOTYPE UNITS FOR COMPONENT MODIFICATION AND FURTHER TESTING**

Category	Unit	Refrigerant(s) for Prototype Development
Decorative Split	6	HFC-32
		R-454B
Ducted Split	10	R-447B
		R-452B

This activity involves modifying the existing prototypes to include the new components while making additional changes, such as adding valves, to enable leak testing in Activity 5.

##### Activity 4: Evaluation of the Optimized Prototypes

This activity involves physically testing performance of the modified units for at least two ambient conditions:

- ❖ Measurement points include:
  - a. Refrigerant Side
    - i. Compressor suction – temperature, pressure
    - ii. Compressor discharge – temperature, pressure
    - iii. Expansion valve inlet – temperature, pressure
    - iv. Evaporator Inlet – temperature, pressure
    - v. Evaporator Outlet – temperature
  - b. Air Side
    - i. Environmental chamber ambient temperature, relative humidity
    - ii. Condenser incoming air temperature

- iii. Condenser exhaust air temperature
- iv. Evaporator incoming air temperature
- v. Evaporator exhaust air temperature
- vi. Evaporator pressure drop
- vii. Indoor air flow rate
- c. Power
  - i. Compressor
  - ii. Fans
  - iii. Any additional controls or electrical components
- ❖ Conduct troubleshooting measures, as needed, to confirm operation prior to start of testing.
- ❖ Charging the unit was conducted at 35°C (95°F) in the outdoor unit environmental chamber. Conduct a charge optimization to assess the most appropriate refrigerant charge given the test set-up. This will include testing the unit at three different charge amounts to determine the charge that produces the best possible result (COP) at the rating condition. Conducting this step ensures appropriate charge levels and good measurement values.
- ❖ Tests repeated at the high ambient condition T3 (46°C outdoor).
- ❖ Test data analyzed and compared against the modeling predictions from Activity 2. Any system modifications that have potential to improve performance, including further adjustments to the refrigerant charge, were identified.

#### Activity 5: Analyzing Leaks of Alternatives

In addition to addressing the performance of the individual systems, analysis on refrigerant leakage is needed to meet Project Objective #3. Additional testing were conducted following the performance tests

#### Results

The detailed outcomes and test data can be found in the OTS report which is attached to this report. The following is a summary of the results:

#### Unit 6

Some modifications were made to Unit 6 to improve its efficiency. The baseline compressor was replaced with alternate models to account for the change in refrigerant and to improve efficiency. The compressor used with R-454B had a higher displacement volume than the one used with HFC-32. Furthermore, the capillary tubes were replaced with a manual throttling valve simulating the TXV that was installed directly at the evaporator inlet to increase the cooling capacity of the evaporator. A summary of the design modifications evaluated for Unit 6 is listed in Table 8.

Tables 9 and 10 show the performance of Unit 6 for baseline and modifications at 35°C and 46°C ambient, respectively. There is a discrepancy in the measurements from condenser outlet to expansion inlet in the baseline case, since the capillary tube (removed in the modified systems) was located in the outdoor unit. The expansion causes the refrigerant to flash in the liquid line thus compromising the readings at the expansion device. For calculation purposes, the condenser outlet enthalpy was used instead of the expansion inlet.



**TABLE 8: UNIT 6 MODIFICATIONS FOR TESTING.**

System	Unit 6		
	Baseline	Alternate 1	Alternate 2
Refrigerant	R32	R32	R454B
Compressor	GMCC KSG226N1UMT	Copeland ZP20K5E	Copeland ZP21K5E
Expansion Device	Capillary Tube (outdoor unit)	Manual valve <sup>2</sup> (indoor unit)	Manual valve (indoor unit)

Cooling capacity for the modified unit with either refrigerant was consistently lower by 6-12% than the baseline. The modified HFC-32 system reportedly showed lower mass flow rate than expected, likely the main cause for the lower-than-expected thermal performance. The R4-54B system resulted in a lower performance but was less sensitive to ambient temperature than its R32 counterpart - i.e. cooling capacity was near the same at both 35°C and 46°C, while for HFC-32 there was a ~2,000 BTU/hr reduction with the temperature increase. It is also possible that there is a mismatch between thermophysical property library and actual refrigerant properties for R454B which can happen with newer fluids. The libraries need periodic update as more test data become available.

**TABLE 9: UNIT 6 - PERFORMANCE TEST SUMMARY FOR R32 BASELINE (OTS) @ 35°C.**

		Baseline (35°C)	Alternate 1 (35°C)	Alternate 2 (35°C)	Alt. 1 vs. Baseline	Alt. 2 vs. Baseline
Refrigerant	-	HFC-32	HFC-32	R-454B	-	-
Charge	lbs.	3.83	4.27	5.02	11.5%	31.1%
Cooling Capacity	BTU/hr	25,192	23,585	21,966	-6.4%	-12.8%
Energy Balance	%	-2.28%	-4.66%	-3.06%	-	-
Compressor Power	kW	2.11	1.79	1.77	-15.1%	-16.2%
Fan Power	kW	0.32	0.33	0.33	2.2%	2.2%
Total Power	kW	2.43	2.12	2.10	-12.8%	-13.5%
EER	BTU/hr. W	10.37	11.12	10.44	7.2%	0.68%

**TABLE 10: UNIT 6 - PERFORMANCE TEST SUMMARY FOR R32 BASELINE (OTS) @ 46°C.**

		Baseline (46°C)	Alternate 1 (46°C)	Alternate 2 (46°C)	Alt. 1 vs. Baseline	Alt. 2 vs. Baseline
Refrigerant	-	HFC-32	HFC-32	R-454B	-	-
Charge	lbs.	3.83	4.27	5.02	11.5%	31.1%
Cooling Capacity	BTU/hr	23,390	21,450	21,821	-8.3%	-6.7%
Energy Balance	%	-1.78%	-4.42%	-7.61%	-	-
Compressor Power	kW	2.71	2.32	2.25	-14.2%	-16.6%
Fan Power	kW	0.40	0.42	0.42	5.3%	5.3%
Total Power	kW	3.10	2.74	2.67	-11.7%	-13.8%
EER	BTU/hr. W	7.55	7.84	8.17	3.8%	8.2%

<sup>2</sup> A manual valve was used to mimic a TXV or EXV; recommended as component modification in these systems.

## Unit 10

Applying what was learned in the initial modifications to Unit 6, modifications to Unit 10 were limited to include the compressor and expansion device only. Unlike Unit 6, however, the re-test of the baseline system was not successful; refer Appendix D of the OTS report for additional information. However since Unit 6 baseline re-test showed good reproducibility from original data, it is assumed that the Unit 10 original baseline will act similarly. A summary of the design modifications evaluated for Unit 10 is listed in Table 11. The detailed test data is presented in Appendix E of the OTS report.

**TABLE 11: UNIT 10 MODIFICATION FOR TETSING**

System	Unit 10		
	Baseline	Alternate 1	Alternate 2
Refrigerant	R32	R447B	R452B
Compressor	Copeland ZP42K6E	Copeland ZP34K5E	Copeland ZP31K5E
Expansion Device	Orifice	Manual Valve	Manual Valve

At 35°C the modified units exhibited almost 20% less cooling capacity with 10% less power consumption, resulting in up to 11% less EER (Table 12). These results were not unexpected since the modified units were re-designed using the 46°C temperature, when the baseline system's performance showed a great degradation of performance. At 46°C condition, the tests confirmed exhibited 2-5% greater cooling capacity with up to 12% less power consumption compared to the baseline, which was equivalent to 13-17% greater system performance.

In Activity 2 the compressor power consumptions were underestimated, as well as the total fan power consumption, leaving the impression the overall performance improvement would considerably be greater than the observed. The cooling capacity, on the other hand, was predicted with less than 2% deviation from test data, validating at least the models created.

**TABLE 12: UNIT 10 - PERFORMANCE TEST SUMMARY AT 35°C.**

		Baseline (35°C)	Alternate 1 (35°C)	Alternate 2 (35°C)	Alt. 1 vs. Baseline	Alt. 2 vs. Baseline
Refrigerant	-	HFC-32	R-447B	R-452B	-	-
Charge	lbs.	5.625	6.625	6.625	17.78%	17.78%
Cooling Capacity	BTU/hr	35,543	32,195	28,128	-9.42%	-20.86%
Energy Balance	%	---	7.52%	-3.29%	-	-
Compressor Power	kW	-	2.67	2.4	-	-
Fan Power	kW	-	0.95	0.98	-	-
Total Power	kW	3.761	3.62	3.38	-3.75%	-10.13%
EER	BTU/hr. W	9.451	8.894	8.322	-5.89%	-11.94%

**TABLE 13 : UNIT 10 -PERFORMANCE TEST SUMMARY AT 46°C**

		<b>Baseline (46°C)</b>	<b>Alternate 1 (46°C)</b>	<b>Alternate 2 (46°C)</b>	<b>Alt. 1 vs. Baseline</b>	<b>Alt. 2 vs. Baseline</b>
<b>Refrigerant</b>	-	<b>HFC-32</b>	<b>R-447B</b>	<b>R-452B</b>	-	-
<b>Charge</b>	lbs.	5.625	6.625	6.625	17.78%	17.78%
<b>Cooling Capacity</b>	BTU/hr	29,633	31,073	30,292	4.86%	2.22%
<b>Energy Balance</b>	%	---	4.21%	1.21%	-	-
<b>Compressor Power</b>	kW	---	3.18	2.93	-	-
<b>Fan Power</b>	kW	---	0.95	0.97	-	-
<b>Total Power</b>	kW	4.466	4.13	3.9	-7.52%	-12.67%
<b>EER</b>	BTU/hr. W	6.64	7.52	7.76	13.33%	16.95%

### Leak Tests

In the interest of time the leak tests were conducted only on Unit 10 for R447B. The choice of refrigerant was based on temperature glide, where R447B exhibits the highest glide amongst the refrigerants evaluated between Unit 6 and Unit 10 (refer to Figure 6). The leak tests were conducted to closely represent field operation. The procedure applied include the following steps:

- 1- Run unit until steady-state is achieved (repeat 46°C performance test), monitoring capacity and sub-cooling
- 2- Gradually remove refrigerant from vapor line until capacity is reduced to approximately 50%, if possible
- 3- Store and weigh removed refrigerant
- 4- Re-charge with new refrigerant until same sub-cooling is achieved
- 5- Compare cooling capacities; if more than 5% deviation is observed, repeat steps 1-4, however in step 2, reduce capacity to 25% only
- 6- Repeat steps 1-5 for the liquid line

The comparison herein presented refers to a leakage of approximately 30% of charge, while reducing capacity in approximately 50% based on airside only. The leak tests showed less than 2% deviation in cooling capacity after re-charge from both vapor and liquid lines (Table 14). Since the capacity deviation was less than 5%, no further testing for 25% capacity reduction was conducted. The results suggest little impact due to fractionation.

**TABLE 14: UNIT 10 – R447B LEAK TEST SUMMARY RESULTS.**

System			Liquid Line Leak		Vapor Line Leak	
			Full Charge	Low Charge	Re-Charged	Low Charge
Refrigerant	-	R-447B	R-447B	R-447B	R-447B	R-447B
Charge	lbs.	6.625	4.27	6.625	4.23	6.77
Cooling Capacity	BTU/hr	31,073	14,216	30,865	15,171	30,587
Energy Balance	%	4.21%	-34.72%	0.35%	-31.55%	1.87%
Compressor Power	kW	3.18	2.93	3.18	2.94	*
Fan Power	kW	0.95	0.98	0.98	0.98	0.98
Total Power	kW	4.13	3.90	4.16	3.92	*
EER	BTU/hr. W	7.52	3.64	7.42	3.87	*

\*Compressor power consumption was not properly recorded for this test; the error was identified after the fact and the team was unable to retrieve that information. While that compromises the assessment of the overall system performance, the deviations are expected to be marginal. The leak test on liquid line suggest minimal impact on power consumption after re-charge, while cooling capacity was reportedly fully recovered after recharge on both leak tests.

### **3.8. Conclusion and Recommendations from the Optimization Element**

The original scope and schedule were modified during the project as new findings and challenges surfaced. The data analysis and processing from the tests conducted in the PRAHA-I project showed that more testing parameters and instrumentation would have been needed to support the optimization and/or redesign process within the scope of PRAHA-II since PRAHA-I was designed to conduct testing and comparison of cooling capacity vs. EER for the prototypes against the baseline units from same manufacturers. This affected the evaluation of the units’ performance and consequently in building the baseline models.

The Conclusion from **Activity 1** is that for systems operating in considerably higher temperatures (greater than 46°C), the resultant impact on performance must be considered since performance will degrade compared to operating under more temperate conditions. Furthermore, the discharge temperature should be considered when selecting alternative refrigerants.

The key components for performance improvement identified were the compressor, condenser and expansion device.

- At higher temperatures, the saturation temperatures and refrigerant density at the compressor suction port can be very different than that from the rated conditions. Larger displacement volumes and efficiency curves optimized for higher pressure lifts might be required. Therefore, the proper selection of the compressor is paramount.

- A better performance condenser will reduce the approach temperature between refrigerant and air, reducing discharge pressure.

At high ambient conditions, the system is forced to operate in higher pressure lift than at rated conditions, but still requires a certain refrigerant mass flow rate. Passive devices such as capillary tubes and orifices may not be able to provide enough expansion to allow the system to operate in higher temperature conditions. An active expansion device such as Electronic expansive valve (EXV) can adequately control operating conditions and maintain design superheat.

The analyses presented in **Activity 2** (design evaluation through modeling) provided good insights on adequate component design and/or selection for proper system functioning when using alternative refrigerants. The tests in activities 3-5 partially served as validation for the models developed, and as check for previous test data from PRAHA I. The key conclusions and recommendations are:

- I. HC-290 and HFC32 have wider saturation regions allowing the system to operate with smaller superheat and sub-cooling, while benefiting from two-phase heat transfer.
- II. Refrigerants with high temperature glide may require new heat exchanger (HX) designs, namely condensers. The original designs proved to be sufficiently effective to allow for most systems to operate with the different refrigerants; however, better designs would allow for higher system efficiency and potentially less charge. HX designs are severely constrained by allowed envelope dimensions. A complete system re-design would provide an opportunity for designing HX's with even higher efficiency.
- III. The results of this analysis suggest that for an effective use of alternate low-GWP refrigerant, a proper compressor selection must be done. Higher isentropic efficiencies are desired for higher temperatures, but most importantly, the displacement volume requirements can vary from one refrigerant to another.
- IV. It is also imperative that having an active expansion device (preferably an EXV) to not only allow for more controlled superheat, but also to enable the unit to run with different refrigerants with very different thermophysical properties.

#### For Activities 3, 4, and 5

- I. Unit 6 re-tested baseline exhibited similar performance to that found in PRAHA I testing. It should be stressed that the baseline unit by design had its capillary tube located in the outdoor unit. This would cause liquid refrigerant leaving the outdoor unit to flash. The refrigerant enthalpy at the condenser outlet state was used to calculate the refrigerant-side capacity assuming an isenthalpic expansion without heat loss in connecting pipe. This is different from the modified systems of which the capillary tube was removed, and a manual expansion valve was placed at the inlet of the indoor unit. For modified systems, the enthalpy at the expansion valve inlet was used to calculate the refrigerant-side capacity.
- II. The Unit 6 modified systems had lower performance than expected from the Activity 2 models. The R32 system configuration exhibited more than 10% less flow rate than anticipated due to performance maps over prediction, which corresponded to 10% lower capacity. The R454B configuration exhibited a deviation of 5% between model and test due also in part to a 3% flow rate over prediction in the model.
- III. Unit 10, on the other hand, exhibited an excellent agreement to the models with less than 2% deviation in cooling capacity.

- IV. Unit 10 exhibited a considerable reduction in power consumption at the high ambient test condition (46°C) as compared to the original test data. This also indicates the importance of proper compressor selection.
- V. The higher-than-expected power consumption in the Unit 10 baseline tests is also evidenced by the fact that even with zeotropic mixtures (R-447B and R-452B), Unit 10 had higher cooling capacity and efficiency than the baseline for the 46°C test condition, as projected in activity 2.
- VI. Because of the differences in saturation curves from the Activity 2 analysis, HFC-32 tends to result in systems with higher efficiency and less charge when no modifications to the hardware are made. The results showed however, that making appropriate component selection, such as compressors with larger displacement volumes for the other refrigerants, cooling capacities and overall performance were of the same order of magnitude.
- VII. Refrigerant fractionation as evidenced by the leak tests, does not appear to be a great concern since less than 2% in cooling capacity was observed after the system's re-charge.
- VIII. The model validation adds confidence in the numerical simulation findings and recommendations provided in activity 2.

The **recommendations** for future development are:

- Establish a baseline system by conducting comprehensive testing including measurements and metrics not typically performed in energy certification tests.
- Replacing refrigerants is viable and can be competitive to presently used refrigerants but doing so requires proper component design and selection; compressor and expansion device particularly. Drop-in replacement without hardware change is never recommended.
- It is recommended to always perform numerical simulations, and to conduct at least some level of "soft" optimization analyses that will provide information for an educated system re-design / retrofit at much lower costs than gradual trial-and-error changes.
- Always test the modified systems in the same test setup as the baseline, with the same instrumentation.

## *Nomenclature*

COP	Coefficient of Performance	-
$D_o$	Tube Outer Diameter	mm
f	Frequency	Hz
FPI	Fins per Inch	1/in
h	Enthalpy	kJ/kg
$h_t$	Tube Height	mm
HX	Heat Exchanger	-
$\dot{m}$	Mass Flow Rate	kg/s
MCHX	Microchannel Heat Exchanger	-
P	Pressure	kPa
$P_l$	Tube Longitudinal Pitch	mm
$P_t$	Tube Transverse Pitch	mm
s	Entropy	kJ/kg.K
T	Temperature	°C
TFHX	Tube-Fin Heat Exchanger	-

UA	Thermal Conductance	kW/K
V	Volume	m <sup>3</sup>
w <sub>t</sub>	Tube Width	mm
η <sub>vol</sub>	Volumetric Efficiency	-
ρ	Density	kg/m <sup>3</sup>

## 4. Risk Assessment

This component includes designing, developing and examining a risk assessment model suitable for the use pattern and operating conditions at high ambient conditions and in particular for the Gulf Cooperation Council (GCC) region. The plan was to coordinate with local institutes and experts in HAT countries to build a special risk assessment model that suits the countries' local needs and operating conditions. This process was to be conducted through the following elements:

- I. Developing comprehensive terms of reference for building the local risk assessment model;
- II. Analyzing the needs of local technical and research institutes to implement the risk assessment model including the technical capacities of personnel and laboratories;
- III. Examining the risk assessment model and validating its applicability at levels of manufacturing, installations, operation and servicing.

Each of the above elements was to be led by a local research institute in consultation and cooperation with international associations partnering in this project. This chapter explains what was achieved given the large scope of this component of PRAHA-II.

### 4.1. Background on Risk Assessment

The concept of risk assessment in RACHP applications is fairly new as it was introduced with the advent of flammable refrigerants. A brief background is presented in this section to explain the concept and the different terms.

#### 4.1.1. Flammability Definition and Classes

##### Flammability

For a fire to happen there needs to be three elements: a rapid leak of the flammable gas, a concentration higher than the lower flammability level, and a source of ignition as shown in figure below. Figure 12 shows the probability of ignition as the resultant of these three elements. Lower Flammability Limit (LFL), usually expressed in volume per cent, is the lower end of the concentration range over which a flammable gas can be ignited at a given temperature and pressure.




FIGURE 12: FACTORS AND PROBABILITY OF IGNITION



$$Probability = [rapid\ Leakage] \times [High\ Concentration] \times [Ignition\ Source]$$

This report does not aim to cover all aspects of flammability such as the ignition source energy and speed of propagation etc.

Flammability Classification for Refrigerants: Table 15 shows the classes of flammability as defined in ISO 847 and ASHRAE 34.

**TABLE 15: FLAMMABILITY CLASSIFICATION FOR REFRIGERANTS**

Class	
1	No flame propagation when tested at 60°C and 101.3 kPa
2	Flame propagation and LFL > 0.1 kg/m <sup>3</sup> and HOC < 19,000 kJ/kg
2L	Same as 2 except Burning Velocity < 10 cm/s
3	Flame propagation and LFL ≤ 0.1 kg/m <sup>3</sup> and HOC ≥ 19,000 kJ/kg

Refer to Annex II for a discussion on safety and standards.

#### **4.1.2. Concept of Risk Assessment**

The concept behind risk assessment is to define what is an acceptable risk given the conditions for ignition in a particular location. To begin with, a definition of risk is agreed upon and a matrix of probability vs. severity is built. For this purpose, this report adopts the work done by JRAIA in Japan.

##### **Definition of Risk**

Risk is a combination of the probability of concurrence of harm and the severity of that harm. Tolerable risk is the level of risk that is accepted in a given context based on the current acceptable values by a community. Residual risk is the risk remaining after reduction measures have been implemented. Safety is freedom from risk which is not tolerable.

The risk levels depend on the severity of injury, the amount of damage to the environment, the frequency at which people are exposed to the danger and the duration of exposure.

Tolerable risk is determined by the search for an optimal balance between the ideal absolute safety and the demands to be met by a product. The factors influencing risk are the practicality and means to reduce risk, the benefit to users, cost effectiveness, and social conventions.

The concept of tolerable vs. unacceptable risk was introduced based on the probability of harm and the severity of harm as per Figure 13.




FIGURE 13: TOLERABLE VS. ACCEPTABLE RISK (SOURCE: UL)

The sources of risk start with manufacturing all the way to the end of life of the refrigerant and the equipment. It includes transport and storage, installation and service, operation, as well as removal and dismantling.

#### 4.1.3. Approach of a Risk Assessment Model

The following is part of the process to build a model:

- An outline of the methodology and the components that are the basis for the risk assessment model;
- A model of what data can be collected;
- Information on the regulatory regime and the enforcement mechanisms;
- International standards play a role in the next step of risk assessment in the form of recommendations for local standards; however, the intention is to build a model, not convert it into regulation. Rigorous regulations as those adopted in other regions must be adapted to HAT countries.
- Stakeholders: governments and local research institutions, industry and private sector, and UN Environment & UNIDO;

To determine the outline of the risk assessment model, PRAHA organized a roundtable meeting in cooperation with The Japanese Refrigeration and Air Conditioning Industry Association (JRAIA), and the Air Conditioning, Heating, and Refrigeration Institute (AHRI) as international partners.

The roundtable briefly reviewed the research and testing projects on lower-GWP alternatives for HAT countries as well as the research projects conducted in the United States on A2L refrigerants such as ASHRAE and AHRTI research on flammable refrigerants. Underwriters Laboratory (UL) presented the work that is being done on safety standards and KISR presented a glimpse of their research projects. The industry was also represented in the proceedings and presented their own research and R&D on flammable refrigerants.

A review of the adoptability of flammable refrigerants globally shows the four regions where refrigerants are accepted to varying degrees. Work still needs to be done on HAT regions.


#### 4.1.4. Outline of a Risk Assessment Model

A special expert meeting was held in Cairo in August 2018 focused on the first step of building a risk assessment model through collecting local data and assumptions needed for drafting the model. The meeting aimed to discuss, review and comment on the data collection methodology designed. The meeting was attended by selected experts from the air-conditioning servicing and firefighting sectors, including participation of two members from the Montreal Protocol Refrigeration Technical Options Committee and members of the Halons Technical Options Committee, as well as research institutes' experts, servicing sector expert and National Ozone Officers from Egypt and Kuwait.

JRAIA experts joined the meeting through web-conferencing during the two days. The meeting built clarity and better understanding about the model suggested by JRAIA and included the following:

- Quick Overview of PRAHA-II and First Roundtable Meeting
- JRAIA Risk Assessment Model (Via Web-Meeting)
- Brief Introduction to Risk Assessment Concept
- Risk Scenarios for installation, use and service of split A/Cs
- Explanation of field data/assumptions needed for building the model
- Discussion on Risk Assessment Datasheet and Compilation of Enquiries and Clarification needed from JRAIA
- JRAIA Risk Assessment Model
- Risk Scenarios for installation, use and service of split A/Cs
- Field data/assumptions needed for building the model
- Work plan for Data Collection, Review and Validation

The process that will be used is outlined in Figure 14.



**FIGURE 14: PROCEDURE OF RISK EVALUATION ACCORDING TO ISO/IEC 51 (SOURCE: JRAIA)**

The experts also discussed the application for the model for which data and information which will be collected. Several applications were suggested with size and use of the room and the sources of ignition. One application will be chosen.

An example of the data tables to be filled before the workshop is shown in **Annex I**.

For more info about the Cairo meeting, please refer to:

<https://www.unenvironment.org/ozonaction/news/editorial/un-environment-and-unido-help-countries-high-ambient-temperatures-assess-risk>

#### **4.1.5. Global Risk Assessment Efforts**

The purpose of this section is not to present a comprehensive background on all the work that has been done globally, but to review those efforts that were presented or shared during the different PRAHA-II events. The PRAHA team is aware of risk assessment efforts done in Columbia and India, among others, some done with the help of implementing or bilateral agencies. Similarly, Chinese associations and industry built their own local risk assessment for the use of A3 refrigerants in unitary air-conditioning applications.

The following is a brief review of research projects that were reviewed both at the International Workshop on Risk Assessment for HAT in Kuwait in Oct 2017 and the Flammable Refrigerant Research and Planning Conference in Chicago in Oct 2018:

Note: AHRTI is the research arm of AHRI in the United States, ASHRAE is the Association of engineers and NFPA is the National Fire Protection Association:

- AHRTI-9007 to conduct refrigerant leak and ignition testing and investigate the control limits and safety factors proposed for IEC 603325-2-40 for air conditioners and 60223-2-89 for refrigeration;
- AHRTI-9009 refrigerant leak detector long-term reliability assessment, to conduct a thorough review of sensor technologies that can detect A2L refrigerants;
- AHRTI-9008 investigation of hot surface ignition temperatures for A2L refrigerants in order to establish a standard;
- ASHRAE-1806 to determine the severity of ignition events using computer modeling;
- ASHRAE-1808 to determine leak rates through mechanical joints;
- NFPA evaluation of fire hazard of A3 refrigerants

AS an example of the work done on A3 refrigerants, the project “Benchmarking Risk by Whole Room Scale Leaks and Ignitions Testing of A3 Refrigerants” conducted by AHRTI conducted leak and ignition testing for HC-290 (propane) under whole room scale conditions to develop data and insight into the risks associated with the use of Class A3 refrigerants. This included parametric testing to investigate how key variables (refrigerant charge amount, release rate and height etc.) influence the ‘ignition event’ under whole room scale scenarios. It involved releasing liquid HC-290 refrigerant into spaces with a variety of viable ignition sources present. The testing scenario simulated a Packaged Terminal Air Conditioner (PTAC) and a mini-split air conditioner (AC) in a typical motel room plus a single door reach-in cooler and a three-door reach-in cooler in a convenience store. The testing scenario was according to the existing requirements or proposed requirements in the IEC Standards 60335-2-40 (for air-conditioning products) and IEC 60335-2-89 (for commercial refrigeration products), and their equivalent North American version published by Underwriters Laboratory (UL).

UL in the US has done work in developing requirements for flammable refrigerants applicable to both air conditioning and refrigeration equipment, as well as the requirements for testing and evaluation of flammable refrigerants including A2L refrigerants. As a result of the work, Standards were published for air conditioners recommending three times the Lower Flammability Limit (3xLFL) under UL 484. For refrigeration, Standard UL 250 for household refrigerators published a 57 gram limit, while UL 60335-2-24 published a 150 gram limit for commercial refrigerators. The transitioning to IEC standards 60335-2-40; 60335-2-24; and 60335-2-89 is now complete.

JRAIA developed a comprehensive risk assessment model for A2L refrigerants. The JRAIA model was used by the PRAHA-II team in the risk assessment work and studied in detail in this chapter. PRAHA-II collaborated with JRAIA to build a model that suits the HAT countries usage and servicing practices.

Initially, it was hoped to cover models for both A3 and A2L. UN Environment and UNIDO were planning to build another parallel model for HAT countries addressing flammable (A3) refrigerants in cooperation with China, given China’s expertise and knowledge about hydrocarbon refrigerants, HC-290 in particular. The work which was planned to be with the Chinese association CHEEA.

## 4.2. Process of a Risk Assessment Model

The following is a step-by-step outline of a Risk Assessment model based on the workshop that was held in Japan in April 2019. Experts from Kuwait and Egypt were invited along with the representative of the national Ozone unit of Kuwait to a two and a half days of workshop and lab visit in Tokyo. The agenda covered a reintroduction of the risk assessment model of Japan with focus on minisplits as well as the introduction of Japan's experience in data collections methodology. The rest of the workshop was dedicated to the study of a risk scenario prepared by the PRAHA team.

A Step-by-step approach to the case study by the PRAHA team is outlined below:

- I. **Selection of equipment type and application:** From residential to refrigeration as per figure below identified by JRAIA. The work on VRF and refrigeration assessment by JRAIA is completed. The PRAHA-II team chose residential air conditioning as it is the most used type in number of units and where the risk might be greatest. The team also identified servicing of the indoor unit as the most relevant for the model.




FIGURE 15: SELECTION OF EQUIPMENT AND LIFE STAGE FOR THE RISK ASSESSMENT MODEL

- II. **Identify Acceptable and tolerable risk:** Tolerable risk depends on the number of units in the market of the product identified. Tolerable risk depends on the frequency and severity of the accident.

JRAIA defines risk in terms of probability and frequency vs. severity. A low risk is where the probability of an accident is lower and the severity is least. An extreme risk is where the probability is high and the severity is also high.

Table 16 shows the frequency of accidents vs. severity. Frequent accidents leading to catastrophic events are the least acceptable; while improbable of incredible (as in incredibly low frequency) with the least severity are socially acceptable.

**TABLE 16 RISK MATRIX - FREQUENCY VS. SEVERITY (SOURCE JRAIA)**


	<b>None</b>	<b>Negligible</b> (slight injury)	<b>Marginal</b> (need for outpatient treatment)	<b>Critical</b> (serious injury or need to be hospitalized)	<b>Catastrophic</b> (death)
<b>Frequent</b>	C	B3	A1	A2	A3
<b>Probable</b>	C	B2	B3	A1	A2
<b>Occasional</b>	C	B1	B2	B3	A1
<b>Remote</b>	C	C	B1	B2	B3
<b>Improbable</b>	C	C	C	B1	B2
<b>Incredible</b>	C	C	C	C	C
A = Unacceptable risk levels: 1=least, 3= highest		B= Risk levels should be reduced 1= least, 3= highest		C= Socially acceptable risk levels	

### III. Analyze Product Cycle

It is necessary to classify the air conditioners into groups and assess the individual risk of each group. If the classification is very narrow, the risk assessment becomes complicated, and data common to different groups cannot be collected because the risk assessment needs to be performed on an individual basis.

The most important considerations for HAT relate primarily to the installation and servicing issue and technicians' skill levels. The temperature has no direct effect on the risk, it is the practice that matters. The question of whether to build a model from scratch or adopt an international model is moot since there is a need to know the status of doing things in the countries that built similar models in order to plug into the locally built model, i.e. level of service, frequency of service, types of installation etc. The team decided to build a model from scratch.

The life cycle range for assessment is shown in Figure 16. Each stage has to be assessed separately and added together to get to the total risk.



**FIGURE 16: LIFE CYCLE RANGE FOR ASSESSMENT**

The determination of tolerable risk depends on the population of products in the country. The example from Japan is in Table 17:

**TABLE 17: DETERMINATION OF TOLERABLE RISK LEVELS**

Product/System	Unit Population	Tolerable risk	
		Usage stage	Service stage
Residential AC	$1 \times 10^8$	$1 \times 10^{-10}$	$1 \times 10^{-9}$
Commercial AC	$7.8 \times 10^6$	$1.3 \times 10^{-9}$	$1.3 \times 10^{-8}$
VRF	$1 \times 10^7$	$1 \times 10^{-9}$	$1 \times 10^{-8}$
Chillers	$1.34 \times 10^5$	$7.5 \times 10^{-7}$	$7.5 \times 10^{-7}$
Condensing units	$1.46 \times 10^5$	$6.9 \times 10^{-8}$	$6.9 \times 10^{-7}$

The PRAHA team used the JRAIA approach to set the tolerable risk for residential units at the following levels:

For the usage stage =  $1 / 100 \times$  unit population

For the service stage =  $1 / 10 \times$  unit population

And the risk map becomes as in Figure 17:






FIGURE 17: RISK MAP

#### IV. Risk Scenarios

A critical stage of the risk assessment is to identify those scenarios in which an ignition source is present in conjunction with a flammable concentration of leaked refrigerant. To better understand these scenarios, one must consider the various triggering events which could cause refrigerant to be released, the location of the release, and the specific type of person that might be present (*i.e.*, a worker, repair person or customer) at the time of the release. It is important to note that, during normal operations, the refrigerant will be contained within the system, and thus there is no risk of adverse events associated with these refrigerants during regular use. However, if refrigerant leaks from the equipment and is not dispersed prior to accumulating to a flammable concentration and a sufficient energy source is present, refrigerant ignition could occur (AHRTI 8009)

The first step in a risk analysis is to select a risk assessment method. There are three known methods used: Event Tree Analysis (ETA), and Failure Modes and Effects Analysis (FMEA), and Fault Tree Analysis (FTA). ETA is based on binary logic, in which an event either has or has not happened or a component has or has not failed. FMEA is a structured approach to discovering potential failures that may exist within the design of a product or process. Failure modes are the ways in which a process can fail. Effects are the ways that these failures can lead to harmful outcomes for the user. The goal of FTA is to provide an order of magnitude estimate of the likelihood that the outcome in question will occur (US NRC, 1981).

The team chose the fault tree analysis in line with JRAIA. Refer to item VII for FTA description.

The risk assessment of flammable refrigerants considers two individual phenomena: the presence of an ignition source and the generation of a flammable volume. The risk scenarios that were considered were:

- A. Refrigerant leak during maintenance work on the indoor unit during brazing and due to pipe breakage by corrosion with an ignition source caused by live wire, static electricity, or electric tool such as screw drivers;

- B. Refrigerant leak during brazing of outdoor unit with leakage caused by prior maintenance work or during maintenance work and an ignition source from the brazing torch;
- C. Refrigerant leakage during normal home use caused by pipe breakage through corrosion, external pressure or natural causes such as earthquakes with an ignition source of an open flame, electric spark or static electricity.

## **V. Select Risk Analysis Sources**

The input into the model is taken from data tables for the type of application and usage of the equipment that are being studied. Source for input into the volume of the flammable cloud can be taken from research done for the type of gas. Data for source and time of ignition can sometimes be available from the fire department.

## **VI. Data Collection**


Data collection takes into consideration the following:

- a) Select the stages of the life cycle of the air conditioners. Choose the manner of classification of manufacturing, transportation, use, service, and disposal of an air conditioner into separate stages for evaluation. The evaluation of the manufacturing stages of each product is normally the responsibility of the manufacturer;
- b) Investigate the conditions of installation of the selected air conditioner to determine the conditions to be evaluated during the risk assessment;
- c) Determine the severity of the hazard focusing on the damage caused by flammability;
- d) Set tolerance levels. Set socially acceptable probability of harm for the air conditioner;
- e) Investigate refrigerant leakage rate, speed, and amount based on surveys conducted with air conditioning service companies. The initial leakage location and leakage concentration should also be determined;
- f) Determine flammable time volume through CFD or calculations. For the conditions set as per point (b), the flammable time volume can be calculated by CFD simulation based on the leakage amount, speed, and concentration of the refrigerant as per point (e).
- g) Consider ignition sources. Distinguish the ignition properties depending on whether the ignition source is a spark (for example, electrical contacts, lighter, and/or static electricity), or an open flame (for example, candles, matches, and/or combustion equipment).

## **VII. Fault Tree Analysis (FTA)**


It utilizes a "top-down" approach, starting with the undesired effect as the top event of a tree of logic. Fault trees (FTs) consist of various event boxes, which reflect the probability or frequency of key events leading up to a system failure. The event boxes are linked by connectors (gates),

which describe how the contributing events may combine to produce the system failure. Events may be combined in different ways: in cases where a series of events must all occur to produce an outcome (e.g., ignition source and sufficient oxygen to support combustion), the probabilities or frequencies of the individual contributing events are multiplied via an "AND" gate; in cases where only one of a series of events is needed to produce an outcome (e.g., a strong spark, open flame, or a hot surface all possibly leading to refrigerant ignition), the probabilities are usually added via an "OR" gate. (AHRTI 8009, 2015).



**FIGURE 18: FAULT TREE ANALYSIS (FTA) MODEL**

In the case of flammability, the probability of leakage is combined with ("and" gate) the possibility that the length of time that flammable cloud exits covered area would lead to ignition in case of the existence of an ignition source (another "and" gate).




**FIGURE 19: PROBABILITY OF IGNITION FTA**

In the development of FTA for flammability, the presence of the flammable region and the ignition source correspond to independent trees. Then, their probabilities are multiplied in the final step to calculate the accident probability.

When the contents are reviewed, the risk is evaluated against the risk map in item III above and the calculated accident probability is compared to the acceptable probability in the risk map. The risk tolerance propriety is then determined.

#### **VIII. Suggest Measure to Mitigate Intolerable Risk**

When the tolerance from the risk evaluation in the steps above is satisfactory, the risk assessment ends. If the risk exceeds the tolerance, countermeasures to reduce the risk should be taken. These countermeasures include the implementation of regulations and other measures like introducing safety procedures in order to reduce the risk of accidents. In some instances, it might be necessary to revise laws and regulations in order to ensure that they cover the accepted probability. The reiterative process, which is explained in Figure 20, is as follows:



- a) Select risk assessment method
- b) Select product
- c) Select stages of the product life, i.e. usage or service etc.
- d) Investigate installation circumstances
- e) Determine severity of hazard
- f) Set tolerance levels
- g) Investigate refrigerant leak rate, speed and amount
- h) Determine flammable time volume
- i) Consider ignition sources
- j) Develop FTA
- k) Compare against tolerance
- l) Evaluate risk against tolerance
- m) Reduce risk with countermeasures
- n) Redevelop FTA
- o) Confirm and publish

FIGURE 20: FTA REITERATIVE PROCESS

## IX. Recommend Standards and Codes

Once the countermeasures have been introduced, the FTA factors are reviewed and these countermeasures are added in the appropriate position of the tree. A new calculation can then be made and repeated until the calculations confirm the accepted tolerance according to the risk map. The results can then be released to the public and standards and codes can be drawn.

### 4.3. Example of a Risk Assessment Model

The team chose a case study of an office space in a government building during the usage phase when the equipment is running and during the repair/service stage. The target product is a 5.3 kW split system using an A2L refrigerant. The team selected the Fault Tree Analysis method which is described under item VII below. The target product and the indoor and outdoor conditions plus the service case are shown in the tables below.

At the workshop in Tokyo in April 2019, the PRAHA team worked with the JRAIA experts to do two case studies using the information provided by the PRAHA team. The two case studies are:

- During usage of an air conditioner in a government office. The sources of ignition are extreme including charcoal and lighter used for incense burning, an aroma candle, as well as cigarettes and lighters as smoking is still allowed.
- During the repair stage during brazing with sources of ignition including the brazing burner, a cigarette and a lighter.

Table 18 lists the equipment as well as the indoor and outdoor conditions

**TABLE 18: INFORMATION FOR THE RISK ASSESSMENT MODEL USED BY PRAHA TEAM**

Target Product	Value
Model number	CS-PC36JKF
Type(cooling / HP)	HP
Capacity(kW)	10.5
Refrigerant type	A2L
Refrigerant amount(kg)	2.7
Alternative refrigerant type	HFC-32, R-454B

Indoor Condition during usage of target product		Value
Room size (m <sup>2</sup> )	max	25
	min	16
Height of installation(m)		2.1
Ceiling height(m)		2.8
Ventilation	yes/no	YES
	Ventilation amount (m <sup>3</sup> /hr.)	80
The area of the gap under the door (m <sup>2</sup> )		0.02
other openings, if any (m <sup>2</sup> )		0

Outdoor Condition during usage of target product		Value
Size of the place enclosed with walls , or fences etc.(m <sup>2</sup> )	max	8
	min	4

Condition during repair of target product	value
Average size of outdoor spaces for repairs (m <sup>3</sup> )	20
Percentage of single outdoor unit installations( A%)	50
Percentage of the installations of multiple outdoor units ( B%)	50
Average working hours per repair (outdoor unit) (hr.)	1
Average working hours per repair (indoor unit)(hr.)	0.5
Wind condition (wind velocity) (m/s)	1 TO 3
Windless condition percentage (%)	10

(Windless condition; 0.1m/s or less. the windless rate in one year.)

**Notes:**

- No alternative refrigerant is available from the manufacturer for this product;
- Ventilation amount was calculated based on 1.5 air changes per hour;
- Gap under door was based on the door width is 1.00 m, gap with floor is 2 cm;
- The outdoor unit was assumed to be installed on a roof open area.

The methodology is to calculate the probability of ignition due to a space factor and a time factor.

**Space Factor**

The space factor takes into consideration the space volume, the volume of the flammable cloud, and the volume of the source of ignition. The volume of the flammable cloud depends on the leakage rate and other considerations such as pressure. The volume of the source of ignition can be very small as in the case of a spark, or sizeable as in the case of an open flame.

**Time Factor**

The time factor takes into consideration the number of occurrences of the ignition source and the duration of each occurrence.

**Terminology**

The following terminology will be used in the calculation example:

$T_{Ref}$  = Time of application: 24 hours for usage or duration of maintenance for service

$T_S$  = Time of Ignition Source

$T_F$  = Time of Flammable Cloud

$V_{FT}$  = Flammable Volume Time Integration

$V_{SOI}$  = Volume of source of Ignition

$V_{FCloud}$  = Volume of Flammable Cloud

$V_{Ref}$  = Volume of space or room

$P_{A, B \text{ or } C}$  = Probability of ignition for the different sources of ignition (A), (B), or (C)

$P_R$  = Refrigerant Leak Probability

## Equations

The Volume of Flammable Cloud is the Flammable Volume Time Integration divided by the Time of Flammable Cloud

$$V_{F \text{ Cloud}} = V_{FT} / T_F$$

The probability of ignition is the sum of the space and time factors for each source of ignition.

The probability of time is calculated as the sum of the time of the flammable cloud plus time of source of ignition divided by the time of reference (usage or service time).

$$P_T = (T_F + T_S) / T_{\text{Ref}}$$

The Probability for Space is similarly calculated as the sum of the volume of source of ignition plus the volume of the flammable cloud divided by the reference volume which is the volume of the room or space where service is done.

$$P_S = (V_{F \text{ Cloud}} + V_{\text{SOI}}) / V_{\text{Ref}}$$

The probability for one source of ignition (A), referred to as “Event” is the multiple of the Time probability and the Space probability:

$$P_A = P_T \times P_S$$

The probability for all events is sum of the probabilities for all sources of ignition. The three sources identified in the example i.e. charcoal, cigarette and candle are herein called A, B, and C

$$P_{\text{Events}} = P_A + P_B + P_C$$

$P_R$  = Leak Frequency x Number of Occurrence in a 24 hour period

The Total probability is the multiple of the probability of each event by the Refrigerant Leak probability

$$P_{\text{Total}} = P_{\text{Events}} \times P_R$$

### 4.3.1. Simulation of Time Factor and Space factor During Usage Stage

The data in Table 19 was provided by the PRAHA-II team for the workshop.

TABLE 19: DATA FOR THE CALCULATION OF RISK FOR USAGE STAGE


Event	Ignition source	No. of Occurrence	Duration per day	T <sub>S</sub> = Time of Source
A	Charcoal + lighter	2	1 hour	1 hr/2
B	Cigarette+ lighter	2	0.2 hour	0.2 hr/2
C	Aroma candle	4	3 hours	3 hr/4



**Flammable volume Time Integration:**

- $T_F = 18 \text{ minutes}/60 \text{ minutes} = 18/60 \text{ hour}$  Time of the flammable cloud. The time is derived from lab data for the type of refrigerant
- $T_s$  is show in table 19
- $V_{F \text{ Cloud}} = 6.4 \times 10^{-2} \text{ m}^3 \text{ min}/ 18 \text{ minutes}$ : Volume of the flammable cloud for indoor unit is derived from simulation data for the class of refrigerant and type of application.
- $V_{SOI}$  is negligible.
- $T_{Ref} = 24 \text{ hours}$ : Time of application is 24 hours since usage is throughout the day
- $V_{Ref} = 25 \text{ m}^2 \text{ floor area} \times 2.1 \text{ m height of the indoor unit.}$
- $1 \times 10^{-3} = \text{Leak frequency per year}$  taken from a study for Japan as data is not available from the countries under study.

Figure 21 shows the FTA calculation for the usage stage.



**FIGURE 21: FTA FOR USAGE STAGE**

For each event, i.e. charcoal, oil lighter, and aroma candle the probability of time and space are calculated according to the equations given above, for example:

- For charcoal the time factor is the sum of the time of the flammable cloud and the time of the ignition source divided by the usage time which is 24 hours. The probability equation is  $(T_F + T_s)/T_{Ref}$ .  $T_F$  is 18/60 derived from data,  $T_s = 1/2$  from table 19 and  $T_{Ref}$  is 24 hours.
- The space factor for charcoal is  $(V_{F \text{ Cloud}} + V_{SOI})/V_{Ref}$ .  $V_{F \text{ Cloud}}$  is  $6.4 \times 10^{-2} / 18$  while  $V_{SOI}$  is negligible.  $V_{Ref}$  is the volume up to the height of the unit =  $25 \times 2.1$

- The addition of the three ignition sources gives a probability of  $6.2 \times 10^{-6}$  which is  $P_{\text{Events}}$
- $P_R = 1 \times 10^{-3} \times (8/24) = 7 \times 10^{-4}$
- The Total probability is  $P_{\text{Events}} \times P_R = (6.2 \times 10^{-6}) \times (7 \times 10^{-4}) = 4.3 \times 10^{-9}$  shown in the top “And”. This puts the probability in the “Extremely Difficult” area of Figure 17: Risk Map.

#### 4.3.2. Simulation of Time Factor and Space factor During Servicing Stage

TABLE 20: DATA FOR CALCULATION OF RISK FOR SERVICE STAGE

Event	Ignition source	No. of Occurrence	Duration per day	T <sub>s</sub> = Time of Source
A	Burner	2	2 minutes	4/2
B	Cigarette	2	3 minutes	6/2
C	Lighter	2	10 seconds	0.167/2

Flammable Volume Time Integration

$V_{\text{FCloud}} = 6.3 \times 10^4 \text{ m}^3 \text{ sec} / 3600 \text{ sec}$  Volume of the flammable cloud for outdoor unit is derived from simulation data for the class of refrigerant and type of application.

$V_{\text{SOI}}$  is negligible

$T_{\text{Ref}} = 60 \text{ minutes (1 hour)}$


$V_{\text{Ref}} = 20 \text{ m}^2 \text{ space} \times 3.5 \text{ m height}$ . This is the volume of service space for the outdoor unit.

$T_s$  is shown in table 20

$T_F$  is 60 minutes is the time of the flammable cloud

$T_{\text{Ref}}$  is the time of service which is 60 minutes

The FTA for servicing stage is shown in Figure 22.



**FIGURE 22: FTA FOR SERVICING STAGE**

The calculations are similar to the usage stage example given above.

The Total probability is  $0.77 \times 1 \times 10^{-3} = 7.7 \times 10^{-4}$  which is shown in the top “And”. This puts it in the “Frequent” from the Risk Map of table 17 and mitigation measures should be taken. One evident measure is to ban smoking in the service area!

#### 4.4. Conclusions and Recommendations from the Risk Assessment Element

The above two FTA were created in collaboration with HAT countries and Japan. The purpose of this FTA was to simulate a risk scenario in HAT region with unique climate, product-usage, lifestyle and culture which differs from Japan’s case. The exercise has shown the need for a reliable data for the HAT region on leaks, practices etc.

Building a risk assessment model for the HAT countries that suits the climate and the service practices of the local technicians helps the HAT countries, as well as setting the foot for all A5 countries, in understanding the risk associated with flammable refrigerants and adopting the needed regulations and training programs especially in relation to the logistics of lower-GWP based technologies i.e. installation, transportation, storage, servicing and decommissioning.

The recommendation is for HAT countries to continue the risk assessment based on actual situations, and reduce the risk by implementing various measures that are verified by FTA. It is also important to minimize ignition probability by implementing various measures that are verified by FTA. In addition, the risk assessments of other stages matching cultural and lifestyle aspects should be studied.

## **References for chapter 4**

AHRTI 8009, 2015. Risk Assessment of Refrigeration Systems Using A2L Flammable Refrigerants. April 2015

JSRAE, 2017. Risk Assessment of Mildly Flammable Refrigerants. Final Report 2016. March 2017

US Nuclear Regulatory Commission (US NRC). 1981. "Fault Tree Handbook." NUREG-0492. 209p. January.

## 5. Overall Conclusions and Recommendations

The outcomes of PRAHA-II components can draw several concluding remarks in relation to the main objectives of the project which can be summarized as follows:

### **In relation to support the process advancing the promotion and deployment of lower-GWP alternatives:**

- I. A tailored Risk Assessment is essential, not only for HAT countries, in better understanding safety implications associated with deploying alternative refrigerants, either A2L or A3, considering the specifics of different types of equipment and life stages.
- II. Efforts in building risk assessment models should be exerted towards analyzing risks in the logistics side of the supply-chain i.e. Installation, In-door use, outdoor use, servicing and end of life (decommissioning); understanding the design and manufacturing risk assessment are covered by relevant international standards which should more or less apply to most countries.
- III. The concept of risk assessment is quite similar worldwide, including methodologies in calculating and analyzing severity and frequency of risks. However, criteria for acceptable tolerance levels may differ depending on local considerations. Measures to mitigate risks would depend on type of existing/operational standards and/or codes in each country noting
- IV. Few Article 5 countries and some of the non-Article-5 countries have built similar models. Learning from the pioneers in risk assessment models through partnership and cooperation will leapfrog the technical difficulties and provide a quick access to building the model.
- V. PRAHA-II was the first step in providing the impetus for this leapfrogging. Similarly, Building the risk assessment model with the involvement of local research institutes and organizations will add depth and reach for those institutes and involve the HAT countries in the global research efforts on new alternatives as well as build countries' ownership.
- VI. Building a risk assessment model for the HAT countries that suits the climate and the service practices of the local technicians will help the HAT countries will set the foot of A5 countries, not only HAT, in understanding and establishing local risk assessment models hence adopting the needed regulations and training programs especially in relation to the logistics of lower-GWP based technologies i.e. installation, transportation, storage, servicing and decommissioning.

### **In relation to building capacities of local industry to better design with lower-GWP alternatives:**


- VII. The optimization work on the prototypes of PRAHA-I is helping the OEMs who built the original prototypes get the best support in their R&D efforts. The activities of that element substantiated by result of testing of the optimized units confirm that enhanced design and the use of the proper components can lead to better performance and energy efficiency.

- VIII. The optimization element of PRAHA-II also pointed out that components, especially compressors for the new refrigerants, are still not widely available. These and other limitations have to be dealt in order to help manufacturers make an informed decision on the way forward.
- IX. PRAHA capacity building activities have helped the PRAHA stakeholders in acquiring added knowledge about working with alternative lower-GWP refrigerants that are flammable. The study tours have exposed stakeholders to the latest in technology for both A2L and A3 refrigerants at global technology centers. The capacity building activities helped many manufacturers in HAT countries in building or engaging in other research projects.

**In relation to maintaining sustainable technical platform to support PRAHA process and sharing knowledge about up-to-date technological developments amongst HAT countries:**

- X. The capacity building efforts have turned PRAHA into a global process that can be extended to all 35 HAT countries and not only the Gulf and Middle East countries that were engaged with PRAHA-I.
- XI. PRAHA-II events continued to attract global and regional participation in terms of government authorities, technology providers, manufacturers, and international/regional institutes. PRAHA presentations and knowledge sharing at networks of ozone officers and international conferences have become a fixture for exchanging experiences and knowledge about HAT technological related aspects. PRAHA-II has helped to spread the awareness of HAT challenges in optimization and risk assessment as well as opportunities.

Key take-home messages from PRAHA-II conclusions and recommendations can be illustrated as below.



## Annex I – Examples of Risk Assessment Model Data Tables filled

### A. Target Product

	value
model number	
type(cooling / HP)	
capacity(kW)	
refrigerant type	
refrigerant amount(kg)	
alternative refrigerant type	R32?

### B-1. Indoor condition during usage of target product

		value
room size ( m <sup>2</sup> )	max	
	min	
height of installation(m)		
ceiling height(m)		
ventilation	yes/no	
	Ventilation ( m <sup>3</sup> /hr.)	
gap under door area ( m <sup>2</sup> )		
other openings, if any ( m <sup>2</sup> )		

### B-2. Outdoor condition during usage of target product

		value
the size of the place enclosed with walls ,or fences etc.(m2)	max	
	min	

(ex. the internal area of a balcony)

### C. Condition during repair of target product

	value
the average size of outdoor spaces for repairs ( m <sup>3</sup> )	
the percentage of single outdoor unit installations (A% )	
the percentage of the installations of multiple outdoor units (B% )	
the average working hours per repair (outdoor unit) (hr.)	
the average working hours per repair (indoor unit) (hr.)	
wind condition (wind velocity ) (m/s)	
windless condition (percentage % )	
(Windless condition; 0.1m/s or less. the windless rate in one year.)	

(note1)A+B=100% (note 2) multiple outdoor units installed with a considerable amount of spaces between them is included in the single installation category.

**Praha-II List of Possible Ignition Source and estimation of ignition occurrence in Kuwait's case**

(during usage - indoor)

			Estimate of ignition occurrence / day	
Type of Ignition source	Ignition Source		Occurrence (times/day)	Duration (hours/day)
Ignition source caused within flammable region (triggered by the ignition source)	open flame	cigarette		
	Electric spark (human conduct)	oil lighter		
		ignition switch of heater		
		connect / disconnect of electric plug		
		on/off relay within electrical equipment		
		relay operation of electrical equipment		
		brush motor		
	Electric spark (excluding human conduct)	malfunction of equipment		
		slip on / off the clothes		
	Human conduct	slip on / off the clothes		
open flame (triggered by flammable region)	open flame	candle		
		heater		
		stove burner		
		catch fire		
	High temperature surface	Electric heater		



## Annex II - Safety

**Overview of RACHP safety standards** (Source: TEAP report Volume 4: Decision XXX/5 on Cost and Availability of Low-GWP Technologies/Equipment that Maintain/Enhance Energy Efficiency)

The requirements and implications of various international and regional safety standards covering RACHP sectors are detailed in report TEAP TF XXVIII/4.<sup>3</sup> This includes a table of relevant standards and the applicable various sub-sectors (Table 2-1). An extract of that table is provided below (Table I).

Throughout the report there are discussions on what the upper charge limits are.

Table I: Scope of selected RACHP safety standards that include flammable refrigerants

Sector	Vertical (Product Standards)		Horizontal (Group Standards)
	IEC 60335-2-40	IEC 60335-2-89	ISO 5149-1,-2,-3,-4
Commercial refrigeration		x	x
Air-to-air air conditioners & heat pumps	x		x

Table II attempts to summarise the upper charge limits, where values have been separated into two categories.

- “with limited measures” means only with elimination of potential ignition sources
- “With additional measures” refers to situations where additional protective measures have to be applied, such as imposing a minimum room size, additional ventilation, etc.

It is not straight-forwards to summarise the “with additional measures” charge limits as they often depend upon the choice of several measures, installation conditions and so on. The exercise should be carried out on a case-by-case basis.

Table II: Maximum charge size limits for flammable refrigerants according to RACHP safety standards

	With limited measures			With additional measures		
	A3	A2	A2L	A3	A2	A2L
IEC 60335-2-89	0.15 kg	0.15 kg	0.15 kg	n/a	n/a	n/a
IEC 60335-2-40	0.15 kg	0.5 kg	1.8 kg	0.3 kg/1.0 kg	3.4 kg	8.0 kg/78 kg
ISO 5149	0.15 kg	0.5 kg	1.8 kg	1.5 kg/2.5 kg/ unlimited	3.4 kg/ unlimited	60 kg/ unlimited

All of these standards are in various stages of revision including with special attention to application of flammable refrigerants. Again, a summary of these may be found in the TEAP TF XXVIII/4 report.

### Overview of safe refrigerant handling

In terms of refrigerant safe handling training, the situation differs widely amongst countries, due to the variety of national legislation. The IIR has published an information note on qualification and competence of technicians,<sup>4</sup> which offers an overview of schemes available in many countries.

<sup>3</sup> TEAP TASK FORCE Decision XXVIII/4 Report: on safety standards relevant for low-GWP alternatives

<sup>4</sup> [http://www.iifiir.org/userfiles/file/publications/notes/NoteTech\\_28\\_EN.pdf](http://www.iifiir.org/userfiles/file/publications/notes/NoteTech_28_EN.pdf)

Some international and regional standard touch on the topic. An international standard is under preparation, ISO 22712 - Refrigerating systems and heat pumps — Competence of personnel (currently in the form EN 13113), which addresses the required competence of technicians for all refrigerant types and tasks. More specifically, IEC 60335-2-40 includes an Annex (DD) covering requirements for operation, service and installation manuals of appliances using flammable refrigerants, which is essentially a compilation of procedures. Another annex (HH) addresses “Competence of service personnel”. Whilst neither IEC 60335-2-89 nor ISO 5149 contains any such material, EN 378-4 does have a short annex on competence of persons working with flammables.

Most countries tend to operate training programmes that are either national or private schemes. There are also a number of regional training programmes in existence, such as the “Real Alternatives” scheme, which covers most of the European countries.<sup>5</sup> In North America there are two such schemes: North America Training Excellence (NATE) for HVAC<sup>6</sup> and AHAM-Home Appliance<sup>7</sup>. China operates a national training scheme for flammables as does JRAIA in Japan.

The entire topic is rather disparate, but it is expected that the global approach will become more harmonised as introduction of flammable refrigerants become more prevalent.

---

<sup>5</sup> <https://www.realalternatives.eu/learning-platform>

<sup>6</sup> <https://www.natex.org/site/1/Homehttp://>

<sup>7</sup> [www.aham.org/AHAM/Safety/Safe\\_Servicing\\_of\\_Cold\\_Appliances/AHAM/Safety/Safe\\_Servicing\\_of\\_Cold\\_Appliances.aspx?hkey=23d1344d-f8b0-410a-9e21-8181048b2b82](http://www.aham.org/AHAM/Safety/Safe_Servicing_of_Cold_Appliances/AHAM/Safety/Safe_Servicing_of_Cold_Appliances.aspx?hkey=23d1344d-f8b0-410a-9e21-8181048b2b82)

ANNEX-III: AHRTI Final Report

**Promoting Alternative Refrigerants in High-Ambient Countries Phase (PRAHA-II):  
Optimization Study on PRAHA I Equipment**

September 2019



**Air-Conditioning, Heating and  
Refrigeration Technology Institute**

## **Final Report**

AHRTI Report No. 9011

### **Promoting Alternative Refrigerants in High-Ambient Countries Phase II (PRAHA-II): Optimization Study on PRAHA I Equipment**

Final Report

September 2019

By

Daniel Bacellar, Song Li, Paul Kalinowski, Cara Martin



Optimized Thermal Systems, Inc. (OTS)  
7040 Virginia Manor Road, Beltsville, MD 20705

Prepared for

AIR-CONDITIONING, HEATING AND REFRIGERATION TECHNOLOGY INSTITUTE, INC

2311 Wilson Boulevard, Suite 400, Arlington, Virginia 22201

©2019 AHRTI

## **DISCLAIMER**

This report was prepared as an account of work sponsored by the Air-Conditioning, Heating and Refrigeration Technology Institute, Inc. (AHRTI). Neither AHRTI, its research program financial supporters, or any agency thereof, nor any of their employees, contractors, subcontractors or employees thereof - makes any warranty, expressed or implied; assumes any legal liability or responsibility for the accuracy, completeness, any third party's use of, or the results of such use of any information, apparatus, product, or process disclosed in this report; or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute nor imply its endorsement, recommendation, or favoring by AHRTI, its sponsors, or any agency thereof or their contractors or subcontractors. The views and opinions of authors expressed herein do not necessarily state or reflect those of AHRTI, its program sponsors, or any agency thereof.

## TABLE OF CONTENTS

1. Executive Summary.....	5
2. Introduction .....	9
3. Activity 1 - Analyzing the Design of PRAHA-I Prototypes.....	9
3.1. Physical Units .....	9
3.2. PRAHA-I Performance Reports Assessment.....	10
3.3. Hardware Improvement Assessment .....	11
3.3.1. Heat Exchanger (HX) First Order Analysis (FOA).....	11
3.3.2. Compressors .....	12
3.3.3. Expansion Devices.....	12
3.3.4. Fan and Blower .....	12
3.3.5. Units Component Modification Potential.....	12
3.4. Conclusions and Recommendations.....	12
4. Activity 2 - Design Improvements.....	13
4.1. Hardware .....	13
4.2. Refrigerant .....	13
4.3. System Design Modification Framework.....	14
4.3.1. Compressors .....	16
4.3.2. HX Design and Selection .....	17
4.3.3. System Design .....	19
4.4. Modified Systems Results Summary.....	19
4.5. Conclusions and Recommendations.....	19
5. Activities 3, 4 & 5 - Prototype Units Fabrication, Evaluation of the Optimized Prototypes and Analyzing Leaks of Alternatives.....	21
5.1. Unit 6.....	21
5.2. Unit 10.....	22
5.3. Leak Tests.....	23
5.4. Conclusions and Recommendations.....	24
6. Conclusions .....	25
APPENDIX A - Activity 2 Design Framework Results .....	27
APPENDIX B – Unit 6 Initial Tests, Scope Change and Test Setup.....	36
APPENDIX C - Unit 6 Raw and Processed Tested Data.....	39
APPENDIX D - Unit 10 Baseline Re-Test .....	42
APPENDIX E - Unit 10 Raw and Processed Tested Data.....	42
APPENDIX F - Model Verification and Validation.....	47

## LIST OF FIGURES

Figure 1. Heat Exchangers FOA.....	11
Figure 2. Refrigerants Investigated for Units 1 and 4.....	14
Figure 3. Refrigerants Investigated for Units 6 and 10.....	14
Figure 4. Refrigerant Temperature Glides.....	14
Figure 5. Illustrative T-s diagram for baseline and improved cycles.....	15
Figure 6. P-h Diagrams Illustrating COP Improvement: a) Real Cycle; b) Ideal Cycle (Carnot).....	16
Figure 7. System Re-Design Framework, .....	16
Figure 8. Condenser Forms: Unit 1 (left), Unit 10 (center), Unit 6 Cabinet (right).....	18
Figure 9. HX Form Examples: L-shape (left), Flat (right).....	18
Figure 10. Unit 1 – Modified Systems P-h Diagrams.....	28
Figure 11. Unit 4 – Modified Systems P-h Diagrams.....	29
Figure 12. Unit 6 – System Level Analysis: Performance Results for R32.....	32
Figure 13. Unit 6 – System Level Analysis: Performance Results for R454B.....	32
Figure 14. Unit 6 - Comparative System Performance Summary for R452B.....	32
Figure 15. Unit 10 – System Level Analysis: Performance Results for R452B.....	35
Figure 16. Unit 10 – System Level Analysis: Performance Results for R447B.....	35
Figure 17. Unit 10 – System Level Analysis: Performance Results for R454B.....	35
Figure 18. Hot Water Thermal Imaging.....	36
Figure 19. Test Diagram.....	37
Figure 20. OTS Setup: outdoor chamber (left), Unit 10 and frequency converter inside chamber (right).....	37
Figure 21. OTS Setup: indoor closed loop left side view (left), refrigerant mass flow meter (right).....	38
Figure 22. OTS Setup: indoor closed loop right side view (left), vapor / liquid lines, sight glasses and TXV (right).....	38
Figure 23. Unit 6 – R32 Performance Test Summary P-h and T-s Diagrams.....	47
Figure 24. Unit 6 – R454B Performance Test Summary P-h and T-s Diagrams.....	48
Figure 25. Unit 10 – R447B P-h and T-s Diagrams.....	48
Figure 26. Unit 10 – R452B P-h and T-s Diagrams.....	49

## LIST OF TABLES

Table 1: Activity 2 Summary Modeling Results.....	6
Table 2: Tests Summary Results.....	7
Table 3: Unit Specifications Summary.....	10
Table 4: Units 1, 4, 6 and 10 Components.....	12
Table 5: Compressor Models.....	17
Table 6: Activity 2 Results.....	20
Table 7: Unit 6 Modifications for Testing.....	21
Table 8: Unit 6 - Performance Test Summary for R32 Baseline (OTS) @ 35°C.....	22
Table 9: Unit 6 - Performance Test Summary for R32 Baseline (OTS) @ 46°C.....	22
Table 10: Unit 10 Modifications for Testing.....	23
Table 8: Unit 10 - Performance Test Summary for R32 Baseline @ 35°C.....	23
Table 9: Unit 10 - Performance Test Summary for R32 Baseline @ 46°C.....	23
Table 12: Unit 10 – R447B Leak Test Summary Results.....	24
Table 13: Unit 1 – Theoretical Cycle Re-Design Summary.....	27
Table 14: Unit 1 – HX Analysis Summary.....	27
Table 15: Unit 1 – Compressor Performance Summary.....	27

Table 16: Unit 1 – Expected Modified System Performances.....	27
Table 17: Unit 4 – Theoretical Cycle Re-Design Summary.....	28
Table 18: Unit 4 – HX Analysis Summary. ....	28
Table 19: Unit 4 – Compressor Performance Summary. ....	29
Table 20: Unit 4 – Expected Modified System Performances.....	29
Table 21: Unit 6 – Theoretical Cycle Re-Design Summary.....	30
Table 22: Unit 6 – HX Analysis for R32.....	30
Table 23: Unit 6 – HX Analysis for R452B.....	30
Table 24: Unit 6 – HX Analysis for R447B.....	31
Table 25: Unit 6 – HX Analysis for R454B.....	31
Table 26: Unit 6 – Compressor Performance Summary. ....	31
Table 27: Unit 10 – Theoretical Cycle Re-Design Summary.....	33
Table 28: Unit 10 – HX Analysis for R32.....	33
Table 29: Unit 10 – HX Analysis for R452B.....	33
Table 30: Unit 10 – HX Analysis for R447B.....	34
Table 31: Unit 10 – HX Analysis for R454B.....	34
Table 32. Unit 10 - Compressor Performance Summary. ....	34
Table 33: Test Scope Change. ....	37
Table 34: List of Measurements.....	39
Table 35: Unit 6 – Performance Tests.....	39
Table 36: Unit 10 – Performance Tests.....	42
Table 37: Unit 10 – R447B Leak Tests .....	44
Table 38: Unit 6 – Model Verification and Validation for Alternative 1 – R32 @ 46°C. ....	47
Table 39: Unit 6 – Model Verification and Validation for Alternative 2 – R454B @ 46°C. ....	47
Table 40: Unit 10 – Model Verification and Validation for Alternative 1 – R447B @ 46°C. ....	48
Table 41: Unit 10 – Model Verification and Validation for Alternative 2 – R452B @ 46°C. ....	48



## 1. Executive Summary

Over the past several years through the Promoting low- Global Warming Potential (GWP) Refrigerants for Air-Conditioning Sectors in High-Ambient Temperature Countries (PRAHA-I) project, 18 different prototypes have been developed and compared to respective baselines to support the assessment of alternative lower-GWP refrigerants for air-conditioning applications. Since the work originally started in 2012, researchers have identified gaps in the performance and operation of the PRAHA-1 prototypes. These gaps include the need to redesign and optimize prototype air-conditioning units, evaluate new alternative refrigerants, and improve component selection. As such, a new project, *Advancing the Designs of PRAHA-I for Meeting or Exceeding the Baseline Designs Performance*, conducted by Optimized Thermal Systems, Inc. (OTS) is herein presented.

The objectives of this project include the following:

- 1) Evaluate the design limitation of the PRAHA-I prototypes;
- 2) Optimize and physically evaluate selected prototypes with new refrigerants not evaluated during PRAHA-I; and,
- 3) Assess potential refrigerant fractionation impact due to leakage.

The project was organized into six activities for which a summary of the results, conclusions and recommendations are presented below:

- 1) [Activity 1: Analyzing the Design of PRAHA-I Prototypes](#)
  - a. Certification laboratories, such as the one used for testing the units in PRAHA I, provide limited information for the purposes of product design and development. For future reference it is recommended that for research-oriented efforts such as this one, the units undergo a more rigorous testing process along with full characterization of the system and its individual components operating conditions and performance.
  - b. In applications of high ambient temperatures, it is expected that performance will degrade as compared to operating under more temperate conditions and the resultant impact on performance must be considered. The key components for performance improvement identified herein were the compressor, condenser and expansion device.
    - i. At higher temperatures, the saturation temperatures and refrigerant density at compressor's suction port can be very different than that from the rated conditions. Larger displacement volumes and efficiency curves optimized for higher pressure lifts might be required. Therefore, the proper selection of the compressor is paramount.
    - ii. A better performance condenser will reduce the approach temperature between refrigerant and air, helping the compressor not to discharge refrigerant at very high pressure and temperatures, which degrade performance.
  - c. At high ambient conditions, the system is forced to operate in higher pressure lift than at rated conditions, but still requires a certain refrigerant mass flow rate. Passive devices such as capillary tubes and orifices may not be able to provide enough expansion to allow the system to operate in higher temperature conditions. An active expansion device such as EXV's can adequately control operating conditions and maintain stable superheat.
- 2) [Activity 2: Design Improvements](#) (Summary results in Table 1)
  - a. R290 and R32 have wider saturation regions allowing the system to operate with smaller superheat and subcooling, while benefiting from two-phase heat transfer. Their cycles

may get closer to that of the ideal Carnot cycle compared to refrigerants with narrower saturation.

- b. Refrigerants with high temperature glide may require new heat exchanger (HX) designs, namely condensers. The original designs proved to be sufficiently effective to allow for most systems to operate with the different refrigerants, however, better designs would allow for higher system efficiency and potentially less charge. HX designs are severely constrained by allowed envelope dimensions. A complete system re-design would provide an opportunity for designing HX's with even higher efficiency.
- c. The results of this analysis suggest that for an effective refrigerant replacement, a proper compressor selection must be accompanied with it. Higher isentropic efficiencies are desired for higher temperatures, but most importantly, the displacement volume requirements can vary considerably from one refrigerant to another.
- d. It is also imperative that having an active expansion device (preferably an Electronic Expansion valve (EXV)) to not only allow for more controlled superheat, but also to enable the unit to run with different refrigerants with very different thermophysical properties.

**Table 1: Activity 2 Summary Modeling Results.**

General Information			Hardware			Performance		
System	Rated Capacity (@35°C)	System Configuration	Compressor	Condenser	Expansion Device	Ref.	Cooling Capacity (@46°C)	EER (@46°C)
-	BTU/hr	-	Efficiency (-)	Type	Type	-	BTU/hr	BTU/hr.W
Unit 1	18000	Baseline	0.66	Tube-Fin (5mm Tube)	Passive	R444B	17403	7.4
		Alternate 1	0.7	Same as Baseline	Active (EXV)	R290	17639	8.01
		Alternate 2	0.69			R454C	18104	7.31
		Alternate 3	0.7	MCHX		R444B	18140	8.14
		Alternate 4	0.68			R457A	17749	7.63
Unit 4	24000	Baseline	0.61	Tube-Fin (9.5mm Tube)	Passive	R290	17940	7.52
		Alternate 1	0.7	Tube-Fin (5mm Tube)	Active (EXV)	R290	18147	9.12
		Alternate 2	0.7			R290	24120	6.72
Unit 6	24000	Baseline	0.6	Tube-Fin (7mm Tube)	Passive	R32	23115	8.46
		Alternate 1	0.65	Tube-Fin (5mm Tube)	Active (EXV)	R32	23798	9.41
		Alternate 2	0.67			R454B	22894	9.71
		Alternate 3	0.7			R452B	23702	9.6
Unit 10	36000	Baseline	0.44	Tube-Fin (9.5mm Tube)	Passive	R32	29005	6.39
		Alternate 1	0.65	Tube-Fin (5mm Tube)	Active (EXV)	R447B	30478	9.43
		Alternate 2	0.67			R452B	30796	10.27
		Alternate 3	0.67			R454B	30809	10

3) [Activities 3-5: Prototype Modification and Testing](#) (Summary results in Table 2)

- a. Unit 6 re-tested baseline exhibited similar performance to that found in PRAHA I testing. It should be stressed that the baseline unit by design had its capillary tube located in the outdoor unit. This would cause liquid refrigerant leaving the outdoor unit to flash. The refrigerant enthalpy at the condenser outlet state was used to calculate the refrigerant-side capacity assuming an isenthalpic expansion without heat loss in connecting pipe. This is different from the modified systems of which the capillary tube was removed, and a manual expansion valve was placed at the inlet of the indoor unit. For modified systems,

the enthalpy at the expansion valve inlet was used to calculate the refrigerant-side capacity.

- b. Unit 10 exhibited a considerable reduction in power consumption at the high ambient test condition (46°C) as compared to the original test data. This supports the hypothesis of low compressor efficiency during PRAHA I tests, which also indicates the importance of proper compressor selection.
- c. The above is also evidenced by the fact that even with R447B and R452B (zeotropic mixtures), Unit 10 had higher cooling capacity and efficiency than the baseline for the 46°C test condition, as projected in activity 2. The tests at 35°C, however, did not have the same trend.
- d. The impact of refrigerant replacement was not very clear, in part due to the hardware change along with it. But because of the differences in saturation curves from the Activity 2 analysis, R32 tends to result in systems with higher efficiency and less charge. The zeotropic mixtures consistently required compressors with larger displacement volumes and even higher mass flow rates for cooling capacities of the same magnitude.
- e. Refrigerant fractionation as evidenced by the leak tests, does not appear to a great concern since less than 2% in cooling capacity was observed after the system’s re-charge.
- f. The Unit 6 modified systems had lower performance than expected from the Activity 2 models. The R32 system configuration exhibited around 10% less flow rate than anticipated, which corresponded to 10% lower capacity. The R454B configuration exhibited a deviation of 5% between model and test due also in part to a 3% flow rate over prediction in the model. Unit 10, on the other hand, exhibited an excellent agreement to the models with less than 2% deviation in cooling capacity.
- g. The model’s validation adds confidence in the numerical simulation findings and recommendations provided in activity 2.

**Table 2: Tests Summary Results.**

Syst.	Test	Refrigerant	Charge	35°C			46°C		
				Cooling Capacity	Total Power	EER	Cooling Capacity	Total Power	EER
				lb	BTU/hr	kW	BTU/hr. W	BTU/hr	kW
Unit 6	Performance	R32 (Baseline)	3.83	25192	2.43	10.4	23390	3.10	7.54
		R32 (Alternate 1)	4.27	23585	2.12	11.1	21450	2.74	7.84
		R454B (Alternate 2)	5.02	21966	2.10	10.4	21821	2.67	8.17
Unit 10	Performance	R32 (Baseline)*	5.63	34517	3.76	9.18	29005	3.84	7.55
		R447B (Alternate 1)	6.63	32195	3.62	8.88	31073	3.90	7.96
		R452B (Alternate 2)	6.63	28128	3.38	8.33	30292	3.90	7.76
	Liquid Line	Low Charge	4.23	N/A			14216	3.90	3.64
		Re-Charged	6.63				30865	4.16	7.42
	Vapor Line	Low Charge	4.27				15171	3.92	3.87
		Re-Charged	6.77				30587	-	-

\*Original baseline values from PRAHA

- 4) Conclusions: This report presented a comprehensive set of activities with the objectives of advancing the PRAHA program. The original scope and schedule were modified during the project as new findings and challenges surfaced. The tests that were carried out for PRAHA-I, while sufficient for the purpose of measuring capacity and energy efficiency for the purposes of PRAHA-I, did not have enough essential data to enable a complete cycle evaluation for optimization purposes. This is primarily due to using standard test rig on systems with critical hardware configuration differences. The analyses presented in Activity 2 (design assessment through modeling) provided good insights on adequate component design and/or selection for proper system functioning when using novel refrigerants. The tests in activities 3-5 partially served as validation for the models developed, and as check for previous test data from PRAHA I. The final recommendations for future development are listed as follows:
- a. Establish a baseline system by conducting comprehensive testing including measurements and metrics not typically performed in energy certification tests. Furthermore, testing systems with different configurations require custom test rigs as such to adequately measure working fluid's states to avoid mischaracterization of the operating conditions and performance. Such approach is considerably more labor-intensive which should be factored in the scope in future developments.
  - b. Using alternate low-GWP refrigerants is viable and can be competitive to commonly used pure refrigerants but doing so requires proper component design and selection; compressor and expansion device particularly. Drop-in replacement without hardware change is never recommended as evidenced by the change requirements in Activity 2 and performance tests in the subsequent activities.
  - c. It is recommended to always perform numerical simulations, and to conduct at least some level of "soft" optimization analyses that will provide information for an educated system re-design / retrofit at much lower costs than gradual trial-and-error changes.
  - d. Always test the modified systems with the same instrumentation as the baseline, however mindful of the modifications as such to properly place sensors to obtain adequate readings as suggested in item a above.

## 2. Introduction

Over the past several years through the Promoting low- Global Warming Potential (GWP) Refrigerants for Air-Conditioning Sectors in High-Ambient Temperature Countries (PRAHA-I) project, 18 different prototypes have been developed and compared to respective baselines to support the assessment of alternative lower-GWP refrigerants for air-conditioning applications. Since the work originally started in 2012, researchers have identified gaps in the performance and operation of the PRAHA-1 prototypes. These gaps include the need to redesign and optimize prototype air-conditioning units, evaluate new alternative refrigerants, and improve component selection. As such, a new project, *Advancing the Designs of PRAHA-I for Meeting or Exceeding the Baseline Designs Performance*, is desired.

The objectives of this project include the following:

- 4) Evaluate the design limitation of the PRAHA-I prototypes;
- 5) Optimize and physically evaluate selected prototypes with new refrigerants not evaluated during PRAHA-I; and,
- 6) Characterize leaks.

The project is divided into six activities namely:

- **Activity 1 – Analyzing the Design of PRAHA-I Prototypes**: evaluate systems performance from selected units tested in PRAHA-I, and assess potential design improvements
- **Activity 2 – Design Improvement**: improve design of specific units targeting higher efficiencies while using alternate low-GWP refrigerants
- **Activity 3 - Prototype Units Fabrication**: modify the a sub-set of the units according to modifications proposed in Activity 2
- **Activity 4 - Evaluation of the Optimized Prototypes**: conduct performance tests on modified units at standard and high ambient temperature conditions (35°C and 46°C)
- **Activity 5 - Analyzing Leaks of Alternatives**: simulate refrigerant leakage and evaluate possible impact of zeotropic mixtures fractionation on performance
- **Activity 6 - Reporting and Data Management**: simulation and test data processing, preparing progress and final reports

## 3. Activity 1 - Analyzing the Design of PRAHA-I Prototypes

Activity 1 was comprised of three major tasks including: reception of 12 physical units at the OTS facility followed by visual inspection and parts identification; review of performance test reports from PRAHA I tests; and lastly, analyze data and identify, for units of interest, opportunity for improvement targeting higher performance and minimal charge. OTS has completed this activity and an executive summary of the findings are presented herein.

### 3.1. Physical Units

All 12 units of interest to this project (Table 3) were received on November 8<sup>th</sup>, 2018. Visual inspection indicated no evident signs of damage. Relevant information to the project such as compressor model, heat exchanger (HX) geometry and circuiting, as well as expansion device were also received.

**Table 3: Unit Specifications Summary.**

Category	Unit #	Ref.	Designed Capacity Btu/h	Measured Cap. Btu/h	Voltage	Ref. (New designs)	Ref. (Tests)
Window	1	L-20 (R-444B)	18,000	19,104	208-230/60/1	L-20, R454C, R290, R457A	R290
	2	L-20 (R-444B)	18,000	16,924	208-230/60/1		
	3	DR-3 (R-454C)	18,000	18,063	208-230/60/1		
Decorative splits	4	R-290	24000 (18,000)	19,000	208-230/60/1	R-290	R-290
	5	R-32	24000 (18,000)	19,328	208-230/60/1		
	6	R-32	24,000	25,456	208-230/60/1	R32, R459A	R32, R459A
	7	L-41 (R-447A)	24,000	24,830	208-230/60/1		
	8	L-20 (R-444B)	24,000	22,740	208-230/60/1		
	9	DR-3	24,000	14,638	208-230/60/1		
Ducted splits	10	R-32	36,000	35,500	220-240/50/1	R447B, R452B	R447B, R452B
	11	L-20	36,000	36,553	220-240/50/1		
	12	DR-3 (R-454C)	36,000	33,032	220-240/50/1		

### 3.2. PRAHA-I Performance Reports Assessment

OTS received a complete package of files containing the performance reports for all units tested in PRAHA I. The tests conducted in PRAHA I were meant to assess high-level performance of these units focusing on a large control volume where only total energy in and out was evaluated. As such, these tests were not comprehensive in terms of measurements for cycle analysis required in PRAHA II. Refrigerant side measurements, in most cases, were very limited (few pressure and temperature measurements and no flow rates); thus, it is not possible to fully characterize the cycle and perform energy balances between air and refrigerant sides of the system. Common issues found in the reports include:

- Tag mislabeling and / or mismatching sensor location and tag
- No independent outdoor capacity reported – typically reported the same as indoor capacity
- Missing energy balance checks
- Missing measurement on either airside pressure drop and temperature or fan power
- Inconsistent reported measurements with thermophysical properties for units tested with L-20
- Systematic inconsistency in reported superheat and subcooling
- Missing measurements on refrigerant side at evaporator inlet
- Missing temperature and/or pressure measurements on refrigerant side
- Missing refrigerant mass flow measurements

A summary of the original PRAHA-1 data and results of the data reduction are provided under separate documentation.

### 3.3. Hardware Improvement Assessment

#### 3.3.1. Heat Exchanger (HX) First Order Analysis (FOA)

This section outlines a FOA for the HXs of Units 1, 4, 6 and 10 to identify improvement potential. The project's objective, as stated above, is to improve performance while minimizing charge. One way of addressing both objectives is by reducing tube / channel diameter. Heat transfer coefficients are inversely proportional to surface hydraulic diameters, however, so is pressure drop. Smaller tubes result in more compact ( $C = \text{surface area} / \text{footprint volume}$ ), with reduced internal volume, HXs.

A qualitative analysis using values from literature was carried out to demonstrate the relative impact of diameter over abovementioned metrics, specifically: heat transfer coefficient, compactness and overall thermal conductance (UA). The left-hand side plot in Figure 1 show three curves inversely proportional to the diameter; a 5mm tube can achieve, in this example, 70% greater UA than a conventional 9.5mm, within the same footprint volume (or cabinet).

These are further explored to illustrate the impact on a system level. Systems respond to UA of both condenser and evaporators, but for the purposes of this analysis, condenser only is considered. The UA represents the overall thermal conductance, which will impact the approach temperatures in the system ( $\Delta T_{app}$ ). If the heat rejection is kept constant, the higher the UA, the smaller are the  $\Delta T_{app}$ 's, thus allowing the condenser to operate in lower pressure levels, which will consequently increase the system performance. An example using a hypothetical R32 cycle with an EER of 12 as base is shown in the right-hand side plot in Figure 1. Performance improvement is limited by the Second Law, when the approach temperatures near zero; however, in this illustration, the EER has potential to increase in over 20% with better condenser design alone.

It is imperative to note that the results presented in this section are for **illustration purposes only**. Further in this report it is presented in more detail a re-design framework, applied to the units of interest in this project, using the metrics outlined in this section.

Unit 1 already had a 5mm condenser, which limits the options for HX re-design. Unit 6 had a 7mm HX on both the indoor and outdoor units, which allows some room for improvement if reducing to 5mm. Lastly, both coils for Unit 10 had 9.5mm tubes, thus there is greater potential for charge reduction and performance improvement for that unit in particular.




Figure 1. Heat Exchangers FOA.

### 3.3.2. Compressors

The existing units mostly use compressors sized specifically for R410A or R22 and in some cases custom made for this effort. There is, however, opportunity for a better compressor selection when migrating from R32 to R454B or R447B on Units 6 and 10, respectively.

### 3.3.3. Expansion Devices

Expansion devices such as TXV's and EXV's may allow for better control and reduced losses in connecting pipes if located near the evaporator. Some units, such as 6 and 10, have a capillary tube in the outdoor unit, which forces the refrigerant to travel in two-phase along the connecting pipes, and at lower temperatures, thus increasing pressure drop and heat gain.

### 3.3.4. Fan and Blower

Replacing the fan and blower may be necessary if newly designed HXs offer considerable change in pressure drop over the baseline since the flow rates are kept constant. The lack of test data on pressure drop forces us to rely on predicted values only. These will be considered for replacement as a last priority.

### 3.3.5. Units Component Modification Potential

Table 4 shows the detailed existing components for the units of interest for modification.

**Table 4: Units 1, 4, 6 and 10 Components.**

System	Unit 1	Unit 4	Unit 6	Unit 10
Refrigerant	R444B	R290	R32	R32
Compressor	HIGHLY SL260DG-C8EU	HIGHLY PSH356DG-C8DU3	GMCC KSG226N1UMT	Copeland ZP42K5E-PFJ-XXX
Condenser	5mm Louver TFHX	9.5mm Wavy TFHX	7mm Louver TFHX	9.5mm Louver TFHX
Expansion Device	Capillary Tube	Capillary Tube	Capillary Tube	Capillary Tube
Evaporator	9.5mm Louver TFHX	7mm Louver TFHX	7mm Slit TFHX	9.5mm Louver TFHX

## 3.4. Conclusions and Recommendations

The first part of this activity regarded data analysis and processing from the original tests conducted in the original PRAHA-I project, which was designed to conduct testing and comparison of cooling capacity vs. EER for the prototypes against the baseline units from same manufacturers. Since limited certification tests were required then, more testing parameters would have been needed to support the optimization and/or redesign process within the scope of PRAHA-II. The second part pertained assessing potential hardware modifications that could result in higher performance and less charge, with the intent of replacing the original refrigerants with alternative, low-GWP ones. The key conclusions and recommendations are:

- 1- Certification laboratories, such as the one used for testing the units in PRAHA I, provide limited information for the purposes of product design and development. For future reference it is recommended that for research-oriented efforts such as this one, the units undergo a more rigorous testing process along with full characterization of the system and its individual components operating conditions and performance.
- 2- In applications of high ambient temperatures, it is expected that performance will degrade as compared to operating under more temperate conditions and the resultant impact on performance must be considered. The key components for performance improvement identified herein were the compressor, condenser and expansion device.



- a. At higher temperatures, the saturation temperatures and refrigerant density at compressor's suction port can be very different than that from the rated conditions. Larger displacement volumes and efficiency curves optimized for higher pressure lifts might be required. Therefore, the proper selection of the compressor is paramount.
  - b. A better performance condenser will reduce the approach temperature between refrigerant and air, helping the compressor not to discharge refrigerant at very high pressure and temperatures, which degrade performance.
- 3- At high ambient conditions, the system is forced to operate in higher pressure lift than at rated conditions, but still requires a certain refrigerant mass flow rate. Passive devices such as capillary tubes and orifices may not be able to provide enough expansion to allow the system to operate in higher temperature conditions. An active expansion device such as EXV's can adequately control operating conditions and maintain stable superheat.

## 4. Activity 2 - Design Improvements

The details of modeling and simulation results are provided in a separate document submitted in conjunction with this one, while in this section only the summarized performance results are presented.

### 4.1. Hardware

A general design improvement assessment was presented in the report for Activity 1, focusing on the units of interest to this study. A first order analysis on the HX's showed that moving towards smaller hydraulic diameter tubes can be beneficial from a material savings and charge reduction standpoint. Units 4 and 10 use conventional 9.5mm diameter tube condensers (Table 4), making them good candidates for condenser replacement with either a smaller tube diameter or a microchannel heat exchanger (MCHX). The compressors used on Units 1, 4 and 6 do not have available performance maps making it difficult to assess their fitness for the system. The focus of this study is on proper compressor selection and condenser re-design.

### 4.2. Refrigerant

R32 and R290 have wide saturation regions (Figure 2 and Figure 3) putting them at an advantage since they may operate with smaller superheat and subcooling, while benefiting from two-phase heat transfer. Their cycles may get closer to that of the ideal Carnot cycle compared to refrigerants with narrower saturation.

Amongst the blends investigated for Unit 1, R444B has the widest saturation region while also having the highest temperature glide (Figure 4). The latter is typically not beneficial, in particular for evaporators, but it may help the condenser. The glide enables the refrigerant temperature profile to get closer to the air temperature profile without crossing (Figure 4). From a thermodynamic perspective, this means R444B can have its condensing pressure reduced further, resulting in higher theoretical COP.

For Units 6 and 10, the investigated blends, although having narrower saturation than the baseline R32, have similar thermophysical characteristics (Figure 3) with lower temperature glides (Figure 4) making them more competitive from a capacity and performance perspective.




Figure 2. Refrigerants Investigated for Units 1 and 4.




Figure 3. Refrigerants Investigated for Units 6 and 10.




Figure 4. Refrigerant Temperature Glides.

#### 4.3. System Design Modification Framework

The systems' re-design herein presented ultimately consists of a retrofit of the existing units by properly designing and selecting components that can be replaced as drop-ins, with minimal or no modification of

the packaging (cabinets). In other words, any component replaced must occupy the same envelope as the baseline component. The focus of the re-design is on:

- Compressor
- Condenser, and
- Expansion valve

The evaporator designs were not changed for two main reasons: a) some are custom-made wrap-around the blower units, such as in Unit 6, making it harder to quickly find an off-the-shelf option; and, b) the goal is to deliver the same cooling capacity while improving efficiency. For the latter, there's more room for improvement in the condenser by reducing condensing pressure, assuming the evaporator can already deliver the expected capacity.

The fans and blowers were also not considered for change, in part due to the lack of information on the performance curves from the baseline models, but also due to potential high cost and lead time for replacement with secondary impact on performance since 80-90% of the power consumed comes from the compressor.

The first step to assess the level of performance required for each component is to investigate an improved theoretical cycle, which will indicate how much COP improvement can be expected, as well as refrigerant flow rate needs and HX size (UA). To improve the performance of a vapor compression cycle, the pressure lift between evaporating and condensing pressures must be reduced. Consequently, the approach temperatures between air and refrigerant will be reduced as well (Figure 5), thus the thermal capacitance of the heat exchangers must increase. Furthermore, the closer to the saturation region, the closer the cycle reaches the ideal Carnot efficiency (Figure 6).




Figure 5. Illustrative T-s diagram for baseline and improved cycles.




Figure 6. P-h Diagrams Illustrating COP Improvement: a) Real Cycle; b) Ideal Cycle (Carnot).

The system design framework is performed according to Figure 7.




Figure 7. System Re-Design Framework,

#### 4.3.1. Compressors

Modeling compressors are handled in two possible ways, as suggested previously: using performance maps when available or using fixed isentropic efficiency and effective displacement volume. For the larger capacity units (6 and 10), performance maps were provided. Although these compressors were originally designed for R410A refrigerant they may operate – not necessarily optimally – with other refrigerants. Compressor manufacturers supporting this project used proprietary simulation tools, with aid from available empirical data (tests with other refrigerants), to develop theoretical maps for the various refrigerants of interest (Table 5) and made them available to OTS for modeling purposes. It is understood that the predictions are for reference only, and the compressor manufacturer does not guarantee performance for any refrigerants for which the compressors haven't been fully tested.

**Table 5: Compressor Models.**

Model	Capacity (BTU/hr)	Frequency (Hz)	Refrigerants
ZP20K5E-PFV	24,000	60	R32, R459A, R454B, R410A
ZP21K5E-PFV	24,000		
ZP31K6E-PFV	36,000	50/60	R447B, R452B, R454B, R410A
ZP34K6E-PFV	36,000		

For the smaller units (1 and 4), which were re-designed using R290 (Propane), compressor performance maps were not available. The approach for these units then was to set a target isentropic efficiency of 0.7 (baseline data suggests that the compressor efficiencies ranged from 0.55 to 0.65). The required mass flow rate is calculated based on capacity in the theoretical cycle model described above. From there, the effective displacement volume can be determined (eq. (1))<sup>1</sup>. The latter serves to determine whether a system can use the same compressors for different refrigerants.

$$V_{eff} = \eta_{vol} \cdot V_{disp} = \frac{\dot{m}_{required}}{f \cdot \rho_{suction}} \quad (1)$$

#### 4.3.2. HX Design and Selection

The condensers design procedure takes into consideration the following:

- **Face area:** baseline face area must be preserved or at most reduced. Furthermore, the aspect ratio must also match that of the baseline so the HX can be drop-in replaced in the same cabinet.
  - o Find the number of tube rows and tube length to match as closely as possible to tube face area and aspect ratio
- **Airside pressure drop and flow rate:** the test data from reports contain only air flow rate measurements, while no information on pressure drop is provided. Additionally, the fan performance curves are also not available, which limits the ability to find the exact operating condition. The baseline models provide an estimate prediction for the pressure drop, which is used as reference.
- **Thermal performance:** this step must be iteratively conducted with the previous step, as such for each design change the air flow rate and capacity are evaluated under the new conditions found in the theoretical cycle re-design.
  - o Gradually increment the condensing pressure until attainable performance is achieved. This process is done iteratively using the theoretical cycle model, to find new expected operating conditions for evaporating pressure, superheat, subcooling and refrigerant flow rate.
- **HX Form:** as indicated previously, the HX design is constrained by cabinet dimensions as well as form. In the case of units 1 and 4, the condensers are flat coils placed 90° inside the cabinet (Figure 8), which makes it simpler for drop-in replacement as long as new designs have the same overall dimensions. For units 6 and 10, however, the condensers are L-shaped inside the cabinet (Figure 8). Forming coils is widely done, however, for custom coils it may be a challenge, in particular for MCHX. For this reason, the MCHX designs for units 6 and 10 are sized for a full-face area, assuming the coil can be formed, and a second design that is a single flat slab placed in longer side of the “L” shape(Figure 9).

<sup>1</sup> Variable definitions in the Nomenclature list after final conclusions section in this document.

- **HX Name Tag Convention:** for practical purposes, the HX's will be tagged according to the following W XX YY Z
  - **W:** B = Baseline or N = New Design
  - **XX:** TF = Tube-Fin or MC = Microchannel
  - **YY:** D# = Tube Diameter or Height
  - **Z:** R = Reduced Face Area
  - **Example:** New Tube Fin Design with 5.0mm diameter with same face area as the baseline → NTFD5




Figure 8. Condenser Forms: Unit 1 (left), Unit 10 (center), Unit 6 Cabinet (right).




Figure 9. HX Form Examples: L-shape (left), Flat (right).

#### 4.3.3. System Design

In the final step, the modified systems are evaluated holistically through system level modeling and simulation using an in-house Steady-State vapor compression cycle software that has the capability to integrate with the HX and compressor models (performance maps, generic etc.). For each modified system and each refrigerant, a system model was created.

#### 4.4. Modified Systems Results Summary

The final results of Activity 2 are summarized in Table 6. For more detailed results in the framework steps refer to APPENDIX A .

#### 4.5. Conclusions and Recommendations

This section presents a systematic approach based on first order analysis providing educated guidance towards the direction of more efficient systems with fewer simulations and minimal changes to the systems. The study includes a wide variety of refrigerants as well as condenser designs and compressor model options. Given the challenges with original test data the baseline models serve as a numerical reference only. The findings are strictly valid to comparisons against the baseline models and OTS does not guarantee that results would be reflected in actual systems as herein reported. The key conclusions and recommendations are:

- 1- R290 and R32 have wider saturation regions allowing the system to operate with smaller superheat and subcooling, while benefiting from two-phase heat transfer.
- 2- Refrigerants with high temperature glide may require new heat exchanger (HX) designs, namely condensers. The original designs proved to be sufficiently effective to allow for most systems to operate with the different refrigerants, however, better designs would allow for higher system efficiency and potentially less charge. HX designs are severely constrained by allowed envelope dimensions. A complete system re-design would provide an opportunity for designing HX's with even higher efficiency.
- 3- The results of this analysis suggest that for an effective use of alternate low-GWP refrigerant, a proper compressor selection must be accompanied with it. Higher isentropic efficiencies are desired for higher temperatures, but most importantly, the displacement volume requirements can vary considerably from one refrigerant to another.
- 4- It is also imperative that having an active expansion device (preferably an EXV) to not only allow for more controlled superheat, but also to enable the unit to run with different refrigerants with very different thermophysical properties.

**Table 6: Activity 2 Results.**

General Information			Hardware					Ref.	Performance			
System	Rated Capacity (@35°C)	System Configuration	Compressor		Condenser		Expansion Device		Cooling Capacity (@46°C)		EER (@46°C)	
-	BTU/hr	-	Effective Disp. Vol. (cm <sup>3</sup> )*	Efficiency (-)	Type	Effectiveness (-)	Type	-	BTU/hr	%	BTU/hr. W	%
Unit 1	18000	Baseline	19.8	0.66	Tube-Fin (5mm Tube)	0.20	Passive	R444B	17403	0.00%	7.4	0.00%
		Alternate 1	25.9	0.70	Same as Baseline	0.35	Active (EXV)	R290	17639	1.40%	8.01	8.20%
		Alternate 2	24.8	0.69		0.26		R454C	18104	4.00%	7.31	-1.30%
		Alternate 3	19.6	0.70		0.23		R444B	18140	4.20%	8.14	9.90%
		Alternate 4	25.3	0.68	MCHX	0.24		R457A	17749	2.00%	7.63	3.10%
Unit 4	24000	Baseline	26.4	0.61	Tube-Fin (9.5mm Tube)	0.24	Passive	R290	17940	0.00%	7.52	0.00%
		Alternate 1	26.3	0.70	Tube-Fin (5mm Tube)	0.26	Active (EXV)	R290	18147	1.20%	9.12	21.40%
		Alternate 2	37.9	0.70		0.20		R290	24120	34.40%	6.72	-10.60%
Unit 6	24000	Baseline	16.0	0.60	Tube-Fin (7mm Tube)	0.12	Passive	R32	23115	0.00%	8.46	0.00%
		Alternate 1	16.9	0.65	Tube-Fin (5mm Tube)	0.15	Active (EXV)	R32	23798	3.00%	9.41	11.20%
		Alternate 2	18.4	0.67		0.19		R454B	22894	-1.00%	9.71	14.80%
		Alternate 3	19.0	0.70		0.17		R452B	23702	2.50%	9.6	13.50%
Unit 10	36000	Baseline	19.6	0.44	Tube-Fin (9.5mm Tube)	0.13	Passive	R32	29005	0.00%	6.39	0.00%
		Alternate 1	22.3	0.65	Tube-Fin (5mm Tube)	0.25	Active (EXV)	R447B	30478	5.10%	9.43	47.50%
		Alternate 2	23.0	0.67		0.25		R452B	30796	6.20%	10.27	60.70%
		Alternate 3	23.3	0.67		0.25		R454B	30809	6.20%	10	56.50%

\* Product of displacement volume and volumetric efficiency



## 5. Activities 3, 4 & 5 - Prototype Units Fabrication, Evaluation of the Optimized Prototypes and Analyzing Leaks of Alternatives

Activities 3-5 officially began in April 2019 when the first round of tests on modified Unit 6 were carried out. Initial tests resulting in unsuccessful outcomes leading OTS to change the system modifications and the scope. Additional information found in APPENDIX B . The detailed test data and charge optimization for Units 6 and 10 are presented in APPENDIX C through APPENDIX E . Comparisons between Activity 2 model validations and experimental data are presented in APPENDIX F .

### 5.1. Unit 6

Some modifications were made to Unit 6 to improve its efficiency. The baseline compressor was replaced with alternate models to account for the change in refrigerant and to improve efficiency. The compressor used with R454B had a higher displacement volume than the one used with R32. Furthermore, the capillary tubes were replaced with a manual TXV that was installed directly at the evaporator inlet to increase the cooling capacity of the evaporator. A summary of the design modifications evaluated for Unit 6 is listed in Table 7, while Table 8 and Table 9 show the performance of Unit 6 for baseline and modifications at 35°C and 46°C ambient, respectively. The baseline system performed similar, within 2%, to reported performance in PRAHA I. There is a discrepancy in the measurements from condenser outlet to expansion inlet in the baseline case, since the capillary tube (removed in the modified systems) was located in the outdoor unit. The expansion causes the refrigerant to flash in the liquid line thus compromising the readings at the expansion device. For calculation purposes, the condenser outlet enthalpy was used instead of the expansion inlet.

**Table 7: Unit 6 Modifications for Testing.**

System	Unit 6		
	Baseline	Alternate 1	Alternate 2
Refrigerant	R32	R32	R454B
Compressor	GMCC KSG226N1UMT	Copeland ZP20K5E	Copeland ZP21K5E
Expansion Device	Capillary Tube (Outdoor unit)	Manual Valve (Indoor Unit) <sup>2</sup>	Manual Valve (Indoor Unit) <sup>2</sup>

Cooling capacity for the modified unit with either refrigerant was consistently lower by 6-12% than the baseline. The modified R32 system reportedly showed lower mass flow rate than expected, likely the main cause for the lower-than-expected thermal performance. The R454B system resulted in a poorer performance but was less sensitive to ambient temperature than its R32 counterpart - i.e. cooling capacity was near the same at both 35°C and 46°C, while for R32 there was a ~2,000BTU/hr reduction with the temperature increase. It is also possible that there is a mismatch between thermophysical property library and actual refrigerant properties for R454B which can happen with newer fluids. The libraries need periodic update as more test data become available.

<sup>2</sup> A manual valve was used to mimic a TXV or EXV recommended as component modification in these systems configurations.

**Table 8: Unit 6 - Performance Test Summary for R32 Baseline (OTS) @ 35°C.**

		Baseline (35°C)	Alternate 1 (35°C)	Alternate 2 (35°C)	Alt. 1 vs. Baseline	Alt. 2 vs. Baseline
<b>Refrigerant</b>	-	<b>R32</b>	<b>R32</b>	<b>R454B</b>	-	-
Charge	lb	3.83	4.27	5.02	11.5%	31.1%
Cooling Capacity	BTU/hr	25192	23585	21966	-6.4%	-12.8%
Energy Balance	%	-2.28%	-4.66%	-3.06%	-	-
Compressor Power	kW	2.11	1.79	1.77	-15.1%	-16.2%
Fan Power	kW	0.32	0.33	0.33	2.2%	4.2%
Total Power	kW	2.43	2.12	2.10	-12.8%	-13.5%
EER	BTU/hr.W	10.37	11.12	10.44	7.2%	0.68%

**Table 9: Unit 6 - Performance Test Summary for R32 Baseline (OTS) @ 46°C.**

		Baseline (46°C)	Alternate 1 (46°C)	Alternate 2 (46°C)	Alt. 1 vs. Baseline	Alt. 2 vs. Baseline
<b>Refrigerant</b>	-	<b>R32</b>	<b>R32</b>	<b>R454B</b>	-	-
Charge	lb	3.83	4.27	5.02	11.5%	31.1%
Cooling Capacity	BTU/hr	23390	21450	21821	-8.3%	-6.7%
Energy Balance	%	-1.78%	-4.42%	-7.61%	-	-
Compressor Power	kW	2.71	2.32	2.25	-14.2%	-16.6%
Fan Power	kW	0.40	0.42	0.42	5.3%	5.3%
Total Power	kW	3.10	2.74	2.67	-11.7%	-13.8%
EER	BTU/hr.W	7.55	7.84	8.17	3.8%	8.2%

## 5.2. Unit 10

Applying what was learned in the initial modifications to Unit 6, modifications to Unit 10 were limited to include the compressor and expansion device only. Unlike Unit 6, however, the re-test of the baseline system was not successful; refer to APPENDIX D for additional information. However since Unit 6 baseline re-test showed good reproducibility from original data, it is assumed that the Unit 10 original baseline is appropriate for comparison against the modified system configurations. A summary of the design modifications evaluated for Unit 10 is listed in Table 10. The detailed test data is presented in APPENDIX E .

At 35°C the modified units exhibited almost 20% less cooling capacity with 10% less power consumption, resulting in up to 11% less EER (Table 11). These results were not unexpected since the modified units were re-designed using the 46°C temperature, when the baseline system’s performance showed a great degradation of performance. At 46°C condition, the tests exhibited 2-5% greater cooling capacity with up to 12% less power consumption compared to the baseline, which was equivalent to 13-17% greater system performance.

In Activity 2 the compressor power consumptions were underestimated, as well as the total fan power consumption, leaving the impression the overall performance improvement would considerably be greater than the observed. The cooling capacity, on the other hand, was predicted with less than 2% deviation from test data, validating at least the models created.

**Table 10: Unit 10 Modifications for Testing.**

System	Unit 10		
	Baseline	Alternate 1	Alternate 2
Refrigerant	R32	R447B	R452B
Compressor	Copeland ZP42K6E	Copeland ZP34K5E	Copeland ZP31K5E
Expansion Device	Orifice	Manual Valve	Manual Valve

**Table 11: Unit 10 - Performance Test Summary for R32 Baseline @ 35°C.**

		Baseline (35°C)	Alternate 1 (35°C)	Alternate 2 (35°C)	Alt. 1 vs. Baseline	Alt. 2 vs. Baseline
<b>Refrigerant</b>	-	<b>R32</b>	<b>447B</b>	<b>452B</b>	-	-
Charge	lb	5.625	6.625	6.625	17.78%	17.78%
Cooling Capacity	BTU/hr	35543	32195	28128	-9.42%	-20.86%
Energy Balance	%	---	7.52%	-3.29%	-	-
Compressor Power	kW	-	2.67	2.4	-	-
Fan Power	kW	-	0.95	0.98	-	-
Total Power	kW	3.761	3.62	3.38	-3.75%	-10.13%
EER	BTU/hr.W	9.451	8.894	8.322	-5.89%	-11.94%

**Table 12: Unit 10 - Performance Test Summary for R32 Baseline @ 46°C.**

		Baseline (46°C)	Alternate 1 (46°C)	Alternate 2 (46°C)	Alt. 1 vs. Baseline	Alt. 2 vs. Baseline
<b>Refrigerant</b>	-	<b>R32</b>	<b>447B</b>	<b>452B</b>	-	-
Charge	lb	5.625	6.625	6.625	17.78%	17.78%
Cooling Capacity	BTU/hr	29633	31073	30292	4.86%	2.22%
Energy Balance	%	---	4.21%	1.21%	-	-
Compressor Power	kW	---	3.18	2.93	-	-
Fan Power	kW	---	0.95	0.97	-	-
Total Power	kW	4.466	4.13	3.9	-7.52%	-12.67%
EER	BTU/hr.W	6.64	7.52	7.76	13.33%	16.95%

### 5.3. Leak Tests

In the interest of time the leak tests were conducted only on Unit 10 for R447B. The choice of refrigerant was based on temperature glide, where R447B exhibits the highest glide amongst the refrigerants evaluated between Unit 6 and Unit 10 (refer to Figure 4). The leak tests were conducted to closely represent field operation. The procedure applied includes the following steps:

- 1- Run unit until steady-state is achieved (repeat 46°C performance test), monitoring capacity and subcooling
- 2- Gradually remove refrigerant from vapor line until capacity is reduced to approximately 50%, if possible
- 3- Store and weigh removed refrigerant
- 4- Re-charge with new refrigerant until same subcooling is achieved
- 5- Compare cooling capacities; if more than 5% deviation is observed, repeat steps 1-4, however in step 2, reduce capacity to 25% only
- 6- Repeat steps 1-5 for the liquid line

The comparison herein presented refers to a leakage of approximately 30% of charge, while reducing capacity by approximately 50% based on airside only. The leak tests showed less than 2% deviation in cooling capacity after re-charge from both vapor and liquid lines (Table 13). Since the capacity deviation was less than 5%, no further testing for 25% capacity reduction was conducted. The results suggest little impact due to fractionation.

**Table 13: Unit 10 – R447B Leak Test Summary Results.**

System		Liquid Line Leak			Vapor Line Leak	
		Full Charge	Low Charge	Re-Charged	Low Charge	Re-Charged
Refrigerant	-	R447B	R447B	R447B	R447B	R447B
Charge	lb	6.625	4.27	6.625	4.23	6.77
Cooling Capacity	BTU/hr	31073	14216	30865	15171	30587
Energy Balance	%	4.21%	-34.72%	0.35%	-31.55%	1.87%
Compressor Power	kW	3.18	2.93	3.18	2.94	.. <sup>3</sup>
Fan Power	kW	0.95	0.98	0.98	0.98	0.98
Total Power	kW	4.13	3.90	4.16	3.92	.. <sup>3</sup>
EER	BTU/hr.W	7.52	3.64	7.42	3.87	.. <sup>3</sup>

#### 5.4. Conclusions and Recommendations

This section presented the performance tests conducted on units 6 and 10. The key conclusions and recommendations are:

- 1- Unit 6 re-tested baseline exhibited similar performance to that found in PRAHA I testing. It should be stressed that the baseline unit by design had its capillary tube located in the outdoor unit. This would cause liquid refrigerant leaving the outdoor unit to flash. The refrigerant enthalpy at the condenser outlet state was used to calculate the refrigerant-side capacity assuming an isenthalpic expansion without heat loss in connecting pipe. This is different from the modified systems of which the capillary tube was removed, and a manual expansion valve was placed at the inlet of the indoor unit. For modified systems, the enthalpy at the expansion valve inlet was used to calculate the refrigerant-side capacity.
- 2- Unit 10 exhibited a considerable reduction in power consumption at the high ambient test condition (46°C) as compared to the original test data. This also indicates the importance of proper compressor selection.
- 3- The higher-than-expected power consumption in the Unit 10 baseline tests is also evidenced by the fact that even with zeotropic mixtures (R447B and R452B), Unit 10 had higher cooling capacity and efficiency than the baseline for the 46°C test condition, as projected in activity 2.
- 4- Because of the differences in saturation curves from the Activity 2 analysis, R32 tends to result in systems with higher efficiency and less charge when no modifications to the hardware are made. The results showed however, that making appropriate component selection, such as compressors with larger displacement volumes and higher mass flow rates for the zeotropic mixtures, cooling capacities and overall performance were of the same order of magnitude.
- 5- Refrigerant fractionation as evidenced by the leak tests, does not appear to be a great concern since less than 2% deviation in cooling capacity was observed after the system's re-charge.
- 6- The Unit 6 modified systems had lower performance than expected from the Activity 2 models. The R32 system configuration exhibited more than 10% less flow rate than anticipated due to performance

<sup>3</sup> Compressor power consumption was not properly recorded for this test; the error was identified after the fact and the team was unable to retrieve that information. While that compromises the assessment of the overall system performance, the deviations are expected to be marginal. The leak test on liquid line suggest minimal impact on power consumption after re-charge, while cooling capacity was reportedly fully recovered after recharge on both leak tests.

maps overprediction, which corresponded to 10% lower capacity. The R454B configuration exhibited a deviation of 5% between model and test due also in part to a 3% flow rate over prediction in the model. Unit 10, on the other hand, exhibited an excellent agreement to the models with less than 2% deviation in cooling capacity.

- 7- The model's validation adds confidence in the numerical simulation findings and recommendations provided in activity 2.

## 6. Conclusions

This report presents a comprehensive set of activities with the objectives of advancing the PRAHA program. The original scope and schedule were modified during the project as new findings and challenges surfaced. The tests that were carried out for PRAHA-I, while sufficient for the purpose of measuring capacity and energy efficiency for the purposes of PRAHA-I, did not have enough essential data to enable a complete cycle evaluation for optimization purposes. This is primarily due to using standard test rig on systems with critical hardware configuration differences. The analyses presented in Activity 2 (design assessment through modeling) provided good insights on adequate component design and/or selection for proper system functioning, when using novel refrigerants.

The final recommendations for future development are listed as follows:

- 1- Establish a baseline system by conducting comprehensive testing including measurements and metrics not typically performed in energy certification tests. Furthermore, testing systems with different configurations require custom test rigs as such to adequately measure working fluid's states to avoid mischaracterization of the operating conditions and performance. Such approach is considerably more labor-intensive which should be factored in the scope in future developments.
- 2- Using alternate low-GWP refrigerants is viable and can be competitive to presently used refrigerants but doing so requires proper component design and selection; compressor and expansion device particularly. Drop-in replacement without hardware change is never recommended as evidenced by the change requirements in Activity 2 and performance tests in the subsequent activities.
- 3- It is recommended to always perform numerical simulations, and to conduct at least some level of "soft" optimization analyses that will provide information for an educated system re-design / retrofit at much lower costs than gradual trial-and-error changes.
- 4- Always test the modified systems with the same instrumentation as the baseline, however mindful of the modifications as such to properly place sensors to obtain adequate readings as suggested in item 1 above.

## *Nomenclature*

COP	Coefficient of Performance	-
$D_o$	Tube Outer Diameter	mm
$f$	Frequency	Hz
FPI	Fins per Inch	1/in
$h$	Enthalpy	kJ/kg
$h_t$	Tube Height	mm
HX	Heat Exchanger	-
$\dot{m}$	Mass Flow Rate	kg/s
MCHX	Microchannel Heat Exchanger	-
$P$	Pressure	kPa
$P_l$	Tube Longitudinal Pitch	mm
$P_t$	Tube Transverse Pitch	mm
$s$	Entropy	kJ/kg.K
$T$	Temperature	°C
TFHX	Tube-Fin Heat Exchanger	-
UA	Thermal Conductance	kW/K
$V$	Volume	$m^3$
$w_t$	Tube Width	mm
$\eta_{vol}$	Volumetric Efficiency	-
$\rho$	Density	kg/ $m^3$

## APPENDIX A - Activity 2 Design Framework Results

**Table 14: Unit 1 – Theoretical Cycle Re-Design Summary.**

System		Baseline	Alternative 1	Alternative 2	Alternative 3	Alternative 4
Case	-	Simulation	Target			
Refrigerant	-	R444B	R290	R454C	R444B	R457A
Condenser	-	BTFD5	-	-	-	-
Compressor	-	SL260DG-C8EU	-	-	-	-
Cooling Capacity	BTU/hr	17403	17477	17477	17477	17477
Compressor Power	kW	1.92	1.49	1.49	1.33	1.43
Fan Power	kW	0.43	0.43	0.43	0.43	0.43
Total Power	kW	2.35	1.92	1.93	1.76	1.86
COP	-	2.17	2.66	2.66	2.91	2.75
COP Gain	-	1.00	1.23	1.23	1.34	1.27

**Table 15: Unit 1 – HX Analysis Summary**

Condenser		R444B		R290		R454C		R457A	
Inputs		BTFD5	NMCD2	BTFD5	NMCD2	BTFD5	NMCD2	BTFD5	NMCD2
Air Dry-Bulb Temperature	°C	46.01	46.01	46.01	46.01	46.01	46.01	46.01	46.01
Relative Humidity	%	16.37	16.37	16.37	16.37	16.37	16.37	16.37	16.37
Air Flowrate	m <sup>3</sup> /s	0.56	0.56	0.56	0.56	0.56	0.56	0.56	0.56
Refrigerant Pressure	kPa	2875.0	2875.0	2170.7	2170.7	2436.4	2436.4	2183.9	2183.9
Saturation Temperature at Inlet	°C	61	61	61	61	61	61	61	61
Refrigerant Temperature	°C	110.00	110.00	110.00	110.00	110.00	110.00	110.00	110.00
Mass Flow Rate	kg/s	0.03	0.03	0.02	0.02	0.03	0.03	0.03	0.03
Outputs									
Heat Load	W	7512.9	7441.2	8232.4	8016.6	6168.0	6040.0	6592.0	6429.0
Air Dry-Bulb Temperature	°C	58.6	58.2	59.7	59.6	56.3	56.3	57.0	56.9
Refrigerant Temperature	°C	46.7	48.1	50.3	53.8	47.2	49.5	48.0	51.1
LMTD	°C	12	15	19	23	14	18	16	21
UA	W/K	635.57	482.84	439.36	350.35	451.67	327.93	424.35	313.48
NTU	-	1.04	0.79	0.72	0.57	0.74	0.53	0.69	0.51
Effectiveness	-	0.1915	0.1896	0.2098	0.2043	0.1572	0.1539	0.1680	0.1638
Refrigerant Pressure Drop	kPa	78.2	1.4	85.0	1.7	79.3	1.4	87.2	1.7
Airside DP	Pa	75.1	75.5	75.1	75.1	75.1	75.5	75.1	75.5
Air Heat Transfer Coefficient (Average)	W/m <sup>2</sup> .K	130.0	148.3	130.0	148.3	130.0	148.3	130.0	148.3
Refrigerant Heat Transfer Coefficient (Average)	W/m <sup>2</sup> .K	3341.0	1721.0	4113.0	2033.0	3040.0	1382.0	3423.0	1601.0
Subcooling	°C	13.20	13.14	8.96	7.35	6.77	5.93	5.34	4.05
Charge	kg	0.3822	0.1143	0.1079	0.0352	0.3097	0.094	0.2522	0.0764

**Table 16: Unit 1 – Compressor Performance Summary.**

Compressor		Baseline				
Refrigerant	-	R444B	R290	R454C	R444B	R457A
Isentropic efficiency	-	0.66	0.70	0.69	0.70	0.68
Power	kW	1.9175	1.7682	2.0449	1.7966	1.8932
Pressure Lift	kPa	2284.8	1556.0	2087.7	1902.2	1904.9
Effective Displacement Volume	cm <sup>3</sup>	19.80	25.87	24.80	19.64	25.35
Rotation Speed	RPM	3600	3600	3600	3600	3600

**Table 17: Unit 1 – Expected Modified System Performances.**

System		Baseline				
Case	-	Simulation	Expected			
Refrigerant	-	R444B	R290	R454C	R444B	R457A
Condenser	-	BTFD5	BTFD5	BTFD5	BTFD5	NMCD2
Compressor	-	SL260DG-C8EU	-	-	-	-
Cooling Capacity	BTU/hr	17403	17639	18104	18140	17749
Compressor Power	kW	1.92	1.77	2.04	1.80	1.89
Fan Power	kW	0.43	0.43	0.43	0.43	0.43
Total Power	kW	2.35	2.20	2.48	2.23	2.33
COP	-	2.17	2.35	2.14	2.38	2.24
COP Gain	-	1.00	1.08	0.99	1.10	1.03




Figure 10. Unit 1 – Modified Systems P-h Diagrams.

Table 18: Unit 4 – Theoretical Cycle Re-Design Summary.

System	Baseline		Alternative 1	Alternative 2
			Target	Target
Refrigerant	-	R290	R290	R290
Condenser	-	BTFD9	-	-
Compressor	-	PSH356DG-C8DU4	-	-
Cooling Capacity	BTU/hr	17940	17940	23920
Compressor Power	kW	2.11	1.40	3.23
Fan Power	kW	0.28	0.28	0.28
Total Power	kW	2.39	1.68	3.51
COP	-	2.20	3.14	2.00
COP Gain	-	1.00	1.42	0.91

Table 19: Unit 4 – HX Analysis Summary.

Condenser			R290 - 18kBTU		R290 - 24kBTU	
Inputs			BTFD9	NTFD5	BTFD9	NTFD5
Air Dry-Bulb Temperature	°C		46.01	46.01	46.01	46.01
Relative Humidity	%		16.37	16.37	16.37	16.37
Air Flowrate	m <sup>3</sup> /s		0.81	0.76	0.81	0.76
Refrigerant Pressure	kPa		2875	2875	2875	2875
Saturation Temperature at Inlet	°C		75.5	75.5	75.5	75.5




Condenser				R290 - 18kBTU		R290 - 24kBTU	
Inputs				<i>BTFD9</i>	<i>NTFD5</i>	<i>BTFD9</i>	<i>NTFD5</i>
Refrigerant Temperature	°C			110	110	110	110
Mass Flow Rate	kg/s			0.02	0.02	0.03	0.03
Outputs							
Heat Load	W			8139	8148	12080	12190
Air Dry-Bulb Temperature	°C			55.0	56.1	59.5	61.2
Refrigerant Temperature	°C			46.2	46.0	47.7	46.4
LMTD	°C			9.6	7.4	14.3	10.0
UA	W/K			848	1097	846	1216
NTU	-			0.97	1.34	0.97	1.48
Effectiveness	-			0.15	0.16	0.22	0.23
Refrigerant Pressure Drop	kPa			4.2	13.4	11.0	35.2
Airside DP	Pa			16.0	15.9	16.0	15.9
Air Heat Transfer Coefficient (Average)	W/m <sup>2</sup> .K			82.9	100.7	82.9	100.7
Refrigerant Heat Transfer Coefficient (Average)	W/m <sup>2</sup> .K			1535.2	1493.7	2382.4	2505.6
Subcooling	°C			29.2	29.2	27.6	28.4
Charge in Tubes	kg			0.90	0.46	0.76	0.39

**Table 20: Unit 4 – Compressor Performance Summary.**

Compressor		Baseline	18kBTU/Hr		24kBTU/Hr	
Refrigerant	-	R290	R290	R290	R290	R290
Isentropic efficiency	-	0.61	0.70	0.70	0.70	0.70
Power	kW	2.1067	1.7364	1.7093	3.3152	3.31
Pressure Lift	kPa	1457.6	1556.3	1513.7	2947.1	2937.4
Effective Displacement Volume	cm <sup>3</sup>	26.394	26.309	26.309	37.866	37.866
Rotation Speed	RPM	3600	3600	3600	3600	3600

**Table 21: Unit 4 – Expected Modified System Performances.**

System		Baseline	Alternative 1		Alternative 2	
			Expected			
Refrigerant	-	R290	R290	R290	R290	R290
Condenser	-	BTFD9	BTFD9	NTFD5	BTFD9	NTFD5
Compressor	-	PSH356DG-C8DU4	-	-	-	-
Cooling Capacity	BTU/hr	17940	17991	18147	24045	24120
Compressor Power	kW	2.11	1.74	1.71	3.32	3.31
Fan Power	kW	0.28	0.28	0.28	0.28	0.28
Total Power	kW	2.39	2.02	1.99	3.60	3.59
COP	-	2.20	2.61	2.67	1.96	1.97
COP Gain	-	1.00	1.19	1.21	0.89	0.89



**Figure 11. Unit 4 – Modified Systems P-h Diagrams.**

**Table 22: Unit 6 – Theoretical Cycle Re-Design Summary.**

System		Simulation	Alternate 1	Alternate 2	Alternate 3
Refrigerant	-	R32	R32	Target R454B	R452B
Condenser	-	BTFD9	-	-	-
Compressor	-	GMCC KSG226N1UMT	ZP20K5E	ZP21K5E	-
Cooling Capacity	BTU/hr	23115	23114	23114	23115
Compressor Power	kW	2.73	2.37	2.29	2.04
Fan Power	kW	8.46	9.75	10.10	11.31
Total Power	kW	2.73	2.37	2.29	2.04
COP	-	2.48	2.86	2.96	3.32
COP Gain	-	1.00	1.15	1.19	1.34

**Table 23: Unit 6 – HX Analysis for R32**

Condenser			BTFD7	NTFD5	NMCD2	NMCD2R
Inputs						
Air Dry-Bulb Temperature	°C		46.01	46.01	46.01	46.01
Relative Humidity	%		16.37	16.37	16.37	16.37
Air Flowrate	m³/s		1.08	0.94	1.08	0.94
Refrigerant Pressure	kPa		3562	3562	3562	3562
Saturation Temperature at Inlet	°C		55.53	55.53	55.53	55.53
Refrigerant Temperature	°C		112.00	112.00	112.00	112.00
Mass Flow Rate	kg/s		0.03	0.03	0.03	0.03
Outputs						
Heat Load	W		9159	9416	9332	9113
Air Dry-Bulb Temperature	°C		53.63	55.35	54.27	55.24
Refrigerant Temperature	°C		49.78	46.15	47.40	50.47
LMTD	°C		19.94	9.46	15.13	20.57
UA	W/K		459.40	995.12	616.75	443.09
NTU	-		0.39	0.97	0.52	0.43
Refrigerant Pressure Drop	kPa		100.98	26.10	3.06	4.70
Airside DP	Pa		26.30	29.30	27.70	28.90
Air Heat Transfer Coefficient (Average)	W/m².K		109.57	126.69	128.70	130.84
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		5543.00	2624.00	2353.00	2978.00
Subcooling	°C		4.48	9.04	8.10	5.07
Charge	kg		0.39	0.71	0.17	0.11

**Table 24: Unit 6 – HX Analysis for R452B**

Condenser			BTFD7	NTFD5	NMCD2	NMCD2R
Inputs						
Air Dry-Bulb Temperature	°C		46.01	46.01	46.01	46.01
Relative Humidity	%		16.37	16.37	16.37	16.37
Air Flowrate	m³/s		1.08	0.94	1.08	0.94
Refrigerant Pressure	kPa		3247	3247	3247	3247
Saturation Temperature at Inlet	°C		55.53	55.53	55.53	55.53
Refrigerant Temperature	°C		112.00	112.00	112.00	112.00
Mass Flow Rate	kg/s		0.03	0.03	0.03	0.03
Outputs						
Heat Load	W		7876	7964	7936	7866
Air Dry-Bulb Temperature	°C		52.52	53.94	53.06	53.99
Refrigerant Temperature	°C		47.41	46.05	46.53	47.61
LMTD	°C		15.49	8.09	12.37	15.72
UA	W/K		508.37	984.95	641.46	500.33
NTU	-		0.43	0.96	0.55	0.49
Refrigerant Pressure Drop	kPa		71.90	21.03	2.60	3.70
Airside DP	Pa		26.30	29.30	27.70	28.90
Air Heat Transfer Coefficient (Average)	W/m².K		109.57	126.69	128.70	130.84
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		4252.00	2077.00	2103.00	2112.00
Subcooling	°C		6.14	8.20	7.99	6.89
Charge	kg		0.55	0.90	0.21	0.15

**Table 25: Unit 6 – HX Analysis for R447B**

<i>Condenser</i>						
<i>Inputs</i>			<i>BTFD7</i>	<i>NTFD5</i>	<i>NMCD2</i>	<i>NMCD2R</i>
Air Dry-Bulb Temperature	°C		46.01	46.01	46.01	46.01
Relative Humidity	%		16.37	16.37	16.37	16.37
Air Flowrate	m³/s		1.08	0.94	1.08	0.94
Refrigerant Pressure	kPa		3025	3025	3025	3025
Saturation Temperature at Inlet	°C		55.53	55.53	55.53	55.53
Refrigerant Temperature	°C		112.00	112.00	112.00	112.00
Mass Flow Rate	kg/s		0.03	0.03	0.03	0.03
<i>Outputs</i>						
Heat Load	W		7607	8241	8157	7914
Air Dry-Bulb Temperature	°C		52.41	54.19	53.25	54.04
Refrigerant Temperature	°C		50.00	46.24	47.63	51.40
LMTD	°C		20.58	10.45	15.92	22.14
UA	W/K		369.65	788.34	512.32	357.47
NTU	-		0.31	0.77	0.44	0.35
Refrigerant Pressure Drop	kPa		185.90	27.30	3.18	4.90
Airside DP	Pa		26.30	29.30	27.70	28.90
Air Heat Transfer Coefficient (Average)	W/m².K		109.57	126.69	128.70	130.84
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		5396.00	2439.00	2397.00	3281.00
Subcooling	°C		0.00	6.05	5.17	1.22
Charge	kg		0.33	0.70	0.16	0.11

**Table 26: Unit 6 – HX Analysis for R454B**

<i>Condenser</i>						
<i>Inputs</i>			<i>BTFD7</i>	<i>NTFD5</i>	<i>NMCD2</i>	<i>NMCD2R</i>
Air Dry-Bulb Temperature	°C		46.01	46.01	46.01	46.01
Relative Humidity	%		16.37	16.37	16.37	16.37
Air Flowrate	m³/s		1.08	0.94	1.08	0.94
Refrigerant Pressure	kPa		3204	3204	3204	3204
Saturation Temperature at Inlet	°C		55.53	55.53	55.53	55.53
Refrigerant Temperature	°C		112.00	112.00	112.00	112.00
Mass Flow Rate	kg/s		0.03	0.03	0.03	0.03
<i>Outputs</i>						
Heat Load	W		7993	8094	8060	7976
Air Dry-Bulb Temperature	°C		52.61	54.06	53.16	54.10
Refrigerant Temperature	°C		47.59	46.06	46.61	47.91
LMTD	°C		15.95	8.28	12.72	16.40
UA	W/K		501.09	977.17	633.67	486.37
NTU	-		0.43	0.96	0.54	0.48
Refrigerant Pressure Drop	kPa		74.70	22.02	2.70	4.10
Airside DP	Pa		26.30	29.30	27.70	28.90
Air Heat Transfer Coefficient (Average)	W/m².K		109.57	126.69	128.70	130.84
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		4445.93	2140.00	2008.00	2201.00
Subcooling	°C		5.75	8.03	7.75	6.43
Charge	kg		0.51	0.87	0.20	0.14

**Table 27: Unit 6 – Compressor Performance Summary.**

		<i>Baseline</i>	<i>Alternate 1</i>	<i>Alternate 2</i>	<i>Alternate 3</i>
<b>Refrigerant</b>		<b>R32</b>	<b>R32</b>	<b>R454B</b>	<b>R452B</b>
Isentropic Efficiency	-	0.60	0.64	0.66	0.70
Volumetric Efficiency	-	-	0.87	0.90	-
Displacement Volume	cm³	-	19.34	20.31	-
Frequency	Hz	60	60	60	60
Effective Displacement	cm³	16.0	16.8	18.3	19.0
Compressor Power	kW	2.4	2.3	2.3	2.1




Figure 12. Unit 6 – System Level Analysis: Performance Results for R32.




Figure 13. Unit 6 – System Level Analysis: Performance Results for R454B.




Figure 14. Unit 6 - Comparative System Performance Summary for R452B.

**Table 28: Unit 10 – Theoretical Cycle Re-Design Summary.**

System			Baseline	Alternate 1	Alternate 2	Alternate 3
	Refrigerant	-	Simulation R32	R452B	Target R447B	R454B
Condenser	-		BTFD9	-	-	-
Compressor	-		ZP42K5E	ZP31K5E	ZP34K5E	ZP31K5E
Cooling Capacity	BTU/hr		29005	34311	31611	34608
Compressor Power	kW		3.84	2.81	2.31	2.65
Fan Power	kW		0.70	0.70	0.70	0.70
Total Power	kW		4.54	3.51	3.01	3.35
COP	-		1.87	2.87	3.08	3.03
COP Gain	-		1.00	1.53	1.64	1.62

**Table 29: Unit 10 – HX Analysis for R32**

Condenser						
Inputs			BTFD7	NTFD5	NMCD2	NMCD2R
Air Dry-Bulb Temperature	°C		46	46	46	46
Relative Humidity	%		16.4	16.4	16.4	16.4
Air Flowrate	m³/s		1.23	0.94	1.23	1.04
Refrigerant Pressure	kPa		3562	3562	3562	3562
Saturation Temperature at Inlet	°C		56	56	56	56
Refrigerant Temperature	°C		100	100	100	100
Mass Flow Rate	kg/s		0.04	0.04	0.04	0.04
Outputs						
Heat Load	W		10693	11074	11435	10669
Air Dry-Bulb Temperature	°C		54.1	57.0	54.9	55.8
Refrigerant Temperature	°C		55.2	52.9	49.3	55.4
LMTD	°C		22.8	19.8	15.9	22.5
UA	W/K		468	560	717	475
NTU	-		0.35	0.55	0.54	0.42
Refrigerant Pressure Drop	kPa		26.7	67.1	6.8	10.1
Airside DP	Pa		29.6	26.7	25.7	26.0
Air Heat Transfer Coefficient (Average)	W/m².K		100.4	117.0	124.8	125.3
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		3823	4239	3050	3991
Subcooling	°C		0.00	1.75	6.17	0.00
Charge	kg		0.61	0.43	0.17	0.11

**Table 30: Unit 10 – HX Analysis for R452B**

Condenser						
Inputs			BTFD7	NTFD5	NMCD2	NMCD2R
Air Dry-Bulb Temperature	°C		46	46	46	46
Relative Humidity	%		16.4	16.4	16.4	16.4
Air Flowrate	m³/s		1.23	0.94	1.23	1.04
Refrigerant Pressure	kPa		3247	3247	3247	3247
Saturation Temperature at Inlet	°C		56	56	56	56
Refrigerant Temperature	°C		100	100	100	100
Mass Flow Rate	kg/s		0.04	0.04	0.04	0.04
Outputs						
Heat Load	W		9549	9812	9751	9500
Air Dry-Bulb Temperature	°C		53.2	55.8	53.6	54.8
Refrigerant Temperature	°C		49.5	46.4	47.1	50.1
LMTD	°C		16.7	9.2	12.2	17.1
UA	W/K		573	1067	802	557
NTU	-		0.43	1.04	0.60	0.49
Refrigerant Pressure Drop	kPa		17.2	47.1	5.6	8.2
Airside DP	Pa		29.6	26.7	25.7	26.0
Air Heat Transfer Coefficient (Average)	W/m².K		100.4	117.0	124.8	125.3
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		2974	3038	2537	2812
Subcooling	°C		4.82	7.51	7.34	4.38
Charge	kg		0.83	0.79	0.23	0.15

**Table 31: Unit 10 – HX Analysis for R447B**

<i>Condenser</i>						
<i>Inputs</i>			<i>BTFD7</i>	<i>NTFD5</i>	<i>NMCD2</i>	<i>NMCD2R</i>
Air Dry-Bulb Temperature	°C		46	46	46	46
Relative Humidity	%		16.4	16.4	16.4	16.4
Air Flowrate	m³/s		1.23	0.94	1.23	1.04
Refrigerant Pressure	kPa		3025	3025	3025	3025
Saturation Temperature at Inlet	°C		56	56	56	56
Refrigerant Temperature	°C		100	100	100	100
Mass Flow Rate	kg/s		0.04	0.04	0.04	0.04
<i>Outputs</i>						
Heat Load	W		9016	9632	9923	9085
Air Dry-Bulb Temperature	°C		52.9	55.6	53.8	54.4
Refrigerant Temperature	°C		52.4	51.7	49.9	52.7
LMTD	°C		20.4	18.9	17.1	20.3
UA	W/K		441	510	579	448
NTU	-		0.33	0.50	0.43	0.40
Refrigerant Pressure Drop	kPa		29.2	67.3	7.2	10.8
Airside DP	Pa		29.6	26.7	25.7	26.0
Air Heat Transfer Coefficient (Average)	W/m².K		100.4	117.0	124.8	125.3
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		3528	3833	2999	3458
Subcooling	°C		0.00	0.00	2.67	0.00
Charge	kg		0.56	0.45	0.17	0.10

**Table 32: Unit 10 – HX Analysis for R454B**

<i>Condenser</i>						
<i>Inputs</i>			<i>BTFD7</i>	<i>NTFD5</i>	<i>NMCD2</i>	<i>NMCD2R</i>
Air Dry-Bulb Temperature	°C		46	46	46	46
Relative Humidity	%		16.4	16.4	16.4	16.4
Air Flowrate	m³/s		1.23	0.94	1.23	1.04
Refrigerant Pressure	kPa		3204	3204	3204	3204
Saturation Temperature at Inlet	°C		56	56	56	56
Refrigerant Temperature	°C		100	100	100	100
Mass Flow Rate	kg/s		0.04	0.04	0.04	0.04
<i>Outputs</i>						
Heat Load	W		9634	9953	9901	9597
Air Dry-Bulb Temperature	°C		53.3	55.9	53.8	54.9
Refrigerant Temperature	°C		50.4	46.7	47.3	50.8
LMTD	°C		17.9	10.5	12.7	18.0
UA	W/K		537	952	782	532
NTU	-		0.40	0.93	0.59	0.47
Refrigerant Pressure Drop	kPa		18.8	51.1	5.9	8.7
Airside DP	Pa		29.6	26.7	25.7	26.0
Air Heat Transfer Coefficient (Average)	W/m².K		100.4	117.0	124.8	125.3
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		3095	3211	2633	2942
Subcooling	°C		3.71	6.98	6.98	3.40
Charge	kg		0.78	0.71	0.22	0.14

**Table 33. Unit 10 - Compressor Performance Summary.**

<i>Compressor</i>			Copeland ZP31K5E-PFV	Copeland ZP34K5E-PFV	Copeland ZP31K5E-PFV
<b>Refrigerant</b>		<b>R32</b>	<b>R452B</b>	<b>R447B</b>	<b>R454B</b>
Isentropic Efficiency	-	0.439	0.638	0.662	0.662
Volumetric Efficiency	-		0.760	0.803	0.790
Displacement Volume	cm³		29.350	29.350	29.350
Frequency	Hz	50	50	50	50
Effective Displacement Volume	cm³	19.646	22.301	23.581	23.183





Figure 15. Unit 10 – System Level Analysis: Performance Results for R452B.





Figure 16. Unit 10 – System Level Analysis: Performance Results for R447B.





Figure 17. Unit 10 – System Level Analysis: Performance Results for R454B.

## APPENDIX B – Unit 6 Initial Tests, Scope Change and Test Setup

Unit 6 was initially modified and tested at a separate facility and the test results exhibited a considerably lower cooling capacity than expected (~20%). Power consumption was also greater than designed. The condensing pressures were 20-30% above expectations, and the refrigerant pressure drop across the condenser was at least twice as high as expected. The outlet conditions of the condenser for R32 were possibly in two-phase. The condenser airflow rate was 10%-15% lower than expected. Superheat hardly met the setpoint values.

OTS formulated a hypothesis that the degraded performance was due to the condenser not being fully active; i.e. some regions were not transferring heat. One way for this to happen is by having severe maldistribution thus impeding heat transfer, increasing pressure drop – thus the condensing pressure – and possibly reducing the flow rate as well; all of which were observed in the test data. OTS tested the hypothesis by running hot water through the HX and observing with a thermal camera (Figure 18), which revealed the “dead zones”. Upon inspection by the manufacturer, it was confirmed there were blockages in some of the tubes. A new HX was built, but the same pattern was observed, forcing OTS to remove the condenser replacement from the scope given the project schedule.




Figure 18. Hot Water Thermal Imaging.


Given the challenges with the initial tests and unit modification, the scope was re-defined. The original test plan was changed to accommodate time and resources as appropriate. Table 34 outlines the major changes to the scope. The tests were conducted at the OTS laboratory (Figure 19 to Figure 22). A summary of the key differences between the test setups (original and at OTS) is presented in Table 35.



**Table 34: Test Scope Change.**

Unit	Refrigerant	Test	Original Scope		New Scope	
			Planned	Actual	Planned	Actual
Unit 1	R290	Charge Optimization	Yes	No	No	No
		Performance Tests	Yes	No	No	No
Unit 6	R32 (Baseline)	Charge Optimization	No	No	Yes	Yes
		Performance Tests	No	No	Yes	Yes
	R32 (Modified)	Charge Optimization	Yes	Yes	Yes	Yes
		Performance Tests	Yes	Yes	Yes	Yes
	R454B	Charge Optimization	Yes	Yes	Yes	Yes
		Performance Tests	Yes	Yes	Yes	Yes
Unit 10	R32 (Baseline)	Charge Optimization	No	No	Yes	Yes*
		Performance Tests	No	No	Yes	Yes*
	R447B	Charge Optimization	Yes	No	Yes	Yes
		Performance Tests	Yes	No	Yes	Yes
	R452B	Leak Tests	Yes	No	Yes	Yes
		Charge Optimization	Yes	No	Yes	Yes
	R452B	Performance Tests	Yes	No	Yes	Yes
		Leak Tests	Yes	No	No	No

\* Tests were conducted; however, no useful data was obtained (see section 5.2)



**Figure 19. Test Diagram.**



**Figure 20. OTS Setup: outdoor chamber (left), Unit 10 and frequency converter inside chamber (right).**




Figure 21. OTS Setup: indoor closed loop left side view (left), refrigerant mass flow meter (right).




Figure 22. OTS Setup: indoor closed loop right side view (left), vapor / liquid lines, sight glasses and TXV (right).

**Table 35: List of Measurements.**

Component	Refrigerant Side			Air Side		
	Measurement	Original Scope	New Scope	Measurement	Original Scope	New Scope
Condenser	Inlet Temperature	Yes	Yes	Air Flow Rate	Yes	No
	Inlet Pressure	Yes	Yes	Air Pressure Drop	No	No
	Outlet Temperature	Yes	Yes	Fan Power	No	Yes
	Outlet Pressure	Yes	Yes	Inlet Dry-bulb	Yes	Yes
	Subcooling	Yes*	Yes	Inlet Wet-Bulb / RH	Yes	Yes
				Outlet Dry-bulb	Yes	Yes
Evaporator				Outlet Wet-Bulb / RH	Yes	Yes
	Inlet Temperature	No	No	Air Flow Rate	Yes	Yes
	Inlet Pressure	No	No	Air Pressure Drop	No	Yes**
	Outlet Temperature	Yes	Yes	Blower Power	No	Yes
	Outlet Pressure	Yes	Yes	Inlet Dry-bulb	Yes	Yes
	Superheat	Yes*	Yes	Inlet Wet-Bulb / RH	Yes	Yes
	Refrigerant Mass Flow Rate	No	Yes	Outlet Dry-bulb	Yes	Yes
Compressor				Outlet Wet-Bulb / RH	Yes	Yes
	Suction Temperature	Yes	Yes			
	Suction Pressure	Yes	Yes			
	Discharge Temperature	Yes	Yes			
	Discharge Pressure	Yes	Yes			
	Compressor Power	No	Yes			
Expansion Device	Suction Temperature	Yes	Yes			
	Suction Pressure	Yes	Yes			
	Discharge Temperature	No	No			
	Discharge Pressure	No	No			

Charge Optimization

The charge optimization procedure as originally scoped was not implemented due to the following:

- The systems responded less sensitively to charge on subcooling and superheat, which were difficult to control with charging alone. A manual valve was added (Unit 10 exhibited little expansion) such that superheat could be better controlled. The valve also allowed for better control over the pressure levels compared to charge levels alone.
- For the modified systems, the charge was gradually increased, departing from the original charge from PRAHA I tests, until it was observed that the superheat and subcooling better matched design conditions for validation purposes.
- For the refrigerant blends, removing charge could result in fractionation (evaluated as a separate task), so it was decided to only incrementally increase charge, without removing it. For this procedure, a small gradual increment is necessary to avoid overcharging.

APPENDIX C - Unit 6 Raw and Processed Tested Data

**Table 36: Unit 6 – Performance Tests**

		Baseline (35°C)	Alternate 1 (35°C)	Alternate 2 (35°C)	Baseline (46°C)	Alternate 1 (46°C)	Alternate 2 (46°C)
Refrigerant	-	R32	R32	R454B	R32	R32	R454B
Charge	lb	3.83	4.27	5.02	3.83	4.27	5.02
Cooling Capacity	BTU/hr	25193	23585	21966	23390	21450	21821
Energy Balance	%	-2.28%	-4.66%	-3.06%	-1.78%	-4.42%	-7.61%
Compressor Power	kW	2.11	1.79	1.77	2.71	2.32	2.25
Fan Power	kW	0.32	0.33	0.33	0.40	0.42	0.42
Total Power	kW	2.43	2.12	2.10	3.10	2.74	2.67
EER	BTU/hr.W	10.36	11.12	10.44	7.54	7.84	8.17
<b>Evaporator</b>							
<b>Airside</b>							
<b>Inlet</b>							
Air Flow Rate	m³/s	0.31	0.31	0.31	0.31	0.31	0.30

		Baseline (35°C)	Alternate 1 (35°C)	Alternate 2 (35°C)	Baseline (46°C)	Alternate 1 (46°C)	Alternate 2 (46°C)
<b>Refrigerant</b>	-	<b>R32</b>	<b>R32</b>	<b>R454B</b>	<b>R32</b>	<b>R32</b>	<b>R454B</b>
Temperature	°C	27.0	27.0	27.0	29.0	29.0	29.0
Wet Bulb	°C	19.68	19.68	19.68	21.33	21.33	21.34
Relative Humidity	%	51.0	51.0	51.0	51.0	51.0	51.0
Humidity Ratio	kg/kg	0.011	0.011	0.011	0.013	0.013	0.013
Density	kg/m <sup>3</sup>	1.15	1.15	1.15	1.14	1.14	1.14
Enthalpy	kJ/kg	56.3	56.2	56.2	61.9	62.0	62.0
Specific Heat	kJ/kg.K	1.0	1.0	1.0	1.0	1.0	1.0
<b>Outlet</b>							
Air Flow Rate	m <sup>3</sup> /s	0.29	0.29	0.29	0.29	0.29	0.29
Temperature	°C	14.3	15.1	15.8	16.9	17.7	18.1
Wet Bulb	°C	14.35	14.35	14.35	14.35	14.35	14.35
Relative Humidity	%	83.6	82.4	80.0	84.5	83.3	81.3
Humidity Ratio	kg/kg	0.008	0.009	0.009	0.010	0.011	0.011
Density	kg/m <sup>3</sup>	1.21	1.20	1.20	1.19	1.19	1.19
Enthalpy	kJ/kg	35.8	37.5	38.5	42.7	44.7	45.0
Specific Heat	kJ/kg.K	1.0	1.0	1.0	1.0	1.0	1.0
<b>Refrigerant Side</b>							
<b>Inlet</b>							
Mass Flow Rate	kg/s	0.030	0.028	0.031	0.032	0.027	0.035
Temperature	°C	4.58	6.19	4.76	7.49	8.33	8.47
Pressure	kPa	939.13	986.90	876.76	1026.70	1053.10	979.34
Quality	-	0.16	0.19	0.20	0.20	0.25	0.27
Enthalpy	kJ/kg	273.64	269.78	268.60	301.30	291.37	289.89
Entropy	kJ/kg.K	1.20	1.25	1.30	1.27	1.32	1.37
<b>Outlet</b>							
Mass Flow Rate	kg/s	0.030	0.028	0.031	0.032	0.027	0.035
Temperature	°C	8.08	9.26	9.46	9.08	13.54	11.80
Pressure	kPa	939	987	877	1027	1053	979
Superheat	K	3.50	3.07	4.89	1.59	5.20	3.58
Enthalpy	kJ/kg	520.49	520.22	473.43	518.52	523.27	472.93
Entropy	kJ/kg.K	2.15	2.15	2.03	2.13	2.15	2.02
<b>HX Level</b>							
Average Cooling Capacity	kW	7.384	6.912	6.438	6.855	6.287	6.395
Energy Balance (Qair - Qref)/Qref	%	-2.28%	-4.66%	-3.06%	-1.78%	-4.42%	-7.61%
Sensible Heat Ratio	-	0.64	0.66	0.65	0.64	0.67	0.66
Superheat	K	3.500	3.066	4.885	1.593	5.205	3.582
LMTD	K	13.783	12.822	14.015	13.985	12.184	13.041
UA	kW/K	0.573	0.539	0.459	0.550	0.516	0.490
Air Pressure Drop	Pa	N/A	N/A	N/A	N/A	N/A	N/A
Refrigerant Pressure Drop	kPa	N/A	N/A	N/A	N/A	N/A	N/A
Fan Power	kW	0.120	0.127	0.134	0.196	0.217	0.217
<b>Condenser</b>							
<b>Airside</b>							
<b>Inlet</b>							
Air Flow Rate	m <sup>3</sup> /s	0.9516	0.9838	1.0091	0.9580	0.9735	1.0613
Temperature	°C	35.01	34.76	35.12	46.06	45.93	46.05
Wet Bulb	°C	20.0	19.8	20.0	27.4	27.3	27.4
Humidity Ratio	kg/kg	0.008	0.008	0.009	0.015	0.015	0.015
Density	kg/m <sup>3</sup>	1.13	1.13	1.13	1.08	1.08	1.08
Enthalpy	kJ/kg	57.0	56.4	57.2	86.2	85.8	86.2
Specific Heat	kJ/kg.K	1.01	1.01	1.01	1.02	1.02	1.02
<b>Outlet</b>							
Air Flow Rate	m <sup>3</sup> /s	0.98	1.01	1.03	0.98	1.00	1.09
Temperature	°C	43.40	42.29	42.08	54.74	53.60	53.19
Wet Bulb	°C	22.4	22.0	22.1	29.3	29.0	29.0
Humidity Ratio	kg/kg	0.008	0.008	0.009	0.015	0.015	0.015
Density	kg/m <sup>3</sup>	1.10	1.10	1.10	1.05	1.05	1.05
Enthalpy	kJ/kg	65.6	64.1	64.3	95.2	93.7	93.6
Specific Heat	kJ/kg.K	1.01	1.01	1.01	1.02	1.02	1.02

		Baseline (35°C)	Alternate 1 (35°C)	Alternate 2 (35°C)	Baseline (46°C)	Alternate 1 (46°C)	Alternate 2 (46°C)
<b>Refrigerant</b>	-	<b>R32</b>	<b>R32</b>	<b>R454B</b>	<b>R32</b>	<b>R32</b>	<b>R454B</b>
<b>Refrigerant Side</b>							
<b>Inlet</b>							
Mass Flow Rate	kg/s	0.030	0.028	0.031	0.032	0.027	0.035
Temperature	°C	89.78	82.73	78.33	109.00	107.24	90.75
Pressure	kPa	2724.15	2643.18	2360.90	3464.77	3365.88	3010.13
Superheat	K	45.9	40.1	35.9	54.7	54.2	38.0
Enthalpy	kJ/kg	580.73	573.07	523.39	594.42	593.52	528.90
Entropy	kJ/kg.K	2.20	2.18	2.08	2.21	2.21	2.07
<b>Outlet</b>							
Mass Flow Rate	kg/s	0.030	0.028	0.031	0.032	0.027	0.035
Temperature	°C	39.17	34.52	34.68	51.79	45.63	45.79
Pressure	kPa	2675.81	2598.75	2310.89	3416.39	3324.50	2958.91
Subcooling	K	4.00	7.44	5.59	1.89	6.84	5.07
Enthalpy	kJ/kg	273.6	264.0	266.4	301.3	287.0	287.8
Entropy	kJ/kg.K	1.24	1.21	1.28	1.33	1.28	1.34
<b>HX Level</b>							
Heat Rejection	kW	9.19	8.53	8.08	9.25	8.31	8.42
Subcooling	K	4.00	7.44	5.59	1.89	6.84	5.07
Refrigerant Pressure Drop	kPa	48.34	44.43	50.01	48.38	41.38	51.22
Fan Power	kW	0.20	0.20	0.20	0.20	0.20	0.20
<b>TXV</b>							
<b>Refrigerant</b>							
<b>Inlet</b>							
		4			4		
Temperature	°C	30.64	37.31	35.83	39.70	47.55	46.78
Pressure	kPa	1991.01	2587.20	2301.38	2528.52	3317.42	2945.62
Subcooling	°C	*(Two-Phase)	4.47	4.27	*(Two-Phase)	4.83	3.88
Enthalpy	kJ/kg	*(Two-Phase)	269.8	268.6	*(Two-Phase)	291.4	289.9
Entropy	kJ/kg.K	*(Two-Phase)	1.233	1.284	*(Two-Phase)	1.299	1.349
<b>Compressor</b>							
<b>Refrigerant</b>							
<b>Inlet</b>							
Mass Flow Rate	kg/s	0.030	0.028	0.031	0.032	0.027	0.035
Temperature	°C	11.57	12.55	12.76	13.81	17.63	13.07
Pressure	kPa	936.06	984.95	874.98	1024.91	1052.17	969.56
Superheat	K	7.09	6.43	8.26	6.38	9.32	5.18
Enthalpy	kJ/kg	524.9	524.4	477.3	524.6	528.3	474.8
Entropy	kJ/kg.K	2.170	2.161	2.048	2.156	2.166	2.028
<b>Outlet</b>							
Mass Flow Rate	kg/s	0.030	0.028	0.031	0.032	0.027	0.035
Temperature	°C	89.8	82.7	78.3	109.0	107.2	90.8
Pressure	kPa	2724.2	2643.2	2360.9	3464.8	3365.9	3010.1
Superheat	K	45.9	40.1	35.9	54.7	54.2	38.0
Enthalpy	kJ/kg	580.7	573.1	523.4	594.4	593.5	528.9
Entropy	kJ/kg.K	2.200	2.183	2.084	2.205	2.207	2.074
<b>Compressor Level</b>							
Power Consumption	kW	2.11	1.79	1.77	2.71	2.32	2.25
Isentropic Efficiency	-	0.80	0.84	0.73	0.74	0.76	0.69
Frequency	Hz	60	60	60	60	60	60

<sup>4</sup> The baseline configuration does not have an expansion valve, the state point herein presented refers to measurement readings at indoor unit inlet.

## APPENDIX D - Unit 10 Baseline Re-Test

Prior to modifying Unit 10, it was tested in its received, baseline condition with the components used to test during PRAHA I. Given the results of the data review in Activity 1, and the challenges experienced in the initial testing of Unit 6, the project team agreed that testing the units in their baseline configuration would be important for more accurate comparison.

The electrical components for Unit 10 have phase mismatch, i.e. the fan and blower are three-phase while the compressor is single-phase, but all operate in 50Hz. OTS does not have a Variable Frequency Drive (VFD) for single-phase motors, requiring the use of a frequency converter to reduce the compressor speed. According to the baseline data from PRAHA 1, the total power consumption of Unit 10 varied between 3.5-4.5kW; OTS has a 5.0kW converter, which should be sufficiently large to meet testing needs.

Initial tests suggested that the compressor peak start current exceeds the converter threshold, causing the latter to trip and shut off. Although the blower and the fan run normally with the converter, the compressor alone does not. The compressor motor was tested at 60Hz direct from the grid and it works, thus confirming that the issue is indeed the peak current. A soft starter was acquired with the objective to mitigate the issue. The soft starter capacitors weren't fast enough to smooth the peak current, however, thus requiring manual charging, which eventually lead to component failure.

The last tentative to run the baseline was connecting the compressor to 60Hz and the fans to 50Hz. The refrigerant mass flow rate was too high impeding full condensation and full evaporation. A manual TXV was added along with two sight glasses in the liquid and vapor lines and reasonable data was obtained for the 35°C ambient temperature condition. While attempting to test the system under the 46°C ambient temperature, the compressor overheats and shuts down. Heavier gauge wire, new contactors and switch bypass were unsuccessfully employed. In the interest of time, the baseline re-tests were discontinued. The analysis will be carried out using the original baseline performance for comparison purposes.

## APPENDIX E - Unit 10 Raw and Processed Tested Data

**Table 37: Unit 10 – Performance Tests.**

		Alternate 1 (35°C)	Alternate 2 (35°C)	Alternate 1 (46°C)	Alternate 2 (46°C)
Refrigerant	-	R447B	R452B	R447B	R452B
Charge	lb	6.625	6.625	6.625	6.625
Cooling Capacity	BTU/hr	32195	28128	31073	30292
Energy Balance	%	7.52%	-3.29%	4.21%	1.21%
Compressor Power	kW	2.67	2.40	3.16	2.93
Fan Power	kW	0.95	0.98	0.95	0.97
Total Power	kW	3.62	3.38	4.11	3.90
EER	BTU/hr.W	8.88	8.33	7.55	7.76
<b>Evaporator</b>					
<b>Airside</b>					
<b>Inlet</b>					
Air Flow Rate	m <sup>3</sup> /s	0.74	0.73	0.74	0.73
Temperature	°C	27.0	27.0	29.0	29.0
Wet Bulb	°C	19.68	19.69	21.33	21.34
Relative Humidity	%	51.0	51.0	51.0	51.0
Humidity Ratio	kg/kg	0.011	0.011	0.013	0.013
Density	kg/m <sup>3</sup>	1.15	1.15	1.14	1.14
Enthalpy	kJ/kg	56.2	56.3	62.0	62.0
Specific Heat	kJ/kg.K	1.0	1.0	1.0	1.0

		Alternate 1 (35°C)	Alternate 2 (35°C)	Alternate 1 (46°C)	Alternate 2 (46°C)
Refrigerant	-	R447B	R452B	R447B	R452B
<b>Outlet</b>					
Air Flow Rate	m³/s	0.72	0.71	0.71	0.70
Temperature	°C	17.4	19.1	19.7	19.8
Wet Bulb	°C	15.80	16.64	17.91	18.06
Relative Humidity	%	85.1	78.5	84.7	84.5
Humidity Ratio	kg/kg	0.011	0.011	0.012	0.012
Density	kg/m³	1.19	1.18	1.18	1.18
Enthalpy	kJ/kg	44.3	46.8	50.7	51.1
Specific Heat	kJ/kg.K	1.0	1.0	1.0	1.0
<b>Refrigerant Side</b>					
<b>Inlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047
Temperature	°C	9.81	5.53	12.90	13.09
Pressure	kPa	996.41	907.20	1085.49	1133.86
Quality	-	0.19	0.19	0.27	0.25
Enthalpy	kJ/kg	272.43	264.74	296.09	288.71
Entropy	kJ/kg.K	1.32	1.30	1.40	1.38
<b>Outlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047
Temperature	°C	15.22	25.20	16.76	23.36
Pressure	kPa	996	907	1085	1134
Superheat	K	5.79	19.82	4.42	10.47
Enthalpy	kJ/kg	477.29	485.20	476.43	477.36
Entropy	kJ/kg.K	2.04	2.09	2.03	2.03
<b>HX Level</b>					
Average Cooling Capacity	kW	9.436	8.244	9.107	8.878
Energy Balance (Qair - Qref)/Qref	%	7.52%	-3.29%	4.21%	1.21%
Sensible Heat Ratio	-	0.81	0.85	0.83	0.87
Superheat	K	5.794	19.818	4.422	10.474
LMTD	K	9.534	5.829	9.222	6.171
UA	kW/K	0.990	1.414	0.988	1.439
Air Pressure Drop	Pa	N/A	N/A	N/A	N/A
Refrigerant Pressure Drop	kPa	N/A	N/A	N/A	N/A
Fan Power	kW	0.502	0.523	0.501	0.519
<b>Condenser</b>					
<b>Airside</b>					
<b>Inlet</b>					
Air Flow Rate	m³/s	1.44	1.50	1.44	1.42
Temperature	°C	35.03	35.08	46.14	46.22
Wet Bulb	°C	20.0	20.0	27.4	27.5
Humidity Ratio	kg/kg	0.008	0.009	0.016	0.016
Density	kg/m³	1.13	1.13	1.08	1.07
Enthalpy	kJ/kg	57.0	57.2	86.5	86.7
Specific Heat	kJ/kg.K	1.01	1.01	1.02	1.02
<b>Outlet</b>					
Air Flow Rate	m³/s	1.47	1.53	1.48	1.45
Temperature	°C	41.90	40.83	53.36	53.26
Wet Bulb	°C	22.0	21.7	29.0	29.1
Humidity Ratio	kg/kg	0.008	0.009	0.016	0.016
Density	kg/m³	1.10	1.11	1.05	1.05
Enthalpy	kJ/kg	64.0	63.0	94.0	94.0
Specific Heat	kJ/kg.K	1.01	1.01	1.02	1.02
		0.00010	0.00038	0.00011	-0.00001
<b>Refrigerant Side</b>					
<b>Inlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047

		Alternate 1 (35°C)	Alternate 2 (35°C)	Alternate 1 (46°C)	Alternate 2 (46°C)
<b>Refrigerant</b>	-	<b>R447B</b>	<b>R452B</b>	<b>R447B</b>	<b>R452B</b>
Temperature	°C	78.84	92.46	93.29	97.45
Pressure	kPa	2493.84	2600.61	3199.13	3357.43
Superheat	K	31.5	46.5	35.3	40.4
Enthalpy	kJ/kg	522.20	532.28	529.64	527.68
Entropy	kJ/kg.K	2.09	2.11	2.08	2.07
<b>Outlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047
Temperature	°C	40.68	35.54	53.44	48.65
Pressure	kPa	2481.63	2599.27	3187.26	3351.92
Subcooling	K	3.37	9.26	1.62	7.33
Enthalpy	kJ/kg	274.8	266.6	300.2	291.9
Entropy	kJ/kg.K	1.32	1.29	1.39	1.37
<b>HX Level</b>					
Heat Rejection	kW	11.39	9.94	11.59	11.10
Energy Balance (Qair - Qref)	kW	N/A	N/A	N/A	N/A
Subcooling	K	3.37	9.26	1.62	7.33
Air Pressure Drop	Pa	-	-	-	-
Refrigerant Pressure Drop	kPa	12.21	1.34	11.87	5.51
Fan Power	kW	0.45	0.45	0.45	0.45
<b>TXV</b>					
<b>Refrigerant Inlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047
Temperature	°C	39.42	34.55	51.55	47.11
Pressure	kPa	2462.98	2583.59	3166.49	3331.97
Subcooling	°C	4.31	9.99	3.21	8.59
Enthalpy	kJ/kg	272.4	264.7	296.1	288.7
Entropy	kJ/kg.K	1.310	1.284	1.382	1.358
<b>Compressor</b>					
<b>Refrigerant Inlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047
Temperature	°C	16.84	26.01	17.17	24.96
Pressure	kPa	993.13	902.34	1082.17	1128.72
Superheat	K	7.52	20.81	4.94	12.23
Enthalpy	kJ/kg	479.3	486.2	477.0	479.4
Entropy	kJ/kg.K	2.052	2.090	2.035	2.042
<b>Outlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047
Temperature	°C	78.8	92.5	93.3	97.5
Pressure	kPa	2493.8	2600.6	3199.1	3357.4
Superheat	K	31.5	46.5	35.3	40.4
Enthalpy	kJ/kg	522.2	532.3	529.6	527.7
Entropy	kJ/kg.K	2.087	2.112	2.082	2.073
<b>Compressor Level</b>					
Power Consumption	kW	2.67	2.40	3.16	2.93
Isentropic Efficiency	-	0.72	0.83	0.68	0.77
Frequency	Hz	60	60	60	60

Table 38: Unit 10 – R447B Leak Tests

System			Liquid Line Leak		Vapor Line Leak	
		Full Charge	Low Charge	Re-Charged	Low Charge	Re-Charged
Refrigerant	-	R447B	R447B	R447B	R447B	R447B
Charge	lb	6.625	4.27	6.625	4.23	6.77



System		Liquid Line Leak			Vapor Line Leak	
		Full Charge	Low Charge	Re-Charged	Low Charge	Re-Charged
Refrigerant	-	R447B	R447B	R447B	R447B	R447B
Cooling Capacity	BTU/hr	31073	14216	30865	15171	30587
Energy Balance	%	4.21%	-34.72%	0.35%	-31.55%	1.87%
Compressor Power	kW	3.18	2.93	3.18	2.94	-
Fan Power	kW	0.95	0.98	0.98	0.98	0.98
Total Power	kW	4.13	3.90	4.16	3.92	-
EER	BTU/hr.W	7.52	3.64	7.42	3.87	-
<b>Evaporator</b>						
<b>Airside</b>						
<b>Inlet</b>						
Air Flow Rate	m <sup>3</sup> /s	0.74	0.73	0.74	0.73	0.74
Temperature	°C	29.0	29.0	29.0	29.0	29.0
Wet Bulb	°C	21.33	21.34	21.34	21.34	21.34
Relative Humidity	%	51.0	51.0	51.0	51.0	51.0
Humidity Ratio	kg/kg	0.013	0.013	0.013	0.013	0.013
Density	kg/m <sup>3</sup>	1.14	1.14	1.14	1.14	1.14
Enthalpy	kJ/kg	62.0	62.0	62.0	62.0	62.0
Specific Heat	kJ/kg.K	1.0	1.0	1.0	1.0	1.0
<b>Outlet</b>						
Air Flow Rate	m <sup>3</sup> /s	0.71	0.72	0.71	0.72	0.71
Temperature	°C	19.7	23.3	19.6	23.2	19.7
Wet Bulb	°C	17.91	19.87	18.08	19.77	18.05
Relative Humidity	%	84.7	73.1	86.3	73.6	86.0
Humidity Ratio	kg/kg	0.012	0.013	0.012	0.013	0.012
Density	kg/m <sup>3</sup>	1.18	1.16	1.18	1.16	1.18
Enthalpy	kJ/kg	50.7	57.0	51.2	56.7	51.1
Specific Heat	kJ/kg.K	1.0	1.0	1.0	1.0	1.0
<b>Refrigerant Side</b>						
<b>Inlet</b>						
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050
Temperature	°C	12.90	2.61	12.94	2.81	12.75
Pressure	kPa	1085.49	794.22	1086.62	799.23	1080.50
Quality	-	0.27	0.30	0.27	0.30	0.27
Enthalpy	kJ/kg	296.09	291.52	296.48	290.79	296.24
Entropy	kJ/kg.K	1.40	1.40	1.41	1.40	1.41
<b>Outlet</b>						
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050
Temperature	°C	16.76	28.23	17.07	27.95	17.01
Pressure	kPa	1085	794	1087	799	1080
Superheat	K	4.42	26.24	4.70	25.76	4.82
Enthalpy	kJ/kg	476.43	496.65	476.77	496.25	476.88
Entropy	kJ/kg.K	2.03	2.14	2.03	2.13	2.03
<b>HX Level</b>						
Average Cooling Capacity	kW	9.107	4.167	9.046	4.446	8.965
Energy Balance (Qair – Qref)/Qref	%	4.21%	-34.72%	0.35%	-31.55%	1.87%
Sensible Heat Ratio	-	0.83	1.18	0.90	1.12	0.89
Superheat	K	4.422	26.235	4.695	25.756	4.823
LMTD	K	9.222	6.051	9.065	6.501	9.217
UA	kW/K	0.988	0.689	0.998	0.684	0.973
Fan Power	kW	0.501	0.524	0.524	0.524	0.524
<b>Condenser</b>						
<b>Airside</b>						
<b>Inlet</b>						
Air Flow Rate	m <sup>3</sup> /s	1.44	1.49	1.42	1.48	1.42
Temperature	°C	46.14	46.08	46.21	45.77	46.02
Wet Bulb	°C	27.4	27.4	27.5	27.2	27.4
Humidity Ratio	kg/kg	0.016	0.015	0.016	0.015	0.015
Density	kg/m <sup>3</sup>	1.08	1.08	1.07	1.08	1.08
Enthalpy	kJ/kg	86.5	86.3	86.7	85.3	86.1
Specific Heat	kJ/kg.K	1.02	1.02	1.02	1.02	1.02


System			Liquid Line Leak			Vapor Line Leak	
Refrigerant	-	Full Charge R447B	Low Charge R447B	Re-Charged R447B	Low Charge R447B	Re-Charged R447B	
<b>Outlet</b>							
Air Flow Rate	m <sup>3</sup> /s	1.48	1.52	1.46	1.50	1.46	
Temperature	°C	53.36	51.27	53.52	51.05	53.28	
Wet Bulb	°C	29.0	28.6	29.1	28.4	29.0	
Humidity Ratio	kg/kg	0.016	0.015	0.016	0.015	0.015	
Density	kg/m <sup>3</sup>	1.05	1.06	1.05	1.06	1.05	
Enthalpy	kJ/kg	94.0	91.7	94.3	90.8	93.6	
Specific Heat	kJ/kg.K	1.02	1.02	1.02	1.02	1.02	
<b>Refrigerant Side</b>							
<b>Inlet</b>							
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050	
Temperature	°C	93.29	121.77	94.07	120.31	94.34	
Pressure	kPa	3199.13	2846.79	3200.02	2847.47	3175.47	
Superheat	K	35.3	68.9	36.1	67.4	36.7	
Enthalpy	kJ/kg	529.64	569.70	530.67	567.95	531.39	
Entropy	kJ/kg.K	2.08	2.20	2.08	2.20	2.09	
<b>Outlet</b>							
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050	
Temperature	°C	53.44	50.27	53.37	50.13	53.28	
Pressure	kPa	3187.26	2843.00	3188.61	2843.11	3164.31	
Subcooling	K	1.62	-0.33	1.71	-0.19	1.45	
Enthalpy	kJ/kg	300.2	293.2	300.0	293.2	299.9	
Entropy	kJ/kg.K	1.39	1.37	1.39	1.37	1.39	
<b>HX Level</b>							
Heat Rejection	kW	11.59	8.60	11.57	8.69	11.49	
Energy Balance (Qair – Qref)	kW	N/A	N/A	N/A	N/A	N/A	
Subcooling	K	1.62	-0.33	1.71	-0.19	1.45	
Refrigerant Pressure Drop	kPa	11.87	3.79	11.40	4.36	11.16	
Fan Power	kW	0.45	0.45	0.45	0.45	0.45	
<b>TXV</b>							
<b>Refrigerant</b>							
<b>Inlet</b>							
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050	
Temperature	°C	51.55	49.15	51.74	48.80	51.60	
Pressure	kPa	3166.49	2827.45	3168.66	2827.31	3144.31	
Subcooling	°C	3.21	0.54	3.06	0.89	2.84	
Enthalpy	kJ/kg	296.1	291.5	296.5	290.8	296.2	
Entropy	kJ/kg.K	1.382	1.369	1.383	1.366	1.382	
<b>Compressor</b>							
<b>Refrigerant</b>							
<b>Inlet</b>							
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050	
Temperature	°C	17.17	29.26	18.00	28.98	18.47	
Pressure	kPa	1082.17	793.15	1082.65	797.99	1076.58	
Superheat	K	4.94	27.30	5.75	26.83	6.41	
Enthalpy	kJ/kg	477.0	497.7	478.0	497.3	478.8	
Entropy	kJ/kg.K	2.035	2.140	2.038	2.138	2.041	
<b>Outlet</b>							
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050	
Temperature	°C	93.3	121.8	94.1	120.3	94.3	
Pressure	kPa	3199.1	2846.8	3200.0	2847.5	3175.5	
Superheat	K	35.3	68.9	36.1	67.4	36.7	
Enthalpy	kJ/kg	529.6	569.7	530.7	568.0	531.4	
Entropy	kJ/kg.K	2.082	2.200	2.085	2.195	2.087	
<b>Compressor Level</b>							
Power Consumption	kW	3.18	2.93	3.18	2.94	0.00	
Isentropic Efficiency	-	0.68	0.68	0.68	0.69	0.68	
Frequency	Hz	60	60	60	60	60	

System		Liquid Line Leak			Vapor Line Leak	
Refrigerant	-	Full Charge	Low Charge	Re-Charged	Low Charge	Re-Charged
		R447B	R447B	R447B	R447B	R447B

## APPENDIX F - Model Verification and Validation

**Table 39: Unit 6 – Model Verification and Validation for Alternative 1 – R32 @ 46°C.**

		Test	Model (Test Conditions)	Relative Difference
Refrigerant Mass Flow Rate	g/s	27	31	14%
Cooling Capacity	BTU/hr	21450	23653	10%
Total Power	kW	2.74	2.67	-2%
EER	BTU/hr.W	7.84	8.86	13%



**Figure 23. Unit 6 – R32 Performance Test Summary P-h and T-s Diagrams.**

**Table 40: Unit 6 – Model Verification and Validation for Alternative 2 – R454B @ 46°C.**

		Test	Model (Test Conditions)	Relative Difference
Refrigerant Mass Flow Rate	g/s	35	36	3%
Cooling Capacity	BTU/hr	21821	22969	5%
Total Power	kW	2.67	2.49	-7%
EER	BTU/hr.W	8.17	9.24	13%




Figure 24. Unit 6 – R454B Performance Test Summary P-h and T-s Diagrams.

Table 41: Unit 10 – Model Verification and Validation for Alternative 1 – R447B @ 46°C.

		Test	Model (Test Conditions)	Relative Difference
Refrigerant Mass Flow Rate	g/s	51	49	-3%
Cooling Capacity	BTU/hr	31169	31026	-0.5%
Total Power	kW	2.70	3.00	11%
EER	BTU/hr.W	11.54	10.34	-10%




Figure 25. Unit 10 – R447B P-h and T-s Diagrams.

Table 42: Unit 10 – Model Verification and Validation for Alternative 2 – R452B @ 46°C.

		Test	Model (Test Conditions)	Relative Difference
Refrigerant Mass Flow Rate	g/s	47	48	2%
Cooling Capacity	BTU/hr	30292	30704	1.4%
Total Power	kW	3.90	3.34	-14%
EER	BTU/hr.W	7.76	9.19	18%





Figure 26. Unit 10 – R452B P-h and T-s Diagrams.



**Air-Conditioning, Heating and  
Refrigeration Technology Institute**

## **Final Report**

AHRTI Report No. 9011

### **Promoting Alternative Refrigerants in High-Ambient Countries Phase II (PRAHA-II): Optimization Study on PRAHA I Equipment**

Final Report

September 2019

By

Daniel Bacellar, Song Li, Paul Kalinowski, Cara Martin



Optimized Thermal Systems, Inc. (OTS)  
7040 Virginia Manor Road, Beltsville, MD 20705

Prepared for

AIR-CONDITIONING, HEATING AND REFRIGERATION TECHNOLOGY INSTITUTE, INC

2311 Wilson Boulevard, Suite 400, Arlington, Virginia 22201

©2019 AHRTI

## **DISCLAIMER**

This report was prepared as an account of work sponsored by the Air-Conditioning, Heating and Refrigeration Technology Institute, Inc. (AHRTI). Neither AHRTI, its research program financial supporters, or any agency thereof, nor any of their employees, contractors, subcontractors or employees thereof - makes any warranty, expressed or implied; assumes any legal liability or responsibility for the accuracy, completeness, any third party's use of, or the results of such use of any information, apparatus, product, or process disclosed in this report; or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute nor imply its endorsement, recommendation, or favoring by AHRTI, its sponsors, or any agency thereof or their contractors or subcontractors. The views and opinions of authors expressed herein do not necessarily state or reflect those of AHRTI, its program sponsors, or any agency thereof.

## TABLE OF CONTENTS

1. Executive Summary.....	5
2. Introduction .....	9
3. Activity 1 - Analyzing the Design of PRAHA-I Prototypes.....	9
3.1. Physical Units .....	9
3.2. PRAHA-I Performance Reports Assessment.....	10
3.3. Hardware Improvement Assessment .....	11
3.3.1. Heat Exchanger (HX) First Order Analysis (FOA).....	11
3.3.2. Compressors .....	12
3.3.3. Expansion Devices.....	12
3.3.4. Fan and Blower .....	12
3.3.5. Units Component Modification Potential.....	12
3.4. Conclusions and Recommendations.....	12
4. Activity 2 - Design Improvements.....	13
4.1. Hardware .....	13
4.2. Refrigerant .....	13
4.3. System Design Modification Framework.....	14
4.3.1. Compressors .....	16
4.3.2. HX Design and Selection .....	17
4.3.3. System Design .....	19
4.4. Modified Systems Results Summary.....	19
4.5. Conclusions and Recommendations.....	19
5. Activities 3, 4 & 5 - Prototype Units Fabrication, Evaluation of the Optimized Prototypes and Analyzing Leaks of Alternatives.....	21
5.1. Unit 6.....	21
5.2. Unit 10.....	22
5.3. Leak Tests.....	23
5.4. Conclusions and Recommendations.....	24
6. Conclusions .....	25
APPENDIX A - Activity 2 Design Framework Results .....	27
APPENDIX B – Unit 6 Initial Tests, Scope Change and Test Setup.....	36
APPENDIX C - Unit 6 Raw and Processed Tested Data.....	39
APPENDIX D - Unit 10 Baseline Re-Test .....	42
APPENDIX E - Unit 10 Raw and Processed Tested Data.....	42
APPENDIX F - Model Verification and Validation.....	47



## LIST OF FIGURES

Figure 1. Heat Exchangers FOA.....	11
Figure 2. Refrigerants Investigated for Units 1 and 4.....	14
Figure 3. Refrigerants Investigated for Units 6 and 10.....	14
Figure 4. Refrigerant Temperature Glides.....	14
Figure 5. Illustrative T-s diagram for baseline and improved cycles.....	15
Figure 6. P-h Diagrams Illustrating COP Improvement: a) Real Cycle; b) Ideal Cycle (Carnot).....	16
Figure 7. System Re-Design Framework, .....	16
Figure 8. Condenser Forms: Unit 1 (left), Unit 10 (center), Unit 6 Cabinet (right).....	18
Figure 9. HX Form Examples: L-shape (left), Flat (right).....	18
Figure 10. Unit 1 – Modified Systems P-h Diagrams.....	28
Figure 11. Unit 4 – Modified Systems P-h Diagrams.....	29
Figure 12. Unit 6 – System Level Analysis: Performance Results for R32.....	32
Figure 13. Unit 6 – System Level Analysis: Performance Results for R454B.....	32
Figure 14. Unit 6 - Comparative System Performance Summary for R452B.....	32
Figure 15. Unit 10 – System Level Analysis: Performance Results for R452B.....	35
Figure 16. Unit 10 – System Level Analysis: Performance Results for R447B.....	35
Figure 17. Unit 10 – System Level Analysis: Performance Results for R454B.....	35
Figure 18. Hot Water Thermal Imaging.....	36
Figure 19. Test Diagram.....	37
Figure 20. OTS Setup: outdoor chamber (left), Unit 10 and frequency converter inside chamber (right).....	37
Figure 21. OTS Setup: indoor closed loop left side view (left), refrigerant mass flow meter (right).....	38
Figure 22. OTS Setup: indoor closed loop right side view (left), vapor / liquid lines, sight glasses and TXV (right).....	38
Figure 23. Unit 6 – R32 Performance Test Summary P-h and T-s Diagrams.....	47
Figure 24. Unit 6 – R454B Performance Test Summary P-h and T-s Diagrams.....	48
Figure 25. Unit 10 – R447B P-h and T-s Diagrams.....	48
Figure 26. Unit 10 – R452B P-h and T-s Diagrams.....	49

## LIST OF TABLES

Table 1: Activity 2 Summary Modeling Results.....	6
Table 2: Tests Summary Results.....	7
Table 3: Unit Specifications Summary.....	10
Table 4: Units 1, 4, 6 and 10 Components.....	12
Table 5: Compressor Models.....	17
Table 6: Activity 2 Results.....	20
Table 7: Unit 6 Modifications for Testing.....	21
Table 8: Unit 6 - Performance Test Summary for R32 Baseline (OTS) @ 35°C.....	22
Table 9: Unit 6 - Performance Test Summary for R32 Baseline (OTS) @ 46°C.....	22
Table 10: Unit 10 Modifications for Testing.....	23
Table 8: Unit 10 - Performance Test Summary for R32 Baseline @ 35°C.....	23
Table 9: Unit 10 - Performance Test Summary for R32 Baseline @ 46°C.....	23
Table 12: Unit 10 – R447B Leak Test Summary Results.....	24
Table 13: Unit 1 – Theoretical Cycle Re-Design Summary.....	27
Table 14: Unit 1 – HX Analysis Summary.....	27
Table 15: Unit 1 – Compressor Performance Summary.....	27

Table 16: Unit 1 – Expected Modified System Performances.....	27
Table 17: Unit 4 – Theoretical Cycle Re-Design Summary.....	28
Table 18: Unit 4 – HX Analysis Summary.....	28
Table 19: Unit 4 – Compressor Performance Summary.....	29
Table 20: Unit 4 – Expected Modified System Performances.....	29
Table 21: Unit 6 – Theoretical Cycle Re-Design Summary.....	30
Table 22: Unit 6 – HX Analysis for R32.....	30
Table 23: Unit 6 – HX Analysis for R452B.....	30
Table 24: Unit 6 – HX Analysis for R447B.....	31
Table 25: Unit 6 – HX Analysis for R454B.....	31
Table 26: Unit 6 – Compressor Performance Summary.....	31
Table 27: Unit 10 – Theoretical Cycle Re-Design Summary.....	33
Table 28: Unit 10 – HX Analysis for R32.....	33
Table 29: Unit 10 – HX Analysis for R452B.....	33
Table 30: Unit 10 – HX Analysis for R447B.....	34
Table 31: Unit 10 – HX Analysis for R454B.....	34
Table 32. Unit 10 - Compressor Performance Summary.....	34
Table 33: Test Scope Change.....	37
Table 34: List of Measurements.....	39
Table 35: Unit 6 – Performance Tests.....	39
Table 36: Unit 10 – Performance Tests.....	42
Table 37: Unit 10 – R447B Leak Tests.....	44
Table 38: Unit 6 – Model Verification and Validation for Alternative 1 – R32 @ 46°C.....	47
Table 39: Unit 6 – Model Verification and Validation for Alternative 2 – R454B @ 46°C.....	47
Table 40: Unit 10 – Model Verification and Validation for Alternative 1 – R447B @ 46°C.....	48
Table 41: Unit 10 – Model Verification and Validation for Alternative 2 – R452B @ 46°C.....	48

## 1. Executive Summary

Over the past several years through the Promoting low- Global Warming Potential (GWP) Refrigerants for Air-Conditioning Sectors in High-Ambient Temperature Countries (PRAHA-I) project, 18 different prototypes have been developed and compared to respective baselines to support the assessment of alternative lower-GWP refrigerants for air-conditioning applications. Since the work originally started in 2012, researchers have identified gaps in the performance and operation of the PRAHA-1 prototypes. These gaps include the need to redesign and optimize prototype air-conditioning units, evaluate new alternative refrigerants, and improve component selection. As such, a new project, *Advancing the Designs of PRAHA-I for Meeting or Exceeding the Baseline Designs Performance*, conducted by Optimized Thermal Systems, Inc. (OTS) is herein presented.

The objectives of this project include the following:

- 1) Evaluate the design limitation of the PRAHA-I prototypes;
- 2) Optimize and physically evaluate selected prototypes with new refrigerants not evaluated during PRAHA-I; and,
- 3) Assess potential refrigerant fractionation impact due to leakage.

The project was organized into six activities for which a summary of the results, conclusions and recommendations are presented below:

- 1) [Activity 1: Analyzing the Design of PRAHA-I Prototypes](#)
  - a. Certification laboratories, such as the one used for testing the units in PRAHA I, provide limited information for the purposes of product design and development. For future reference it is recommended that for research-oriented efforts such as this one, the units undergo a more rigorous testing process along with full characterization of the system and its individual components operating conditions and performance.
  - b. In applications of high ambient temperatures, it is expected that performance will degrade as compared to operating under more temperate conditions and the resultant impact on performance must be considered. The key components for performance improvement identified herein were the compressor, condenser and expansion device.
    - i. At higher temperatures, the saturation temperatures and refrigerant density at compressor's suction port can be very different than that from the rated conditions. Larger displacement volumes and efficiency curves optimized for higher pressure lifts might be required. Therefore, the proper selection of the compressor is paramount.
    - ii. A better performance condenser will reduce the approach temperature between refrigerant and air, helping the compressor not to discharge refrigerant at very high pressure and temperatures, which degrade performance.
  - c. At high ambient conditions, the system is forced to operate in higher pressure lift than at rated conditions, but still requires a certain refrigerant mass flow rate. Passive devices such as capillary tubes and orifices may not be able to provide enough expansion to allow the system to operate in higher temperature conditions. An active expansion device such as EXV's can adequately control operating conditions and maintain stable superheat.
- 2) [Activity 2: Design Improvements](#) (Summary results in Table 1)
  - a. R290 and R32 have wider saturation regions allowing the system to operate with smaller superheat and subcooling, while benefiting from two-phase heat transfer. Their cycles

may get closer to that of the ideal Carnot cycle compared to refrigerants with narrower saturation.

- b. Refrigerants with high temperature glide may require new heat exchanger (HX) designs, namely condensers. The original designs proved to be sufficiently effective to allow for most systems to operate with the different refrigerants, however, better designs would allow for higher system efficiency and potentially less charge. HX designs are severely constrained by allowed envelope dimensions. A complete system re-design would provide an opportunity for designing HX's with even higher efficiency.
- c. The results of this analysis suggest that for an effective refrigerant replacement, a proper compressor selection must be accompanied with it. Higher isentropic efficiencies are desired for higher temperatures, but most importantly, the displacement volume requirements can vary considerably from one refrigerant to another.
- d. It is also imperative that having an active expansion device (preferably an Electronic Expansion valve (EXV)) to not only allow for more controlled superheat, but also to enable the unit to run with different refrigerants with very different thermophysical properties.

**Table 1: Activity 2 Summary Modeling Results.**

General Information			Hardware			Performance		
System	Rated Capacity (@35°C)	System Configuration	Compressor	Condenser	Expansion Device	Ref.	Cooling Capacity (@46°C)	EER (@46°C)
-	BTU/hr	-	Efficiency (-)	Type	Type	-	BTU/hr	BTU/hr.W
Unit 1	18000	Baseline	0.66	Tube-Fin (5mm Tube)	Passive	R444B	17403	7.4
		Alternate 1	0.7	Same as Baseline	Active (EXV)	R290	17639	8.01
		Alternate 2	0.69			R454C	18104	7.31
		Alternate 3	0.7	MCHX		R444B	18140	8.14
		Alternate 4	0.68			R457A	17749	7.63
Unit 4	24000	Baseline	0.61	Tube-Fin (9.5mm Tube)	Passive	R290	17940	7.52
		Alternate 1	0.7	Tube-Fin (5mm Tube)	Active (EXV)	R290	18147	9.12
		Alternate 2	0.7			R290	24120	6.72
Unit 6	24000	Baseline	0.6	Tube-Fin (7mm Tube)	Passive	R32	23115	8.46
		Alternate 1	0.65	Tube-Fin (5mm Tube)	Active (EXV)	R32	23798	9.41
		Alternate 2	0.67			R454B	22894	9.71
		Alternate 3	0.7			R452B	23702	9.6
Unit 10	36000	Baseline	0.44	Tube-Fin (9.5mm Tube)	Passive	R32	29005	6.39
		Alternate 1	0.65	Tube-Fin (5mm Tube)	Active (EXV)	R447B	30478	9.43
		Alternate 2	0.67			R452B	30796	10.27
		Alternate 3	0.67			R454B	30809	10

3) [Activities 3-5: Prototype Modification and Testing](#) (Summary results in Table 2)

- a. Unit 6 re-tested baseline exhibited similar performance to that found in PRAHA I testing. It should be stressed that the baseline unit by design had its capillary tube located in the outdoor unit. This would cause liquid refrigerant leaving the outdoor unit to flash. The refrigerant enthalpy at the condenser outlet state was used to calculate the refrigerant-side capacity assuming an isenthalpic expansion without heat loss in connecting pipe. This is different from the modified systems of which the capillary tube was removed, and a manual expansion valve was placed at the inlet of the indoor unit. For modified systems,

the enthalpy at the expansion valve inlet was used to calculate the refrigerant-side capacity.

- b. Unit 10 exhibited a considerable reduction in power consumption at the high ambient test condition (46°C) as compared to the original test data. This supports the hypothesis of low compressor efficiency during PRAHA I tests, which also indicates the importance of proper compressor selection.
- c. The above is also evidenced by the fact that even with R447B and R452B (zeotropic mixtures), Unit 10 had higher cooling capacity and efficiency than the baseline for the 46°C test condition, as projected in activity 2. The tests at 35°C, however, did not have the same trend.
- d. The impact of refrigerant replacement was not very clear, in part due to the hardware change along with it. But because of the differences in saturation curves from the Activity 2 analysis, R32 tends to result in systems with higher efficiency and less charge. The zeotropic mixtures consistently required compressors with larger displacement volumes and even higher mass flow rates for cooling capacities of the same magnitude.
- e. Refrigerant fractionation as evidenced by the leak tests, does not appear to a great concern since less than 2% in cooling capacity was observed after the system's re-charge.
- f. The Unit 6 modified systems had lower performance than expected from the Activity 2 models. The R32 system configuration exhibited around 10% less flow rate than anticipated, which corresponded to 10% lower capacity. The R454B configuration exhibited a deviation of 5% between model and test due also in part to a 3% flow rate over prediction in the model. Unit 10, on the other hand, exhibited an excellent agreement to the models with less than 2% deviation in cooling capacity.
- g. The model's validation adds confidence in the numerical simulation findings and recommendations provided in activity 2.

**Table 2: Tests Summary Results.**

Syst.	Test	Refrigerant	Charge	35°C			46°C		
				Cooling Capacity	Total Power	EER	Cooling Capacity	Total Power	EER
			lb	BTU/hr	kW	BTU/hr. W	BTU/hr	kW	BTU/hr. W
Unit 6	Performance	R32 (Baseline)	3.83	25192	2.43	10.4	23390	3.10	7.54
		R32 (Alternate 1)	4.27	23585	2.12	11.1	21450	2.74	7.84
		R454B (Alternate 2)	5.02	21966	2.10	10.4	21821	2.67	8.17
Unit 10	Performance	R32 (Baseline)*	5.63	34517	3.76	9.18	29005	3.84	7.55
		R447B (Alternate 1)	6.63	32195	3.62	8.88	31073	3.90	7.96
		R452B (Alternate 2)	6.63	28128	3.38	8.33	30292	3.90	7.76
	Liquid Line	Low Charge	4.23	N/A			14216	3.90	3.64
		Re-Charged	6.63				30865	4.16	7.42
	Vapor Line	Low Charge	4.27	N/A			15171	3.92	3.87
		Re-Charged	6.77				30587	-	-

\*Original baseline values from PRAHA

- 4) Conclusions: This report presented a comprehensive set of activities with the objectives of advancing the PRAHA program. The original scope and schedule were modified during the project as new findings and challenges surfaced. The tests that were carried out for PRAHA-I, while sufficient for the purpose of measuring capacity and energy efficiency for the purposes of PRAHA-I, did not have enough essential data to enable a complete cycle evaluation for optimization purposes. This is primarily due to using standard test rig on systems with critical hardware configuration differences. The analyses presented in Activity 2 (design assessment through modeling) provided good insights on adequate component design and/or selection for proper system functioning when using novel refrigerants. The tests in activities 3-5 partially served as validation for the models developed, and as check for previous test data from PRAHA I. The final recommendations for future development are listed as follows:
- a. Establish a baseline system by conducting comprehensive testing including measurements and metrics not typically performed in energy certification tests. Furthermore, testing systems with different configurations require custom test rigs as such to adequately measure working fluid's states to avoid mischaracterization of the operating conditions and performance. Such approach is considerably more labor-intensive which should be factored in the scope in future developments.
  - b. Using alternate low-GWP refrigerants is viable and can be competitive to commonly used pure refrigerants but doing so requires proper component design and selection; compressor and expansion device particularly. Drop-in replacement without hardware change is never recommended as evidenced by the change requirements in Activity 2 and performance tests in the subsequent activities.
  - c. It is recommended to always perform numerical simulations, and to conduct at least some level of "soft" optimization analyses that will provide information for an educated system re-design / retrofit at much lower costs than gradual trial-and-error changes.
  - d. Always test the modified systems with the same instrumentation as the baseline, however mindful of the modifications as such to properly place sensors to obtain adequate readings as suggested in item a above.

## 2. Introduction

Over the past several years through the Promoting low- Global Warming Potential (GWP) Refrigerants for Air-Conditioning Sectors in High-Ambient Temperature Countries (PRAHA-I) project, 18 different prototypes have been developed and compared to respective baselines to support the assessment of alternative lower-GWP refrigerants for air-conditioning applications. Since the work originally started in 2012, researchers have identified gaps in the performance and operation of the PRAHA-1 prototypes. These gaps include the need to redesign and optimize prototype air-conditioning units, evaluate new alternative refrigerants, and improve component selection. As such, a new project, *Advancing the Designs of PRAHA-I for Meeting or Exceeding the Baseline Designs Performance*, is desired.

The objectives of this project include the following:

- 4) Evaluate the design limitation of the PRAHA-I prototypes;
- 5) Optimize and physically evaluate selected prototypes with new refrigerants not evaluated during PRAHA-I; and,
- 6) Characterize leaks.

The project is divided into six activities namely:

- **Activity 1 – Analyzing the Design of PRAHA-I Prototypes:** evaluate systems performance from selected units tested in PRAHA-I, and assess potential design improvements
- **Activity 2 – Design Improvement:** improve design of specific units targeting higher efficiencies while using alternate low-GWP refrigerants
- **Activity 3 - Prototype Units Fabrication:** modify the a sub-set of the units according to modifications proposed in Activity 2
- **Activity 4 - Evaluation of the Optimized Prototypes:** conduct performance tests on modified units at standard and high ambient temperature conditions (35°C and 46°C)
- **Activity 5 - Analyzing Leaks of Alternatives:** simulate refrigerant leakage and evaluate possible impact of zeotropic mixtures fractionation on performance
- **Activity 6 - Reporting and Data Management:** simulation and test data processing, preparing progress and final reports

## 3. Activity 1 - Analyzing the Design of PRAHA-I Prototypes

Activity 1 was comprised of three major tasks including: reception of 12 physical units at the OTS facility followed by visual inspection and parts identification; review of performance test reports from PRAHA I tests; and lastly, analyze data and identify, for units of interest, opportunity for improvement targeting higher performance and minimal charge. OTS has completed this activity and an executive summary of the findings are presented herein.

### 3.1. Physical Units

All 12 units of interest to this project (Table 3) were received on November 8<sup>th</sup>, 2018. Visual inspection indicated no evident signs of damage. Relevant information to the project such as compressor model, heat exchanger (HX) geometry and circuiting, as well as expansion device were also received.

**Table 3: Unit Specifications Summary.**

Category	Unit #	Ref.	Designed Capacity Btu/h	Measured Cap. Btu/h	Voltage	Ref. (New designs)	Ref. (Tests)
Window	1	L-20 (R-444B)	18,000	19,104	208-230/60/1	L-20, R454C, R290, R457A	R290
	2	L-20 (R-444B)	18,000	16,924	208-230/60/1		
	3	DR-3 (R-454C)	18,000	18,063	208-230/60/1		
Decorative splits	4	R-290	24000 (18,000)	19,000	208-230/60/1	R-290	R-290
	5	R-32	24000 (18,000)	19,328	208-230/60/1		
	6	R-32	24,000	25,456	208-230/60/1	R32, R459A	R32, R459A
	7	L-41 (R-447A)	24,000	24,830	208-230/60/1		
	8	L-20 (R-444B)	24,000	22,740	208-230/60/1		
	9	DR-3	24,000	14,638	208-230/60/1		
Ducted splits	10	R-32	36,000	35,500	220-240/50/1	R447B, R452B	R447B, R452B
	11	L-20	36,000	36,553	220-240/50/1		
	12	DR-3 (R-454C)	36,000	33,032	220-240/50/1		

### 3.2. PRAHA-I Performance Reports Assessment

OTS received a complete package of files containing the performance reports for all units tested in PRAHA I. The tests conducted in PRAHA I were meant to assess high-level performance of these units focusing on a large control volume where only total energy in and out was evaluated. As such, these tests were not comprehensive in terms of measurements for cycle analysis required in PRAHA II. Refrigerant side measurements, in most cases, were very limited (few pressure and temperature measurements and no flow rates); thus, it is not possible to fully characterize the cycle and perform energy balances between air and refrigerant sides of the system. Common issues found in the reports include:

- Tag mislabeling and / or mismatching sensor location and tag
- No independent outdoor capacity reported – typically reported the same as indoor capacity
- Missing energy balance checks
- Missing measurement on either airside pressure drop and temperature or fan power
- Inconsistent reported measurements with thermophysical properties for units tested with L-20
- Systematic inconsistency in reported superheat and subcooling
- Missing measurements on refrigerant side at evaporator inlet
- Missing temperature and/or pressure measurements on refrigerant side
- Missing refrigerant mass flow measurements

A summary of the original PRAHA-1 data and results of the data reduction are provided under separate documentation.



### 3.3. Hardware Improvement Assessment

#### 3.3.1. Heat Exchanger (HX) First Order Analysis (FOA)

This section outlines a FOA for the HXs of Units 1, 4, 6 and 10 to identify improvement potential. The project's objective, as stated above, is to improve performance while minimizing charge. One way of addressing both objectives is by reducing tube / channel diameter. Heat transfer coefficients are inversely proportional to surface hydraulic diameters, however, so is pressure drop. Smaller tubes result in more compact ( $C = \text{surface area} / \text{footprint volume}$ ), with reduced internal volume, HXs.

A qualitative analysis using values from literature was carried out to demonstrate the relative impact of diameter over abovementioned metrics, specifically: heat transfer coefficient, compactness and overall thermal conductance (UA). The left-hand side plot in Figure 1 show three curves inversely proportional to the diameter; a 5mm tube can achieve, in this example, 70% greater UA than a conventional 9.5mm, within the same footprint volume (or cabinet).

These are further explored to illustrate the impact on a system level. Systems respond to UA of both condenser and evaporators, but for the purposes of this analysis, condenser only is considered. The UA represents the overall thermal conductance, which will impact the approach temperatures in the system ( $\Delta T_{app}$ ). If the heat rejection is kept constant, the higher the UA, the smaller are the  $\Delta T_{app}$ 's, thus allowing the condenser to operate in lower pressure levels, which will consequently increase the system performance. An example using a hypothetical R32 cycle with an EER of 12 as base is shown in the right-hand side plot in Figure 1. Performance improvement is limited by the Second Law, when the approach temperatures near zero; however, in this illustration, the EER has potential to increase in over 20% with better condenser design alone.

It is imperative to note that the results presented in this section are for **illustration purposes only**. Further in this report it is presented in more detail a re-design framework, applied to the units of interest in this project, using the metrics outlined in this section.

Unit 1 already had a 5mm condenser, which limits the options for HX re-design. Unit 6 had a 7mm HX on both the indoor and outdoor units, which allows some room for improvement if reducing to 5mm. Lastly, both coils for Unit 10 had 9.5mm tubes, thus there is greater potential for charge reduction and performance improvement for that unit in particular.




Figure 1. Heat Exchangers FOA.

### 3.3.2. Compressors

The existing units mostly use compressors sized specifically for R410A or R22 and in some cases custom made for this effort. There is, however, opportunity for a better compressor selection when migrating from R32 to R454B or R447B on Units 6 and 10, respectively.

### 3.3.3. Expansion Devices

Expansion devices such as TXV's and EXV's may allow for better control and reduced losses in connecting pipes if located near the evaporator. Some units, such as 6 and 10, have a capillary tube in the outdoor unit, which forces the refrigerant to travel in two-phase along the connecting pipes, and at lower temperatures, thus increasing pressure drop and heat gain.

### 3.3.4. Fan and Blower

Replacing the fan and blower may be necessary if newly designed HXs offer considerable change in pressure drop over the baseline since the flow rates are kept constant. The lack of test data on pressure drop forces us to rely on predicted values only. These will be considered for replacement as a last priority.

### 3.3.5. Units Component Modification Potential

Table 4 shows the detailed existing components for the units of interest for modification.

**Table 4: Units 1, 4, 6 and 10 Components.**

System	Unit 1	Unit 4	Unit 6	Unit 10
Refrigerant	R444B	R290	R32	R32
Compressor	HIGHLY SL260DG-C8EU	HIGHLY PSH356DG-C8DU3	GMCC KSG226N1UMT	Copeland ZP42K5E-PFJ-XXX
Condenser	5mm Louver TFHX	9.5mm Wavy TFHX	7mm Louver TFHX	9.5mm Louver TFHX
Expansion Device	Capillary Tube	Capillary Tube	Capillary Tube	Capillary Tube
Evaporator	9.5mm Louver TFHX	7mm Louver TFHX	7mm Slit TFHX	9.5mm Louver TFHX

## 3.4. Conclusions and Recommendations

The first part of this activity regarded data analysis and processing from the original tests conducted in the original PRAHA-I project, which was designed to conduct testing and comparison of cooling capacity vs. EER for the prototypes against the baseline units from same manufacturers. Since limited certification tests were required then, more testing parameters would have been needed to support the optimization and/or redesign process within the scope of PRAHA-II. The second part pertained assessing potential hardware modifications that could result in higher performance and less charge, with the intent of replacing the original refrigerants with alternative, low-GWP ones. The key conclusions and recommendations are:

- 1- Certification laboratories, such as the one used for testing the units in PRAHA I, provide limited information for the purposes of product design and development. For future reference it is recommended that for research-oriented efforts such as this one, the units undergo a more rigorous testing process along with full characterization of the system and its individual components operating conditions and performance.
- 2- In applications of high ambient temperatures, it is expected that performance will degrade as compared to operating under more temperate conditions and the resultant impact on performance must be considered. The key components for performance improvement identified herein were the compressor, condenser and expansion device.

- a. At higher temperatures, the saturation temperatures and refrigerant density at compressor's suction port can be very different than that from the rated conditions. Larger displacement volumes and efficiency curves optimized for higher pressure lifts might be required. Therefore, the proper selection of the compressor is paramount.
  - b. A better performance condenser will reduce the approach temperature between refrigerant and air, helping the compressor not to discharge refrigerant at very high pressure and temperatures, which degrade performance.
- 3- At high ambient conditions, the system is forced to operate in higher pressure lift than at rated conditions, but still requires a certain refrigerant mass flow rate. Passive devices such as capillary tubes and orifices may not be able to provide enough expansion to allow the system to operate in higher temperature conditions. An active expansion device such as EXV's can adequately control operating conditions and maintain stable superheat.

## 4. Activity 2 - Design Improvements

The details of modeling and simulation results are provided in a separate document submitted in conjunction with this one, while in this section only the summarized performance results are presented.

### 4.1. Hardware

A general design improvement assessment was presented in the report for Activity 1, focusing on the units of interest to this study. A first order analysis on the HX's showed that moving towards smaller hydraulic diameter tubes can be beneficial from a material savings and charge reduction standpoint. Units 4 and 10 use conventional 9.5mm diameter tube condensers (Table 4), making them good candidates for condenser replacement with either a smaller tube diameter or a microchannel heat exchanger (MCHX). The compressors used on Units 1, 4 and 6 do not have available performance maps making it difficult to assess their fitness for the system. The focus of this study is on proper compressor selection and condenser re-design.

### 4.2. Refrigerant

R32 and R290 have wide saturation regions (Figure 2 and Figure 3) putting them at an advantage since they may operate with smaller superheat and subcooling, while benefiting from two-phase heat transfer. Their cycles may get closer to that of the ideal Carnot cycle compared to refrigerants with narrower saturation.

Amongst the blends investigated for Unit 1, R444B has the widest saturation region while also having the highest temperature glide (Figure 4). The latter is typically not beneficial, in particular for evaporators, but it may help the condenser. The glide enables the refrigerant temperature profile to get closer to the air temperature profile without crossing (Figure 4). From a thermodynamic perspective, this means R444B can have its condensing pressure reduced further, resulting in higher theoretical COP.

For Units 6 and 10, the investigated blends, although having narrower saturation than the baseline R32, have similar thermophysical characteristics (Figure 3) with lower temperature glides (Figure 4) making them more competitive from a capacity and performance perspective.




Figure 2. Refrigerants Investigated for Units 1 and 4.




Figure 3. Refrigerants Investigated for Units 6 and 10.




Figure 4. Refrigerant Temperature Glides.

#### 4.3. System Design Modification Framework

The systems' re-design herein presented ultimately consists of a retrofit of the existing units by properly designing and selecting components that can be replaced as drop-ins, with minimal or no modification of

the packaging (cabinets). In other words, any component replaced must occupy the same envelope as the baseline component. The focus of the re-design is on:

- Compressor
- Condenser, and
- Expansion valve

The evaporator designs were not changed for two main reasons: a) some are custom-made wrap-around the blower units, such as in Unit 6, making it harder to quickly find an off-the-shelf option; and, b) the goal is to deliver the same cooling capacity while improving efficiency. For the latter, there's more room for improvement in the condenser by reducing condensing pressure, assuming the evaporator can already deliver the expected capacity.

The fans and blowers were also not considered for change, in part due to the lack of information on the performance curves from the baseline models, but also due to potential high cost and lead time for replacement with secondary impact on performance since 80-90% of the power consumed comes from the compressor.

The first step to assess the level of performance required for each component is to investigate an improved theoretical cycle, which will indicate how much COP improvement can be expected, as well as refrigerant flow rate needs and HX size (UA). To improve the performance of a vapor compression cycle, the pressure lift between evaporating and condensing pressures must be reduced. Consequently, the approach temperatures between air and refrigerant will be reduced as well (Figure 5), thus the thermal capacitance of the heat exchangers must increase. Furthermore, the closer to the saturation region, the closer the cycle reaches the ideal Carnot efficiency (Figure 6).




Figure 5. Illustrative T-s diagram for baseline and improved cycles.




Figure 6. P-h Diagrams Illustrating COP Improvement: a) Real Cycle; b) Ideal Cycle (Carnot).

The system design framework is performed according to Figure 7.




Figure 7. System Re-Design Framework,

#### 4.3.1. Compressors

Modeling compressors are handled in two possible ways, as suggested previously: using performance maps when available or using fixed isentropic efficiency and effective displacement volume. For the larger capacity units (6 and 10), performance maps were provided. Although these compressors were originally designed for R410A refrigerant they may operate – not necessarily optimally – with other refrigerants. Compressor manufacturers supporting this project used proprietary simulation tools, with aid from available empirical data (tests with other refrigerants), to develop theoretical maps for the various refrigerants of interest (Table 5) and made them available to OTS for modeling purposes. It is understood that the predictions are for reference only, and the compressor manufacturer does not guarantee performance for any refrigerants for which the compressors haven't been fully tested.

**Table 5: Compressor Models.**

Model	Capacity (BTU/hr)	Frequency (Hz)	Refrigerants
ZP20K5E-PFV	24,000	60	R32, R459A, R454B, R410A
ZP21K5E-PFV	24,000		
ZP31K6E-PFV	36,000	50/60	R447B, R452B, R454B, R410A
ZP34K6E-PFV	36,000		

For the smaller units (1 and 4), which were re-designed using R290 (Propane), compressor performance maps were not available. The approach for these units then was to set a target isentropic efficiency of 0.7 (baseline data suggests that the compressor efficiencies ranged from 0.55 to 0.65). The required mass flow rate is calculated based on capacity in the theoretical cycle model described above. From there, the effective displacement volume can be determined (eq. (1))<sup>1</sup>. The latter serves to determine whether a system can use the same compressors for different refrigerants.

$$V_{eff} = \eta_{vol} \cdot V_{disp} = \frac{\dot{m}_{required}}{f \cdot \rho_{suction}} \quad (1)$$

#### 4.3.2. HX Design and Selection

The condensers design procedure takes into consideration the following:

- **Face area:** baseline face area must be preserved or at most reduced. Furthermore, the aspect ratio must also match that of the baseline so the HX can be drop-in replaced in the same cabinet.
  - o Find the number of tube rows and tube length to match as closely as possible to tube face area and aspect ratio
- **Airside pressure drop and flow rate:** the test data from reports contain only air flow rate measurements, while no information on pressure drop is provided. Additionally, the fan performance curves are also not available, which limits the ability to find the exact operating condition. The baseline models provide an estimate prediction for the pressure drop, which is used as reference.
- **Thermal performance:** this step must be iteratively conducted with the previous step, as such for each design change the air flow rate and capacity are evaluated under the new conditions found in the theoretical cycle re-design.
  - o Gradually increment the condensing pressure until attainable performance is achieved. This process is done iteratively using the theoretical cycle model, to find new expected operating conditions for evaporating pressure, superheat, subcooling and refrigerant flow rate.
- **HX Form:** as indicated previously, the HX design is constrained by cabinet dimensions as well as form. In the case of units 1 and 4, the condensers are flat coils placed 90° inside the cabinet (Figure 8), which makes it simpler for drop-in replacement as long as new designs have the same overall dimensions. For units 6 and 10, however, the condensers are L-shaped inside the cabinet (Figure 8). Forming coils is widely done, however, for custom coils it may be a challenge, in particular for MCHX. For this reason, the MCHX designs for units 6 and 10 are sized for a full-face area, assuming the coil can be formed, and a second design that is a single flat slab placed in longer side of the “L” shape(Figure 9).

<sup>1</sup> Variable definitions in the Nomenclature list after final conclusions section in this document.





#### 4.3.3. System Design

In the final step, the modified systems are evaluated holistically through system level modeling and simulation using an in-house Steady-State vapor compression cycle software that has the capability to integrate with the HX and compressor models (performance maps, generic etc.). For each modified system and each refrigerant, a system model was created.

#### 4.4. Modified Systems Results Summary

The final results of Activity 2 are summarized in Table 6. For more detailed results in the framework steps refer to APPENDIX A .

#### 4.5. Conclusions and Recommendations

This section presents a systematic approach based on first order analysis providing educated guidance towards the direction of more efficient systems with fewer simulations and minimal changes to the systems. The study includes a wide variety of refrigerants as well as condenser designs and compressor model options. Given the challenges with original test data the baseline models serve as a numerical reference only. The findings are strictly valid to comparisons against the baseline models and OTS does not guarantee that results would be reflected in actual systems as herein reported. The key conclusions and recommendations are:

- 1- R290 and R32 have wider saturation regions allowing the system to operate with smaller superheat and subcooling, while benefiting from two-phase heat transfer.
- 2- Refrigerants with high temperature glide may require new heat exchanger (HX) designs, namely condensers. The original designs proved to be sufficiently effective to allow for most systems to operate with the different refrigerants, however, better designs would allow for higher system efficiency and potentially less charge. HX designs are severely constrained by allowed envelope dimensions. A complete system re-design would provide an opportunity for designing HX's with even higher efficiency.
- 3- The results of this analysis suggest that for an effective use of alternate low-GWP refrigerant, a proper compressor selection must be accompanied with it. Higher isentropic efficiencies are desired for higher temperatures, but most importantly, the displacement volume requirements can vary considerably from one refrigerant to another.
- 4- It is also imperative that having an active expansion device (preferably an EXV) to not only allow for more controlled superheat, but also to enable the unit to run with different refrigerants with very different thermophysical properties.

**Table 6: Activity 2 Results.**

General Information			Hardware					Ref.	Performance			
System	Rated Capacity (@35°C)	System Configuration	Compressor		Condenser		Expansion Device		Cooling Capacity (@46°C)		EER (@46°C)	
-	BTU/hr	-	Effective Disp. Vol. (cm <sup>3</sup> )*	Efficiency (-)	Type	Effectiveness (-)	Type	-	BTU/hr	%	BTU/hr. W	%
Unit 1	18000	Baseline	19.8	0.66	Tube-Fin (5mm Tube)	0.20	Passive	R444B	17403	0.00%	7.4	0.00%
		Alternate 1	25.9	0.70	Same as Baseline	0.35	Active (EXV)	R290	17639	1.40%	8.01	8.20%
		Alternate 2	24.8	0.69		0.26		R454C	18104	4.00%	7.31	-1.30%
		Alternate 3	19.6	0.70		0.23		R444B	18140	4.20%	8.14	9.90%
		Alternate 4	25.3	0.68	MCHX	0.24		R457A	17749	2.00%	7.63	3.10%
Unit 4	24000	Baseline	26.4	0.61	Tube-Fin (9.5mm Tube)	0.24	Passive	R290	17940	0.00%	7.52	0.00%
		Alternate 1	26.3	0.70	Tube-Fin (5mm Tube)	0.26	Active (EXV)	R290	18147	1.20%	9.12	21.40%
		Alternate 2	37.9	0.70		0.20		R290	24120	34.40%	6.72	-10.60%
Unit 6	24000	Baseline	16.0	0.60	Tube-Fin (7mm Tube)	0.12	Passive	R32	23115	0.00%	8.46	0.00%
		Alternate 1	16.9	0.65	Tube-Fin (5mm Tube)	0.15	Active (EXV)	R32	23798	3.00%	9.41	11.20%
		Alternate 2	18.4	0.67		0.19		R454B	22894	-1.00%	9.71	14.80%
		Alternate 3	19.0	0.70		0.17		R452B	23702	2.50%	9.6	13.50%
Unit 10	36000	Baseline	19.6	0.44	Tube-Fin (9.5mm Tube)	0.13	Passive	R32	29005	0.00%	6.39	0.00%
		Alternate 1	22.3	0.65	Tube-Fin (5mm Tube)	0.25	Active (EXV)	R447B	30478	5.10%	9.43	47.50%
		Alternate 2	23.0	0.67		0.25		R452B	30796	6.20%	10.27	60.70%
		Alternate 3	23.3	0.67		0.25		R454B	30809	6.20%	10	56.50%

\* Product of displacement volume and volumetric efficiency

## 5. Activities 3, 4 & 5 - Prototype Units Fabrication, Evaluation of the Optimized Prototypes and Analyzing Leaks of Alternatives

Activities 3-5 officially began in April 2019 when the first round of tests on modified Unit 6 were carried out. Initial tests resulting in unsuccessful outcomes leading OTS to change the system modifications and the scope. Additional information found in APPENDIX B . The detailed test data and charge optimization for Units 6 and 10 are presented in APPENDIX C through APPENDIX E . Comparisons between Activity 2 model validations and experimental data are presented in APPENDIX F .

### 5.1. Unit 6

Some modifications were made to Unit 6 to improve its efficiency. The baseline compressor was replaced with alternate models to account for the change in refrigerant and to improve efficiency. The compressor used with R454B had a higher displacement volume than the one used with R32. Furthermore, the capillary tubes were replaced with a manual TXV that was installed directly at the evaporator inlet to increase the cooling capacity of the evaporator. A summary of the design modifications evaluated for Unit 6 is listed in Table 7, while Table 8 and Table 9 show the performance of Unit 6 for baseline and modifications at 35°C and 46°C ambient, respectively. The baseline system performed similar, within 2%, to reported performance in PRAHA I. There is a discrepancy in the measurements from condenser outlet to expansion inlet in the baseline case, since the capillary tube (removed in the modified systems) was located in the outdoor unit. The expansion causes the refrigerant to flash in the liquid line thus compromising the readings at the expansion device. For calculation purposes, the condenser outlet enthalpy was used instead of the expansion inlet.

**Table 7: Unit 6 Modifications for Testing.**

System	Unit 6		
	Baseline	Alternate 1	Alternate 2
Refrigerant	R32	R32	R454B
Compressor	GMCC KSG226N1UMT	Copeland ZP20K5E	Copeland ZP21K5E
Expansion Device	Capillary Tube (Outdoor unit)	Manual Valve (Indoor Unit) <sup>2</sup>	Manual Valve (Indoor Unit) <sup>2</sup>

Cooling capacity for the modified unit with either refrigerant was consistently lower by 6-12% than the baseline. The modified R32 system reportedly showed lower mass flow rate than expected, likely the main cause for the lower-than-expected thermal performance. The R454B system resulted in a poorer performance but was less sensitive to ambient temperature than its R32 counterpart - i.e. cooling capacity was near the same at both 35°C and 46°C, while for R32 there was a ~2,000BTU/hr reduction with the temperature increase. It is also possible that there is a mismatch between thermophysical property library and actual refrigerant properties for R454B which can happen with newer fluids. The libraries need periodic update as more test data become available.

---

<sup>2</sup> A manual valve was used to mimic a TXV or EXV recommended as component modification in these systems configurations.

**Table 8: Unit 6 - Performance Test Summary for R32 Baseline (OTS) @ 35°C.**

		Baseline (35°C)	Alternate 1 (35°C)	Alternate 2 (35°C)	Alt. 1 vs. Baseline	Alt. 2 vs. Baseline
<b>Refrigerant</b>	-	<b>R32</b>	<b>R32</b>	<b>R454B</b>	-	-
Charge	lb	3.83	4.27	5.02	11.5%	31.1%
Cooling Capacity	BTU/hr	25192	23585	21966	-6.4%	-12.8%
Energy Balance	%	-2.28%	-4.66%	-3.06%	-	-
Compressor Power	kW	2.11	1.79	1.77	-15.1%	-16.2%
Fan Power	kW	0.32	0.33	0.33	2.2%	4.2%
Total Power	kW	2.43	2.12	2.10	-12.8%	-13.5%
EER	BTU/hr.W	10.37	11.12	10.44	7.2%	0.68%

**Table 9: Unit 6 - Performance Test Summary for R32 Baseline (OTS) @ 46°C.**

		Baseline (46°C)	Alternate 1 (46°C)	Alternate 2 (46°C)	Alt. 1 vs. Baseline	Alt. 2 vs. Baseline
<b>Refrigerant</b>	-	<b>R32</b>	<b>R32</b>	<b>R454B</b>	-	-
Charge	lb	3.83	4.27	5.02	11.5%	31.1%
Cooling Capacity	BTU/hr	23390	21450	21821	-8.3%	-6.7%
Energy Balance	%	-1.78%	-4.42%	-7.61%	-	-
Compressor Power	kW	2.71	2.32	2.25	-14.2%	-16.6%
Fan Power	kW	0.40	0.42	0.42	5.3%	5.3%
Total Power	kW	3.10	2.74	2.67	-11.7%	-13.8%
EER	BTU/hr.W	7.55	7.84	8.17	3.8%	8.2%

## 5.2. Unit 10

Applying what was learned in the initial modifications to Unit 6, modifications to Unit 10 were limited to include the compressor and expansion device only. Unlike Unit 6, however, the re-test of the baseline system was not successful; refer to APPENDIX D for additional information. However since Unit 6 baseline re-test showed good reproducibility from original data, it is assumed that the Unit 10 original baseline is appropriate for comparison against the modified system configurations. A summary of the design modifications evaluated for Unit 10 is listed in Table 10. The detailed test data is presented in APPENDIX E .

At 35°C the modified units exhibited almost 20% less cooling capacity with 10% less power consumption, resulting in up to 11% less EER (Table 11). These results were not unexpected since the modified units were re-designed using the 46°C temperature, when the baseline system's performance showed a great degradation of performance. At 46°C condition, the tests exhibited 2-5% greater cooling capacity with up to 12% less power consumption compared to the baseline, which was equivalent to 13-17% greater system performance.

In Activity 2 the compressor power consumptions were underestimated, as well as the total fan power consumption, leaving the impression the overall performance improvement would considerably be greater than the observed. The cooling capacity, on the other hand, was predicted with less than 2% deviation from test data, validating at least the models created.

**Table 10: Unit 10 Modifications for Testing.**

System	Unit 10		
	Baseline	Alternate 1	Alternate 2
Refrigerant	R32	R447B	R452B
Compressor	Copeland ZP42K6E	Copeland ZP34K5E	Copeland ZP31K5E
Expansion Device	Orifice	Manual Valve	Manual Valve

**Table 11: Unit 10 - Performance Test Summary for R32 Baseline @ 35°C.**

		Baseline (35°C)	Alternate 1 (35°C)	Alternate 2 (35°C)	Alt. 1 vs. Baseline	Alt. 2 vs. Baseline
<b>Refrigerant</b>	-	<b>R32</b>	<b>447B</b>	<b>452B</b>	-	-
Charge	lb	5.625	6.625	6.625	17.78%	17.78%
Cooling Capacity	BTU/hr	35543	32195	28128	-9.42%	-20.86%
Energy Balance	%	---	7.52%	-3.29%	-	-
Compressor Power	kW	-	2.67	2.4	-	-
Fan Power	kW	-	0.95	0.98	-	-
Total Power	kW	3.761	3.62	3.38	-3.75%	-10.13%
EER	BTU/hr.W	9.451	8.894	8.322	-5.89%	-11.94%

**Table 12: Unit 10 - Performance Test Summary for R32 Baseline @ 46°C.**

		Baseline (46°C)	Alternate 1 (46°C)	Alternate 2 (46°C)	Alt. 1 vs. Baseline	Alt. 2 vs. Baseline
<b>Refrigerant</b>	-	<b>R32</b>	<b>447B</b>	<b>452B</b>	-	-
Charge	lb	5.625	6.625	6.625	17.78%	17.78%
Cooling Capacity	BTU/hr	29633	31073	30292	4.86%	2.22%
Energy Balance	%	---	4.21%	1.21%	-	-
Compressor Power	kW	---	3.18	2.93	-	-
Fan Power	kW	---	0.95	0.97	-	-
Total Power	kW	4.466	4.13	3.9	-7.52%	-12.67%
EER	BTU/hr.W	6.64	7.52	7.76	13.33%	16.95%

### 5.3. Leak Tests

In the interest of time the leak tests were conducted only on Unit 10 for R447B. The choice of refrigerant was based on temperature glide, where R447B exhibits the highest glide amongst the refrigerants evaluated between Unit 6 and Unit 10 (refer to Figure 4). The leak tests were conducted to closely represent field operation. The procedure applied includes the following steps:

- 1- Run unit until steady-state is achieved (repeat 46°C performance test), monitoring capacity and subcooling
- 2- Gradually remove refrigerant from vapor line until capacity is reduced to approximately 50%, if possible
- 3- Store and weigh removed refrigerant
- 4- Re-charge with new refrigerant until same subcooling is achieved
- 5- Compare cooling capacities; if more than 5% deviation is observed, repeat steps 1-4, however in step 2, reduce capacity to 25% only
- 6- Repeat steps 1-5 for the liquid line

The comparison herein presented refers to a leakage of approximately 30% of charge, while reducing capacity by approximately 50% based on airside only. The leak tests showed less than 2% deviation in cooling capacity after re-charge from both vapor and liquid lines (Table 13). Since the capacity deviation was less than 5%, no further testing for 25% capacity reduction was conducted. The results suggest little impact due to fractionation.

**Table 13: Unit 10 – R447B Leak Test Summary Results.**

System		Liquid Line Leak			Vapor Line Leak	
		Full Charge	Low Charge	Re-Charged	Low Charge	Re-Charged
Refrigerant	-	R447B	R447B	R447B	R447B	R447B
Charge	lb	6.625	4.27	6.625	4.23	6.77
Cooling Capacity	BTU/hr	31073	14216	30865	15171	30587
Energy Balance	%	4.21%	-34.72%	0.35%	-31.55%	1.87%
Compressor Power	kW	3.18	2.93	3.18	2.94	.. <sup>3</sup>
Fan Power	kW	0.95	0.98	0.98	0.98	0.98
Total Power	kW	4.13	3.90	4.16	3.92	.. <sup>3</sup>
EER	BTU/hr.W	7.52	3.64	7.42	3.87	.. <sup>3</sup>

#### 5.4. Conclusions and Recommendations

This section presented the performance tests conducted on units 6 and 10. The key conclusions and recommendations are:

- 1- Unit 6 re-tested baseline exhibited similar performance to that found in PRAHA I testing. It should be stressed that the baseline unit by design had its capillary tube located in the outdoor unit. This would cause liquid refrigerant leaving the outdoor unit to flash. The refrigerant enthalpy at the condenser outlet state was used to calculate the refrigerant-side capacity assuming an isenthalpic expansion without heat loss in connecting pipe. This is different from the modified systems of which the capillary tube was removed, and a manual expansion valve was placed at the inlet of the indoor unit. For modified systems, the enthalpy at the expansion valve inlet was used to calculate the refrigerant-side capacity.
- 2- Unit 10 exhibited a considerable reduction in power consumption at the high ambient test condition (46°C) as compared to the original test data. This also indicates the importance of proper compressor selection.
- 3- The higher-than-expected power consumption in the Unit 10 baseline tests is also evidenced by the fact that even with zeotropic mixtures (R447B and R452B), Unit 10 had higher cooling capacity and efficiency than the baseline for the 46°C test condition, as projected in activity 2.
- 4- Because of the differences in saturation curves from the Activity 2 analysis, R32 tends to result in systems with higher efficiency and less charge when no modifications to the hardware are made. The results showed however, that making appropriate component selection, such as compressors with larger displacement volumes and higher mass flow rates for the zeotropic mixtures, cooling capacities and overall performance were of the same order of magnitude.
- 5- Refrigerant fractionation as evidenced by the leak tests, does not appear to be a great concern since less than 2% deviation in cooling capacity was observed after the system's re-charge.
- 6- The Unit 6 modified systems had lower performance than expected from the Activity 2 models. The R32 system configuration exhibited more than 10% less flow rate than anticipated due to performance

<sup>3</sup> Compressor power consumption was not properly recorded for this test; the error was identified after the fact and the team was unable to retrieve that information. While that compromises the assessment of the overall system performance, the deviations are expected to be marginal. The leak test on liquid line suggest minimal impact on power consumption after re-charge, while cooling capacity was reportedly fully recovered after recharge on both leak tests.

maps overprediction, which corresponded to 10% lower capacity. The R454B configuration exhibited a deviation of 5% between model and test due also in part to a 3% flow rate over prediction in the model. Unit 10, on the other hand, exhibited an excellent agreement to the models with less than 2% deviation in cooling capacity.

- 7- The model's validation adds confidence in the numerical simulation findings and recommendations provided in activity 2.

## 6. Conclusions

This report presents a comprehensive set of activities with the objectives of advancing the PRAHA program. The original scope and schedule were modified during the project as new findings and challenges surfaced. The tests that were carried out for PRAHA-I, while sufficient for the purpose of measuring capacity and energy efficiency for the purposes of PRAHA-I, did not have enough essential data to enable a complete cycle evaluation for optimization purposes. This is primarily due to using standard test rig on systems with critical hardware configuration differences. The analyses presented in Activity 2 (design assessment through modeling) provided good insights on adequate component design and/or selection for proper system functioning, when using novel refrigerants.

The final recommendations for future development are listed as follows:

- 1- Establish a baseline system by conducting comprehensive testing including measurements and metrics not typically performed in energy certification tests. Furthermore, testing systems with different configurations require custom test rigs as such to adequately measure working fluid's states to avoid mischaracterization of the operating conditions and performance. Such approach is considerably more labor-intensive which should be factored in the scope in future developments.
- 2- Using alternate low-GWP refrigerants is viable and can be competitive to presently used refrigerants but doing so requires proper component design and selection; compressor and expansion device particularly. Drop-in replacement without hardware change is never recommended as evidenced by the change requirements in Activity 2 and performance tests in the subsequent activities.
- 3- It is recommended to always perform numerical simulations, and to conduct at least some level of "soft" optimization analyses that will provide information for an educated system re-design / retrofit at much lower costs than gradual trial-and-error changes.
- 4- Always test the modified systems with the same instrumentation as the baseline, however mindful of the modifications as such to properly place sensors to obtain adequate readings as suggested in item 1 above.

## Nomenclature

COP	Coefficient of Performance	-
$D_o$	Tube Outer Diameter	mm
f	Frequency	Hz
FPI	Fins per Inch	1/in
h	Enthalpy	kJ/kg
$h_t$	Tube Height	mm
HX	Heat Exchanger	-
$\dot{m}$	Mass Flow Rate	kg/s
MCHX	Microchannel Heat Exchanger	-
P	Pressure	kPa
$P_l$	Tube Longitudinal Pitch	mm
$P_t$	Tube Transverse Pitch	mm
s	Entropy	kJ/kg.K
T	Temperature	°C
TFHX	Tube-Fin Heat Exchanger	-
UA	Thermal Conductance	kW/K
V	Volume	$m^3$
$w_t$	Tube Width	mm
$\eta_{vol}$	Volumetric Efficiency	-
$\rho$	Density	kg/ $m^3$



## APPENDIX A - Activity 2 Design Framework Results

**Table 14: Unit 1 – Theoretical Cycle Re-Design Summary.**

System		Baseline	Alternative 1	Alternative 2	Alternative 3	Alternative 4
Case	-	Simulation	Target			
Refrigerant	-	R444B	R290	R454C	R444B	R457A
Condenser	-	BTFD5	-	-	-	-
Compressor	-	SL260DG-C8EU	-	-	-	-
Cooling Capacity	BTU/hr	17403	17477	17477	17477	17477
Compressor Power	kW	1.92	1.49	1.49	1.33	1.43
Fan Power	kW	0.43	0.43	0.43	0.43	0.43
Total Power	kW	2.35	1.92	1.93	1.76	1.86
COP	-	2.17	2.66	2.66	2.91	2.75
COP Gain	-	1.00	1.23	1.23	1.34	1.27

**Table 15: Unit 1 – HX Analysis Summary**

Condenser		R444B		R290		R454C		R457A	
Inputs		BTFD5	NMCD2	BTFD5	NMCD2	BTFD5	NMCD2	BTFD5	NMCD2
Air Dry-Bulb Temperature	°C	46.01	46.01	46.01	46.01	46.01	46.01	46.01	46.01
Relative Humidity	%	16.37	16.37	16.37	16.37	16.37	16.37	16.37	16.37
Air Flowrate	m³/s	0.56	0.56	0.56	0.56	0.56	0.56	0.56	0.56
Refrigerant Pressure	kPa	2875.0	2875.0	2170.7	2170.7	2436.4	2436.4	2183.9	2183.9
Saturation Temperature at Inlet	°C	61	61	61	61	61	61	61	61
Refrigerant Temperature	°C	110.00	110.00	110.00	110.00	110.00	110.00	110.00	110.00
Mass Flow Rate	kg/s	0.03	0.03	0.02	0.02	0.03	0.03	0.03	0.03
Outputs									
Heat Load	W	7512.9	7441.2	8232.4	8016.6	6168.0	6040.0	6592.0	6429.0
Air Dry-Bulb Temperature	°C	58.6	58.2	59.7	59.6	56.3	56.3	57.0	56.9
Refrigerant Temperature	°C	46.7	48.1	50.3	53.8	47.2	49.5	48.0	51.1
LMTD	°C	12	15	19	23	14	18	16	21
UA	W/K	635.57	482.84	439.36	350.35	451.67	327.93	424.35	313.48
NTU	-	1.04	0.79	0.72	0.57	0.74	0.53	0.69	0.51
Effectiveness	-	0.1915	0.1896	0.2098	0.2043	0.1572	0.1539	0.1680	0.1638
Refrigerant Pressure Drop	kPa	78.2	1.4	85.0	1.7	79.3	1.4	87.2	1.7
Airside DP	Pa	75.1	75.5	75.1	75.1	75.1	75.5	75.1	75.5
Air Heat Transfer Coefficient (Average)	W/m².K	130.0	148.3	130.0	148.3	130.0	148.3	130.0	148.3
Refrigerant Heat Transfer Coefficient (Average)	W/m².K	3341.0	1721.0	4113.0	2033.0	3040.0	1382.0	3423.0	1601.0
Subcooling	°C	13.20	13.14	8.96	7.35	6.77	5.93	5.34	4.05
Charge	kg	0.3822	0.1143	0.1079	0.0352	0.3097	0.094	0.2522	0.0764

**Table 16: Unit 1 – Compressor Performance Summary.**

Compressor		Baseline				
Refrigerant	-	R444B	R290	R454C	R444B	R457A
Isentropic efficiency	-	0.66	0.70	0.69	0.70	0.68
Power	kW	1.9175	1.7682	2.0449	1.7966	1.8932
Pressure Lift	kPa	2284.8	1556.0	2087.7	1902.2	1904.9
Effective Displacement Volume	cm³	19.80	25.87	24.80	19.64	25.35
Rotation Speed	RPM	3600	3600	3600	3600	3600

**Table 17: Unit 1 – Expected Modified System Performances.**

System		Baseline				
Case	-	Simulation	Expected			
Refrigerant	-	R444B	R290	R454C	R444B	R457A
Condenser	-	BTFD5	BTFD5	BTFD5	BTFD5	NMCD2
Compressor	-	SL260DG-C8EU	-	-	-	-
Cooling Capacity	BTU/hr	17403	17639	18104	18140	17749
Compressor Power	kW	1.92	1.77	2.04	1.80	1.89
Fan Power	kW	0.43	0.43	0.43	0.43	0.43
Total Power	kW	2.35	2.20	2.48	2.23	2.33
COP	-	2.17	2.35	2.14	2.38	2.24
COP Gain	-	1.00	1.08	0.99	1.10	1.03




Figure 10. Unit 1 – Modified Systems P-h Diagrams.

Table 18: Unit 4 – Theoretical Cycle Re-Design Summary.

System	Baseline		Alternative 1	Alternative 2
			Target	Target
Refrigerant	-	R290	R290	R290
Condenser	-	BTFD9	-	-
Compressor	-	PSH356DG-C8DU4	-	-
Cooling Capacity	BTU/hr	17940	17940	23920
Compressor Power	kW	2.11	1.40	3.23
Fan Power	kW	0.28	0.28	0.28
Total Power	kW	2.39	1.68	3.51
COP	-	2.20	3.14	2.00
COP Gain	-	1.00	1.42	0.91

Table 19: Unit 4 – HX Analysis Summary.

Condenser			R290 - 18kBTU		R290 - 24kBTU	
Inputs			BTFD9	NTFD5	BTFD9	NTFD5
Air Dry-Bulb Temperature	°C		46.01	46.01	46.01	46.01
Relative Humidity	%		16.37	16.37	16.37	16.37
Air Flowrate	m <sup>3</sup> /s		0.81	0.76	0.81	0.76
Refrigerant Pressure	kPa		2875	2875	2875	2875
Saturation Temperature at Inlet	°C		75.5	75.5	75.5	75.5


Condenser				R290 - 18kBTU		R290 - 24kBTU	
		Inputs		BTFD9	NTFD5	BTFD9	NTFD5
	Refrigerant Temperature	°C	110	110	110	110	110
	Mass Flow Rate	kg/s	0.02	0.02	0.03	0.03	0.03
Outputs							
	Heat Load	W	8139	8148	12080	12190	12190
	Air Dry-Bulb Temperature	°C	55.0	56.1	59.5	61.2	61.2
	Refrigerant Temperature	°C	46.2	46.0	47.7	46.4	46.4
	LMTD	°C	9.6	7.4	14.3	10.0	10.0
	UA	W/K	848	1097	846	1216	1216
	NTU	-	0.97	1.34	0.97	1.48	1.48
	Effectiveness	-	0.15	0.16	0.22	0.23	0.23
	Refrigerant Pressure Drop	kPa	4.2	13.4	11.0	35.2	35.2
	Airside DP	Pa	16.0	15.9	16.0	15.9	15.9
	Air Heat Transfer Coefficient (Average)	W/m <sup>2</sup> .K	82.9	100.7	82.9	100.7	100.7
	Refrigerant Heat Transfer Coefficient (Average)	W/m <sup>2</sup> .K	1535.2	1493.7	2382.4	2505.6	2505.6
	Subcooling	°C	29.2	29.2	27.6	28.4	28.4
	Charge in Tubes	kg	0.90	0.46	0.76	0.39	0.39

**Table 20: Unit 4 – Compressor Performance Summary.**

Compressor		Baseline	18kBTU/Hr			24kBTU/Hr	
Refrigerant	-	R290	R290	R290	R290	R290	R290
Isentropic efficiency	-	0.61	0.70	0.70	0.70	0.70	0.70
Power	kW	2.1067	1.7364	1.7093	3.3152	3.31	3.31
Pressure Lift	kPa	1457.6	1556.3	1513.7	2947.1	2937.4	2937.4
Effective Displacement Volume	cm <sup>3</sup>	26.394	26.309	26.309	37.866	37.866	37.866
Rotation Speed	RPM	3600	3600	3600	3600	3600	3600

**Table 21: Unit 4 – Expected Modified System Performances.**

System		Baseline	Alternative 1			Alternative 2	
			Expected				
Refrigerant	-	R290	R290	R290	R290	R290	
Condenser	-	BTFD9	BTFD9	NTFD5	BTFD9	NTFD5	
Compressor	-	PSH356DG-C8DU4	-	-	-	-	
Cooling Capacity	BTU/hr	17940	17991	18147	24045	24120	
Compressor Power	kW	2.11	1.74	1.71	3.32	3.31	
Fan Power	kW	0.28	0.28	0.28	0.28	0.28	
Total Power	kW	2.39	2.02	1.99	3.60	3.59	
COP	-	2.20	2.61	2.67	1.96	1.97	
COP Gain	-	1.00	1.19	1.21	0.89	0.89	



**Figure 11. Unit 4 – Modified Systems P-h Diagrams.**

**Table 22: Unit 6 – Theoretical Cycle Re-Design Summary.**

System		Simulation	Alternate 1	Alternate 2	Alternate 3
Refrigerant	-	R32	R32	Target R454B	R452B
Condenser	-	BTFD9	-	-	-
Compressor	-	GMCC KSG226N1UMT	ZP20K5E	ZP21K5E	-
Cooling Capacity	BTU/hr	23115	23114	23114	23115
Compressor Power	kW	2.73	2.37	2.29	2.04
Fan Power	kW	8.46	9.75	10.10	11.31
Total Power	kW	2.73	2.37	2.29	2.04
COP	-	2.48	2.86	2.96	3.32
COP Gain	-	1.00	1.15	1.19	1.34

**Table 23: Unit 6 – HX Analysis for R32**

Condenser			BTFD7	NTFD5	NMCD2	NMCD2R
Inputs						
Air Dry-Bulb Temperature	°C	46.01	46.01	46.01	46.01	46.01
Relative Humidity	%	16.37	16.37	16.37	16.37	16.37
Air Flowrate	m³/s	1.08	0.94	1.08	0.94	0.94
Refrigerant Pressure	kPa	3562	3562	3562	3562	3562
Saturation Temperature at Inlet	°C	55.53	55.53	55.53	55.53	55.53
Refrigerant Temperature	°C	112.00	112.00	112.00	112.00	112.00
Mass Flow Rate	kg/s	0.03	0.03	0.03	0.03	0.03
Outputs						
Heat Load	W	9159	9416	9332	9113	9113
Air Dry-Bulb Temperature	°C	53.63	55.35	54.27	55.24	55.24
Refrigerant Temperature	°C	49.78	46.15	47.40	50.47	50.47
LMTD	°C	19.94	9.46	15.13	20.57	20.57
UA	W/K	459.40	995.12	616.75	443.09	443.09
NTU	-	0.39	0.97	0.52	0.43	0.43
Refrigerant Pressure Drop	kPa	100.98	26.10	3.06	4.70	4.70
Airside DP	Pa	26.30	29.30	27.70	28.90	28.90
Air Heat Transfer Coefficient (Average)	W/m².K	109.57	126.69	128.70	130.84	130.84
Refrigerant Heat Transfer Coefficient (Average)	W/m².K	5543.00	2624.00	2353.00	2978.00	2978.00
Subcooling	°C	4.48	9.04	8.10	5.07	5.07
Charge	kg	0.39	0.71	0.17	0.11	0.11

**Table 24: Unit 6 – HX Analysis for R452B**

Condenser			BTFD7	NTFD5	NMCD2	NMCD2R
Inputs						
Air Dry-Bulb Temperature	°C	46.01	46.01	46.01	46.01	46.01
Relative Humidity	%	16.37	16.37	16.37	16.37	16.37
Air Flowrate	m³/s	1.08	0.94	1.08	0.94	0.94
Refrigerant Pressure	kPa	3247	3247	3247	3247	3247
Saturation Temperature at Inlet	°C	55.53	55.53	55.53	55.53	55.53
Refrigerant Temperature	°C	112.00	112.00	112.00	112.00	112.00
Mass Flow Rate	kg/s	0.03	0.03	0.03	0.03	0.03
Outputs						
Heat Load	W	7876	7964	7936	7866	7866
Air Dry-Bulb Temperature	°C	52.52	53.94	53.06	53.99	53.99
Refrigerant Temperature	°C	47.41	46.05	46.53	47.61	47.61
LMTD	°C	15.49	8.09	12.37	15.72	15.72
UA	W/K	508.37	984.95	641.46	500.33	500.33
NTU	-	0.43	0.96	0.55	0.49	0.49
Refrigerant Pressure Drop	kPa	71.90	21.03	2.60	3.70	3.70
Airside DP	Pa	26.30	29.30	27.70	28.90	28.90
Air Heat Transfer Coefficient (Average)	W/m².K	109.57	126.69	128.70	130.84	130.84
Refrigerant Heat Transfer Coefficient (Average)	W/m².K	4252.00	2077.00	2103.00	2112.00	2112.00
Subcooling	°C	6.14	8.20	7.99	6.89	6.89
Charge	kg	0.55	0.90	0.21	0.15	0.15

**Table 25: Unit 6 – HX Analysis for R447B**


<i>Condenser</i>						
<i>Inputs</i>			<i>BTFD7</i>	<i>NTFD5</i>	<i>NMCD2</i>	<i>NMCD2R</i>
Air Dry-Bulb Temperature	°C		46.01	46.01	46.01	46.01
Relative Humidity	%		16.37	16.37	16.37	16.37
Air Flowrate	m³/s		1.08	0.94	1.08	0.94
Refrigerant Pressure	kPa		3025	3025	3025	3025
Saturation Temperature at Inlet	°C		55.53	55.53	55.53	55.53
Refrigerant Temperature	°C		112.00	112.00	112.00	112.00
Mass Flow Rate	kg/s		0.03	0.03	0.03	0.03
<i>Outputs</i>						
Heat Load	W		7607	8241	8157	7914
Air Dry-Bulb Temperature	°C		52.41	54.19	53.25	54.04
Refrigerant Temperature	°C		50.00	46.24	47.63	51.40
LMTD	°C		20.58	10.45	15.92	22.14
UA	W/K		369.65	788.34	512.32	357.47
NTU	-		0.31	0.77	0.44	0.35
Refrigerant Pressure Drop	kPa		185.90	27.30	3.18	4.90
Airside DP	Pa		26.30	29.30	27.70	28.90
Air Heat Transfer Coefficient (Average)	W/m².K		109.57	126.69	128.70	130.84
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		5396.00	2439.00	2397.00	3281.00
Subcooling	°C		0.00	6.05	5.17	1.22
Charge	kg		0.33	0.70	0.16	0.11

**Table 26: Unit 6 – HX Analysis for R454B**


<i>Condenser</i>						
<i>Inputs</i>			<i>BTFD7</i>	<i>NTFD5</i>	<i>NMCD2</i>	<i>NMCD2R</i>
Air Dry-Bulb Temperature	°C		46.01	46.01	46.01	46.01
Relative Humidity	%		16.37	16.37	16.37	16.37
Air Flowrate	m³/s		1.08	0.94	1.08	0.94
Refrigerant Pressure	kPa		3204	3204	3204	3204
Saturation Temperature at Inlet	°C		55.53	55.53	55.53	55.53
Refrigerant Temperature	°C		112.00	112.00	112.00	112.00
Mass Flow Rate	kg/s		0.03	0.03	0.03	0.03
<i>Outputs</i>						
Heat Load	W		7993	8094	8060	7976
Air Dry-Bulb Temperature	°C		52.61	54.06	53.16	54.10
Refrigerant Temperature	°C		47.59	46.06	46.61	47.91
LMTD	°C		15.95	8.28	12.72	16.40
UA	W/K		501.09	977.17	633.67	486.37
NTU	-		0.43	0.96	0.54	0.48
Refrigerant Pressure Drop	kPa		74.70	22.02	2.70	4.10
Airside DP	Pa		26.30	29.30	27.70	28.90
Air Heat Transfer Coefficient (Average)	W/m².K		109.57	126.69	128.70	130.84
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		4445.93	2140.00	2008.00	2201.00
Subcooling	°C		5.75	8.03	7.75	6.43
Charge	kg		0.51	0.87	0.20	0.14

**Table 27: Unit 6 – Compressor Performance Summary.**


		<i>Baseline</i>	<i>Alternate 1</i>	<i>Alternate 2</i>	<i>Alternate 3</i>
<b>Refrigerant</b>		<b>R32</b>	<b>R32</b>	<b>R454B</b>	<b>R452B</b>
Isentropic Efficiency	-	0.60	0.64	0.66	0.70
Volumetric Efficiency	-	-	0.87	0.90	-
Displacement Volume	cm³	-	19.34	20.31	-
Frequency	Hz	60	60	60	60
Effective Displacement	cm³	16.0	16.8	18.3	19.0
Compressor Power	kW	2.4	2.3	2.3	2.1



**Figure 12. Unit 6 – System Level Analysis: Performance Results for R32.**



**Figure 13. Unit 6 – System Level Analysis: Performance Results for R454B.**



**Figure 14. Unit 6 - Comparative System Performance Summary for R452B.**

**Table 28: Unit 10 – Theoretical Cycle Re-Design Summary.**

System			Baseline	Alternate 1	Alternate 2	Alternate 3
	Refrigerant	-	Simulation R32	R452B	Target R447B	R454B
Condenser	-		BTFD9	-	-	-
Compressor	-		ZP42K5E	ZP31K5E	ZP34K5E	ZP31K5E
Cooling Capacity	BTU/hr		29005	34311	31611	34608
Compressor Power	kW		3.84	2.81	2.31	2.65
Fan Power	kW		0.70	0.70	0.70	0.70
Total Power	kW		4.54	3.51	3.01	3.35
COP	-		1.87	2.87	3.08	3.03
COP Gain	-		1.00	1.53	1.64	1.62

**Table 29: Unit 10 – HX Analysis for R32**

Condenser						
Inputs			BTFD7	NTFD5	NMCD2	NMCD2R
Air Dry-Bulb Temperature	°C		46	46	46	46
Relative Humidity	%		16.4	16.4	16.4	16.4
Air Flowrate	m³/s		1.23	0.94	1.23	1.04
Refrigerant Pressure	kPa		3562	3562	3562	3562
Saturation Temperature at Inlet	°C		56	56	56	56
Refrigerant Temperature	°C		100	100	100	100
Mass Flow Rate	kg/s		0.04	0.04	0.04	0.04
Outputs						
Heat Load	W		10693	11074	11435	10669
Air Dry-Bulb Temperature	°C		54.1	57.0	54.9	55.8
Refrigerant Temperature	°C		55.2	52.9	49.3	55.4
LMTD	°C		22.8	19.8	15.9	22.5
UA	W/K		468	560	717	475
NTU	-		0.35	0.55	0.54	0.42
Refrigerant Pressure Drop	kPa		26.7	67.1	6.8	10.1
Airside DP	Pa		29.6	26.7	25.7	26.0
Air Heat Transfer Coefficient (Average)	W/m².K		100.4	117.0	124.8	125.3
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		3823	4239	3050	3991
Subcooling	°C		0.00	1.75	6.17	0.00
Charge	kg		0.61	0.43	0.17	0.11

**Table 30: Unit 10 – HX Analysis for R452B**

Condenser						
Inputs			BTFD7	NTFD5	NMCD2	NMCD2R
Air Dry-Bulb Temperature	°C		46	46	46	46
Relative Humidity	%		16.4	16.4	16.4	16.4
Air Flowrate	m³/s		1.23	0.94	1.23	1.04
Refrigerant Pressure	kPa		3247	3247	3247	3247
Saturation Temperature at Inlet	°C		56	56	56	56
Refrigerant Temperature	°C		100	100	100	100
Mass Flow Rate	kg/s		0.04	0.04	0.04	0.04
Outputs						
Heat Load	W		9549	9812	9751	9500
Air Dry-Bulb Temperature	°C		53.2	55.8	53.6	54.8
Refrigerant Temperature	°C		49.5	46.4	47.1	50.1
LMTD	°C		16.7	9.2	12.2	17.1
UA	W/K		573	1067	802	557
NTU	-		0.43	1.04	0.60	0.49
Refrigerant Pressure Drop	kPa		17.2	47.1	5.6	8.2
Airside DP	Pa		29.6	26.7	25.7	26.0
Air Heat Transfer Coefficient (Average)	W/m².K		100.4	117.0	124.8	125.3
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		2974	3038	2537	2812
Subcooling	°C		4.82	7.51	7.34	4.38
Charge	kg		0.83	0.79	0.23	0.15

**Table 31: Unit 10 – HX Analysis for R447B**

<i>Condenser</i>						
<i>Inputs</i>			<i>BTFD7</i>	<i>NTFD5</i>	<i>NMCD2</i>	<i>NMCD2R</i>
Air Dry-Bulb Temperature	°C		46	46	46	46
Relative Humidity	%		16.4	16.4	16.4	16.4
Air Flowrate	m³/s		1.23	0.94	1.23	1.04
Refrigerant Pressure	kPa		3025	3025	3025	3025
Saturation Temperature at Inlet	°C		56	56	56	56
Refrigerant Temperature	°C		100	100	100	100
Mass Flow Rate	kg/s		0.04	0.04	0.04	0.04
<i>Outputs</i>						
Heat Load	W		9016	9632	9923	9085
Air Dry-Bulb Temperature	°C		52.9	55.6	53.8	54.4
Refrigerant Temperature	°C		52.4	51.7	49.9	52.7
LMTD	°C		20.4	18.9	17.1	20.3
UA	W/K		441	510	579	448
NTU	-		0.33	0.50	0.43	0.40
Refrigerant Pressure Drop	kPa		29.2	67.3	7.2	10.8
Airside DP	Pa		29.6	26.7	25.7	26.0
Air Heat Transfer Coefficient (Average)	W/m².K		100.4	117.0	124.8	125.3
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		3528	3833	2999	3458
Subcooling	°C		0.00	0.00	2.67	0.00
Charge	kg		0.56	0.45	0.17	0.10

**Table 32: Unit 10 – HX Analysis for R454B**

<i>Condenser</i>						
<i>Inputs</i>			<i>BTFD7</i>	<i>NTFD5</i>	<i>NMCD2</i>	<i>NMCD2R</i>
Air Dry-Bulb Temperature	°C		46	46	46	46
Relative Humidity	%		16.4	16.4	16.4	16.4
Air Flowrate	m³/s		1.23	0.94	1.23	1.04
Refrigerant Pressure	kPa		3204	3204	3204	3204
Saturation Temperature at Inlet	°C		56	56	56	56
Refrigerant Temperature	°C		100	100	100	100
Mass Flow Rate	kg/s		0.04	0.04	0.04	0.04
<i>Outputs</i>						
Heat Load	W		9634	9953	9901	9597
Air Dry-Bulb Temperature	°C		53.3	55.9	53.8	54.9
Refrigerant Temperature	°C		50.4	46.7	47.3	50.8
LMTD	°C		17.9	10.5	12.7	18.0
UA	W/K		537	952	782	532
NTU	-		0.40	0.93	0.59	0.47
Refrigerant Pressure Drop	kPa		18.8	51.1	5.9	8.7
Airside DP	Pa		29.6	26.7	25.7	26.0
Air Heat Transfer Coefficient (Average)	W/m².K		100.4	117.0	124.8	125.3
Refrigerant Heat Transfer Coefficient (Average)	W/m².K		3095	3211	2633	2942
Subcooling	°C		3.71	6.98	6.98	3.40
Charge	kg		0.78	0.71	0.22	0.14

**Table 33. Unit 10 - Compressor Performance Summary.**

<i>Compressor</i>			Copeland ZP31K5E-PFV	Copeland ZP34K5E-PFV	Copeland ZP31K5E-PFV
<b>Refrigerant</b>		<b>R32</b>	<b>R452B</b>	<b>R447B</b>	<b>R454B</b>
Isentropic Efficiency	-	0.439	0.638	0.662	0.662
Volumetric Efficiency	-		0.760	0.803	0.790
Displacement Volume	cm³		29.350	29.350	29.350
Frequency	Hz	50	50	50	50
Effective Displacement Volume	cm³	19.646	22.301	23.581	23.183







Figure 15. Unit 10 – System Level Analysis: Performance Results for R452B.





Figure 16. Unit 10 – System Level Analysis: Performance Results for R447B.





Figure 17. Unit 10 – System Level Analysis: Performance Results for R454B.

## APPENDIX B – Unit 6 Initial Tests, Scope Change and Test Setup

Unit 6 was initially modified and tested at a separate facility and the test results exhibited a considerably lower cooling capacity than expected (~20%). Power consumption was also greater than designed. The condensing pressures were 20-30% above expectations, and the refrigerant pressure drop across the condenser was at least twice as high as expected. The outlet conditions of the condenser for R32 were possibly in two-phase. The condenser airflow rate was 10%-15% lower than expected. Superheat hardly met the setpoint values.

OTS formulated a hypothesis that the degraded performance was due to the condenser not being fully active; i.e. some regions were not transferring heat. One way for this to happen is by having severe maldistribution thus impeding heat transfer, increasing pressure drop – thus the condensing pressure – and possibly reducing the flow rate as well; all of which were observed in the test data. OTS tested the hypothesis by running hot water through the HX and observing with a thermal camera (Figure 18), which revealed the “dead zones”. Upon inspection by the manufacturer, it was confirmed there were blockages in some of the tubes. A new HX was built, but the same pattern was observed, forcing OTS to remove the condenser replacement from the scope given the project schedule.





Figure 18. Hot Water Thermal Imaging.

Given the challenges with the initial tests and unit modification, the scope was re-defined. The original test plan was changed to accommodate time and resources as appropriate. Table 34 outlines the major changes to the scope. The tests were conducted at the OTS laboratory (Figure 19 to Figure 22). A summary of the key differences between the test setups (original and at OTS) is presented in Table 35.

**Table 34: Test Scope Change.**

Unit	Refrigerant	Test	Original Scope		New Scope	
			Planned	Actual	Planned	Actual
Unit 1	R290	Charge Optimization	Yes	No	No	No
		Performance Tests	Yes	No	No	No
Unit 6	R32 (Baseline)	Charge Optimization	No	No	Yes	Yes
		Performance Tests	No	No	Yes	Yes
	R32 (Modified)	Charge Optimization	Yes	Yes	Yes	Yes
		Performance Tests	Yes	Yes	Yes	Yes
	R454B	Charge Optimization	Yes	Yes	Yes	Yes
		Performance Tests	Yes	Yes	Yes	Yes
Unit 10	R32 (Baseline)	Charge Optimization	No	No	Yes	Yes*
		Performance Tests	No	No	Yes	Yes*
	R447B	Charge Optimization	Yes	No	Yes	Yes
		Performance Tests	Yes	No	Yes	Yes
	R452B	Leak Tests	Yes	No	Yes	Yes
		Charge Optimization	Yes	No	Yes	Yes
	R452B	Performance Tests	Yes	No	Yes	Yes
		Leak Tests	Yes	No	No	No

\* Tests were conducted; however, no useful data was obtained (see section 5.2)



**Figure 19. Test Diagram.**



**Figure 20. OTS Setup: outdoor chamber (left), Unit 10 and frequency converter inside chamber (right).**




Figure 21. OTS Setup: indoor closed loop left side view (left), refrigerant mass flow meter (right).



Figure 22. OTS Setup: indoor closed loop right side view (left), vapor / liquid lines, sight glasses and TXV (right).

**Table 35: List of Measurements.**

Component	Refrigerant Side			Air Side		
	Measurement	Original Scope	New Scope	Measurement	Original Scope	New Scope
Condenser	Inlet Temperature	Yes	Yes	Air Flow Rate	Yes	No
	Inlet Pressure	Yes	Yes	Air Pressure Drop	No	No
	Outlet Temperature	Yes	Yes	Fan Power	No	Yes
	Outlet Pressure	Yes	Yes	Inlet Dry-bulb	Yes	Yes
	Subcooling	Yes*	Yes	Inlet Wet-Bulb / RH	Yes	Yes
				Outlet Dry-bulb	Yes	Yes
Evaporator				Outlet Wet-Bulb / RH	Yes	Yes
	Inlet Temperature	No	No	Air Flow Rate	Yes	Yes
	Inlet Pressure	No	No	Air Pressure Drop	No	Yes**
	Outlet Temperature	Yes	Yes	Blower Power	No	Yes
	Outlet Pressure	Yes	Yes	Inlet Dry-bulb	Yes	Yes
	Superheat	Yes*	Yes	Inlet Wet-Bulb / RH	Yes	Yes
Compressor	Refrigerant Mass Flow Rate	No	Yes	Outlet Dry-bulb	Yes	Yes
				Outlet Wet-Bulb / RH	Yes	Yes
	Suction Temperature	Yes	Yes			
	Suction Pressure	Yes	Yes			
	Discharge Temperature	Yes	Yes			
	Discharge Pressure	Yes	Yes			
Expansion Device	Compressor Power	No	Yes			
	Suction Temperature	Yes	Yes			
	Suction Pressure	Yes	Yes			
	Discharge Temperature	No	No			
	Discharge Pressure	No	No			

**Charge Optimization**

The charge optimization procedure as originally scoped was not implemented due to the following:

- The systems responded less sensitively to charge on subcooling and superheat, which were difficult to control with charging alone. A manual valve was added (Unit 10 exhibited little expansion) such that superheat could be better controlled. The valve also allowed for better control over the pressure levels compared to charge levels alone.
- For the modified systems, the charge was gradually increased, departing from the original charge from PRAHA I tests, until it was observed that the superheat and subcooling better matched design conditions for validation purposes.
- For the refrigerant blends, removing charge could result in fractionation (evaluated as a separate task), so it was decided to only incrementally increase charge, without removing it. For this procedure, a small gradual increment is necessary to avoid overcharging.

**APPENDIX C - Unit 6 Raw and Processed Tested Data**

**Table 36: Unit 6 – Performance Tests**

		Baseline (35°C)	Alternate 1 (35°C)	Alternate 2 (35°C)	Baseline (46°C)	Alternate 1 (46°C)	Alternate 2 (46°C)
<b>Refrigerant</b>	-	<b>R32</b>	<b>R32</b>	<b>R454B</b>	<b>R32</b>	<b>R32</b>	<b>R454B</b>
Charge	lb	3.83	4.27	5.02	3.83	4.27	5.02
Cooling Capacity	BTU/hr	25193	23585	21966	23390	21450	21821
Energy Balance	%	-2.28%	-4.66%	-3.06%	-1.78%	-4.42%	-7.61%
Compressor Power	kW	2.11	1.79	1.77	2.71	2.32	2.25
Fan Power	kW	0.32	0.33	0.33	0.40	0.42	0.42
Total Power	kW	2.43	2.12	2.10	3.10	2.74	2.67
EER	BTU/hr.W	10.36	11.12	10.44	7.54	7.84	8.17
<b>Evaporator</b>							
<b>Airside</b>							
<b>Inlet</b>							
Air Flow Rate	m³/s	0.31	0.31	0.31	0.31	0.31	0.30

		Baseline (35°C)	Alternate 1 (35°C)	Alternate 2 (35°C)	Baseline (46°C)	Alternate 1 (46°C)	Alternate 2 (46°C)
<b>Refrigerant</b>	-	<b>R32</b>	<b>R32</b>	<b>R454B</b>	<b>R32</b>	<b>R32</b>	<b>R454B</b>
Temperature	°C	27.0	27.0	27.0	29.0	29.0	29.0
Wet Bulb	°C	19.68	19.68	19.68	21.33	21.33	21.34
Relative Humidity	%	51.0	51.0	51.0	51.0	51.0	51.0
Humidity Ratio	kg/kg	0.011	0.011	0.011	0.013	0.013	0.013
Density	kg/m <sup>3</sup>	1.15	1.15	1.15	1.14	1.14	1.14
Enthalpy	kJ/kg	56.3	56.2	56.2	61.9	62.0	62.0
Specific Heat	kJ/kg.K	1.0	1.0	1.0	1.0	1.0	1.0
<b>Outlet</b>							
Air Flow Rate	m <sup>3</sup> /s	0.29	0.29	0.29	0.29	0.29	0.29
Temperature	°C	14.3	15.1	15.8	16.9	17.7	18.1
Wet Bulb	°C	14.35	14.35	14.35	14.35	14.35	14.35
Relative Humidity	%	83.6	82.4	80.0	84.5	83.3	81.3
Humidity Ratio	kg/kg	0.008	0.009	0.009	0.010	0.011	0.011
Density	kg/m <sup>3</sup>	1.21	1.20	1.20	1.19	1.19	1.19
Enthalpy	kJ/kg	35.8	37.5	38.5	42.7	44.7	45.0
Specific Heat	kJ/kg.K	1.0	1.0	1.0	1.0	1.0	1.0
<b>Refrigerant Side</b>							
<b>Inlet</b>							
Mass Flow Rate	kg/s	0.030	0.028	0.031	0.032	0.027	0.035
Temperature	°C	4.58	6.19	4.76	7.49	8.33	8.47
Pressure	kPa	939.13	986.90	876.76	1026.70	1053.10	979.34
Quality	-	0.16	0.19	0.20	0.20	0.25	0.27
Enthalpy	kJ/kg	273.64	269.78	268.60	301.30	291.37	289.89
Entropy	kJ/kg.K	1.20	1.25	1.30	1.27	1.32	1.37
<b>Outlet</b>							
Mass Flow Rate	kg/s	0.030	0.028	0.031	0.032	0.027	0.035
Temperature	°C	8.08	9.26	9.46	9.08	13.54	11.80
Pressure	kPa	939	987	877	1027	1053	979
Superheat	K	3.50	3.07	4.89	1.59	5.20	3.58
Enthalpy	kJ/kg	520.49	520.22	473.43	518.52	523.27	472.93
Entropy	kJ/kg.K	2.15	2.15	2.03	2.13	2.15	2.02
<b>HX Level</b>							
Average Cooling Capacity	kW	7.384	6.912	6.438	6.855	6.287	6.395
Energy Balance (Qair - Qref)/Qref	%	-2.28%	-4.66%	-3.06%	-1.78%	-4.42%	-7.61%
Sensible Heat Ratio	-	0.64	0.66	0.65	0.64	0.67	0.66
Superheat	K	3.500	3.066	4.885	1.593	5.205	3.582
LMTD	K	13.783	12.822	14.015	13.985	12.184	13.041
UA	kW/K	0.573	0.539	0.459	0.550	0.516	0.490
Air Pressure Drop	Pa	N/A	N/A	N/A	N/A	N/A	N/A
Refrigerant Pressure Drop	kPa	N/A	N/A	N/A	N/A	N/A	N/A
Fan Power	kW	0.120	0.127	0.134	0.196	0.217	0.217
<b>Condenser</b>							
<b>Airside</b>							
<b>Inlet</b>							
Air Flow Rate	m <sup>3</sup> /s	0.9516	0.9838	1.0091	0.9580	0.9735	1.0613
Temperature	°C	35.01	34.76	35.12	46.06	45.93	46.05
Wet Bulb	°C	20.0	19.8	20.0	27.4	27.3	27.4
Humidity Ratio	kg/kg	0.008	0.008	0.009	0.015	0.015	0.015
Density	kg/m <sup>3</sup>	1.13	1.13	1.13	1.08	1.08	1.08
Enthalpy	kJ/kg	57.0	56.4	57.2	86.2	85.8	86.2
Specific Heat	kJ/kg.K	1.01	1.01	1.01	1.02	1.02	1.02
<b>Outlet</b>							
Air Flow Rate	m <sup>3</sup> /s	0.98	1.01	1.03	0.98	1.00	1.09
Temperature	°C	43.40	42.29	42.08	54.74	53.60	53.19
Wet Bulb	°C	22.4	22.0	22.1	29.3	29.0	29.0
Humidity Ratio	kg/kg	0.008	0.008	0.009	0.015	0.015	0.015
Density	kg/m <sup>3</sup>	1.10	1.10	1.10	1.05	1.05	1.05
Enthalpy	kJ/kg	65.6	64.1	64.3	95.2	93.7	93.6
Specific Heat	kJ/kg.K	1.01	1.01	1.01	1.02	1.02	1.02

		Baseline (35°C)	Alternate 1 (35°C)	Alternate 2 (35°C)	Baseline (46°C)	Alternate 1 (46°C)	Alternate 2 (46°C)
<b>Refrigerant</b>	-	<b>R32</b>	<b>R32</b>	<b>R454B</b>	<b>R32</b>	<b>R32</b>	<b>R454B</b>
<b>Refrigerant Side</b>							
<b>Inlet</b>							
Mass Flow Rate	kg/s	0.030	0.028	0.031	0.032	0.027	0.035
Temperature	°C	89.78	82.73	78.33	109.00	107.24	90.75
Pressure	kPa	2724.15	2643.18	2360.90	3464.77	3365.88	3010.13
Superheat	K	45.9	40.1	35.9	54.7	54.2	38.0
Enthalpy	kJ/kg	580.73	573.07	523.39	594.42	593.52	528.90
Entropy	kJ/kg.K	2.20	2.18	2.08	2.21	2.21	2.07
<b>Outlet</b>							
Mass Flow Rate	kg/s	0.030	0.028	0.031	0.032	0.027	0.035
Temperature	°C	39.17	34.52	34.68	51.79	45.63	45.79
Pressure	kPa	2675.81	2598.75	2310.89	3416.39	3324.50	2958.91
Subcooling	K	4.00	7.44	5.59	1.89	6.84	5.07
Enthalpy	kJ/kg	273.6	264.0	266.4	301.3	287.0	287.8
Entropy	kJ/kg.K	1.24	1.21	1.28	1.33	1.28	1.34
<b>HX Level</b>							
Heat Rejection	kW	9.19	8.53	8.08	9.25	8.31	8.42
Subcooling	K	4.00	7.44	5.59	1.89	6.84	5.07
Refrigerant Pressure Drop	kPa	48.34	44.43	50.01	48.38	41.38	51.22
Fan Power	kW	0.20	0.20	0.20	0.20	0.20	0.20
<b>TXV</b>							
<b>Refrigerant</b>							
<b>Inlet</b>							
		4			4		
Temperature	°C	30.64	37.31	35.83	39.70	47.55	46.78
Pressure	kPa	1991.01	2587.20	2301.38	2528.52	3317.42	2945.62
Subcooling	°C	*(Two-Phase)	4.47	4.27	*(Two-Phase)	4.83	3.88
Enthalpy	kJ/kg	*(Two-Phase)	269.8	268.6	*(Two-Phase)	291.4	289.9
Entropy	kJ/kg.K	*(Two-Phase)	1.233	1.284	*(Two-Phase)	1.299	1.349
<b>Compressor</b>							
<b>Refrigerant</b>							
<b>Inlet</b>							
Mass Flow Rate	kg/s	0.030	0.028	0.031	0.032	0.027	0.035
Temperature	°C	11.57	12.55	12.76	13.81	17.63	13.07
Pressure	kPa	936.06	984.95	874.98	1024.91	1052.17	969.56
Superheat	K	7.09	6.43	8.26	6.38	9.32	5.18
Enthalpy	kJ/kg	524.9	524.4	477.3	524.6	528.3	474.8
Entropy	kJ/kg.K	2.170	2.161	2.048	2.156	2.166	2.028
<b>Outlet</b>							
Mass Flow Rate	kg/s	0.030	0.028	0.031	0.032	0.027	0.035
Temperature	°C	89.8	82.7	78.3	109.0	107.2	90.8
Pressure	kPa	2724.2	2643.2	2360.9	3464.8	3365.9	3010.1
Superheat	K	45.9	40.1	35.9	54.7	54.2	38.0
Enthalpy	kJ/kg	580.7	573.1	523.4	594.4	593.5	528.9
Entropy	kJ/kg.K	2.200	2.183	2.084	2.205	2.207	2.074
<b>Compressor Level</b>							
Power Consumption	kW	2.11	1.79	1.77	2.71	2.32	2.25
Isentropic Efficiency	-	0.80	0.84	0.73	0.74	0.76	0.69
Frequency	Hz	60	60	60	60	60	60

<sup>4</sup> The baseline configuration does not have an expansion valve, the state point herein presented refers to measurement readings at indoor unit inlet.

## APPENDIX D - Unit 10 Baseline Re-Test

Prior to modifying Unit 10, it was tested in its received, baseline condition with the components used to test during PRAHA I. Given the results of the data review in Activity 1, and the challenges experienced in the initial testing of Unit 6, the project team agreed that testing the units in their baseline configuration would be important for more accurate comparison.

The electrical components for Unit 10 have phase mismatch, i.e. the fan and blower are three-phase while the compressor is single-phase, but all operate in 50Hz. OTS does not have a Variable Frequency Drive (VFD) for single-phase motors, requiring the use of a frequency converter to reduce the compressor speed. According to the baseline data from PRAHA 1, the total power consumption of Unit 10 varied between 3.5-4.5kW; OTS has a 5.0kW converter, which should be sufficiently large to meet testing needs.

Initial tests suggested that the compressor peak start current exceeds the converter threshold, causing the latter to trip and shut off. Although the blower and the fan run normally with the converter, the compressor alone does not. The compressor motor was tested at 60Hz direct from the grid and it works, thus confirming that the issue is indeed the peak current. A soft starter was acquired with the objective to mitigate the issue. The soft starter capacitors weren't fast enough to smooth the peak current, however, thus requiring manual charging, which eventually lead to component failure.

The last tentative to run the baseline was connecting the compressor to 60Hz and the fans to 50Hz. The refrigerant mass flow rate was too high impeding full condensation and full evaporation. A manual TXV was added along with two sight glasses in the liquid and vapor lines and reasonable data was obtained for the 35°C ambient temperature condition. While attempting to test the system under the 46°C ambient temperature, the compressor overheats and shuts down. Heavier gauge wire, new contactors and switch bypass were unsuccessfully employed. In the interest of time, the baseline re-tests were discontinued. The analysis will be carried out using the original baseline performance for comparison purposes.

## APPENDIX E - Unit 10 Raw and Processed Tested Data

**Table 37: Unit 10 – Performance Tests.**

		Alternate 1 (35°C)	Alternate 2 (35°C)	Alternate 1 (46°C)	Alternate 2 (46°C)
Refrigerant	-	R447B	R452B	R447B	R452B
Charge	lb	6.625	6.625	6.625	6.625
Cooling Capacity	BTU/hr	32195	28128	31073	30292
Energy Balance	%	7.52%	-3.29%	4.21%	1.21%
Compressor Power	kW	2.67	2.40	3.16	2.93
Fan Power	kW	0.95	0.98	0.95	0.97
Total Power	kW	3.62	3.38	4.11	3.90
EER	BTU/hr.W	8.88	8.33	7.55	7.76
<b>Evaporator</b>					
<b>Airside</b>					
<b>Inlet</b>					
Air Flow Rate	m <sup>3</sup> /s	0.74	0.73	0.74	0.73
Temperature	°C	27.0	27.0	29.0	29.0
Wet Bulb	°C	19.68	19.69	21.33	21.34
Relative Humidity	%	51.0	51.0	51.0	51.0
Humidity Ratio	kg/kg	0.011	0.011	0.013	0.013
Density	kg/m <sup>3</sup>	1.15	1.15	1.14	1.14
Enthalpy	kJ/kg	56.2	56.3	62.0	62.0
Specific Heat	kJ/kg.K	1.0	1.0	1.0	1.0



		Alternate 1 (35°C)	Alternate 2 (35°C)	Alternate 1 (46°C)	Alternate 2 (46°C)
Refrigerant	-	R447B	R452B	R447B	R452B
<b>Outlet</b>					
Air Flow Rate	m³/s	0.72	0.71	0.71	0.70
Temperature	°C	17.4	19.1	19.7	19.8
Wet Bulb	°C	15.80	16.64	17.91	18.06
Relative Humidity	%	85.1	78.5	84.7	84.5
Humidity Ratio	kg/kg	0.011	0.011	0.012	0.012
Density	kg/m³	1.19	1.18	1.18	1.18
Enthalpy	kJ/kg	44.3	46.8	50.7	51.1
Specific Heat	kJ/kg.K	1.0	1.0	1.0	1.0
<b>Refrigerant Side</b>					
<b>Inlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047
Temperature	°C	9.81	5.53	12.90	13.09
Pressure	kPa	996.41	907.20	1085.49	1133.86
Quality	-	0.19	0.19	0.27	0.25
Enthalpy	kJ/kg	272.43	264.74	296.09	288.71
Entropy	kJ/kg.K	1.32	1.30	1.40	1.38
<b>Outlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047
Temperature	°C	15.22	25.20	16.76	23.36
Pressure	kPa	996	907	1085	1134
Superheat	K	5.79	19.82	4.42	10.47
Enthalpy	kJ/kg	477.29	485.20	476.43	477.36
Entropy	kJ/kg.K	2.04	2.09	2.03	2.03
<b>HX Level</b>					
Average Cooling Capacity	kW	9.436	8.244	9.107	8.878
Energy Balance (Qair - Qref)/Qref	%	7.52%	-3.29%	4.21%	1.21%
Sensible Heat Ratio	-	0.81	0.85	0.83	0.87
Superheat	K	5.794	19.818	4.422	10.474
LMTD	K	9.534	5.829	9.222	6.171
UA	kW/K	0.990	1.414	0.988	1.439
Air Pressure Drop	Pa	N/A	N/A	N/A	N/A
Refrigerant Pressure Drop	kPa	N/A	N/A	N/A	N/A
Fan Power	kW	0.502	0.523	0.501	0.519
<b>Condenser</b>					
<b>Airside</b>					
<b>Inlet</b>					
Air Flow Rate	m³/s	1.44	1.50	1.44	1.42
Temperature	°C	35.03	35.08	46.14	46.22
Wet Bulb	°C	20.0	20.0	27.4	27.5
Humidity Ratio	kg/kg	0.008	0.009	0.016	0.016
Density	kg/m³	1.13	1.13	1.08	1.07
Enthalpy	kJ/kg	57.0	57.2	86.5	86.7
Specific Heat	kJ/kg.K	1.01	1.01	1.02	1.02
<b>Outlet</b>					
Air Flow Rate	m³/s	1.47	1.53	1.48	1.45
Temperature	°C	41.90	40.83	53.36	53.26
Wet Bulb	°C	22.0	21.7	29.0	29.1
Humidity Ratio	kg/kg	0.008	0.009	0.016	0.016
Density	kg/m³	1.10	1.11	1.05	1.05
Enthalpy	kJ/kg	64.0	63.0	94.0	94.0
Specific Heat	kJ/kg.K	1.01	1.01	1.02	1.02
		0.00010	0.00038	0.00011	-0.00001
<b>Refrigerant Side</b>					
<b>Inlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047

		Alternate 1 (35°C)	Alternate 2 (35°C)	Alternate 1 (46°C)	Alternate 2 (46°C)
<b>Refrigerant</b>	-	<b>R447B</b>	<b>R452B</b>	<b>R447B</b>	<b>R452B</b>
Temperature	°C	78.84	92.46	93.29	97.45
Pressure	kPa	2493.84	2600.61	3199.13	3357.43
Superheat	K	31.5	46.5	35.3	40.4
Enthalpy	kJ/kg	522.20	532.28	529.64	527.68
Entropy	kJ/kg.K	2.09	2.11	2.08	2.07
<b>Outlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047
Temperature	°C	40.68	35.54	53.44	48.65
Pressure	kPa	2481.63	2599.27	3187.26	3351.92
Subcooling	K	3.37	9.26	1.62	7.33
Enthalpy	kJ/kg	274.8	266.6	300.2	291.9
Entropy	kJ/kg.K	1.32	1.29	1.39	1.37
<b>HX Level</b>					
Heat Rejection	kW	11.39	9.94	11.59	11.10
Energy Balance (Qair - Qref)	kW	N/A	N/A	N/A	N/A
Subcooling	K	3.37	9.26	1.62	7.33
Air Pressure Drop	Pa	-	-	-	-
Refrigerant Pressure Drop	kPa	12.21	1.34	11.87	5.51
Fan Power	kW	0.45	0.45	0.45	0.45
<b>TXV</b>					
<b>Refrigerant Inlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047
Temperature	°C	39.42	34.55	51.55	47.11
Pressure	kPa	2462.98	2583.59	3166.49	3331.97
Subcooling	°C	4.31	9.99	3.21	8.59
Enthalpy	kJ/kg	272.4	264.7	296.1	288.7
Entropy	kJ/kg.K	1.310	1.284	1.382	1.358
<b>Compressor</b>					
<b>Refrigerant Inlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047
Temperature	°C	16.84	26.01	17.17	24.96
Pressure	kPa	993.13	902.34	1082.17	1128.72
Superheat	K	7.52	20.81	4.94	12.23
Enthalpy	kJ/kg	479.3	486.2	477.0	479.4
Entropy	kJ/kg.K	2.052	2.090	2.035	2.042
<b>Outlet</b>					
Mass Flow Rate	kg/s	0.046	0.037	0.051	0.047
Temperature	°C	78.8	92.5	93.3	97.5
Pressure	kPa	2493.8	2600.6	3199.1	3357.4
Superheat	K	31.5	46.5	35.3	40.4
Enthalpy	kJ/kg	522.2	532.3	529.6	527.7
Entropy	kJ/kg.K	2.087	2.112	2.082	2.073
<b>Compressor Level</b>					
Power Consumption	kW	2.67	2.40	3.16	2.93
Isentropic Efficiency	-	0.72	0.83	0.68	0.77
Frequency	Hz	60	60	60	60

Table 38: Unit 10 – R447B Leak Tests

System	Liquid Line Leak			Vapor Line Leak	
	Full Charge	Low Charge	Re-Charged	Low Charge	Re-Charged
Refrigerant	-	R447B	R447B	R447B	R447B
Charge	lb	6.625	4.27	6.625	4.23
					6.77

System		Liquid Line Leak			Vapor Line Leak	
		Full Charge	Low Charge	Re-Charged	Low Charge	Re-Charged
Refrigerant	-	R447B	R447B	R447B	R447B	R447B
Cooling Capacity	BTU/hr	31073	14216	30865	15171	30587
Energy Balance	%	4.21%	-34.72%	0.35%	-31.55%	1.87%
Compressor Power	kW	3.18	2.93	3.18	2.94	-
Fan Power	kW	0.95	0.98	0.98	0.98	0.98
Total Power	kW	4.13	3.90	4.16	3.92	-
EER	BTU/hr.W	7.52	3.64	7.42	3.87	-
<b>Evaporator</b>						
<b>Airside</b>						
<b>Inlet</b>						
Air Flow Rate	m <sup>3</sup> /s	0.74	0.73	0.74	0.73	0.74
Temperature	°C	29.0	29.0	29.0	29.0	29.0
Wet Bulb	°C	21.33	21.34	21.34	21.34	21.34
Relative Humidity	%	51.0	51.0	51.0	51.0	51.0
Humidity Ratio	kg/kg	0.013	0.013	0.013	0.013	0.013
Density	kg/m <sup>3</sup>	1.14	1.14	1.14	1.14	1.14
Enthalpy	kJ/kg	62.0	62.0	62.0	62.0	62.0
Specific Heat	kJ/kg.K	1.0	1.0	1.0	1.0	1.0
<b>Outlet</b>						
Air Flow Rate	m <sup>3</sup> /s	0.71	0.72	0.71	0.72	0.71
Temperature	°C	19.7	23.3	19.6	23.2	19.7
Wet Bulb	°C	17.91	19.87	18.08	19.77	18.05
Relative Humidity	%	84.7	73.1	86.3	73.6	86.0
Humidity Ratio	kg/kg	0.012	0.013	0.012	0.013	0.012
Density	kg/m <sup>3</sup>	1.18	1.16	1.18	1.16	1.18
Enthalpy	kJ/kg	50.7	57.0	51.2	56.7	51.1
Specific Heat	kJ/kg.K	1.0	1.0	1.0	1.0	1.0
<b>Refrigerant Side</b>						
<b>Inlet</b>						
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050
Temperature	°C	12.90	2.61	12.94	2.81	12.75
Pressure	kPa	1085.49	794.22	1086.62	799.23	1080.50
Quality	-	0.27	0.30	0.27	0.30	0.27
Enthalpy	kJ/kg	296.09	291.52	296.48	290.79	296.24
Entropy	kJ/kg.K	1.40	1.40	1.41	1.40	1.41
<b>Outlet</b>						
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050
Temperature	°C	16.76	28.23	17.07	27.95	17.01
Pressure	kPa	1085	794	1087	799	1080
Superheat	K	4.42	26.24	4.70	25.76	4.82
Enthalpy	kJ/kg	476.43	496.65	476.77	496.25	476.88
Entropy	kJ/kg.K	2.03	2.14	2.03	2.13	2.03
<b>HX Level</b>						
Average Cooling Capacity	kW	9.107	4.167	9.046	4.446	8.965
Energy Balance (Qair – Qref)/Qref	%	4.21%	-34.72%	0.35%	-31.55%	1.87%
Sensible Heat Ratio	-	0.83	1.18	0.90	1.12	0.89
Superheat	K	4.422	26.235	4.695	25.756	4.823
LMTD	K	9.222	6.051	9.065	6.501	9.217
UA	kW/K	0.988	0.689	0.998	0.684	0.973
Fan Power	kW	0.501	0.524	0.524	0.524	0.524
<b>Condenser</b>						
<b>Airside</b>						
<b>Inlet</b>						
Air Flow Rate	m <sup>3</sup> /s	1.44	1.49	1.42	1.48	1.42
Temperature	°C	46.14	46.08	46.21	45.77	46.02
Wet Bulb	°C	27.4	27.4	27.5	27.2	27.4
Humidity Ratio	kg/kg	0.016	0.015	0.016	0.015	0.015
Density	kg/m <sup>3</sup>	1.08	1.08	1.07	1.08	1.08
Enthalpy	kJ/kg	86.5	86.3	86.7	85.3	86.1
Specific Heat	kJ/kg.K	1.02	1.02	1.02	1.02	1.02


System			Liquid Line Leak			Vapor Line Leak	
Refrigerant	-	Full Charge R447B	Low Charge R447B	Re-Charged R447B	Low Charge R447B	Re-Charged R447B	
<b>Outlet</b>							
Air Flow Rate	m <sup>3</sup> /s	1.48	1.52	1.46	1.50	1.46	
Temperature	°C	53.36	51.27	53.52	51.05	53.28	
Wet Bulb	°C	29.0	28.6	29.1	28.4	29.0	
Humidity Ratio	kg/kg	0.016	0.015	0.016	0.015	0.015	
Density	kg/m <sup>3</sup>	1.05	1.06	1.05	1.06	1.05	
Enthalpy	kJ/kg	94.0	91.7	94.3	90.8	93.6	
Specific Heat	kJ/kg.K	1.02	1.02	1.02	1.02	1.02	
<b>Refrigerant Side</b>							
<b>Inlet</b>							
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050	
Temperature	°C	93.29	121.77	94.07	120.31	94.34	
Pressure	kPa	3199.13	2846.79	3200.02	2847.47	3175.47	
Superheat	K	35.3	68.9	36.1	67.4	36.7	
Enthalpy	kJ/kg	529.64	569.70	530.67	567.95	531.39	
Entropy	kJ/kg.K	2.08	2.20	2.08	2.20	2.09	
<b>Outlet</b>							
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050	
Temperature	°C	53.44	50.27	53.37	50.13	53.28	
Pressure	kPa	3187.26	2843.00	3188.61	2843.11	3164.31	
Subcooling	K	1.62	-0.33	1.71	-0.19	1.45	
Enthalpy	kJ/kg	300.2	293.2	300.0	293.2	299.9	
Entropy	kJ/kg.K	1.39	1.37	1.39	1.37	1.39	
<b>HX Level</b>							
Heat Rejection	kW	11.59	8.60	11.57	8.69	11.49	
Energy Balance (Qair – Qref)	kW	N/A	N/A	N/A	N/A	N/A	
Subcooling	K	1.62	-0.33	1.71	-0.19	1.45	
Refrigerant Pressure Drop	kPa	11.87	3.79	11.40	4.36	11.16	
Fan Power	kW	0.45	0.45	0.45	0.45	0.45	
<b>TXV</b>							
<b>Refrigerant</b>							
<b>Inlet</b>							
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050	
Temperature	°C	51.55	49.15	51.74	48.80	51.60	
Pressure	kPa	3166.49	2827.45	3168.66	2827.31	3144.31	
Subcooling	°C	3.21	0.54	3.06	0.89	2.84	
Enthalpy	kJ/kg	296.1	291.5	296.5	290.8	296.2	
Entropy	kJ/kg.K	1.382	1.369	1.383	1.366	1.382	
<b>Compressor</b>							
<b>Refrigerant</b>							
<b>Inlet</b>							
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050	
Temperature	°C	17.17	29.26	18.00	28.98	18.47	
Pressure	kPa	1082.17	793.15	1082.65	797.99	1076.58	
Superheat	K	4.94	27.30	5.75	26.83	6.41	
Enthalpy	kJ/kg	477.0	497.7	478.0	497.3	478.8	
Entropy	kJ/kg.K	2.035	2.140	2.038	2.138	2.041	
<b>Outlet</b>							
Mass Flow Rate	kg/s	0.051	0.031	0.050	0.032	0.050	
Temperature	°C	93.3	121.8	94.1	120.3	94.3	
Pressure	kPa	3199.1	2846.8	3200.0	2847.5	3175.5	
Superheat	K	35.3	68.9	36.1	67.4	36.7	
Enthalpy	kJ/kg	529.6	569.7	530.7	568.0	531.4	
Entropy	kJ/kg.K	2.082	2.200	2.085	2.195	2.087	
<b>Compressor Level</b>							
Power Consumption	kW	3.18	2.93	3.18	2.94	0.00	
Isentropic Efficiency	-	0.68	0.68	0.68	0.69	0.68	
Frequency	Hz	60	60	60	60	60	

System		Liquid Line Leak			Vapor Line Leak	
Refrigerant	-	Full Charge	Low Charge	Re-Charged	Low Charge	Re-Charged
		R447B	R447B	R447B	R447B	R447B

## APPENDIX F - Model Verification and Validation

**Table 39: Unit 6 – Model Verification and Validation for Alternative 1 – R32 @ 46°C.**

		Test	Model (Test Conditions)	Relative Difference
Refrigerant Mass Flow Rate	g/s	27	31	14%
Cooling Capacity	BTU/hr	21450	23653	10%
Total Power	kW	2.74	2.67	-2%
EER	BTU/hr.W	7.84	8.86	13%



**Figure 23. Unit 6 – R32 Performance Test Summary P-h and T-s Diagrams.**

**Table 40: Unit 6 – Model Verification and Validation for Alternative 2 – R454B @ 46°C.**

		Test	Model (Test Conditions)	Relative Difference
Refrigerant Mass Flow Rate	g/s	35	36	3%
Cooling Capacity	BTU/hr	21821	22969	5%
Total Power	kW	2.67	2.49	-7%
EER	BTU/hr.W	8.17	9.24	13%




Figure 24. Unit 6 – R454B Performance Test Summary P-h and T-s Diagrams.

Table 41: Unit 10 – Model Verification and Validation for Alternative 1 – R447B @ 46°C.

		Test	Model (Test Conditions)	Relative Difference
Refrigerant Mass Flow Rate	g/s	51	49	-3%
Cooling Capacity	BTU/hr	31169	31026	-0.5%
Total Power	kW	2.70	3.00	11%
EER	BTU/hr.W	11.54	10.34	-10%




Figure 25. Unit 10 – R447B P-h and T-s Diagrams.

Table 42: Unit 10 – Model Verification and Validation for Alternative 2 – R452B @ 46°C.

		Test	Model (Test Conditions)	Relative Difference
Refrigerant Mass Flow Rate	g/s	47	48	2%
Cooling Capacity	BTU/hr	30292	30704	1.4%
Total Power	kW	3.90	3.34	-14%
EER	BTU/hr.W	7.76	9.19	18%





Figure 26. Unit 10 – R452B P-h and T-s Diagrams.

Annex VIII

LIST OF ENTERPRISES WITH REPORTS RELATING TO DECISIONS 84/27 AND 84/42

Country	Agency	Sector	Sub-sector	Name	HCFC	Alternative	Delays due to availability of technology (decision 84/27)	Enterprises experiencing delays/changes in implementation plan (decision 84/42)
Algeria	UNIDO	REF	Air-conditioning	Condor Electronics	HCFC-22	HFC-32	Delay due to higher costs of HFC-32-based units compared to HCFC-22-based units	
Argentina	UNIDO	FOA	Rigid	Friostar	HCFC-141b	Cyclopentane		Delay due to change in agency
Argentina	UNIDO	FOA	Rigid	Argenpur	HCFC-141b	Cyclopentane		Delay due to change in agency
Argentina	UNIDO	FOA	Rigid	Alkanos	HCFC-141b	HFO-based blowing agent		Delay due to change in agency
Argentina	UNIDO	FOA	Rigid	BASF	HCFC-141b	HFO-based blowing agent		Delay due to change in agency
Argentina	UNIDO	FOA	Rigid	Dow	HCFC-141b	HFO-based blowing agent		Delay due to change in agency
Argentina	UNIDO	FOA	Rigid	Ecopur	HCFC-141b	HFO-based blowing agent		Delay due to change in agency
Argentina	UNIDO	FOA	Rigid	Huntsman	HCFC-141b	HFO-based blowing agent		Delay due to change in agency
Argentina	UNIDO	FOA	Rigid	Poliresinas San Luis	HCFC-141b	HFO-based blowing agent		Delay due to change in agency
Argentina	UNIDO	FOA	Rigid	Química del Caucho	HCFC-141b	HFO-based blowing agent		Delay due to change in agency
Argentina	UNIDO	FOA	Polystyrene/polyethylene	Celpak	HCFC-22	Carbon dioxide		Delay due to financial difficulties faced by enterprise
Argentina	UNIDO	FOA	Polystyrene/polyethylene	Perfiles Revestidos	HCFC-22	Carbon dioxide		Delay due to change in agency
Bahrain	UNIDO	REF	Domestic	Awal Gulf Manufacturing Company	HCFC-22	HFC-410A or HFC-407C	Project cancelled; enterprise not inclined to adopt R-290/HFC-32 as R-410A technology is available in favorable commercial terms	
Bangladesh	UNDP	REF	Residential air-conditioning	Walton	HCFC-22	R-290		Delay in signing of project agreement with the Government
Bangladesh	UNDP	REF	Residential air-conditioning	Elite	HCFC-22	R-290		Delay in signing of project agreement with the Government
Bangladesh	UNDP	REF	Residential air-conditioning	AC Bazar	HCFC-22	R-290		Delay in signing of project agreement with the Government



Country	Agency	Sector	Sub-sector	Name	HCFC	Alternative	Delays due to availability of technology (decision 84/27)	Enterprises experiencing delays/changes in implementation plan (decision 84/42)
Bangladesh	UNDP	REF	Residential air-conditioning	Supreme AC	HCFC-22	R-290		Delay in signing of project agreement with the Government
Bangladesh	UNDP	REF	Residential air-conditioning	Unitech Products	HCFC-22	R-290		Delay in signing of project agreement with the Government
Bangladesh	UNDP	REF	Chiller	Cooling Point	HCFC-22	R-290		Delay in signing of project agreement with the Government
Brazil	UNDP	FOA	Rigid	Panisol	HCFC-141b	Methyl formate/HFO		Enterprise not going to be supported as they were not satisfied with the alternative technology and safety issues faced due to location in urban area
Brazil	UNDP	FOA	Systems house	Ecopur (Rodza)	HCFC-141b	HFOs	Delay due to high cost of HFO formulations	
Brazil	UNDP	FOA	Systems house	M.Cassab	HCFC-141b	HFOs	Delay due to high cost of HFO formulations	
Brazil	UNDP	FOA	Systems house	Polisystem	HCFC-141b	HFOs		Enterprise decided not to participate in HPMP due to business reasons
Brazil	UNDP	FOA	Systems house	Shimtek	HCFC-141b	HFOs	Delay due to non-availability of HFOs	
Brazil	UNDP	FOA	Systems house	U-Tech	HCFC-141b	HFOs	Delay due to non-availability of HFOs	
Brazil	UNIDO	REF	Air-conditioning	S.A. ELGIN	HCFC-22	TBD: "alternative fluids": propane, Carbon dioxide and HFOs	Delay as enterprise not inclined to adopt R-290/HFC-32 as R-410A technology is available in favorable commercial terms and R-410A-based equipment have higher energy efficiency	
Brazil	UNIDO	REF	Air-conditioning	GREE	HCFC-22	TBD: "alternative fluids": propane, Carbon dioxide and HFOs	Delay as enterprise not inclined to adopt R-290/HFC-32 as R-410A technology is available in favorable commercial terms and R-410A-based equipment have higher energy efficiency	
Brazil	UNIDO	REF	Air-conditioning	CLIMAZON	HCFC-22	TBD: "alternative fluids": propane, Carbon dioxide and HFOs	Delay as enterprise not inclined to adopt R-290/HFC-32 as R-410A technology is available in favorable commercial terms and R-410A-based equipment have higher energy efficiency	

Country	Agency	Sector	Sub-sector	Name	HCFC	Alternative	Delays due to availability of technology (decision 84/27)	Enterprises experiencing delays/changes in implementation plan (decision 84/42)
Brazil	UNIDO	REF	Commercial	CMR Refrigeração	HCFC-22	TBD: "alternative fluids": propane, Carbon dioxide and HFOs		Change in enterprise due to economic situation in country and financial difficulties for enterprises
Brazil	UNIDO	REF	Commercial	Fermara Refrigeração Indústria e Comércio Ltda	HCFC-22	TBD: "alternative fluids": propane, Carbon dioxide and HFOs		Change in enterprise due to economic situation in country and financial difficulties for enterprises
Brazil	UNIDO	REF	Commercial	Freeart Seral Brasil Metalúrgica Ltda.	HCFC-22	TBD: "alternative fluids": propane, Carbon dioxide and HFOs		Change in enterprise due to economic situation in country and financial difficulties for enterprises
Brazil	UNIDO	REF	Commercial	Polifrio	HCFC-22	TBD: "alternative fluids": propane, Carbon dioxide and HFOs		Change in enterprise due to economic situation in country and financial difficulties for enterprises
Brazil	UNIDO	REF	Commercial	Spacinox	HCFC-22	TBD: "alternative fluids": propane, Carbon dioxide and HFOs		Change in enterprise due to economic situation in country and financial difficulties for enterprises
Chile	UNDP	FOA	Rigid	Superfrigo ingenieria y Refrigeracion Ltda.	HCFC-141b	Different non-ODSs		Delay due to long time taken by enterprise in assessing technology options and review of agreement for project implementation
Chile	UNDP	FOA	Rigid	Ixom group project (6 companies)	HCFC-141b	Different non-ODSs	Delayed due to non-availability and high price of HFOs	
China	UNDP	ICR	Freezers and refrigeration and condensing units	Nanjing TICA	HCFC-22	NH <sub>3</sub> /CO <sub>2</sub>		Delay due to enterprise works relocation
China	UNDP	ICR	Water Chiller (Heat pump)	Dalian Refrigeration	HCFC-22	R-290		Delay due to internal enterprise-level operational delays in project implementation

Country	Agency	Sector	Sub-sector	Name	HCFC	Alternative	Delays due to availability of technology (decision 84/27)	Enterprises experiencing delays/changes in implementation plan (decision 84/42)
China	UNDP	SOL	Metal and Electronics	Guangdong Dechang Micromotor Co., Ltd.	HCFC-141b	HC solvent, Tans-1,2-dichloroethylene		Delay in testing of new alternatives for adoption
China	UNDP	SOL	Metal and Electronics	Dechang Micromotor (Beihai)Co., Ltd.	HCFC-141b	HC solvent, Tans-1,2-dichloroethylene		Delay in testing of new alternatives for adoption
China	UNDP	SOL	Metal and Electronics	Johnson Electric Industrial Manufactory Co., Ltd.	HCFC-141b	HC solvent, Tans-1,2-dichloroethylene		Delay in testing of new alternatives for adoption
China	UNDP	SOL	DMD	Jiangsu Yile Medical Device Co., Ltd.	HCFC-141b	HC diluent/solvent-free silicon		Delay in manufacturing equipment delivery
Colombia	UNDP	FOA	Demonstration	Espumlatex S.A.	HCFC-141b	Different non-ODSs	Delay due to non-availability and high price of HFOs	
Colombia	UNDP	FOA	Polyol production	Olaflex S.A.	HCFC-141b	Different non-ODSs	Delay due to non-availability and high price of HFOs	
Colombia	UNDP	FOA	Polyol production	Química Industrial y Comercial Limitada	HCFC-141b	Different non-ODSs	Delay due to non-availability and high price of HFOs	
Colombia	UNDP	FOA	Polyol production	Espumlatex S.A.	HCFC-141b	Different non-ODSs	Delay due to non-availability and high price of HFOs	
Colombia	UNDP	FOA	Polyol production	G.m.p. productos químicos S.A.	HCFC-141b	Different non-ODSs	Delay due to non-availability and high price of HFOs	
Colombia	UNDP	FOA	Rigid	Espumlatex S.A.	HCFC-141b	Water/carbon dioxide	Delay due to non-availability and high price of HFOs	
Colombia	UNDP	FOA	Rigid	Olaflex S.A.	HCFC-141b	Cyclopentane	Delay due to non-availability and high price of HFOs	
Croatia	UNIDO	FOA	Rigid	Pavusin	HCFC-141b	Pentane		Cancelled project – due to enterprise financial situation
Cuba	UNDP	FOA	Rigid	Friarc	HCFC-141b	Water/carbon dioxide	Delay due to non-availability and high price of HFOs	
Democratic People's Republic of Korea	UNIDO	FOA	Rigid	Pyongyang Sonbong Foam Factory	HCFC-141b	n.a.		Delay due to UN Security Council (UNSC) resolution resulting in inability to implement project

Country	Agency	Sector	Sub-sector	Name	HCFC	Alternative	Delays due to availability of technology (decision 84/27)	Enterprises experiencing delays/changes in implementation plan (decision 84/42)
Democratic People's Republic of Korea	UNIDO	FOA	Rigid	Puhung Building Materials Factory	HCFC-142b	n.a.		Delay due to UNSC resolution resulting in inability to implement project
Egypt	UNIDO	FOA	Rigid	Mondial Freezers Co.	HCFC-141b	Cyclopentane		Delay due political unrest during project implementation period (i.e., around 2011)
Egypt	UNIDO	FOA	Rigid	El Araby Company	HCFC-141b	Cyclopentane		Delay due political unrest during project implementation period (i.e., around 2011)
Egypt	UNIDO	FOA	Rigid	Bahgat	HCFC-141b	Cyclopentane		Commissioning delayed due to COVID-19 outbreak
Egypt	UNIDO	FOA	Rigid	Everest	HCFC-141b	Cyclopentane		Commissioning delayed due to COVID-19 outbreak
Egypt	UNIDO	FOA	Rigid	Fresh	HCFC-141b	Cyclopentane		Commissioning delayed due to COVID-19 outbreak
Egypt	UNIDO	FOA	Rigid	Ocean	HCFC-141b	Cyclopentane		Commissioning delayed due to COVID-19 outbreak
Egypt	UNIDO	FOA	Rigid	Siltal	HCFC-141b	Cyclopentane		Commissioning delayed due to COVID-19 outbreak
Egypt	UNIDO	FOA	Rigid	Star	HCFC-141b	Cyclopentane		Commissioning delayed due to COVID-19 outbreak
Egypt	UNIDO	FOA	Rigid	TopMaker	HCFC-141b	Cyclopentane		Commissioning delayed due to COVID-19 outbreak
Egypt	UNIDO	FOA	Rigid	Tredco	HCFC-141b	Cyclopentane		Commissioning delayed due to COVID-19 outbreak
Indonesia	UNDP	REF	Air-conditioning	PT Gita Mandiri Teknik	HCFC-22	HFC-32	Delay due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Air-conditioning	PT Fata Sarana Makmur	HCFC-22	HFC-32	Delay due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Air-conditioning	PT ITU Airconco	HCFC-22	HFC-32	Delay due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Air-conditioning	PT Metropolitan Bayu Industri	HCFC-22	HFC-32	Delay due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	PT Sumo Elco Mandiri	HCFC-22	HFC-32	Delay due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	PT Rotaryana Prima	HCFC-22	HC-290	Delay due to non-availability and high price of HFC-32-based components	

Country	Agency	Sector	Sub-sector	Name	HCFC	Alternative	Delays due to availability of technology (decision 84/27)	Enterprises experiencing delays/changes in implementation plan (decision 84/42)
Indonesia	UNDP	REF	Commercial	PT Alpine Cool Utama	HCFC-22	HFC-32	Delay due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	PT Anekacool Citratama	HCFC-22	HFC-32	Delay due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	PT Sabindo Refrigeration Technology	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	PT Global Teknik	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	PT Alpin Servis Triutama	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	PT Aneka Froze Triutama	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	PT Graha Cool Technic	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	PT United Refrigeration	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	PT Gaya Teknik Supply	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	PT Ilthabi Mandiri Technic	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Berkat Andijaya Elektrindo	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Cipta Karya Mandiri Insani	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Daikin Aircon	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	

Country	Agency	Sector	Sub-sector	Name	HCFC	Alternative	Delays due to availability of technology (decision 84/27)	Enterprises experiencing delays/changes in implementation plan (decision 84/42)
Indonesia	UNDP	REF	Commercial	Jaya Teknik	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	LG Indonesia	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Maturnuwun Nusantara	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Planet Elektrindo	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Rodamas	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Sarana Aircon Utama	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Sarana Sumber Semesta	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Sekawan Abadi Jaya	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Seltech Utama	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Tata Solusi Pratama	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Trane Indonesia	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Waskita Prima Guna	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	

Country	Agency	Sector	Sub-sector	Name	HCFC	Alternative	Delays due to availability of technology (decision 84/27)	Enterprises experiencing delays/changes in implementation plan (decision 84/42)
Indonesia	UNDP	REF	Commercial	Wira Kusuma Sejahtera	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Airtech Inti	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Jalur Sejuk	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Indo Prima Teknik	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Koronka Nusantara	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	ACR Kapuk	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Jasa Teknik	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Kulkasindo	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Intermas Pacific	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Pagoda Sakti Prima	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Rotaryana Engineering	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Indonesia	UNDP	REF	Commercial	Copel Andalan	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	

Country	Agency	Sector	Sub-sector	Name	HCFC	Alternative	Delays due to availability of technology (decision 84/27)	Enterprises experiencing delays/changes in implementation plan (decision 84/42)
Indonesia	UNDP	REF	Commercial	Tegar Inti Sentosa	HCFC-22	HFC-32	Enterprise withdrew due to non-availability and high price of HFC-32-based components	
Iran (Islamic Republic of)	Germany	FOA	Rigid	Kian Panel Co.	HCFC-141b	Isopentane	Non-availability of suitable raw materials to meet performance standards and equipment supplier delays	
Iran (Islamic Republic of)	Germany	FOA	Rigid	Parlo Co.	HCFC-141b	Isopentane		Delay in obtaining enterprise counterpart funding
Iran (Islamic Republic of)	Germany	FOA	Rigid	Behdor Rangin Co.	HCFC-141b	Equipment modification		Enterprise stopped business operations; project cancelled and funds have been returned to MLF
Iran (Islamic Republic of)	Germany	FOA	INT	Zivar Khodro	HCFC-141b	Water-blown		Delay due to UN sanctions resulting in difficulties in supply of imported equipment for conversion and raw material
Iran (Islamic Republic of)	Germany	FOA	INT	Erish Khodro	HCFC-141b	Water-blown		Delay due to UN sanctions resulting in difficulties in supply of imported equipment for conversion and raw material
Iran (Islamic Republic of)	UNIDO	FOA	Rigid	Emersun	HCFC-141b	Cyclopentane		Delay due to UN sanctions resulting in financial restrictions affecting project implementation
Iran (Islamic Republic of)	UNIDO	FOA	Rigid	Parto Shiva Sanat	HCFC-141b	Cyclopentane		Delay due to UN sanctions resulting in high procurement costs for manufacturing equipment
Iran (Islamic Republic of)	UNIDO	FOA	Rigid	Javaهران Tehran	HCFC-141b	Cyclopentane		Delay due to UN sanctions resulting in high procurement costs for manufacturing equipment
Kuwait	UNIDO	FOA	Rigid	Kirby Building Systems	HCFC-141b	Cyclopentane		Delay due to lengthy process of issuing local regulations for implementing project and non-availability of standards for new product
Kuwait	UNIDO	FOA	Rigid	Kuwait Polyurethane Industry Co.	HCFC-141b	Cyclopentane		Delay due to the lengthy process of issuing local regulations for implementing project and non-availability of standards for new product



Country	Agency	Sector	Sub-sector	Name	HCFC	Alternative	Delays due to availability of technology (decision 84/27)	Enterprises experiencing delays/changes in implementation plan (decision 84/42)
Kuwait	UNIDO	FOA	XPS	Gulf	HCFC-22	Carbon dioxide/DME/HFO		Delay due to the lengthy process of issuing local regulations for implementing project and non-availability of standards for new product
Kuwait	UNIDO	FOA	XPS	Isofoam	HCFC-22	Carbon dioxide/DME/HFO		Delay due to the lengthy process of issuing local regulations for implementing project and non-availability of standards for new product
Lebanon	UNDP	FOA	Rigid	Iceberg S.A.L.	HCFC-141b	HFC-365mfc	Delay due to non-availability of HFOs	
Libya	UNIDO	FOA	Rigid	Al-Najah	HCFC-141b	Cyclopentane		Delay due to security situation in the country
Libya	UNIDO	FOA	Rigid	(Al-Amal Alkhadar) Al Najm	HCFC-141b	Cyclopentane		Delay due to security situation in the country
Libya	UNIDO	FOA	Rigid	Alyem Engineering	HCFC-141b	Cyclopentane		Delay due to security situation in the country
Mexico	UNDP	FOA	XPS	Termofoam	HCFC-142b	HFO-1234ze		Delay due to safety certification and commissioning of equipment
Nigeria	UNDP	FOA	Spray/Panel	Slavit Group	HCFC-141b	Cyclopentane/Methyl formate		Delay in signing of project agreement with the Government
Nigeria	UNDP	FOA	Spray/Panel	Group project with 37 companies	HCFC-141b	Methyl formate		Delay in signing of project agreement with the Government
Nigeria	UNIDO	FOA	Multiple-subsectors	Group project for the conversions of foam manufacturing (75 enterprises)	HCFC-141b	Methyl formate/water		Delay due to financial difficulties faced by the beneficiaries resulting in delays in counter-part funding
Pakistan	UNIDO	FOA	Rigid	Shoaibee Industries	HCFC-141b	Water/carbon dioxide		Delay in finalisation of implementation modalities with enterprise
Pakistan	UNIDO	FOA	Rigid	Full Bright Plastic	HCFC-141b	Water/carbon dioxide		Delay in finalisation of implementation modalities with enterprise
Pakistan	UNIDO	FOA	Rigid	Asif Zubair & Co.,	HCFC-141b	Water/carbon dioxide		Delay in finalisation of implementation modalities with enterprise
Pakistan	UNIDO	FOA	Rigid	Tropical Plastic	HCFC-141b	Water/carbon dioxide		Delay in finalisation of implementation modalities with enterprise
Pakistan	UNIDO	FOA	Rigid	Unique Plastic	HCFC-141b	Water/carbon dioxide		Delay in finalisation of implementation modalities with enterprise

Country	Agency	Sector	Sub-sector	Name	HCFC	Alternative	Delays due to availability of technology (decision 84/27)	Enterprises experiencing delays/changes in implementation plan (decision 84/42)
Pakistan	UNIDO	FOA	Rigid	Delight Plastic	HCFC-141b	Water/carbon dioxide		Delay in finalisation of implementation modalities with enterprise
Pakistan	UNIDO	FOA	Rigid	Decent Plastic	HCFC-141b	Water/carbon dioxide		Delay in finalisation of implementation modalities with enterprise
Pakistan	UNIDO	FOA	Rigid	Informal Sector	HCFC-141b	Water/carbon dioxide		Delay in finalisation of implementation modalities with enterprise
Pakistan	UNIDO	FOA	Rigid	Pakistan Insulation (Pvt.) Ltd.,	HCFC-141b	Cyclopentane		Delay due to questions raised by NOU in assessment of eligibility of enterprise and eligibility of alternative technology
Pakistan	UNIDO	FOA	Rigid	PAECO	HCFC-141b	Cyclopentane		Delay due to questions raised by NOU in assessment of eligibility of enterprise and eligibility of alternative technology
Pakistan	UNIDO	FOA	Rigid	Foster Refrigerators (Pvt.) Ltd.,	HCFC-141b	Cyclopentane		Delay due to questions raised by NOU in assessment of eligibility of enterprise and eligibility of alternative technology
Pakistan	UNIDO	FOA	Rigid	Kold Kraft (Pvt.) Ltd.,	HCFC-141b	Cyclopentane		Delay due to questions raised by NOU in assessment of eligibility of enterprise and eligibility of alternative technology
Pakistan	UNIDO	FOA	Rigid	Informal Sector	HCFC-141b	Cyclopentane		Delay due to questions raised by NOU in assessment of eligibility of enterprise and eligibility of alternative technology
Philippines	UNIDO	REF	Air-conditioning	Panasonic	HCFC-22	HFC-32		Delay due to change of agency from World Bank to UNIDO and change in enterprises' business plans
Philippines	UNIDO	REF	Air-conditioning	Concepcion-Carrier	HCFC-22	HFC-32		Delay due to change of agency from World Bank to UNIDO, change in enterprises' business plans and financial issues faced by the enterprise
Philippines	UNIDO	REF	Air-conditioning	Hitachi	HCFC-22	HFC-32		Delay due to change of agency from World Bank to UNIDO and change in enterprises' business plans
Philippines	UNIDO	REF	Air-conditioning	Koppel	HCFC-22	HFC-32		Delay due to change of agency from World Bank to UNIDO, change in enterprises' business plans and financial issues faced by the enterprise
Qatar	UNIDO	FOA	Polystyrene/polyethylene	Orient Insulation	HCFC-22	Carbon dioxide	Delay due to non-availability of equipment in manufacturing line resulting in delay	

Country	Agency	Sector	Sub-sector	Name	HCFC	Alternative	Delays due to availability of technology (decision 84/27)	Enterprises experiencing delays/changes in implementation plan (decision 84/42)
Sudan	UNIDO	FOA	Rigid	Mina Factory for Electrical and Home Appliances	HCFC-141b	Cyclopentane		Delay in finalisation of implementation modalities with enterprise
Sudan	UNIDO	FOA	Rigid	Target Group Factory for Insulation panels	HCFC-141b	Cyclopentane		Delay in finalisation of implementation modalities with enterprise
Syria Arab Republic	UNIDO	REF	Multiple-subsectors	Al Hafez Group	HCFC-22	HFC-410A		Delay due to security situation in the country
Trinidad and Tobago	UNDP	FOA	Multiple-subsectors	Seal Sprayed Solutions (TT) Ltd.	HCFC-141b	Methyl formate	Delay due to non-availability of methyl formate	
Tunisia	UNIDO	REF	Air-conditioning	Société Afrivision	HCFC-22	Propane (R-290)	Delay due to non-availability of alternative technology using R-290 in commercially attractive terms	
Tunisia	UNIDO	REF	Air-conditioning	Société Electrostar	HCFC-22	Propane (R-290)	Delay due to non-availability of alternative technology using R-290 in commercially attractive terms	
Tunisia	UNIDO	REF	Air-conditioning	Hachicha High World Wide (HHW)	HCFC-22	Propane (R-290)	Delay due to non-availability of alternative technology using R-290 in commercially attractive terms	
Tunisia	UNIDO	REF	Air-conditioning	Société Industrielle Mega	HCFC-22	Propane (R-290)	Delay due to non-availability of alternative technology using R-290 in commercially attractive terms	
Uruguay	UNDP	FOA	Multiple-subsectors	Group project (23 companies)	HCFC-141b	HFO-1234ze	Delay due to non-availability and high price of HFOs	
Zimbabwe	Germany	FOA	Rigid	Ref Air Ltd	HCFC-141b	Cyclopentane		Delay in procurement of raw materials by the enterprise
Zimbabwe	Germany	FOA	Rigid	Capri refrigeration Ltd	HCFC-141b	Cyclopentane		Delay in obtaining enterprise counterpart funding resulting in delays in installation of equipment

**Annex IX**

**DETAILED INFORMATION ON HFC-RELATED INVESTMENT PROJECTS FUNDED  
UNDER ADDITIONAL CONTRIBUTIONS**

<b>Country:</b> Argentina		<b>Agency:</b> UNIDO		<b>Meeting approved:</b> 81 <sup>st</sup>		<b>Status:</b> Ongoing	
<b>Project title and objective:</b> Conversion project for replacement of HFC-134a with isobutane (R-600a)/propane (R-290)-based refrigerant in the manufacture of domestic and commercial refrigeration equipment at Briket, Bambi and Mabe-Kronen							
<b>Sector/application:</b> Domestic and commercial refrigeration							
<b>HFC (s)</b>	<b>Metric tonnes</b>	<b>CO<sub>2</sub> eq mt</b>	<b>Alternatives</b>	<b>Metric tonnes</b>	<b>CO<sub>2</sub> eq mt</b>		
HFC-134a	96.6	138,138	R-600a/R-290	48.28	145		
<b>Funds approved (US \$)</b>		<b>Funds disbursed (US \$)</b>		<b>Date of completion</b>			
1,840,755		1,065,380		December 2020			
<b>Status of implementation:</b> The project started in June 2018. Equipment is on site. Installation at the first company Bambi started in March 2019. All activities have to be suspended due to the COVID-19 pandemic. New appliances have been designed and tested.							
1. Signature of grant agreement (or equivalent) UNIDO does not use grant agreements. After approval of the project in May 2018, UNIDO expert visited the site in June 2018, discussed and agreed with the Government and the enterprise the scope of activities and delineated the Multilateral Fund and counterpart inputs. Based on this, UNIDO prepared the terms of reference (TOR1) and received the counterparts' agreement to it (July 2018). TOR2 were prepared for the assistance and advice in redesign of appliances by a national expert (September 2018); the three counterparts agreed to redesign the equipment under the guidance of a national expert and cover all the related costs.							
2. Status of planning for procurement of equipment The equipment bidding process was initiated in September 2018; bids were received in November 2018 and evaluated by UNIDO and the lowest priced, technically acceptable bid was selected. UNIDO's selection was discussed with the counterparts on the site and some adjustments were made. The purchase order was issued in February 2019; the supplier visited the counterpart to agree on the schedule of work. Minutes of meeting (MoM) were signed between the three counterparts and the supplier on June 2019. The supplier manufactured the equipment and delivered it to the site.							
3. Status of delivery and installation of equipment The equipment was shipped from Europe, passed the customs in November 2019 and delivered to the three counterparts in December 2019. The installation started at Bambi in March 2020 but due to the COVID-19 all activities have been put on hold.							
4. Status of design of products using alternative technology The counterparts have completed the design of the new appliances; additional details will be communicated upon resumption of the project.							
5. Status of commercial production of products using alternative technology Not started yet on account of COVID-19.							
6. Energy efficiency performance The details will be communicated to the Secretariat upon resumption of the project.							
7. Status of implementation of service sector component (as applicable) N/A							
8. Key observations and lessons learnt relating to conversion The details will be communicated upon completion of the project.							

<b>Country:</b> Bangladesh		<b>Agency:</b> UNDP		<b>Meeting approved:</b> 80 <sup>th</sup>		<b>Status:</b> Completed	
<b>Project title and objective:</b> Conversion from HFC-134a to isobutane as refrigerant in manufacturing household refrigerator and of reciprocating compressor of HFC-134a to energy efficient compressor (isobutane) in Walton Hi-Tech Industries Limited							
<b>Sector/application:</b> Domestic refrigeration							
<b>HFC (s)</b>	<b>Metric tonnes</b>	<b>CO<sub>2</sub> eq mt</b>	<b>Alternatives</b>	<b>Metric tonnes</b>	<b>CO<sub>2</sub> eq mt</b>		
HFC-134a	230.63	329,801	R-600a	143	429		
<b>Funds approved (US \$)</b>		<b>Funds disbursed (US \$)</b>		<b>Date of completion</b>			
3,131,610		3,126,415		December 2020			
<b>Status of implementation:</b> The project is completed. For details, please, refer to the final report being submitted separately to the 86 <sup>th</sup> meeting.							
1. Signature of grant agreement (or equivalent) The project document is signed.							
2. Status of planning for procurement of equipment Done.							
3. Status of delivery and installation of equipment Done.							
4. Status of design of products using alternative technology Done.							
5. Status of commercial production of products using alternative technology Final report was submitted separately.							
6. Energy efficiency performance Final report was submitted separately.							
7. Status of implementation of service sector component (as applicable) Final report was submitted separately.							
8. Key observations and lessons learnt relating to conversion							

<b>Country:</b> China		<b>Agency:</b> UNDP		<b>Meeting approved:</b> 82 <sup>nd</sup>		<b>Status:</b> Ongoing	
<b>Project title and objective:</b> Conversion from C5+HFC-245fa to C5+HFOs in a domestic refrigerator manufacturer (Hisense Kelon)							
<b>Sector/application:</b> Domestic refrigeration – insulation foam							
<b>HFC (s)</b>	<b>Metric tonnes</b>	<b>CO<sub>2</sub> eq mt</b>	<b>Alternatives</b>	<b>Metric tonnes</b>	<b>CO<sub>2</sub> eq mt</b>		
Cyclopentane +HFC-245fa	250	257,500	Cyclopentane +HFO-1233zd(E)	750	750		
<b>Funds approved (US \$)</b>		<b>Funds disbursed (US \$)</b>		<b>Date of completion</b>			
1,275,000		380,000		December 2020			
<b>Status of implementation:</b> Project document was signed in April 2019; total budget and work plan was signed in July 2019; the contract between FECO and Hisense-Kelon was signed in August 2019; and on-site verification for the CD line conversion was conducted in November 2019. Up to March 2020, Hisense-Kelon has completed the CD line conversion and started trial production in large scale.							
1. Signature of grant agreement (or equivalent) Project document signed 30 April 2019 by FECO and UNDP; work plan for 2019 and 2020 was agreed and signed between UNDP and FECO on 24 July 2019; and the project agreement between FECO and Hisense-Kelon was signed 8 August 2019							
2. Status of planning for procurement of equipment The planning for procurement related to modification of the seal rings in the pre-mix units, raw material storage tanks and pumps for converting to HFOs took place in August 2019							
3. Status of delivery and installation of equipment The change/modification of the seal rings in the essential equipment took place during August to October 2019.							
4. Status of design of products using alternative technology The capacity of the production manufacturing line is 1.2 million units per year. Details of testing of new blend is given in 5 below.							
5. Status of commercial production of products using alternative technology Hisense-Kelon conducted trial production with cyclopentane/HFOs blend and sent samples for testing in October 2019. FECO contracted experts and undertook on-site visit to the beneficiary in November 2019, where it was reported that the beneficiary had gained the capacity of using the alternative technology for production.							
6. Energy efficiency performance Since the enterprise manufactures various product models, additional time is needed for the energy efficiency performance testing. FECO will follow up on the progress.							
7. Status of implementation of service sector component (as applicable) N/A							
8. Key observations and lessons learnt relating to conversion The conversion required significant investment on equipment modification; besides the change of seal rings of essential equipment, the beneficiary enterprise had to modify the foam machines to enhance the control on metering of raw materials, temperature and other (the counterpart funding will be indicated in a future report). During onsite visits, it was reported that knowledge and experience was gained for other production lines that are not financially supported by the MLF.							

<b>Country:</b> Lebanon		<b>Agency:</b> UNIDO		<b>Meeting approved:</b> 81 <sup>st</sup>		<b>Status:</b> Ongoing	
<b>Project title and objective:</b> Conversion from HFC-134a and R-404A to R-600a and R-290 in domestic refrigeration at Lematic Industries							
<b>Sector/application:</b> Domestic refrigeration							
<b>HFC (s)</b>	<b>Metric tonnes</b>	<b>CO<sub>2</sub> eq mt</b>	<b>Alternatives</b>	<b>Metric tonnes</b>	<b>CO<sub>2</sub> eq mt</b>		
HFC-134a	78.5	112,198	R-600a	33.5	101		
R-404A	34.08	133,662	R-290	6.5	19.5		
<b>Funds approved (US \$)</b>		<b>Funds disbursed (US \$)</b>			<b>Date of completion</b>		
1,053,858		842,975			July 2020		
<b>Status of implementation:</b> The Government endorsed the project for submission in April 2018. The project was approved at the 81 <sup>st</sup> meeting (decision 81/63). The contract with Lematic was signed in December 2018 with an agreed date of completion of 30 December 2019; however, due to the security problems in October 2019, the completion date was extended to July 2020. The conversion is ongoing; procurement equipment and components required for the production line modification is ongoing, all equipment procured from overseas has been received and some items have been installed. While the completion of the project is expected in July 2020, the factory is currently closed due to the COVID-19, and all work is paused until further notice.							
1. Signature of grant agreement (or equivalent) Agreement with the enterprise was signed in December 2018.							
2. Status of planning for procurement of equipment Modifications to the storage and refrigerant supply system to make these explosion-proof by replacing the refrigerant supply pumps, refrigerant charging units, installation of a safety system (i.e., leak detectors, fire-fighting equipment, shut-off valves, pressure sensors, water sprinkler, smoke detectors, and ventilation system); and relevant certifications needed for implementing the project. For the assembly line modifications, the installation of helium charging/recycling unit to complement the existing helium sniffer, safety system that includes the installation of HC sensors and ventilation, ultrasonic welding equipment for sealing of the refrigeration system, hand-held HC leak detector for storage area, and addition of repair area on assembly lines with safe recovery of R-600a/R-290, are needed.							
3. Status of delivery and installation of equipment All equipment procured was delivered to the enterprise in January-February 2020.							
4. Status of design of products using alternative technology As for the product development using the alternative technology, the enterprise made all the necessary engineering and safety design modifications. Once all the equipment are installed the products (domestic refrigerator and freezer) for the different categories will be produced within a period of two weeks.							
5. Status of commercial production of products using alternative technology Same as above							
6. Energy efficiency performance Lematic efforts to switch to more efficient appliances are met by several obstacles, among which the switch to testing their equipment and customizing their laboratory according to the new IEC 62552:2015 standard. The current measurement and testing process at Lematic are done with an international instrument acquisition using data system to record refrigerator temperature, ambient temperature, humidity, voltage, amperage, power, and test period using lab-view. In order to perform the testing following IEC 62552:2015, commercial analyzing software is needed, to communicate with the current testing equipment and produce energy calculations and level rating. UNIDO under the K-CEP global project will support Lematic with this transformation, through the purchase of a technical and software support through the delivery of a software package, offering training, and providing support throughout the process.							
7. Status of implementation of service sector component (as applicable) Lematic have their own crew of servicing workshops and technicians spread all over Lebanon. All the service workshops were equipped with necessary equipment and tools such as recovery machines, vacuum pumps, leak detectors, scales, and recovery cylinders. A team of 15 senior technicians including the technical director from Lematic were trained on dealing with flammable refrigerants, charging, safety, recovery, in the newly established RAC training center in Beirut in September 2019. In February 2020, a training session was conducted by HEAT team (Germany) and OTB Consults (Lebanon) for lab technician on energy efficiency standards and MEPS that are proposed to be established in Lebanon. Additional training on installation and commissioning of the equipment are also planned.							

8. Key observations and lessons learnt relating to conversion

Lematic was keen to move fast in the conversion process mainly by offering their products to the international market. The project helped in building their technical capacities dealing with flammable refrigerants, updating their products to include energy efficiency standards.

The conversion of their products using the alternative technologies including energy efficiency standards led to an increase in their cost of production by 10 per cent. This might lead according to the enterprise to a tough competition with imported products into the local market.

The conversion process time based on BAU could be done in 14-16 months. The cost of the conversion is acceptable without any additional cost from the enterprise.



<b>Country:</b> Mexico		<b>Agency:</b> UNIDO		<b>Meeting approved:</b> 81 <sup>st</sup>		<b>Status:</b> Ongoing	
<b>Project title and objective:</b> Conversion of commercial refrigeration manufacturing in two facilities from the use of HFC-134a and R-404A as the refrigerants to propane (R-290) and isobutane (R-600a) at Imbera							
<b>Sector/application:</b> Commercial refrigeration							
<b>HFC (s)</b>	<b>Metric tonnes</b>	<b>CO<sub>2</sub> eq mt</b>	<b>Alternatives</b>	<b>Metric tonnes</b>	<b>CO<sub>2</sub> eq mt</b>		
HFC-134a	51.73	73,974	R-600a/R-290	28.3	84.9		
R-404A	4.31	16,904	R-290				
<b>Funds approved (US \$)</b>		<b>Funds disbursed (US \$)</b>		<b>Date of completion</b>			
1,018,123		41		December 2020 (depending on the pandemic; UNIDO can provide update at the 86 <sup>th</sup> meeting)			
<b>Status of implementation:</b> The project started in July 2018. As at 20 March 2020, equipment required for the conversion was shipped from Europe in mid February 2020 and expected to arrive to Mexico in March 2020; new appliances have been designed and tested, but all other activities had to be suspended due to the COVID-19 pandemic.							
1. Signature of grant agreement (or equivalent) UNIDO does not use grant agreements. After approval of the project, UNIDO expert visited the site, discussed and agreed with the Government and the enterprise the scope of activities and delineated the Multilateral Fund and counterpart inputs. Based on this, UNIDO prepared TOR and received the counterparts' agreement to it (October 2018). The counterpart agreed to implement all redesign work as counterpart input.							
2. Status of planning for procurement of equipment The equipment bidding process was initiated by UNIDO in November 2018; the bids were received in March 2019 and evaluated by UNIDO, and the lowest priced technically acceptable bid was selected. UNIDO selection was discussed with the counterparts on the site where adjustments were made. UNIDO and the counterpart signed a MoM reflecting their agreement on 24 April 2019. The purchase order was issued in May 2019. The supplier visited the counterpart to agree on the schedule of work. A MoM was signed between the counterpart and the supplier on 31 July 2019. The supplier manufactured the equipment in 2019, but delivery was delayed until March 2020.							
3. Status of delivery and installation of equipment The equipment was shipped from Europe in the second half of February 2020 and arrival to Mexico expected around 20 March 2020.							
4. Status of design of products using alternative technology The counterpart has completed the design of the new appliances. The details will be communicated upon resumption of the project.							
5. Status of commercial production of products using alternative technology This has not started yet due to suspension of the project.							
6. Energy efficiency performance The details will be communicated upon resumption of the project.							
7. Status of implementation of service sector component (as applicable) N/A							
8. Key observations and lessons learnt relating to conversion The details will be communicated upon completion of the project.							

<b>Country:</b> Thailand		<b>Agency:</b> IBRD		<b>Meeting approved:</b> 82 <sup>nd</sup>		<b>Status:</b> Ongoing	
<b>Project title and objective:</b> Conversion from HFC to propane (R-290) and isobutene (R-600a) as a refrigerant in manufacturing commercial refrigeration appliances in Pattana Intercool Co. Ltd.							
<b>Sector / application:</b> Commercial refrigeration							
<b>HFC (s)</b>	<b>Metric tonnes</b>	<b>CO<sub>2</sub> eq mt</b>	<b>Alternatives</b>	<b>Metric tonnes</b>	<b>CO<sub>2</sub> eq mt</b>		
HFC-134a	8.78	12,555	R-600a	3.95	12		
<b>Funds approved (US \$)</b>		<b>Funds disbursed (US \$)</b>			<b>Date of completion</b>		
183,514		Not available; retroactive payment after sub-grant agreement signature			December 2020		
<b>Status of implementation:</b>							
1. Signature of grant agreement (or equivalent) The grant agreement between the Government and the World Bank has been presented to the Cabinet for its approval. Once the grant Agreement is approved, sub-grant agreement with Pattana Intercool will be processed. The company has already completed preparation of a safety plan focusing on occupational health and safety that meets the local authority's requirement. The plan has been reviewed and endorsed by the Bank.							
2. Status of planning for procurement of equipment Pattana Intercool has developed specifications of equipment items to be financed by the Fund and confirmed its counterpart funding. The procurement process started in September 2019. Any expenditures incurred prior to the signing of the grant agreement will be reimbursed by the Bank through the retroactive financing provision agreed earlier by Department of Industrial Works (DIW) and the Bank. Key equipment includes vacuum pumps, charging machine, leak detectors, and safety equipment (ventilation system and sensor alarm system).							
3. Status of delivery and installation of equipment Not all equipment has arrived. Due to COVID-19, the enterprise is not able to estimate when all equipment can be installed yet.							
4. Status of design of products using alternative technology Not yet started.							
5. Status of commercial production of products using alternative technology Not yet started.							
6. Energy efficiency performance Not available.							
7. Status of implementation of service sector component (as applicable) Not applicable.							
8. Key observations and lessons learnt relating to conversion Not yet available.							

**Annex X**

**LIST OF COUNTRIES WITH ENABLING ACTIVITIES FUNDED UNDER ADDITIONAL CONTRIBUTIONS**

<b>Country</b>	<b>Agency</b>	<b>Date approved</b>	<b>Funds approved (US \$)</b>
Afghanistan	UNEP	Jun-2018	150,000
Albania	UNIDO	Nov-2017	94,978
Angola	UNEP	Nov-2017	150,000
Argentina	UNIDO	Jun-2018	250,000
Armenia	UNIDO	Nov-2017	150,000
Bahamas	UNEP	Dec-2018	95,000
Benin	UNEP	Jun-2018	150,000
Bhutan	UNEP	Nov-2017	50,000
Bolivia (Plurinational State of)	UNEP	Dec-2018	150,000
Bosnia and Herzegovina	UNIDO	Nov-2017	95,000
Botswana	UNEP	Jun-2018	150,000
Brunei Darussalam	UNEP	Dec-2018	150,000
Burkina Faso	UNIDO	Nov-2017	150,000
Cambodia	UNEP	Nov-2017	150,000
Cameroon	UNIDO	Nov-2017	150,000
Cabo Verde	UNEP	Dec-2018	95,000
Chad	UNEP	Jun-2018	150,000
Chile	UNIDO	Nov-2017	86,000
Chile	UNDP	Nov-2017	33,000
Chile	UNEP	Nov-2017	31,000
China	UNEP	Nov-2017	85,000
China	UNDP	Nov-2017	165,000
Colombia	UNDP	Nov-2017	250,000
Comoros	UNEP	Jun-2018	50,000
Congo	UNIDO	Nov-2017	150,000
Cook Islands	UNEP	Dec-2018	50,000
Costa Rica	UNDP	Nov-2017	150,000
Cote d'Ivoire	UNEP	Jun-2018	150,000
Democratic Republic of the Congo	UNEP	Jun-2018	150,000
Djibouti	UNEP	Jun-2018	50,000
Dominica	UNEP	Nov-2017	50,000
Dominican Republic	UNEP	Nov-2017	150,000
Ecuador	UNEP	Nov-2017	150,000
Egypt	UNIDO	Jun-2018	105,000
Egypt	UNEP	Jun-2018	145,000
Equatorial Guinea	UNEP	Jun-2018	150,000
Eritrea	UNEP	Nov-2017	95,000
Eswatini	UNEP	Jun-2018	95,000
Ethiopia	UNEP	Jun-2018	95,000
Fiji	UNDP	Nov-2017	150,000
Gabon	UNEP	Nov-2017	150,000
Gambia	UNIDO	Nov-2017	95,000
Georgia	UNEP	Jun-2018	95,000
Ghana	UNEP	Nov-2017	150,000
Grenada	UNIDO	Jun-2018	50,000
Guatemala	UNEP	Nov-2017	150,000
Guinea-Bissau	UNEP	Jun-2018	95,000

<b>Country</b>	<b>Agency</b>	<b>Date approved</b>	<b>Funds approved (US \$)</b>
Guyana	UNEP	Jun-2018	95,000
Honduras	UNEP	Jun-2018	150,000
Indonesia	IBRD	Jun-2018	250,000
Jamaica	UNDP	Nov-2017	150,000
Kenya	UNEP	Jun-2018	150,000
Kiribati	UNEP	Jun-2018	50,000
Kyrgyzstan	UNEP	Nov-2017	95,000
Lao People's Democratic Republic	UNEP	Jun-2018	95,000
Lebanon	UNDP	Nov-2017	150,000
Lesotho	UNEP	Nov-2017	55,000
Lesotho	Italy	Nov-2017	40,000
Liberia	Germany	Nov-2017	95,000
Libya	UNIDO	Jun-2018	150,000
Madagascar	UNEP	Jun-2018	150,000
Malawi	UNEP	Jun-2018	150,000
Malaysia	IBRD	Nov-2017	250,000
Maldives	UNEP	Nov-2017	55,000
Maldives	Italy	Nov-2017	40,000
Mali	UNEP	Jun-2018	150,000
Marshall Islands	UNEP	Jun-2018	50,000
Mauritania	UNEP	Jun-2018	150,000
Mexico	UNIDO	Nov-2017	220,000
Mexico	UNEP	Nov-2017	30,000
Micronesia (Federated States of)	UNEP	Jun-2018	50,000
Mongolia	UNEP	Nov-2017	95,000
Montenegro	UNIDO	Nov-2017	49,973
Morocco	UNIDO	Jun-2018	150,000
Mozambique	UNEP	Jun-2018	150,000
Myanmar	UNEP	Jun-2018	95,000
Namibia	UNEP	Nov-2017	150,000
Nauru	UNEP	Jun-2018	50,000
Nepal	UNEP	Jun-2018	95,000
Nicaragua	UNIDO	Jun-2018	150,000
Niger	UNIDO	Jun-2018	150,000
Nigeria	UNEP	Nov-2017	250,000
Niue	UNEP	Jun-2018	50,000
North Macedonia	UNIDO	Nov-2017	95,000
Palau	UNEP	Nov-2017	50,000
Papua New Guinea	Germany	Nov-2017	95,000
Paraguay	UNDP	Jun-2018	75,000
Paraguay	UNEP	Jun-2018	75,000
Peru	UNDP	Nov-2017	150,000
Philippines	UNIDO	Nov-2017	225,992
Philippines	IBRD	Nov-2017	24,008
Rwanda	UNEP	Nov-2017	55,000
Rwanda	Italy	Nov-2017	40,000
Saint Kitts and Nevis	UNEP	Jun-2018	50,000
Saint Lucia	UNEP	Nov-2017	95,000
Saint Vincent and the Grenadines	UNEP	Nov-2017	50,000
Samoa	UNEP	Jun-2018	50,000
Sao Tome and Principe	UNEP	Jun-2018	95,000
Senegal	UNEP	Nov-2017	150,000
Serbia	UNIDO	Nov-2017	150,000

<b>Country</b>	<b>Agency</b>	<b>Date approved</b>	<b>Funds approved (US \$)</b>
Seychelles	Germany	Nov-2017	95,000
Sierra Leone	UNEP	Jun-2018	95,000
Solomon Islands	UNEP	Jun-2018	95,000
Somalia	UNIDO	Nov-2017	150,000
South Africa	UNIDO	Dec-2018	240,000
South Sudan	UNEP	Jun-2018	95,000
Sri Lanka	UNEP	Jun-2018	150,000
Sudan	UNIDO	Nov-2017	75,000
Sudan	UNEP	Nov-2017	75,000
Suriname	UNEP	Nov-2017	95,000
Syrian Arab Republic	UNEP	May-2019	250,000
Thailand	IBRD	Nov-2017	250,000
Togo	UNEP	Nov-2017	150,000
Tonga	UNEP	Nov-2017	50,000
Trinidad and Tobago	UNDP	Nov-2017	150,000
Tunisia	Italy	Nov-2017	75,000
Tunisia	UNIDO	Nov-2017	75,000
Turkey	UNIDO	Nov-2017	250,000
Turkmenistan	UNEP	Nov-2017	150,000
Tuvalu	UNEP	Jun-2018	50,000
Uganda	UNEP	Jun-2018	50,000
United Republic of Tanzania	UNEP	Jun-2018	95,000
Uruguay	UNIDO	Nov-2017	50,000
Uruguay	UNDP	Nov-2017	100,000
Vanuatu	UNEP	Jun-2018	50,000
Venezuela (Bolivarian Republic of)	UNIDO	Jun-2018	250,000
Viet Nam	UNIDO	Nov-2017	250,000
Zambia	UNEP	Nov-2017	95,000
Zimbabwe	UNEP	Nov-2017	150,000
<b>Total</b>			<b>15,184,951</b>