



**Programme des
Nations Unies pour
l'environnement**

Distr.
GÉNÉRALE

UNEP/OzL.Pro/ExCom/94/33
19 février 2024

FRANÇAIS
ORIGINAL: ANGLAIS

COMITÉ EXÉCUTIF
DU FONDS MULTILATÉRAL AUX FINS
D'APPLICATION DU PROTOCOLE DE MONTRÉAL
Quatre-vingt-quatorzième réunion
Montréal, 27 – 31 mai 2024
Point 9(d) de l'ordre du jour provisoire¹

PROPOSITION DE PROJET : ÉGYPTE

Le présent document comporte les observations et la recommandation du Secrétariat sur la proposition de projet suivante :

Élimination

- Plan de gestion de l'élimination des HCFC (phase II, quatrième tranche)

ONUDI, PNUD, PNUE
et gouvernement de
l'Allemagne

¹ UNEP/OzL.Pro/ExCom/94/1

FICHE D'ÉVALUATION DU PROJET – PROJETS PLURIANNUELS**Égypte**

(I) TITRE DU PROJET	AGENCE	RÉUNION D'APPROBATION	MESURE DE RÉGLEMENTATION
Plan de gestion de l'élimination des HCFC (phase II)	ONUDI (agence principale), PNUD, PNUE, Allemagne	79 ^e	70 % d'élimination d'ici 2025

(II) DERNIÈRES DONNÉES COMMUNIQUÉES EN VERTU DE L'ARTICLE 7 (Annexe C Groupe I)	Année : 2023	236,65 tonnes PAO
---	--------------	-------------------

(III) DERNIÈRES DONNÉES SECTORIELLES DU PROGRAMME DU PAYS (tonnes PAO)							Année : 2023	
Produits chimiques	Aérosol	Mous ses	Lutte contre l'incendie	Réfrigération	Solvants	Agent de transformation	Utilisation en laboratoire	Consommation totale du secteur
				Fabrication	Entretien			
HCFC-22					236,64			236,64
HCFC-124					0,01			0,01

(IV) DONNÉES SUR LA CONSOMMATION (tonnes PAO)				
Consommation de référence 2009-2010 :	386,30	Point de départ des réductions globales durables :		484,61
CONSOMMATION ADMISSIBLE AU FINANCEMENT				
Déjà approuvée :	386,41	Restante :		98,20

(V) PLAN D'ACTIVITÉS ENTÉRINÉ		2024	2025	2026	Total
ONUDI	Élimination des SAO (tonnes PAO)	39,21	1,89	0,00	41,10
	Financement (\$ US)	4 322 172	208 650	0	4 530 822
PNUD	Élimination des SAO (tonnes PAO)	0,00	0,00	0,00	0,00
	Financement (\$ US)	0	0	0	0
PNUE	Élimination des SAO (tonnes PAO)	1,75	1,02	0,00	2,77
	Financement (\$ US)	201 506	118 105	0	319 611
Allemagne	Élimination des SAO (tonnes PAO)	0,00	0,00	0,00	0,00
	Financement (\$ US)	0	0	0	0

(VI) DONNÉES DU PROJET			2017	2018	2019	2020	2021	2022	2023	2024	2025	Total
Limites de consommation du Protocole de Montréal (tonnes PAO)			347,64	347,64	347,64	251,08	251,08	251,08	251,08	251,08	125,54	s.o.
Consommation maximale admissible (tonnes PAO)			347,64	289,70	289,70	251,08	251,08	251,08	241,08*	241,08*	115,54*	s.o.
Financement convenu en principe (\$ US)	ONUDI	Coûts de projet	3 356 641	0	4 668 214	0	4 664 196	0	4 039 413	0	195 000	16 923 464
		Coûts d'appui	234 965	0	326 775	0	326 494	0	282 759	0	13 650	1 184 643
	PNUD	Coûts de projet	1 042 352	0	1 836 750	0	816 620	0	0	0	0	3 695 722
		Coûts d'appui	72 965	0	128 573	0	57 163	0	0	0	0	258 701
	PNUE	Coûts de projet	230 000	0	279 500	0	260 000	0	180 000	0	105 500	1 055 000
		Coûts d'appui	27 480	0	33 394	0	31 064	0	21 506	0	12 605	126 049
	Allemagne	Coûts de projet	0	0	207 300	0	0	0	0	0	0	207 300
		Coûts d'appui	0	0	26 949	0	0	0	0	0	0	26 949
	Financement approuvé par ExCom (\$ US)	Coûts de projet	4 628 993	0	6 991 764	0	5 740 816					17 361 573
		Coûts d'appui	335 410	0	515 691	0	414 721					1 265 822
Total des fonds recommandés aux fins d'approbation lors de la présente réunion (\$ US)	Coûts de projet								2 480 298**			2 480 298**
	Coûts d'appui								182 527**			182 527**

* La consommation totale maximale admissible des substances du Groupe I de l'Annexe C a été réduite de 10 tonnes PAO après approbation à la 84^e réunion d'un plan pour le secteur de la climatisation domestique dans le cadre de la phase II.

** Recommandé à la présente réunion, de noter que l'ONUDI, au nom du gouvernement, soumettrait une demande pour les 1 739 115 \$ US restants, plus coûts d'appui d'agence à hauteur de 121 738 \$ US, lors de la réunion où le pays soumettra la phase I de son plan de mise en œuvre de l'Amendement de Kigali relatif aux HFC ou lors de la 96e réunion, à la première occurrence.

Remarque : l'Accord conclu entre le gouvernement de l'Égypte et le Comité exécutif a été révisé lors de la 84^e réunion.

Recommandation du Secrétariat :	Pour examen individuel
---------------------------------	------------------------

DESCRIPTION DU PROJET

1. Au nom du gouvernement de l'Égypte, l'ONUDI, en sa qualité d'agence d'exécution principale, a présenté une demande de financement de la quatrième tranche de la phase II du plan de gestion de l'élimination des HCFC (PGEH), pour un montant total de 4 523 678 \$ US, comprenant 4 039 413 \$ US, plus les coûts d'appui d'agence à hauteur de 282 759 \$ US pour l'ONUDI, et 180 000 \$ US, plus les coûts d'appui d'agence à hauteur de 21 506 \$ US pour le PNUE.² La proposition comprend un rapport périodique sur la mise en œuvre de la troisième tranche, le rapport de vérification de la consommation de HCFC pour la période 2021-2023 et le plan de mise en œuvre de la tranche pour 2024-2026.

Rapport sur la consommation de HCFC

2. Le gouvernement de l'Égypte a déclaré une consommation de 236,65 tonnes PAO de HCFC en 2023, quantité de 39 pour cent inférieure à la valeur de référence des HCFC aux fins de conformité. La consommation de HCFC pour la période 2019-2023 est indiquée au tableau 1.

Tableau 1. Consommation de HCFC en Égypte (2019-2023, données au titre de l'article 7)

HCFC	2019	2020	2021	2022	2023	Valeur de référence
Tonnes métriques (tm)						
HCFC-22	4 083,33	4 481,91	3 759,59	3 244,76	4 302,55	4 367,16
HCFC-123	3,75	0,00	7,75	2,50	0,00	5,25
HCFC-124	0,00	0,00	0,34	0,00	0,54	0,00
HCFC-141b	547,62	0,00	0,00	0,00	0,00	1 178,26
HCFC-142b	52,37	52,93	34,13	18,37	0,00	251,69
Total (tm)	4 687,07	4 534,84	3 801,81	3 265,63	4 303,09	5 802,36
HCFC-141b importés sous forme de polyols prémélangés*	0,00	0,00	0,00	0,00	0,00	894,00**
Tonnes PAO						
HCFC-22	224,58	246,51	206,78	178,46	236,64	240,19
HCFC-123	0,08	0,00	0,16	0,05	0,00	0,11
HCFC-124	0,00	0,00	0,01	0,00	0,01	0,00
HCFC-141b	60,24	0,00	0,00	0,00	0,00	129,61
HCFC-142b	3,40	3,44	2,22	1,19	0,00	16,36
Total (tonnes PAO)	288,30	249,95	209,16	179,71	236,65	386,27
HCFC-141b importés sous forme de polyols prémélangés*	0,00	0,00	0,00	0,00	0,00	98,34**

* Données du programme du pays.

** Consommation moyenne entre 2007 et 2009.

3. En 2023, le HCFC-22 consommé l'a été uniquement dans l'entretien d'équipements de réfrigération et de climatisation existants ; l'augmentation de consommation d'entretien en 2023 est discutée plus en détail au paragraphe 24 ci-dessous. Avec le soutien aux conversions entreprises dans le cadre de ce projet, le pays a éliminé sa consommation de HCFC-22 dans la fabrication d'équipements de réfrigération et de climatisation et dans la fabrication de mousse de polystyrène extrudé. Le HCFC-142b, qui était utilisé comme agent d'expansion combiné au HCFC-22 dans la fabrication de mousse de polystyrène extrudé, a été éliminé de la même manière, conformément à l'interdiction datant du 1^{er} janvier 2023 d'utiliser des HCFC dans la fabrication de mousse de polystyrène extrudé. L'importation et la fabrication d'équipements utilisant des HCFC ont été interdites le 1^{er} janvier 2023, les importations de R-406A le 1^{er} janvier 2023, celles de HCFC-141b le 1^{er} janvier 2020 et celles de HCFC-141b contenu dans

² Selon la lettre du 2 février 2024 du Ministère de l'environnement de l'Égypte adressée à l'ONUDI.

les polyols prémélangés, le 1^{er} janvier 2018. De petites quantités de HCFC-123 et de HCFC-124 sont utilisées de manière intermittente dans l'entretien des équipements de réfrigération et de climatisation.

Rapport de mise en œuvre du programme du pays

4. Le gouvernement de l'Égypte a communiqué des données sur la consommation sectorielle de HCFC dans le cadre du rapport sur la mise en œuvre du programme de pays de 2023 qui correspondent aux données déclarées en vertu de l'article 7 du Protocole de Montréal.

Rapport de vérification

5. Le rapport de vérification a confirmé que le Gouvernement met en œuvre un système d'octroi de licences et de quotas des importations et des exportations de HCFC, et que la consommation totale de HCFC déclarée au titre de l'article 7 du Protocole de Montréal de 2021 à 2022 et au titre du rapport de mise en œuvre du programme du pays de 2023 était correcte (comme indiqué dans le tableau 1 plus haut). La vérification a conclu que l'Égypte était en conformité avec la consommation maximale admissible pour 2021-2023 de toutes les substances du Groupe I de l'Annexe C, conformément à son Accord avec le Comité exécutif.

Rapport périodique de la mise en œuvre de la troisième tranche de la phase II du plan de gestion de l'élimination des HCFC

Cadre juridique

6. En date du 1^{er} janvier 2023, le pays a mis en vigueur l'interdiction d'importer et de fabriquer des équipements utilisant du HCFC-22 ; d'utiliser des HCFC et des mélanges de HCFC pour la fabrication de mousse de polystyrène extrudé ; d'importer du R-406A et d'importer du HCFC-142b. Les importations de HCFC-141b ont été interdites le 1^{er} janvier 2020 et celles de HCFC-141b contenu dans les polyols prémélangés, le 1^{er} janvier 2018. Le gouvernement de l'Égypte a ratifié l'Amendement de Kigali le 22 août 2023. En 2022, le Gouvernement a amendé les tarifs douaniers d'importations pour exempter les frigorigènes à faible potentiel de réchauffement planétaire (PRP) (notamment le HFC-32, le R-290, le R-600a, le R-717 et le R-744) de la taxe de 5 pour cent appliquée au HCFC-22, aux HFC et aux mélanges de HFC.

Activités dans le secteur de la fabrication

Secteur de la fabrication des mousse de polystyrène extrudé

7. La phase II comprenait la conversion de quatre fabricants de mousse de polystyrène extrudé (CMB, Insutech, Chema-Foam et Modern Plastics) dont la consommation totale de HCFC-22 était de 559,0 tm et celle de HCFC-142b était de 24,3 tm à un mélange à 60/40 de HFO-1234ze et d'éther diméthyle. L'équipement pour les quatre fabricants a été livré et installé et les inspections de sécurité ont été entamées. Ces conversions ont été réalisées et un mémorandum d'accord a été finalisé afin de permettre le paiement des surcoûts d'exploitation, d'ici décembre 2024.

Secteur de la fabrication des mousse de polyuréthane

8. La phase II comprenait l'élimination du HCFC-141b par le biais de la conversion des entreprises restantes du secteur de la fabrication des mousse de polyuréthane (PU), notamment la conversion au cyclopentane de huit entreprises de fabrication de réfrigérateurs domestiques afin d'éliminer 372,5 tm de HCFC-141b ; de deux entreprises de fabrication de chauffe-eau électriques afin d'éliminer 50,0 tm de HCFC-141b au cyclopentane ; et un projet groupé afin de remplacer 114,4 tm de HCFC-141b utilisé par 38 petites et moyennes entreprises (PME) par du formate de méthyle. Ces conversions ont été réalisées à

l'exception de celle d'une entreprise, Bahgat.

9. Lors la 92^e réunion, l'ONUDI a déclaré³ que Bahgat s'était retiré du projet et avait quitté le secteur de la fabrication d'équipements de réfrigération domestique en raison des fluctuations du marché dues à la pandémie de COVID-19. Comme l'ONUDI avait déjà acheté et livré l'équipement pour convertir cette entreprise, conformément à la décision 79/34(e), l'ONUDI a recherché une autre entreprise qui pourrait utiliser cet équipement plutôt que d'essayer de le mettre aux enchères. Bien que l'ONUDI n'ait pas été en mesure de trouver une entreprise pour laquelle le financement n'avait pas déjà été demandé, Tredco, une entreprise éligible qui participait à la phase II du PGEH, a souhaité acquérir la ligne de production existante chez Bahgat et utiliser l'équipement fourni par l'ONUDI afin de convertir la ligne en la déplaçant dans ses propres installations. Par conséquent, l'ONUDI a proposé de fournir à Tredco l'équipement et d'utiliser le solde restant du projet de fabrication des mousses de polyuréthane (7 214 \$ US) pour le transport de l'équipement de Bahgat à Tredco, toute étude d'ingénierie nécessaire, et pour détruire/rendre inutilisable la machine de production de mousse utilisant du HCFC-141b. De façon exceptionnelle, le Comité exécutif a approuvé cette demande (décision 92/12).

10. Ultérieurement, l'ONUDI a déclaré que les deux entreprises Bahgat et Tredco n'avaient pas réussi à se mettre d'accord sur les termes de transfert de l'équipement et a demandé au Secrétariat si elle pouvait inviter un autre fabricant de mousses de polyuréthane, Siltal, à acheter la ligne de fabrication existante de Bahgat, afin que Siltal puisse, avec le soutien de l'ONUDI, convertir la ligne au cyclopentane. De façon exceptionnelle, et sachant que l'objectif de ce changement de bénéficiaire lors de la 92^e et de la présente réunion restait identique, à savoir, garantir que l'équipement fourni par le Fonds multilatéral n'aurait pas besoin d'être vendu aux enchères, mais pourrait à la place être utilisé pour assister une entreprise éligible à convertir une capacité éligible de HCFC au cyclopentane, le Secrétariat a conseillé à l'ONUDI de procéder au changement de bénéficiaire, étant entendu que Siltal remplissait les mêmes conditions que Tredco lors de la 92^e réunion, à savoir, (a) que Siltal devrait autrement acheter ce même type d'équipement, (b) que les spécifications de l'équipement existant soient conformes aux besoins de Siltal de façon à ce que l'entreprise puisse rapidement utiliser l'équipement une fois les travaux nécessaires de génie civil effectués, (c) que le solde restant (7 214 \$ US) ne serait pas utilisé pour les travaux de génie civil, mais que ces éventuels coûts soient pris en charge par Siltal et (d) que le solde restant soit utilisé uniquement pour le transport de l'équipement, toute étude d'ingénierie nécessaire et pour détruire/rendre inutilisable la machine existante de production de mousse utilisant du HCFC-141b.

11. Les entreprises Siltal et Bahgat ont conclu un accord pour le transfert de l'équipement. Au moment de la finalisation du présent document, l'ONUDI était en train de prendre les dispositions nécessaires avec le fournisseur de la technologie et les entreprises afin de mener à bien le transfert et l'installation.

Secteur de la fabrication des appareils de climatisation résidentiels

12. La phase II comprenait la conversion de cinq entreprises de fabrication de climatiseurs résidentiels (El-Araby, Fresh, Miraco, Power et Unionaire) (pour une consommation totale de 1 189,78 tm de HCFC-22) au HFC-32 et, si les entreprises le décidaient une fois la technologie disponible, au R-454B (décision 84/72(b)). Les équipements destinés à El-Araby, Fresh, Power et Unionaire ont été livrés et installés, et la mise en route a été réalisée dans toutes les entreprises sauf Power. L'équipement pour Miraco a été fourni, mais, en raison de délais d'importation de l'équipement, n'a pas encore été livré ; la livraison et l'installation devraient être terminées d'ici décembre 2024.

13. Conformément à la décision 88/70(a)(ii), l'ONUDI a fourni une version révisée du calendrier du Gouvernement pour la transition des entreprises de fabrication d'équipements de climatisation à la fabrication exclusive d'équipement à faible PRP pour le marché local. Comme proposé lors de la 88^e réunion, le Gouvernement exigera que les cinq fabricants produisent exclusivement des équipements

³ Paragraphes 31 à 36 du document UNEP/OzL.Pro/ExCom/92/9.

de climatisation résidentielle au HFC-32 pour le marché local d'ici le 1^{er} janvier 2028. Cependant, en vue d'établir un calendrier plus rapide que celui indiqué au Tableau 3 du document UNEP/OzL.Pro/ExCom/88/47, le Gouvernement demanderait aux entreprises de fabriquer exclusivement des équipements de climatisation résidentielle au HFC-32 pour le marché local d'ici le 31 décembre 2026 de façon à être éligible pour recevoir les surcoûts d'exploitation. Par conséquent, l'ONUDI a signé des contrats pour le décaissement des surcoûts d'exploitation conformément au calendrier pour El-Araby et Fresh ; Unionaire a accepté d'avancer son calendrier dans son contrat de surcoûts d'exploitation (à savoir, au 1^{er} janvier 2025). Le contrat avec Power devait être signé au troisième trimestre 2024 ; comme Unionaire, l'entreprise a accepté d'avancer son calendrier pour fabriquer exclusivement des équipements de climatisation résidentielle au HFC-32 pour le marché local d'ici le 1^{er} janvier 2025. En raison des délais de conversion pour Miraco, un contrat de surcoûts d'exploitation pour cette entreprise n'a pas encore été développé.

14. Conformément à la décision 88/70(a)(ii), l'ONUDI a aussi soumis les résultats de ses études d'évaluation des risques et d'étude de marché concernant le secteur de la fabrication d'équipements de climatisation résidentielle ; ces rapports sont annexés au présent document. L'évaluation des risques a conclu, entre autres, que pour les scénarios considérés, la probabilité qu'une source d'inflammation soit présente en conjonction avec une fuite de frigorigène HFC-32 à concentration inflammable était de 10⁻⁹ (« extrêmement difficile ») dans toutes les catégories de sévérité, et donc que le risque associé à l'utilisation d'équipements de climatisation utilisant du HFC-32 est considéré comme acceptable. Les principales conclusions de l'étude de pénétration sur le marché étaient entre autres que le rendement énergétique était une priorité importante pour les consommateurs ; que la disponibilité de services après-vente robustes serait importante afin de garantir la pénétration sur le marché d'équipements de climatisation résidentielle au HFC-32 ; que les consommateurs sont prêts à accepter une hausse de prix modeste de 5 pour cent des climatiseurs pour leurs spécifications respectueuses de l'environnement ; que les plateformes de médias numériques étaient recommandées comme canal de communication primaire afin de transmettre les bénéfices des climatiseurs respectueux de l'environnement et d'intéresser les consommateurs.

Secteur de la fabrication des appareils de climatisation commerciale

15. La phase II comprenait l'assistance technique pour la conversion de trois entreprises (EGAT, Volta et Delta Construction and Manufacturing (DCM)) qui fabriquent des équipements de climatisation centrale pour une utilisation commerciale légère et résidentielle (approximativement inférieure à 144 000 BTU/h (12 tonnes de réfrigération (TR)) à des solutions de remplacement à faible PRP et, pour des systèmes de plus grande capacité, à une combinaison de solutions de remplacement à faible PRP et de refroidissement par évaporation indirecte (IEC), résultant en une unité hybride détente directe-évaporation indirecte (IEC-H). Lors de la 88^e réunion, l'ONUDI a déclaré que durant les consultations avec les parties prenantes, trois fabricants de climatiseurs commerciaux supplémentaires (Tiba Engineering Industries, Misr Engineering and Industries et Miraco-Carrier)⁴ avaient exprimé de l'intérêt pour participer au projet ; après des consultations avec le Secrétariat, des lettres confirmant leur participation, comprenant l'engagement à s'assurer que l'équipement serait converti uniquement à des solutions de remplacement à faible PRP pour la composante à détente directe, ont été reçues.

16. L'ONUDI a soumis un rapport sur le bilan de l'assistance technique fournie aux entreprises de climatisation commerciale qui a, entre autres, conclu que les performances du système hybride détente directe-évaporation indirecte (IEC-H) dépassaient celles des systèmes à détente directe. Des tests sur les prototypes ont été entrepris dans deux zones climatiques représentatives du Caire, du delta du Nil et de la côte est en été. Une analyse économique a montré des économies nettes réalisées sur les unités hybrides

⁴ La participation de ces entreprises supplémentaires ne coûterait rien de plus au Fonds multilatéral, et aucun financement ne serait directement octroyé aux entreprises au titre de cette activité d'assistance technique ; leur participation facilitera l'adoption de la technologie à faible PRP sur le marché, contribuant ainsi à la pérennité de l'activité.

ICE-H en raison de leur consommation électrique réduite par rapport à une unité à détente directe après avoir pris en compte les coûts initiaux plus élevés pour les unités hybrides et leurs coûts en eau plus élevés aussi. Le seuil de rentabilité pour cette unité était atteint en 3,11 ans. Le rapport est annexé au présent document.

17. Dans le cadre de sa campagne de sensibilisation aux équipements de climatisation commerciale à faible PRP et bon rendement énergétique, les unités hybrides IEC-H fabriquées par les entreprises ont été exposées lors de la 15^e Conférence internationale sur les constructions durables et les avancées en nanotechnologies dans le domaine de la protection incendie, de la réfrigération et climatisation et de l'environnement de la construction qui s'est tenue au Caire les 2 et 3 mars 2024. Cette exposition comprenait aussi une unité hybride IEC-H fabriquée par une septième entreprise, Sustainable Air Technology, qui a découvert cette technologie grâce au projet. Quatre entreprises (DCM, Volta, Tiba Engineering Industries, Misr Engineering and Industries) offrent désormais des unités hybrides IEC-H dans leur catalogue de production usuelle.

Secteur de l'entretien de l'équipement de réfrigération

18. Les activités suivantes ont été mises en œuvre dans le cadre de la troisième tranche :

- (a) Des formations ont été dispensées à 115 agents des douanes et importateurs (dont 19 femmes) traitant des frigorifices illégaux et frauduleux ; du programme de surveillance du marché des frigorifices et de la mise en œuvre des interdictions au 1^{er} janvier 2023 ; de plus, 375 techniciens (dont 150 techniciennes) ont été formés aux bonnes pratiques d'entretien des équipements de réfrigération et de climatisation ;
- (b) Une formation aux achats écologiques a été dispensée à 471 fonctionnaires et consultants (dont 87 femmes) dans le cadre de la formation sur la mise en vigueur du code de la réfrigération ; une autre formation est prévue en mai 2024 ;
- (c) De l'équipement a été fourni à huit centres de formation (unités de récupération, pompes à vide, jeux de pinces Lokring, détecteurs de fuites, manomètres à 4 voies et outils d'entretien) ; et
- (d) Des kits d'outils d'entretien et des équipements ont été livrés aux sept centres de formation.⁵

19. Les activités suivantes ont été retardées et sont à divers stades de mise en œuvre :

- (a) Les outils réglementaires et institutionnels afin de faire appliquer le programme de certification sont encore en cours de conception et la formation et la sensibilisation aux normes et aux codes locaux n'ont pas encore eu lieu ;
- (b) Le programme pilote de certification des techniciens a été lancé par le biais d'un contrat de certification des techniciens après-vente ; le premier lot de techniciens n'a pas encore été certifié. Les 167 kits d'outils précédemment fournis (à savoir, unité de récupération, bonbonne, pompe à vide, ensemble d'outils d'entretien) doivent toujours être distribués aux ateliers d'entretien comprenant des techniciens certifiés ;
- (c) Quatre codes nationaux sont en cours de révision, les révisions au code relatives au réseau de froid urbain sont terminées ; les révisions relatives au refroidissement durable dans les

⁵ Comportant des unités de récupération, des jeux de pinces Lokring, des appareils pédagogiques avec différents frigorifices, des outils d'entretien et des consommables.

nouvelles communautés urbaines sont presque terminées,⁶ les révisions relatives au chauffage, à la ventilation et à la climatisation ont été entamées ; et les révisions relatives à la chaîne du froid ont été entamées ;

- (d) Deux cents kits d'appareils (à savoir, des machines de récupération, des pompes à vide et manomètres, des manomètres de haute précision, des bonbonnes, des thermomètres) ont été achetés pour les centres pilotes de récupération et de régénération de frigorigènes ; ces kits d'appareils seront distribués aux ateliers afin de collecter les substances réglementées pour leur régénération au centre qui a été établi. Le centre de régénération est en attente de finalisation d'un permis de travail, celui-ci devrait être accordé d'ici le 31 mai 2024, avant la réception des frigorigènes récupérés et le début de la régénération ; l'objectif de récupération d'au moins 80 tm et de régénération d'au moins 56 tm de frigorigène devrait être atteint d'ici juin 2026 ;
- (e) Une évaluation des équipements nécessaires au réseau de services après-vente en climatisation a été réalisée et un contrat a été signé avec un expert en sécurité afin de conseiller sur les mesures de sécurité nécessaires pour les centres du réseau de services après-vente, avec la fourniture de kits d'outils d'entretien portables pour les équipes de terrain et les outils de soutien aux centres d'après-vente n'ont pas encore été finalisés ;
- (f) Le programme d'endiguement et de prévention des fuites de frigorigènes a été mis en œuvre, et se concentre sur les gros équipements de réfrigération et de climatisation ; et l'inspection et la certification pilote d'un ou deux bâtiments devraient avoir lieu d'ici décembre 2024.
- (g) La livraison d'équipement à l'institut de formation qui a été sélectionné pour accueillir le centre d'excellence en matière de frigorigènes inflammables, prévue d'ici mars 2022, a été retardée ; le matériel pédagogique a été préparé et le centre devrait être opérationnel après la livraison des équipements ;
- (h) Le projet de guide des bonnes pratiques d'entretien pour les programmes de formation, prévu pour décembre 2022 ; a été préparé, mais il est toujours en cours de révision et de commentaire ; et
- (i) Le développement d'un système de suivi des frigorigènes basé sur des codes QR pour les bonbonnes de frigorigène a été entamé, mais n'est pas terminé ; les codes QR pour les bonbonnes de frigorigène devraient devenir obligatoires d'ici 2026.

20. Les activités suivantes n'ont pas commencé :

- (a) Les activités relatives au programme de formation sur site aux bonnes pratiques d'entretien pour les petits ateliers employant un ou deux techniciens et consommant deux à trois bonbonnes de frigorigène par mois n'ont pas commencé ; Entre 150 et 200 techniciens devaient être formés et recevoir un certificat de participation. Ces formations seront supplémentées par des formations supplémentaires aux petits ateliers dans le cadre de la quatrième tranche ; et
- (b) L'Égypte a décidé d'introduire le Permis de conduire les frigorigènes (RDL) en tant que

⁶ Comme souligné par le Ministère de la coopération internationale, les nouvelles villes du pays seront établies dans le cadre du programme de villes intelligentes, qui seront alimentées par des énergies renouvelables et des technologies intelligentes, des infrastructures durables et écologiques et connectées à des réseaux de transport multimodaux (<https://sponsored.bloomberg.com/article/ministry-of-international-cooperation/egypts-new-cities> ; consulté le 10 avril 2024).

programme national de certification parallèle dont le lancement du pilote était prévu pour 2022 ; le pays poursuivra son programme de certification des services après-vente et pourrait introduire le RDL en 2029.

Mise en œuvre et suivi des projets

21. L'unité de mise en œuvre et de supervision du projet (PMU) coordonne et supervise la mise en œuvre du PGEH, dont les visites des bénéficiaires et des parties prenantes, l'organisation d'ateliers et de réunions, et la préparation des rapports pertinents. Les décaissements dans le cadre de l'unité de mise en œuvre et de supervision du projet pour la troisième tranche s'élèvent à 125 702 \$ US (sur les 245 000 \$ US alloués), comprenant les coûts opérationnels et de personnel (86 880 \$ US), de consultants (13 822 \$ US), de soutien aux conversions dans le secteur de la climatisation domestique (10 000 \$ US), et les imprévus (15 000 \$ US).

Niveau de décaissement des fonds

22. En date de mars 2024, sur le montant de 17 361 573 \$ US approuvé jusqu'ici, 10 815 162 \$ US ont été décaissés (7 236 700 \$ US pour l'ONUDI, 2 639 762 \$ US pour le PNUD, 731 400 \$ US pour le PNUE et 207 300 \$ US pour l'Allemagne), comme l'indique le Tableau 2. Le solde qui s'élève à 6 546 411 \$ US devrait être décaissé entre 2024 et 2026.

Tableau 2. Rapport financier de la phase II du PGEH pour l'Égypte (\$ US)

Tranche		ONUDI	PNUD	PNUE	Allemagne	Total	Taux de décaissement (%)
Première	Approuvé	3 356 641	1 042 352	230 000	0	4 628 993	95
	Décaissé	3 117 186	1 035 119	230 000	0	4 382 305	
Deuxième	Approuvé	4 668 214	1 836 750	279 500	207 300	6 991 764	70
	Décaissé	2 960 540	1 448 333	279 500	207 300	4 895 673	
Troisième	Approuvé	4 664 196	816 620	260 000	0	5 740 816	27
	Décaissé	1 158 974	156 310	221 900	0	1 537 184	
Total	Approuvé	12 689 051	3 695 722	769 500	207 300	17 361 573	62
	Décaissé	7 236 700	2 639 762	731 400	207 300	10 815 162	
	Solde	5 452 351	1 055 960	38 100	0	6 546 411	

Plan de mise en œuvre de la quatrième tranche de la phase II du plan de gestion de l'élimination des HCFC

23. Les activités dans le cadre de la quatrième tranche seront mises en œuvre entre juin 2024 et décembre 2026 et sont résumées dans le Tableau 3.

Tableau 3. Résumé et coût des activités à mettre en œuvre dans le cadre de la quatrième tranche

Activité	Agence	Coûts (\$ US)
Fabrication	ONUDI	3 249 213
Cadre politique et mise en vigueur	Finalisation de la conversion de cinq entreprises de fabrication de climatisation résidentielle	ONUDI
	Approvisionnement et livraison de 15 identificateurs de frigorigènes aux douanes et aux agents d'importation	ONUDI
	Poursuite de la mise en vigueur du réseau réglementaire et de la révision des codes nationaux	PNUE
	Organisation de cinq ateliers de formation pour 75 agents des douanes et parties prenantes concernées sur le contrôle des importations et des exportations de substances réglementées	PNUE
	Organisation de cinq ateliers de sensibilisation auprès de 60 parties prenantes liées aux douanes sur le système de suivi des frigorigènes par code QR	PNUE

	Révision des normes et des codes locaux afin de soutenir le programme de l'endiguement et de la prévention des fuites de frigorigènes et organisation de quatre ateliers de sensibilisation auprès de 200 participants sur la mise en vigueur des codes révisés	PNUE	40 000
Entretien d'équipement de réfrigération	Approvisionnement de l'équipement d'entretien de réfrigération et de climatisation pour la mise à niveau de huit centres de formation (unités de récupération, pompes à vide, jeux de pinces Lokring, détecteurs de fuites, manomètres à 4 voies et outils d'entretien)	ONUDI	80 000
	Achèvement de l'approvisionnement de kits d'outils d'entretien portables pour les équipes de terrain et d'outils de soutien aux centres de services après-vente de cinq fabricants d'équipement de climatisation résidentielle (y compris trois dans le cadre de la présente tranche), et formation et certification de 100 techniciens après-vente	ONUDI	50 000
	Organisation de dix ateliers supplémentaires de formation sur site pour former 150 à 200 techniciens aux bonnes pratiques d'entretien pour les petits ateliers employant un ou deux techniciens et consommant deux à trois bonbonnes de frigorigène par mois.	ONUDI	20 000
	Formation de 375 techniciens supplémentaires aux bonnes pratiques d'entretien des équipements de réfrigération et de climatisation	PNUE	50 000
Récupération et régénération	Fourniture de 200 kits d'outils de récupération supplémentaires, comprenant des unités de récupération et des bonbonnes, et distribution de tous les kits d'outils aux ateliers d'entretien comprenant des techniciens certifiés	ONUDI	250 000
	Soutien au centre de régénération existant et établissement d'un second centre de régénération qui a déjà été identifié	ONUDI	150 200
Sensibilisation	Organisation d'une campagne de sensibilisation pour les consultants, les sous-traitants et d'autres parties prenantes pertinentes à l'existence et à l'utilisation de technologies utilisant des frigorigènes de remplacement	PNUE	15 000
Gestion de projet	Dépenses opérationnelles et relatives au personnel, réunions, frais de déplacement, documentation et rédaction de rapports (90 000 \$ US), consultants, supervision et évaluation de la mise en œuvre et rapports de vérification (40 000 \$ US), soutien aux conversions dans le secteur de la climatisation domestique (35 000 \$ US), et imprévus (15 000 \$ US).	ONUDI	180 000
	Réunions (9 000 \$ US), consultants (10 000 \$ US) et frais de déplacement (16 000 \$ US).	PNUE	35 000
Sous-total (ONUDI)			4 039 413
Sous-total (PNUE)			180 000
Total			4 219 413

OBSERVATIONS ET RECOMMANDATION DU SECRÉTARIAT

OBSERVATIONS

Rapport sur la consommation de HCFC

24. Le Secrétariat a cherché à comprendre les raisons pour lesquelles la consommation de HCFC-22 déclarée par le pays dans le secteur de l'entretien a quasiment triplé entre 2022 et 2023. Après de plus amples discussions, l'ONUDI a expliqué que cette augmentation était due à la constitution de stocks de HCFC-22 par les fournisseurs de frigorigènes en raison de la hausse prévue des prix de HCFC-22. Cette

hausse de prix était prévue en raison de l'importante réduction des quotas qui sera mise en œuvre en 2025, conformément aux objectifs spécifiés dans l'Accord entre le pays et le Comité exécutif.

Rapport périodique de la mise en œuvre de la troisième tranche de la phase II du plan de gestion de l'élimination des HCFC

Cadre juridique

25. Le gouvernement de l'Égypte a déjà émis des quotas d'importation de 241,08 tonnes PAO de HCFC pour 2024, ce qui est inférieur aux objectifs de réglementation du Protocole de Montréal et conforme aux objectifs fixés pour cette année-là dans l'Accord du PGEH.

Activités dans le secteur de la fabrication

Secteur de la fabrication des appareils de climatisation résidentiels

26. En examinant les mesures réglementaires prévues soumises lors de la 88^e réunion conformément à la décision 84/72(e)(i)d, le Secrétariat avait considéré que ces mesures seraient insuffisantes pour permettre un essor réussi de la technologie d'ici l'achèvement de la phase II. Par conséquent, le Comité exécutif avait demandé à l'ONUDI, entre autres, de présenter dans le cadre de sa demande pour la quatrième tranche un cadre réglementaire détaillé afin de garantir l'essor de la technologie à faible PRP convenue (décision 88/70(a)(ii)a.). Par conséquent, l'ONUDI a fourni un résumé détaillé des réglementations du pays. En examinant ces informations, le Secrétariat a noté que le pays possède des réglementations robustes pour permettre la conformité avec les objectifs d'élimination du HCFC du Protocole de Montréal. Cependant, à l'exception des tarifs d'importation accordés au HFC-32 et aux frigorigènes à faible PRP, le Secrétariat comprend que le Gouvernement n'a pas encore mis en place de réglementations conçues pour permettre l'essor d'unités de climatisation résidentielle utilisant du HFC-32 face aux unités de climatisation résidentielle utilisant du R-410A sur le marché local.

27. De plus, tout en notant l'avancement de la conversion des lignes de production afin de permettre la fabrication d'unités de climatisation résidentielle utilisant du HFC-32, le Secrétariat a demandé des clarifications concernant les proportions relatives d'unités utilisant du R-410A et du HFC-32 qui étaient produites par les cinq entreprises. L'ONUDI a clarifié qu'entre le 1^{er} janvier 2023 et le 13 mars 2024, les entreprises ont fabriqué un total de 1 294 642 unités de climatisation résidentielle, parmi lesquelles 507 (0,04 %) utilisaient du HFC-32.

28. Compte tenu de l'absence apparente de mesures réglementaires et de la fabrication limitée notée plus haut, et sachant que le pays a ratifié l'amendement de Kigali le 22 août 2023 et que l'ONUDI a prévu de soumettre la phase I du plan de mise en œuvre de l'amendement de Kigali relatif aux HFC à la 95^e ou à la 96^e réunion, le Secrétariat a cherché à mieux comprendre le lien entre le calendrier de fabrication d'unités de climatisation résidentielle à faible PRP pour le marché local dans le cadre du PGEH et les activités prévues dans le cadre du plan de mise en œuvre de l'amendement de Kigali relatif aux HFC. L'ONUDI a clarifié qu'en plus des cinq entreprises fabriquant des unités de climatisation résidentielle en cours de conversion dans le cadre du PGEH, il y avait sept entreprises fabriquant des unités de climatisation résidentielle utilisant du R-410A ; que parmi ces sept entreprises, l'ONUDI estimait que six pouvaient être éligibles dans le cadre du plan de mise en œuvre de l'amendement de Kigali relatif aux HFC du pays, bien que cela reste à confirmer ; que l'intention du Gouvernement était d'inclure la conversion de l'intégralité du secteur de la fabrication des équipements de climatisation résidentielle au HFC-32 dans le cadre de la phase I du plan de mise en œuvre de l'amendement de Kigali relatif aux HFC et que le calendrier pour la mise en œuvre du KIP s'étendait de 2025 à 2029. L'ONUDI a de plus expliqué que, dans le cadre de la préparation du plan de mise en œuvre de l'amendement de Kigali relatif aux HFC, une étude détaillée et une collecte de données avaient été entreprises sur les entreprises supplémentaires de fabrication d'équipements de climatisation résidentielle ; ainsi, les données concernant la proportion relative de

fabrication d'unités de climatisation résidentielle au R-410A pour le marché local dans les cinq entreprises participant au PGEH par rapport aux sept entreprises restantes n'étaient pas encore disponibles.

29. En examinant la proposition lors de la 84^e réunion, en raison d'une incompréhension involontaire, le Secrétariat avait compris que les cinq entreprises converties dans le cadre du PGEH constituaient l'intégralité du secteur de fabrication de climatisation résidentielle et, sur cette base, avait proposé un nombre de mesures politiques et réglementaires que le Gouvernement pourrait envisager afin de garantir la mise en œuvre réussie du projet ; par conséquent, le Comité exécutif avait noté l'engagement du Gouvernement à, entre autres : garantir le contrôle total des équipements de climatisation résidentielle utilisant du R-410A et du R-407C, importés ou en place dans le marché local ; sécuriser l'essor du HFC-32 et, si l'entreprise le décidait une fois la technologie disponible, du R-454B sur le marché local ; présenter un bilan des mesures réglementaires prévues ou introduites et un calendrier prévisionnel pour les entreprises afin qu'elles fabriquent exclusivement pour le marché local en utilisant du HFC-32 ou une substance de remplacement à faible PRP, dans le cadre de la demande de la troisième tranche en 2021 (décision 84/72(e)(i)b-d). Le Secrétariat ne saisit pas bien comment le gouvernement pourrait développer un cadre réglementaire détaillé afin de garantir l'essor de la technologie à base de HFC-32 si certaines entreprises ont converti leur fabrication pour le marché local au HFC-32 tandis que d'autres continuent à fabriquer des équipements utilisant du R-410A pour le marché local. Par exemple, le Secrétariat ne saisit pas bien si le gouvernement pourrait, comme proposé, imposer une taxe d'importation sur les équipements utilisant du R-410A alors que des entreprises dans le pays continuent à fabriquer de tels équipements étant donné les principes de non-discrimination de l'Organisation mondiale du commerce.

30. De plus, le Secrétariat a noté que le Gouvernement avait notifié le Secrétariat de l'ozone de son intention d'utiliser la dérogation relative aux hautes températures décrites aux paragraphes 26 à 37 de la décision XXVIII/2, qui incluent, entre autres, les équipements de climatisation résidentielle dans la liste des équipements exemptés.

31. En dépit des circonstances, le Secrétariat note qu'en général, quand les pays visés à l'Article 5 ont décidé de convertir leur climatisation résidentielle à la technologie à base de HFC-32, ces conversions ont été mises en œuvre. Le Secrétariat estime que l'engagement du Gouvernement et des entreprises ayant signé les contrats de surcoûts d'exploitation à respecter un calendrier de fabrication intégrale pour le marché local de technologie à base de HFC-32 d'ici le 1^{er} janvier 2025 ou le 31 décembre 2026 significatif, et a noté avec satisfaction la confirmation que l'ONUDI ne paierait pas les surcoûts d'exploitation avant d'avoir vérifié que les entreprises fabriquaient bien des équipements utilisant du HFC-32, conformément à la décision 77/35(a)(vi). Par conséquent, il a été décidé que le Secrétariat recommanderait l'approbation du financement alloué au secteur de la fabrication de climatisation résidentielle dans le cadre de la quatrième tranche à l'exception des surcoûts d'exploitation convenus pour les deux entreprises n'ayant pas encore signé leur contrat de surcoûts d'exploitation (à savoir, Miraco et Power, pour lesquelles des surcoûts d'exploitation à hauteur de 1 454 835 \$ US et 284 280 \$ US avaient été convenus), étant entendu que l'ONUDI, au nom du Gouvernement, pourrait soumettre une demande pour le financement restant dans le cadre de la quatrième tranche (à savoir 1 739 115 \$ US) à la même réunion à laquelle il soumettra la phase I ou lors de la 96^e réunion, à la première occurrence.

Secteur de la fabrication des appareils de climatisation commerciale

32. Le rapport soumis à la présente réunion indique que les unités hybrides IEC-H ouvrent de nouvelles voies pour des technologies de climatisation alternatives et fournissent un système alternatif aux applications de climatisation qui dépasse l'efficacité des systèmes à détente directe existants. Bien que le Secrétariat soit d'accord avec cette évaluation encourageante, et note que les autres pays visés à l'Article 5 et possédant une fabrication d'appareils de climatisation commerciale pourraient souhaiter examiner les conclusions du rapport, le Secrétariat a noté que le frigorigène utilisé dans les unités hybrides IEC-H était du R-410A et non du HFC-32 ou une des substances de remplacement à faible PRP convenues durant l'approbation du projet. L'ONUDI a expliqué que c'était en raison d'un manque de disponibilité de

composants clés (à savoir, des compresseurs et des détendeurs) à l'époque, mais que ces composants étaient désormais disponibles. Par conséquent, l'ONUDI prévoit de tester des unités utilisant du HFC-32 (et, si disponible, du R-454B) dans la zone climatique possédant les températures ambiantes les plus élevées au thermomètre sec et le plus faible taux d'humidité durant l'été 2024.

33. À la 79^e réunion, il a été noté que la pérennité de la reconversion sur le secteur de la fabrication des climatiseurs commerciaux était l'une des principales préoccupations, étant donné que le marché utilisait déjà des HFC à fort PRP dans des unités monoblocs, des unités centrales et des refroidisseurs, y compris du HFC-134a et du R-410A. Il a donc été convenu que le Gouvernement présenterait, par l'intermédiaire de l'ONUDI, un rapport sur la mise en œuvre des politiques et des mesures pour garantir la pérennité de la reconversion, dans le rapport périodique sur la mise en œuvre des tranches de la phase II du PGEH, jusqu'à l'acceptation réussie dans le marché des solutions de remplacement.⁷ À la 88^e réunion, l'ONUDI a noté que la sélection de politiques et de mesures dépendait du succès de l'achèvement des activités d'assistance technique, dont la construction et les essais des prototypes, et du développement de la technologie hybride détente directe-évaporation indirecte (IEC-H), dont l'achèvement était prévu d'ici septembre 2022. Par conséquent, le Comité exécutif a demandé à l'ONUDI de présenter, dans le cadre de la demande pour la quatrième tranche, les mesures politiques proposées afin de garantir la pérennité de la conversion à des substances de remplacement à faible PRP dans le secteur de la fabrication des appareils de climatisation commerciale (décision 88/70(a)(ii)b.) L'ONUDI a indiqué que les mesures politiques seraient développées à la suite des tests supplémentaires prévus à l'été 2024. Le Comité exécutif pourrait aussi souhaiter prendre en considération toutes les informations relatives au secteur de la fabrication d'appareils de climatisation commerciale, y compris de possibles mesures politiques, au moment de son examen de la phase I du plan de mise en œuvre de l'Amendement de Kigali relatif aux HFC du pays, prévue d'ici la 96^e réunion.

Secteur de l'entretien de l'équipement de réfrigération

34. Le Secrétariat a noté qu'un certain nombre d'activités prévues pour le secteur de l'entretien ont été retardées, notamment, entre autres, le développement d'outils réglementaires et institutionnels afin de mettre en vigueur le programme de certification et la formation et la sensibilisation aux normes et aux codes locaux ; la finalisation du guide pour les programmes de formation ; la certification de 500 techniciens dans le cadre du programme de certification pilote ; la finalisation de quatre codes nationaux ; l'inspection et la certification pilote de quelques bâtiments et la mise en œuvre des codes QR obligatoires pour les bonbonnes de frigorigène. Tout en notant que la pandémie de COVID-19 ait pu contribuer à certains de ces retards et que la mise en œuvre de certaines des mesures prévues était inédite et pourrait prendre du temps (à savoir le programme de certification des bâtiments, les QR codes pour les bonbonnes de frigorigène), le Secrétariat a invité instamment l'ONUDI et le PNUE à intensifier leurs efforts afin d'aider le pays, sachant la réduction importante des objectifs 2025 spécifiés dans l'Accord entre le pays et le Comité exécutif.

35. En examinant la proposition lors de la 79^e réunion, le Secrétariat avait considéré la formation qui serait dispensée aux petits ateliers (à savoir les ateliers comprenant seulement un ou deux techniciens et consommant seulement deux ou trois bonbonnes de frigorigène par mois) comme particulièrement utile étant donné la capacité probablement limitée de ces ateliers. Le Secrétariat a de même encouragé l'ONUDI à intensifier ses efforts afin de dispenser les formations prévues dans le cadre de la troisième tranche et celles prévues dans le cadre de la quatrième tranche. Le Secrétariat a aussi noté qu'en fonction des résultats du programme de certification des services après-vente, le pays pourrait introduire le RDL en 2029.

36. Étant donné que le centre de régénération avait été identifié en 2021, le Secrétariat a cherché à mieux comprendre la raison du retard dans l'accord du permis nécessaire à son fonctionnement. L'ONUDI a clarifié que bien que le centre possède un permis pour remplir des frigorigènes, il ne possédait pas de permis pour des activités de régénération, qui constituaient une nouvelle catégorie d'opérations commerciales récemment créées par le Ministère de l'industrie. Bien que le second centre de régénération

⁷ Paragraphe 50(b) du document UNEP/OzL.Pro/ExCom/79/32.

à être établi dans le cadre de la quatrième tranche ait aussi besoin d'un permis pour des activités de régénération, l'ONUDI ne prévoit pas que cela entraîne un retard, car cette nouvelle catégorie d'opérations commerciales a déjà été établie.

37. Il y a eu des retards de dédouanement des équipements achetés dans le cadre du projet, notamment pour les frigorigènes inflammables destinés au centre d'excellence. En particulier, bien que la plupart des équipements aient été dédouanés sans problème, certains outils étaient toujours en cours de dédouanement ; les ateliers de formation devant avoir lieu au centre d'excellence seront dispensés une fois les équipements livrés. Lors de la 93^e réunion, le Comité exécutif a approuvé la prorogation au 30 juin 2024 de la date d'achèvement de la composante de formation mise en œuvre par l'Allemagne (EGY/PHA/84/INV/142). Le Secrétariat recommande de proroger le projet au 31 octobre 2024 afin de permettre le dédouanement de l'équipement restant nécessaire pour les formations et pour les formations d'avoir lieu.

Mise en œuvre de la politique d'égalité des genres

38. La phase II du PGEH a été approuvée avant l'approbation de la politique opérationnelle sur l'intégration des questions de genre (décision 84/92(d)). Toutefois, des ingénieres ont participé au projet de conversion à El-Araby et Fresh, et l'unité nationale de l'ozone (UNO) a mesuré la participation des femmes aux activités de formation (détailée ci-dessous). Trois femmes ont participé aux ateliers de formation de formateurs et trois ingénieres ont reçu des certificats d'appréciation du Ministère de l'environnement, du Ministère de la main-d'œuvre et du Ministère de la solidarité sociale, soulignant leur contribution à l'organisation des ateliers de formation de formateurs et à la mise à niveau des centres de formation pour qu'ils soient capables de former aux frigorigènes inflammables. Il est à espérer que ces formations et certificats d'appréciation contribueront à encourager une participation accrue de formatrices et de techniciennes aux formations ultérieures. Le projet de programme de promotion de la politique d'égalité des genres préparé par l'UNO n'a pas encore été finalisé.

Pérennité de l'élimination des HCFC et évaluation des risques

39. Afin de garantir la pérennité de la conversion des secteurs des mousses de polystyrène extrudé et des mousses de polyuréthane, le gouvernement a mis en œuvre l'interdiction d'utiliser des HCFC dans la fabrication des mousses de polystyrène extrudé (depuis le 1^{er} janvier 2023), d'importer du HCFC-141b (depuis le 1^{er} janvier 2020) et du HCFC-141b contenu dans des polyols pré-mélangés (depuis le 1^{er} janvier 2018). Le gouvernement a aussi interdit l'importation de HCFC-142b et de R-406A et a interdit l'importation et la fabrication d'équipements utilisant du HCFC depuis le 1^{er} janvier 2023. Ces mesures et la mise en œuvre du système d'octroi de licences et de quotas du pays contribueront à garantir la pérennité de l'élimination des HCFC.

40. L'augmentation substantielle de consommation de HCFC-22 en 2023 était probablement due à une constitution de stocks ; cela ne devrait pas persister et pourrait réduire les importations de HCFC-22 en 2024 et 2025. Le Secrétariat a noté la réduction substantielle de consommation requise afin d'atteindre les objectifs 2025 et a encouragé l'ONUDI et le PNUE à poursuivre leur assistance au pays dans la mise en œuvre des activités prévues dans le cadre du PGEH qui aideront le pays à se conformer à son Accord avec le Comité exécutif.

41. Bien que le Secrétariat considère que les risques liés à la pérennité de l'élimination des HCFC dans les secteurs de la fabrication d'appareils de climatisation résidentielle et commerciale soient faibles, évaluer les risques relatifs à une conversion durable à des technologies à faible PRP dans ces secteurs est difficile étant donné l'utilisation dominante du R-410A dans le pays pour ces applications et en l'absence d'informations qui seront fournies quand le pays soumettra la phase I du plan de mise en œuvre de l'Amendement de Kigali relatif aux HFC, y compris : comment le pays appliquerait la dérogation pour température élevée dans ces secteurs s'il choisit de le faire ; une vue d'ensemble globale du secteur de la fabrication d'appareils de climatisation commerciale et résidentielle au R-410A dans le pays ; les

conversions additionnelles qui pourraient être intégrées dans le cadre de ce plan et les mesures politiques et réglementaires qui pourraient être intégrées dans le cadre de ce plan qui pourraient aider à faciliter l'essor sur le marché des technologies convenues dans le cadre du PGEH. Une soumission conjointe de la phase I du plan de mise en œuvre de l'Amendement de Kigali relatif aux HFC du pays et de la demande pour les 1 739 115 \$ US restants, plus les coûts d'appui d'agence pour l'ONUDI, permettra au Comité exécutif d'avoir une compréhension globale de ces sujets. Étant donné le solde restant à l'ONUDI, le Secrétariat estime que retarder l'examen du financement restant dans le cadre de la quatrième tranche à la 95^e ou à la 96^e réunion ne devrait pas retarder outre mesure l'achèvement de la conversion dans le secteur de la fabrication d'appareils de climatisation résidentielle. À l'inverse, le Secrétariat estime que l'approbation du financement demandé contribuera à permettre aux entreprises de fabrication d'appareils de climatisation résidentielle ayant signé des contrats de surcoûts d'exploitation de fabriquer exclusivement des équipements de climatisation résidentielle au HFC-32 pour le marché local d'ici le 1^{er} janvier 2025 ou le 31 décembre 2026. Ce calendrier, qui est plus rapide que celui indiqué au tableau 3 du document UNEP/OzL.Pro/ExCom/88/47, contribuera à renforcer la confiance dans la technologie et devrait faciliter des conversions ultérieures.

Conclusion

42. Le système d'octroi de licences et de quotas d'importation du pays est opérationnel, et la consommation vérifiée pour 2021, 2022 et 2023 est inférieure aux objectifs définis dans l'Accord du pays avec le Comité exécutif. Les conversions dans les secteurs de la fabrication des mousses de polystyrène extrudé et des mousses de polyuréthane sont achevées et le Gouvernement a mis en œuvre un certain nombre d'interdictions afin de soutenir l'élimination des HCFC. Le niveau de décaissement de la troisième tranche s'élève à 27 pour cent, et à 62 pour cent du financement approuvé à ce jour. Bien qu'une assistance technique ait été mise en œuvre afin d'assister les fabricants d'appareils de climatisation commerciale du pays à fabriquer des équipements basés sur une nouvelle technologie hybride détente directe-évaporation indirecte (IEC-H), les entreprises ne fabriquent pas encore de tels équipements avec du HFC-32 ou des substances de remplacement à faible PRP. Des essais supplémentaires, prévus pour l'été 2024 devraient permettre une telle fabrication. De plus, bien que des équipements dédiés à la fabrication d'unités de climatisation résidentielle utilisant du HFC-32 aient été installés dans quatre des cinq entreprises participant au PGEH, la fabrication pour le marché local dans ces entreprises reste presque exclusivement basée sur le R-410A et des entreprises supplémentaires fabricants des unités de climatisation résidentielle utilisant du R-410A pour le marché local ont été identifiées. Le Secrétariat estime que la ratification de l'amendement de Kigali par le pays et la décision du Gouvernement d'accorder les surcoûts d'exploitation uniquement aux entreprises fabriquant exclusivement des unités de climatisation résidentielle à base de HFC-32 pour le marché local d'ici le 31 décembre 2026 (ou plus tôt) constituent des signaux importants pour l'industrie et le marché et devraient contribuer à permettre leur conversion au HFC-32. Étant donné la réduction substantielle des objectifs 2025, des efforts continus et constants de la part du Gouvernement avec le soutien de l'ONUDI et du PNUE seront nécessaires pour s'assurer que le pays continue à respecter les objectifs spécifiés dans son Accord avec le Comité exécutif.

RECOMMANDATION

43. Le Comité exécutif pourrait souhaiter envisager :

- (a) Prendre note du rapport périodique sur la mise en œuvre de la troisième tranche de la phase II du plan de gestion de l'élimination des HCFC (PGEH) pour l'Égypte ;
- (b) D'approuver la prorogation au 31 octobre 2024, de la date d'achèvement de la phase II du PGEH de l'Égypte (deuxième tranche) (EGY/PHA/84/INV/142) afin de permettre l'achèvement des activités en cours restantes ; et
- (c) D'approuver, pour la quatrième tranche de la phase II du PGEH de l'Égypte, un montant

de 2 662 825 \$ US, comprenant 2 300 298 \$ US, plus les coûts d'appui d'agence à hauteur de 161 021 \$ US pour l'ONUDI, et 180 000 \$ US, plus les coûts d'appui d'agence à hauteur de 21 506 \$ US pour le PNUE, et le plan correspondant de mise en œuvre de la tranche pour 2024-2026, étant entendu que l'ONUDI, au nom du Gouvernement, soumettra la demande de financement restant pour la quatrième tranche d'un montant de 1 739 115 \$ US, plus les coûts d'appui d'agence à hauteur de 121 738 \$ US pour l'ONUDI, lors de la même réunion que la soumission de la phase I du plan de mise en œuvre de l'Amendement de Kigali relatif aux HFC du pays ou lors de la 96^e réunion du Comité exécutif, à la première occurrence.

Background

This component covers the risk assessment of the places where explosive atmospheres may occur by classification of areas followed by arrangements to deal with accidents and emergencies, in addition to instructions and training for people in the area, along with the design and installation of safety systems.

Residential Air Conditioning Risk Assessment from 1 to 3 ton using R32 chosen as a model in Egypt which considered a HAT country (High Ambient Temperature).

1- Flammability definition and classes

For a fire to happen there needs to be three elements: a rapid leak of the flammable gas, a concentration higher than the lower flammability level, and a source of ignition as shown in figure below.

Figure 1 shows the probability of ignition as the resultant of these three elements. Lower Flammability Limit (LFL), usually expressed in volume per cent, is the lower end of the concentration range over which a flammable gas can be ignited at a given temperature and pressure.




Figure 1: FACTORS AND PROBABILITY OF IGNITION

$$\text{Probability} = [\text{rapid Leakage}] \times [\text{High Concentration}] \times [\text{Ignition Source}]$$

Flammability Classification for Refrigerants: Table 1 shows the classes of flammability as defined in ISO 847 and ASHRAE 34.

TABLE 1: FLAMMABILITY CLASSIFICATION FOR REFRIGERANTS

Class	
1	No flame propagation when tested at 60°C and 101.3 kPa
2	Flame propagation and LFL > 0.1 kg/m3 and HOC < 19,000 kJ/kg
2L	Same as 2 except Burning Velocity < 10 cm/s
3	Flame propagation and LFL <= 0.1 kg/m3 and HOC >= 19,000 kJ/kg

2- Definition of Risk

- **Risk** is a combination of the probability of concurrence of harm and the severity of that harm.
- **Tolerable risk** is the level of risk that is accepted in a given context based on the current acceptable values by a community.
- **Residual risk** is the risk remaining after reduction measures have been implemented. Safety is freedom from risk which is not tolerable.

The risk levels depend on the severity of injury, the amount of damage to the environment, the frequency at which people are exposed to the danger and the duration of exposure.

Tolerable risk is determined by the search for an optimal balance between the ideal absolute safety and the demands to be met by a product. The factors influencing risk are the practicality and means to reduce risk, the benefit to users, cost effectiveness, and social conventions.

The concept of tolerable vs. unacceptable risk was introduced based on the probability of harm and the severity of harm as per Figure 2.




FIGURE 2: TOLERABLE VS. ACCEPTABLE RISK (SOURCE: UL)

3- Process of a Risk Assessment Model

The Risk Assessment model is based on the workshop that was held in Japan in cooperation with Japan Refrigeration and Air Conditioning Industry Association (JARAIA) in April 2019. The workshop was dedicated to the study of a risk scenario prepared by the PRAHA team, and also the following should be taken into consideration;

- An outline of the methodology and the components that are the basis for the risk assessment model.
- A model of what data can be collected.

- Information on the regulatory regime and the enforcement mechanisms.
- International standards play a role in the next step of risk assessment in the form of recommendations for local standards.
- Rigorous regulations as those adopted in other regions must be adapted to HAT countries.
- Stakeholders: governments and local research institutions, industry and private sector, and UN Environment & UNIDO.

3.1. Selection of equipment type and Life stage for the risk assessment model

Residential air conditioning unit is chosen, as it is the most used type in number of units and where the risk might be greatest, also servicing of the indoor unit as the most relevant for the model. Figure 3 identify the life stages of the residential air conditioning.



FIGURE 3: AC LIFE STAGES

3.2. Procedure of Risk Assessment

The process that will be used is outlined in Figure 4, according to ISO/IEC 51 (Source: JRAIA)




FIGURE 4: PROCEDURE OF RISK EVALUATION

3.3. Acceptable and tolerable risk:

Tolerable risk depends on the number of units in the market of the product identified, also on the frequency and severity of the accident.

JRAIA defines risk in terms of probability and frequency vs. severity. A low risk is where the probability of an accident is lower and the severity is least. An extreme risk is where the probability is high and the severity is also high.

Table 2 shows the frequency of accidents vs. severity. Frequent accidents leading to catastrophic events are the least acceptable, while improbable or incredible (as in incredibly low frequency) with the least severity are socially acceptable.

TABLE 2 RISK MATRIXES - FREQUENCY VS. SEVERITY (SOURCE JRAIA)

	None	Negligible (slight injury)	Marginal (need for outpatient treatment)	Critical (serious injury or need to be hospitalized)	Catastrophic (death)
Frequent	C	B3	A1	A2	A3
Probable	C	B2	B3	A1	A2
Occasional	C	B1	B2	B3	A1
Remote	C	C	B1	B2	B3
Improbable	C	C	C	B1	B2
Incredible	C	C	C	C	C

A = Unacceptable risk levels:
1=least, 3=highest B= Risk levels should be reduced
1= least, 3= highest C= Socially acceptable risk levels

3.4. Product Cycle

The life cycle range for assessment is shown in Figure 5. Each stage has to be assessed separately and added together to get to the total risk.




FIGURE 5: LIFE CYCLE RANGE FOR ASSESSMENT

The determination of tolerable risk depends on the population of products in the country. The example from Japan is in Table 3:

TABLE 3: DETERMINATION OF TOLERABLE RISK LEVELS

Product/System	Unit Population	Tolerable risk	
		Usage stage	Service stage
Residential AC	1×10^8	1×10^{-10}	1×10^{-9}

The JRAIA approach is used to set the tolerable risk for residential units at the following levels:

For the usage stage = $1 / 100 \times$ unit population

For the service stage = $1 / 10 \times$ unit population

And the risk map becomes as in Figure 6:




FIGURE 6: RISK MAP

4- Risk Scenarios

A critical stage of the risk assessment is to identify those scenarios in which an ignition source is present in conjunction with a flammable concentration of leaked refrigerant. To better understand these scenarios, one must consider the various triggering events which could cause refrigerant to be released, the location of the release, and the specific type of person that might be present (i.e., a worker, repair person or customer) at the time of the release. It is important to note that, during normal operations, the refrigerant will be contained within the system, and thus there is no risk of adverse events associated with these refrigerants during regular use.

However, if refrigerant leaks from the equipment and is not dispersed prior to accumulating to a flammable concentration and a sufficient energy source is present, refrigerant ignition could occur (AHRTI 8009)

The fault tree analysis (FTA) is chosen.

The risk assessment of flammable refrigerants considers two individual phenomena: the presence of an ignition source and the generation of a flammable volume. The risk scenarios that were considered were:

- A. Refrigerant leak during maintenance work on the indoor unit during brazing and due to pipe breakage by corrosion with an ignition source caused by live wire, static electricity, or electric tool such as screw drivers
- B. Refrigerant leak during brazing of outdoor unit with leakage caused by prior maintenance work or during maintenance work and an ignition source from the brazing torch;
- C. Refrigerant leakage during normal home use caused by pipe breakage through corrosion, external pressure or natural causes such as earthquakes with an ignition source of an open flame, electric spark or static electricity.

5- Select Risk Analysis Sources

The input into the model is taken from data tables for the type of application and usage of the equipment that are being studied. Source for input into the volume of the flammable cloud can be taken from research done for the type of gas. Data for source and time of ignition can sometimes be available from the fire department.

6- Data Collection

Data collection takes into consideration the following:

- a) Select the stages of the life cycle of the air conditioners. Choose the manner of classification of manufacturing, transportation, use, service, and disposal of an air conditioner into separate stages for evaluation. The evaluation of the manufacturing stages of each product is normally the responsibility of the manufacturer.
- b) Investigate the conditions of installation of the selected air conditioner to determine the conditions to be evaluated during the risk assessment.
- c) Determine the severity of the hazard focusing on the damage caused by flammability.
- d) Set tolerance levels. Set socially acceptable probability of harm for the air conditioner.
- e) Investigate refrigerant leakage rate, speed, and amount based on surveys conducted with air conditioning service companies. The initial leakage location and leakage concentration should also be determined.
- f) Determine flammable time volume through CFD or calculations. For the conditions set as per point (b), the flammable time volume can be calculated by CFD simulation based on the leakage amount, speed, and concentration of the refrigerant as per point (e).
- g) Consider ignition sources. Distinguish the ignition properties depending on whether the ignition source is a spark (for example, electrical contacts, lighter, and/or static electricity), or an open flame (for example, candles, matches, and/or combustion equipment).

7- Fault Tree Analysis (FTA)

It utilizes a "top-down" approach, starting with the undesired effect as the top event of a tree of logic. Fault trees (FTs) consist of various event boxes, which reflect the probability or frequency of key events leading up to a system failure. The event boxes are linked by connectors (gates), which describe how the contributing events may combine to produce the system failure. Events may be combined in different ways: in cases where a series of events must all occur to produce an outcome (e.g., ignition source and sufficient oxygen to support combustion), the probabilities or frequencies of the individual contributing events are multiplied via an "AND" gate; in cases where only one of a series of events is needed to produce an outcome (e.g., a strong spark, open flame, or a hot surface all possibly leading to refrigerant ignition), the probabilities are usually added via an "OR" gate. (AHRTI 8009, 2015).




FIGURE 7: FAULT TREE ANALYSIS (FTA) MODEL

In the case of flammability, the probability of leakage is combined with (“and” gate) the possibility that the length of time that flammable cloud exists covered area would lead to ignition in case of the existence of an ignition source (another “and” gate).




FIGURE 8: PROBABILITY OF IGNITION FTA

8- Suggest Measure to Mitigate Intolerable Risk

When the tolerance from the risk evaluation in the steps above is satisfactory, the risk assessment ends.

If the risk exceeds the tolerance, countermeasures to reduce the risk should be taken. These countermeasures include the implementation of regulations and other measures like introducing safety procedures in order to reduce the risk of accidents. In some instances, it might be necessary to revise laws and regulations in order to ensure that they cover the accepted probability. The reiterative process, which is explained in Figure 9, is as follows:




FIGURE 9: FTA REITERATIVE PROCESS

- Once the countermeasures have been introduced, the FTA factors are reviewed and these countermeasures are added in the appropriate position of the tree.
- A new calculation can then be made and repeated until the calculations confirm the accepted tolerance according to the risk map.
- The results can then be released to the public and standards and codes can be drawn.

9- Type of premises that residential AC applications likely to be deployed in.

- 3.1. Governmental offices
- 3.2. Barber shop
- 3.3. Home use
- 3.4. Retail shop
- 3.5. Educational premises

10- Data analysis of potential risks with Example of a Risk Assessment Model

Case study of an office space in a government building during the usage phase when the equipment is running and during the repair/service stage. The target product is a 5.3 kW split system using an A2L (R32) refrigerant. Fault Tree Analysis (FTA) method is selected. The target product and the indoor and outdoor conditions plus the service case are shown in the tables below.

The two cases study using the information provided by the PRAHA team for the Egyptian model is:

- During usage of an air conditioner in a government office. The sources of ignition are extreme including charcoal and lighter used for incense burning, an aroma candle, as well as cigarettes and lighters as smoking is still allowed.
- During the repair stage during brazing with sources of ignition including the brazing burner, a cigarette and a lighter.

Table 4 lists the equipment as well as the indoor and outdoor conditions

Target Product	Value	
Model number	CS-PC36JKF	
Type(cooling / HP)	HP	
Capacity(kW)	10.5	
Refrigerant type	A2L	
Refrigerant amount(kg)	2.7	
Alternative refrigerant type	HFC-32, R-454B	

Indoor Condition during usage of target product	Value	
Room size (m ²)	max	25
	min	16
Height of installation(m)	2.1	
Ceiling height(m)	2.8	
Ventilation	yes/no	YES
	Ventilation amount (m ³ /hr.)	80
The area of the gap under the door (m ²)	0.02	
other openings, if any (m ²)	0	

Outdoor Condition during usage of target product	Value	
Size of the place enclosed with walls , or fences etc.(m ²)	max	8
	min	4

Condition during repair of target product	value
Average size of outdoor spaces for repairs (m ³)	20
Percentage of single outdoor unit installations(A%)	50
Percentage of the installations of multiple outdoor units (B%)	50
Average working hours per repair (outdoor unit) (hr.)	1
Average working hours per repair (indoor unit)(hr.)	0.5
Wind condition (wind velocity) (m/s)	1 TO 3
Windless condition percentage (%)	10

(Windless condition; 0.1m/s or less. the windless rate in one year.)

Notes:

- Ventilation amount was calculated based on 1.5 air changes per hour;
- Gap under door was based on the door width is 1.00 m, gap with floor is 2 cm;
- The outdoor unit was assumed to be installed on a roof open area.

The methodology is to calculate the probability of ignition due to a space factor and a time factor.

Space Factor

The space factor takes into consideration the space volume, the volume of the flammable cloud, and the volume of the source of ignition. The volume of the flammable cloud depends on the leakage rate and other considerations such as pressure. The volume of the source of ignition can be very small as in the case of a spark, or sizeable as in the case of an open flame.

Time Factor

The time factor takes into consideration the number of occurrences of the ignition source and the duration of each occurrence.

Simulation of Time Factor and Space factor During Usage Stage

The data in Table 5 was provided by the PRAHA-II team for the Egyptian model.

TABLE 5: DATA FOR THE CALCULATION OF RISK FOR USAGE STAGE

Event	Ignition source	No. of Occurrence	Duration per day	T_s = Time of Source
A	Charcoal + lighter	2	1 hour	1 hr/2
B	Cigarette+ lighter	2	0.2 hour	0.2 hr/2
C	Aroma candle	4	3 hours	3 hr/4

The FTA calculation for the usage stage is shown in Figure 10.




FIGURE 10: FTA FOR USAGE STAGE

For each event, i.e. charcoal, oil lighter, and aroma candle the probability of time and space are calculated according to **Fault Tree Analysis (FTA)** for the usage stage.

The calculation made by JRAIA during the workshop puts this Total calculated probability in the “Extremely Difficult” area of Figure 6: Risk Map.

Simulation of Time Factor and Space factor During Servicing Stage

TABLE 6: DATA FOR CALCULATION OF RISK FOR SERVICE STAGE

Event	Ignition source	No. of Occurrence	Duration per day	T _s = Time of Source
A	Burner	2	2 minutes	4/2
B	Cigarette	2	3 minutes	6/2
C	Lighter	2	10 seconds	0.167/2

The FTA for servicing stage is shown in Figure 11.




FIGURE 11: FTA FOR SERVICING STAGE

The calculation made by JRAIA during the workshop puts this Total calculated probability in the “Frequent” area of Figure 6: Risk Map and mitigation measures should be taken. One evident measure is to ban smoking in the service area!

11- Flammable gas region




FIGURE 12: Flammable gas region

11.1. Flammable gas region of the wall mounted AC unit:

- Flammable region can only be seen near the unit.
- The small flammable region existed below the air outlet of indoor unit only.
- The flammable gas volume was small.
- After leakage, the flammable region vanished in less than a second.




FIGURE 13: Flammable gas of the wall mounted AC

11.2. Flammable gas region of the floor mounted AC unit:

- Flammable region appears on the floor.
- There was a large flammable region spread on the floor.
- The flammable region did not vanish for some time.




FIGURE 14: Flammable gas of the floor mounted AC

12- Conclusions and Recommendations from the Risk Assessment Element

The above two FTA were created in collaboration with HAT countries (Egypt, Kuwait) and Japan. The simulated risk scenario considers climate, product-usage, lifestyle and culture of the Egyptian market. The exercise has shown the need for a reliable data on leaks, practices etc.

Building a risk assessment model for Egypt which suits the climate and the service practices of the local technicians helps in understanding the risk associated with flammable refrigerants and adopting the needed regulations and training programs especially in relation to the logistics of lower-GWP based technologies i.e. installation, transportation, storage, servicing and decommissioning. The Measures to mitigate risks would depend on type of existing/operational standards and/or codes in Egypt.

The mini-split risk assessment for R32 in residential air conditioners, confirming that;

- The simulation of Time Factor and Space factor During Usage Stage indicate that the total calculated probability in the “Extremely Difficult” area of Figure 5: Risk Map.
- It can be used if certain measures are adhered.
- In order to reduce the risks, the manuals used during installation or servicing should be carefully reviewed.
- More precisely, in the “Piping construction manual for residential air conditioners using R32 refrigerant” measures should be adopted.
- Flammable region and concentration distribution for the wall mounted AC unit is relatively better compared with floor mounted type.

The recommendation is to continue the risk assessment based on actual situations, and reduce the risk by implementing various measures that are verified by FTA.

It is also important to minimize ignition probability by implementing various measures that are verified by FTA.

In addition, the risk assessments of other stages matching cultural and lifestyle aspects should be studied.

➤ **Risk Management Plan – RMP**

It is recommended to implement a Risk Management Plan during service of AC units having A2L refrigerants, Annex 1 contain a template as a guide line, and the following control measure can be applied;

- 1- Warning signs must be placed during service time.
- 2- Ensure to open windows during service for well ventilation to ensure that the refrigerants are not concentrated to a large extent in case of a leak.
- 3- Using a portable detector to sense a leakage of refrigerant gases and give an alert if a leak is detected.

- 4- Maintaining a record in which all the details and actions that have been performed on each air conditioning unit, including maintenance, modification, recharging, repairs, and welds, are recorded by date and time.
- 5- Making an emergency plan to deal with any leaks that might go wrong during service activities.
- 6- Avoid any source of ignition inside the place.
- 7- All technicians must be aware of the risks posed by the presence of flammable refrigerant, and familiar with the applicable safety procedures.
- 8- All technicians must have training on the proper use of personal protective equipment (PPE), and how to use fire extinguishers.
- 9- Providing suitable fire extinguishing means to extinguish the different types of dangers present in the place.
- 10- Ensure that all electrical connections inside the place are off during the service time to avoid any electrical sparks to occur.
- 11- Manufacturers are required to include additional safety information in the installation and service manuals for air conditioners using flammable refrigerant. Technicians should follow these instructions.
- 12- Check the relevant material safety data sheets available from refrigerant wholesalers for specific safeguards when handling R32.
- 13- The electrical installation must be in accordance with the NEC and any local codes. This includes using the correct size wire and breaker for the circuit, and ensuring that the wiring is properly grounded.
- 14- Dry nitrogen should always be used when brazing to displace the oxygen and prevent oxidization on the inside of the pipework. This procedure is important as it is also required to displace the residual refrigerant and prevent concentration levels conducive to ignition.
- 15- Safety issues to be aware of when handling R32
- 16- Technicians need to take the relevant safety measures for the correct transport, storage, and handling of flammable gases. This includes ensuring that the gas is not exposed to open flames or other ignition sources. Toxic substances like hydrogen fluoride and carbon dioxide are created when R32 is burnt. Asphyxiation and freeze burns are also a risk.
For transportation purposes, R32 is classified as a dangerous goods class A2L flammable gas, therefore requires additional handling and storage safeguards.

➤ **Equipment Safety**

- All equipment must be inspected regularly.
- Nitrogen must be used instead of air for leak testing.
- All equipment must be labeled with the type of refrigerant used.
- Refrigerants must be disposed of properly.

13- References

- AHRTI 8009, 2015. Risk Assessment of Refrigeration Systems Using A2L Flammable Refrigerants - April 2015
- JSRAE, 2017. Risk Assessment of Mildly Flammable Refrigerants - Final Report 2016 - March 2017
- US Nuclear Regulatory Commission (US NRC). 1981. "Fault Tree Handbook." NUREG-0492. 209p. January.
- Risk Assessment of Mildly Flammable Refrigerants Final Report 2016 by The Japan Society of Refrigerating and Air Conditioning Engineers – JSRAE
- PRAHA-II Project, JRAIA Workshop, April 2019 Tokyo, Japan
- ASHRAE 34 Designation & Safety Classification of Refrigerants.

Risk management plan for refrigerants

The significance of a RMP.

Businesses need to be aware of their risks. Overall business success depends largely on effective management and minimization of risk – refrigerant is no different.

Under the Ozone Protection and Synthetic Greenhouse Gas Management it is important to apply a risk management plan (RMP), which outlines the handling and storage of refrigerant in the holder's business.

RMP to include.

An RMP must identify potential risks which could result in the emission of refrigerant to the atmosphere and identify processes and practices that minimize the possibility of those risks occurring. RMP must reflect the risks of emissions relevant to all parts of the business practices, including refrigerant handling, storage and transport. These apply whether the business is for a sole trader or employ 100 or more technicians.

Apply it for a specific business practices and do the following:

- Identify the type of works field
- Insert relevant person responsible against each risk
- Insert review date
- Read over the whole plan carefully and put lines through the areas that don't relate to your business.
In particular, see the section 'Decommissioning end of life equipment'.
- Add further risks and control measures if relevant to your business.

Risk Management Plan

Activity steps	Potential hazards/risks	Risk control measures	Standards and Code of practice reference	Person responsible (full name)	Next review date (within 12 months)
Purchase of refrigerant	Loose, damaged or missing cylinder caps	<ul style="list-style-type: none"> At time of purchase check that refrigerant cylinders are tightly capped Ensure quarterly purchase records are kept up to date Only accept refrigerant cylinders from wholesalers if they are properly sealed (bunged or capped). 	✓		
	Poor cylinder condition (rusted, corroded, damaged). Expired, or close to expired 'Test Date'	<ul style="list-style-type: none"> Check cylinder date markings/imprints – specifically, that they are 'In Test' Good condition etc. 	✓		
Transportation of refrigerant	Damaged cylinder during transportation	<ul style="list-style-type: none"> Keep out of direct sunlight and/or in cooler area of vehicle Safely stored/fixed when transporting Fitted with safety equipment etc. 	✓		
	Damage to gas cylinders during handling (hand-moved, equipment-moved)	<ul style="list-style-type: none"> Implement proper handling techniques Report accidents immediately. 	✓		
Using equipment containing refrigerant	Leakage of refrigerant during charging of equipment	<ul style="list-style-type: none"> Implement best practice procedure as per Standard and/or code of practice 	✓		
	Improper care of cylinders	<ul style="list-style-type: none"> After each use check that refrigerant cylinders are tightly capped Check for leakage etc. 	✓		
Handling	Unlicensed handling staff or contractors	<ul style="list-style-type: none"> All refrigerant handling must be carried out by qualified licensed staff or contractors Check temporary contractor's license before commencement of refrigerant handling work Ensure quarterly refrigerant handling license holder records are up to date, taking particular note of expiry dates. 	✓		
Installation, service and maintenance of equipment containing refrigerant	Lack of servicing of equipment containing refrigerant	<ul style="list-style-type: none"> Adhere to manufacturers' recommendations and relevant standards Maintain recommended servicing frequency: <ul style="list-style-type: none"> i. Obtain and keep warranties on repairs ii. Keep record of each service to equipment iii. Check cylinder weight regularly etc. Refer to appropriate standards. 	✓		
	Infrequent testing of equipment containing refrigerant	<ul style="list-style-type: none"> Check that all test equipment is in good working condition at least once every three months. Test leak detectors and recovery units Regularly monitor vacuum pump oil etc. Ensure quarterly equipment maintenance records are kept up to date. 	✓		
	Inadequate leak testing	<ul style="list-style-type: none"> Implement best practice procedure as per Standard and/or code of practice Check at least every three months Ensure quarterly cylinder leak test & in-test expiry date records are kept up to date. 	✓		

Risk Management Plan (continued)

Activity steps	Potential hazards/risks	Risk control measures	Standards and Code of practice reference	Person responsible (full name)	Next review date (within 12 months)
Recovery and recycling of refrigerant	Improper filling of cylinders	<ul style="list-style-type: none"> Fill bulk refrigerant cylinders in-line with manufacturers' recommendations etc. 	✓		
	Poor cleaning and flushing	<ul style="list-style-type: none"> Never charge refrigerant into equipment with identified leaks Refer to standards and Code of Practice for leak testing procedures. 	✓		
	Venting	<ul style="list-style-type: none"> Never vent fluorocarbon refrigerant where its release is avoidable etc. 	✓		
Decommission end of life equipment	Leakage of refrigerant if pumped down and left in the equipment	<ul style="list-style-type: none"> All refrigerant is to be reclaimed from all parts of the system at the time of decommissioning After recovery refrigerant is to be recycled or returned to an authorized refrigerant supplier (see 'Disposal'). 	✓		
Storage of refrigerant	Poor storage of cylinders on premises	<ul style="list-style-type: none"> Ensure all cylinders are stored in a safe and secure location: <ol style="list-style-type: none"> climate controlled (cool place, removed from direct sources of heat and the risk of fire) free of obstacles with appropriate signage to provide ready identification for emergency teams. 	✓		
Disposal	Inadequate seals	<ul style="list-style-type: none"> Closed valves when not in use Check all seals for leakage every 3 months. 	✓		
	Mixing refrigerant types	<ul style="list-style-type: none"> Clearly identify refrigerant stored in cylinders Store reclaimed refrigerant separately. 	✓		
	Lack of labeling	<ul style="list-style-type: none"> Clearly label refrigerant type Clearly label lubricant type Store in specific locations Training personnel. 	✓		
	Equipment that cannot be repaired	<ul style="list-style-type: none"> Document and keep records of reasons why Establish a retirement plan of action. 	✓		
	Recovered refrigerant	<ul style="list-style-type: none"> Return refrigerant contaminated to supplier for disposal Document and keep records of recovered refrigerant returned to supplier for disposal Ensure quarterly recovered refrigerant returned records are kept up to date. 	✓		



UNITED NATIONS INDUSTRIAL DEVELOPMENT ORGANIZATION

Montreal Protocol Division
HCFC PHASE-OUT Management Plan Stage II
Market Acceptance Study Report
EGYPT

February 2024

UNIDO Project ID: 200006

Copyright and Confidentiality:

This document showcases the Market Acceptance Study (MAS) report as a part of HCFC PHASE-OUT Management Plan Stage II EGYPT 2023 activities.

For more information on the study please contact Mohamed **NEGM** - Communication Expert M.NEGM2@UNIDO.ORG or Viktoriia **KOTLUBEI** - International Consultant V.KOTLUBEI@UNIDO.ORG

Table of contents:

Abstract	I
Acknowledgment	II
Background	Page 1
Summary	Page 1
Methodology	Page 2
Data Collection Tools	Page 2
Sample Size Formula	Page 2
Questionnaire Structure	Page 3
Results and Outputs (End-Users)	Page 4:8
Results and Outputs (Distributors)	Page 9
Findings	Page 10
Conclusions	Page 10

ABSTRACT

This document outlines the results of the Market Acceptance Study (MAS), which was conducted in Egypt during the 2023 physical year as part of the HCFC PHASE-OUT Management Plan Stage II (HPMP II) activities.

The MAS was conducted to understand consumer perspectives on residential air conditioning products that contribute to reducing climate change and ozone depletion.

The report covers various topics related to the MAS, including its Background, Summary, Objectives, Methodology, Data Collection Tools, Sample Size Formula, Sample Classifications, Results, Findings, and Conclusion.

The findings of the MAS provide valuable insights into the preferences and perceptions of consumers in the Egyptian market regarding eco-friendly ACs. Manufacturers, suppliers, and policymakers can leverage these findings to develop effective marketing strategies, prioritize key attributes, and meet consumer demand for energy-efficient and cost-effective AC solutions.

Acknowledgment

We would like to express our gratitude to Dr. Fukuya Iino, the HPMP II Project Manager, for providing support and facilitating all the necessary logistics to accomplish the study objective. Furthermore, we extend our appreciation to Dr. Ezzat Lewis, the NOU director, for giving effective guidance and valuable insights. Finally, we want to express gratitude to the project team and NOU team for their contributions throughout the various phases of the study.

BACKGROUND

The HPMP II conducted a Market Acceptance Study to analyze the satisfaction levels of end-users and key distributors with current air conditioning (AC) product lineups, energy and environment-related information, and prices in the Egyptian market.

The MAS was conducted to understand consumer perspectives on residential air conditioning products that contribute to reducing climate change and ozone depletion.

SUMMARY

The study focused on the pre-production phase of ACs that uses R32. The sample consisted of 402 participants who owned residential AC units across Cairo, Alexandria, Delta, Suez Canal, and Upper Egypt, proportionate to the population of each governorate.

The Market Acceptance Study was a two-stage survey that aimed to understand consumer perspectives on AC products that contribute to reducing climate change and ozone depletion.

The first stage involved administering an online questionnaire to end-users to assess their level of awareness and knowledge about eco-friendly ACs, the features that are most important to consumers when selecting a residential AC, the willingness of respondents to pay for eco-friendly specifications and energy efficiency, and the level of satisfaction with existing AC products available in the Egyptian market.

The second stage entailed conducting in-depth interviews with AC distributors in Egypt to assess their level of knowledge regarding eco-friendly ACs, understand the key features and characteristics of eco-friendly ACs, determine the potential price increase associated with eco-friendly specifications and energy efficiency, and formulate effective marketing strategies to introduce the concept of eco-friendly ACs to the Egyptian market.

The study findings shed light on the participants' perception of eco-friendly AC, with the majority associating them with energy and electricity savings.

When it comes to essential attributes of an air conditioning system, participants ranked after-sale service as the most significant, followed closely by high performance. While some respondents also considered eco-friendly technologies and affordability important, these attributes were not as highly valued.

The study found that participants were significantly interested in the concept of eco-friendly air conditioning and willing to pay more for it. Specifically, they expressed a willingness to pay a 5% premium to obtain eco-friendly features.

Additionally, the study identified digital media as the preferred communication channel for promoting eco-friendly air conditioning units, emphasizing the importance of online platforms in reaching and engaging with consumers. Offering discounts on the price of air conditioning units was also identified as an effective incentive for encouraging adoption.

Lastly, respondents emphasized the importance of energy efficiency in air conditioning systems as a driving factor in their decision-making process, highlighting the desire for lower electricity bills.

These findings provide valuable insights into the preferences and perceptions of consumers in the Egyptian market regarding eco-friendly air conditioning units. Manufacturers, suppliers, and policymakers can leverage these insights to develop effective marketing strategies, prioritize key attributes, and meet consumer demand for energy-efficient and cost-effective air conditioning solutions.

METHODOLOGY

The end-users quantitative survey was conducted through an online questionnaire that took 20 minutes length with a total sample of **402** respondents.

The sample consisted of **60%** males and **40%** females and there was a soft quota in the respondents' age ranges between **18 – 24** years, **25 – 40** years, and **41- 60** years.

The socio-economic class of the sample was 50% from the A and B classes and 50% from the C class and was calculated based on the education, occupation, and income of respondents. The survey was conducted in three successive phases.

The first phase was a pilot phase that was conducted on a small sample to make sure that all the survey questions were clear and understandable, ensuring that we reached our research objective from each question, with no errors in the survey.

The second phase was conducted in Cairo and Alexandria with the distribution of **44%** from Greater Cairo (Cairo and Giza) and **13%** from Alexandria.

The third phase was conducted on a sample of **22%** from Upper Egypt, **18%** from Delta cities, and **3%** from Suez Canal cities.

The distributors' qualitative survey was conducted through in-depth interviews with three computer assisted telephone interviews with the distributors' of ACs in Egypt.

The study applied a quality checks process throughout the survey different phases to ensure the quality of the respondents that they are all eligible with the survey criteria, and the quality of their responses to ensure that they have a clear understanding of the survey questions.

DATA COLLECTION TOOLS

A comprehensive study was conducted on end-users, surveying a total of 402 consumers. The study used the reliable and accurate Sawtooth SSI tool for conducting online surveys. The survey collected responses on various parameters, providing a rich dataset for analysis. The collected data was then analyzed using the Statistical Package for the Social Sciences (SPSS), which provided deep insights and valuable trends and patterns.

The qualitative phase (distributors) was conducted through In-depth computer-assisted telephone interviews.

SAMPLE SIZE FORMULA

Z score (also called a standard score) gives you an idea of how far from the mean a data point is. But more technically it's a measure of how many standard deviations below or above the population.

Sample Size Formula ($Z^2 \times P(1 - P) / E^2) \div (1 + ((Z^2 \times P(1 - P)) / E^2 N))$

N = AC Annual production size = 1,500,000 units (estimated)

E = Margin of error (5%)

Z = Desired confidence level (1.96) = 95%

P = Standard deviation (0.5)

($3.8416 \times 0.5 (0.5) / (0.05^2)$) $\div (1 + ((3.8416 \times 0.5 (0.5)) / 3.750))$ Total sample size = 385 participants

QUESTIONNAIRE STRUCTURE

The questionnaire has two flows and sequences based on the response to the first question:

- The first sequence is for respondents who purchased an eco-friendly AC; identified as **Yes Sample**
- The second sequence is for respondents who didn't purchase eco-friendly AC; and identified as **No Sample**


Below are the questions along with the objective of each question for the end-user survey.

1) Did you purchase Eco-friendly air conditioning before?		Measure the awareness, knowledge, and interest of the respondents in their willingness to buy Eco-friendly air-conditioning
<input type="checkbox"/> Yes <input type="checkbox"/> No		
2) Concerning the current ACs of the Egyptian Market, Assess your satisfaction level towards them on the level of energy efficiency		Assess the level of satisfaction with the current ACs (Energy efficiency& Price) in the Egyptian Market
<input type="checkbox"/> Extremely satisfied <input type="checkbox"/> Satisfied <input type="checkbox"/> Neutral <input type="checkbox"/> Unsatisfied <input type="checkbox"/> Extremely unsatisfied		
3) What is your definition when you hear that this product is "Eco-friendly"?		
<input type="checkbox"/>		
4) What are the features that make you say that the air conditioner is "Eco-friendly"? (From most important to least important)		Understand the level of awareness and interest of the respondents in environment related features in air conditioners use (R32)
<input type="checkbox"/> Energy efficiency <input type="checkbox"/> Reduces Carbon Emissions <input type="checkbox"/> Air purification feature <input type="checkbox"/> Customized AC Systems		
5) Does the idea of eco-friendly air conditioning motivate you to buy it?		<input type="checkbox"/> Yes <input type="checkbox"/> No
6) Did you know that air conditioning that works with Freon (R32) is eco-friendly that helps combat climate change (reducing global warming), and is more efficient in consuming electricity?		<input type="checkbox"/> Yes <input type="checkbox"/> No
7) Scale the important factors that important to you when you buy an AC?		Identify the respondents' priorities in selecting residential AC
<input type="checkbox"/> High performance <input type="checkbox"/> Affordability <input type="checkbox"/> Eco-friendly technologies <input type="checkbox"/> Brand credibility <input type="checkbox"/> After sale service <input type="checkbox"/> Shape & Design		<ul style="list-style-type: none"> • Extremely Important • Important • Neutral • Unimportant • Extremely unimportant
8) What is the feature that you wish/would like to have, that is not available in your current AC?		Gather info on respondents' potential wishes in ACs.
9) Are you willing to pay for an Eco-Friendly AC that offers less electric bill due to better Energy efficiency, Lower energy consumption, saving environmental & reducing global warming?		Finding out the acceptable price increase percentage that respondents are willing to pay for Eco-friendly AC.
10) To what extent are you willing to pay an extra amount in the price of the air conditioner to obtain higher technical and environmentally friendly specifications?		<ul style="list-style-type: none"> • 5% • 10% • 15% • More than 15%


Finding out the acceptable price increase percentage that respondents are willing to pay for Eco-friendly AC.RESULTS AND OUTPUTS (END-USERS)

The survey was conducted with the participation of 402 individuals. 182 respondents confirmed that they had purchased eco-friendly air-conditioners (ACs) and were referred to as the "**Yes Sample**". The remaining 220 individuals who did not buy eco-friendly ACs were referred to as the "**No Sample**".

The survey aimed to measure the respondents' awareness, knowledge, interest, and willingness to buy eco-friendly air-conditioning. The statistical analysis showed that out of the total sample of respondents, **45%** had already purchased eco-friendly ACs, while **55%** had not bought eco-friendly ACs.




As for the assessment of the satisfaction level with the current ACs products in the Egyptian Market. The statistical analysis of the sample shows that **48%** of the **Yes Sample** and **45%** of the **No Sample** was satisfied with the ACs in the Egyptian Market.



Assess the level of satisfaction with the current ACs (Energy efficiency and Price) in the Egyptian Market


Concerning the definition of the **Eco-friendly**, the statistical analysis of the sample shows that **27%** from **Yes Sample** define Eco-Friendly as it saves electricity, **8%** define it as a protects the environment, **6%** doesn't define it as emit harmful gases or emissions into the air, and **4%** define it as purifies the air.

While **26%** of the **No Sample** define Eco-Friendly as it saves electricity, **10%** define it as it reduces air pollution, **9%** as it purifies the air, and **6%** as it doesn't emit harmful gases or emissions into the air.




What is your definition when you hear that this product is "Eco-friendly"?

The statistical description below shows that respondents of **Yes Sample** and **No Sample** ranked the following attributes from most important to the least important Energy Efficiency comes first, followed by Reducing Carbon Emissions, then Air Purification Feature, and lastly the Customized AC Systems that suit the consumer habits.



What is your definition when you hear that this product is "Eco-friendly"?


The survey also revealed that **97%** of the **Yes Sample** are motivated by the idea of the eco-friendly AC while **3%** are not motivated by the idea. While **88%** from the **No Sample** are motivated and **12%** are not motivated by the idea of Eco-friendly ACs.




Does the idea of eco-friendly air conditioning motivate you to buy it?

According to the statistical analysis of the sample, **69%** of the respondents who answered "**Yes**" were aware that using AC with R32 can help combat climate change and reduce global warming while being more efficient in consuming electricity, while **31%** were not aware of this.

In contrast, only **41%** of the respondents who answered "**No**" knew about the eco-friendly benefits of AC with R32, while **59%** did not know.




According to the statistical analysis of the **Yes Sample**, the factors that most influence the decisions of AC consumers are "After Sale Service" (73%), "High Performance" (69%), "Eco-friendly Technologies" (58%), and "Brand Credibility" (52%). These factors were rated as "Extremely Important" by the majority of respondents.





Factors that affect AC consumer decisions


While, the respondents of **No Sample** rated 'After Sale Service' as the most important factor with an extremely high percentage of 71%, followed by 'High Performance' at 63%, 'Affordability' at 61%, and 'Brand Credibility' at 49%.



Regarding the identification of respondent preferences that are not currently available in the AC. The statistical analysis of the sample shows that 9% of the **Yes Sample** wish to have ACs that save electricity and power, followed by 4% that wish to have Air Purifying ACs, and 3% wish to have smart ACs that controlled by mobile app, while 21% of **No Sample** wish that ACs save electricity and power, followed by 5% that wish to have ACs that purify the air and 3% wish to have quiet ACs.




The last part of the survey is designed to investigate the respondents' willingness to pay for an Eco-Friendly AC that offers Energy efficiency, lower energy consumption, saving the environment, and reducing global warming. The statistical analysis of the sample shows that 93% of the **Yes Sample** and 80% of the **No Sample** are willing to pay an extra amount for the Eco-Friendly AC offered specifications.



Willingness to pay an extra amount for Eco-Friendly AC specifications

The concluded statistics for the acceptable price increase percentage show that the mean of the acceptable price increase is 5% as per 43% of the **Yes Sample** and 55% of the **No Sample**.



The acceptable price increase percentage that respondents are willing to pay for Eco-friendly AC.

RESULTS AND OUTPUTS (DISTRIBUTORS)

The qualitative phase comprised in-depth interviews with three AC distributors in Egypt. The questions and responses are presented below.

Question One: Amidst the current challenges, what opportunities exist in the air conditioning market?

There are various challenges faced by distributors in the air conditioning market such as short supply of all devices, suspension of imports, poor after-sale service, and scarcity of raw materials. Despite these challenges, there are still opportunities in the market such as improvements for after-sales service and the availability of air conditioners again.

Question Two: What are the factors that consumers usually consider when buying air conditioners?

The factors that consumers consider when buying air conditioners include 1) after-sale service, 2) competitive price, 3) material used, 4) brand name, 5) product quality, and 5) warranty.

Question Three: Suppliers were asked to rank the importance of various characteristics to consumers when purchasing an air conditioner?

They rated Price, Brand Credibility, and After-sale Service as Very Important. High Performance and Eco-friendly Technologies were rated as Important. Finally, the Shape and Design of the AC were rated as Neutral.

Question Four: What is the feature that the consumer wishes/ would like to have, that is not available in their current AC?

Suppliers have identified three main factors. Firstly, consumers want ACs that are energy-efficient to reduce electricity consumption. Secondly, they prefer ACs made with high-quality materials that are reasonably priced. Finally, there is a growing demand for smart ACs that can be controlled via Wi-Fi.

Question Five: Rank the characteristics that make you say that the air conditioner is “Eco-Friendly”.

This is the ranking that suppliers gave to the eco-friendly characteristics of ACs: 1) Energy Efficiency, 2) Air Purification Feature, 3) Customized AC Systems, 4) Reduce Carbon Emissions

Question Six: How would you rate the idea of an eco-friendly air conditioning unit that offers better energy efficiency, lower energy consumption, and helps in saving the environment by reducing global warming while also providing a lower electricity bill?

AC distributors were presented with this new concept, and they all rated it as excellent.

Question Seven: What is your perceived average increase in price (as a percentage) that an air conditioner with higher technical and environmentally friendly specifications can be sold for?

Distributors have different opinions on the price increase for the new concept: 10%, more than 15%, and 50%.

Question Eight: How can this concept be marketed effectively to consumers to maximize its value for them?

According to the distributors, the best way to market this concept is through digital media platforms as they are the most common channels of communication with consumers. TV ads can also be used by communicating through the brand itself. Additionally, offering discounts and promotions that encourage consumers to buy the product is another effective way to market this concept.

FINDINGS

Based on the study's findings and results, several key insights emerge:

- I. A significant majority of respondents (97% from the "yes" sample and 88% from the "no" sample) express motivation and interest in the new concept of eco-friendly ACs. This indicates a strong market potential and consumer receptiveness towards environmentally eco-friendly air conditioning solutions.
- II. The study reveals that a substantial proportion of respondents (93% from the "yes" sample and 80% from the "no" sample) are willing to pay an additional amount for eco-friendly ACs. This willingness to invest in eco-friendly features demonstrates a growing awareness and desire among consumers to prioritize sustainable and energy-efficient products.
- III. Among the respondents who express a willingness to pay more for eco-friendly ACs, the most commonly cited percentage increase in the price is 5%. This finding suggests that pricing strategies should consider this benchmark to align with consumer expectations and maximize market acceptance.
- IV. Digital media emerges as the preferred communication channel among consumers. Leveraging online platforms, such as social media, websites, and targeted digital advertising, will be effective in reaching and engaging with the target audience. Additionally, offering discounts or special promotions through these channels can further enhance the appeal and market acceptance of eco-friendly ACs.

These findings underscore the potential for successful market acceptance of eco-friendly ACs in the Egyptian market. By effectively promoting the energy-saving and environmentally conscious aspects of these ACs through digital outreach channels, and considering a reasonable price increase of around 5%, manufacturers and distributors can capitalize on the growing consumer demand for sustainable and energy-efficient air conditioning solutions.

CONCLUSION

- 1) One of the key benefits of eco-friendly air conditioners is their ability to save electricity and operate with high energy efficiency, which is a top priority for consumers. The eco-friendly ACs are similar to inverter ACs but also contribute to environmental preservation. Energy efficiency is a significant attribute that resonates with consumers, and it should be emphasized when introducing the concept.
- 2) Providing robust after-sale service is crucial to ensuring customer satisfaction when purchasing ACs. Consumers consistently rate excellent after-sale service and optimal performance of the AC units as extremely important. Delivering both will enhance customer loyalty and satisfaction.
- 3) Consumers are willing to accept a modest increase of 5% in the price of ACs for eco-friendly specifications. This percentage aligns with the majority of respondents and can serve as a suitable benchmark for pricing strategies.
- 4) Digital media platforms are recommended as the primary communication channel to effectively convey the benefits of eco-friendly ACs and engage with consumers. These platforms offer extensive reach and enable targeted marketing campaigns. Emphasizing the energy-efficient nature of the ACs and implementing discounts or special offers can create a compelling value proposition for prospective buyers.

By incorporating these key points in marketing and business strategies, manufacturers and distributors can effectively promote eco-friendly ACs in the Egyptian market, addressing consumer demands and contributing to sustainable environmental practices.



Technical and Financial Report for the Group Project for Transformation of Commercial Air Conditioning Companies (HCFC Phase-out Management Plan (HPMP) EGYPT (Stage II)),
UNIDO ID:140400

2022

Report

Project supported by

MULTILATERAL FUND FOR THE IMPLEMENTATION OF THE MONTREAL PROTOCOL



UNITED NATIONS ENVIRONMENT



UNITED NATIONS INDUSTRIAL DEVELOPMENT ORGANIZATION

Disclaimer

This report may be reproduced in whole or in part and in any form for educational or non-profit purposes without special permission from United Nations Industrial Development Organization (UNIDO) and United Nations Environment (UNEP), provided acknowledgement of the source is made. UNIDO and UNEP would appreciate receiving a copy of any publication that uses this publication as a source. No use of this publication may be made for resale or for any other commercial purpose whatsoever without prior written permission from UNIDO and UNEP.

While the information contained herein is believed to be accurate, it is of necessity presented in a summary and general fashion. The decision to implement one of the options presented in this document requires careful consideration of a wide range of situation-specific parameters, many of which may not be addressed by this document. Responsibility for this decision and all its resulting impacts rests exclusively with the individual or entity choosing to implement the option. UNIDO, UNEP, their consultants and the reviewers and their employees do not make any warranty or representation, either expressed or implied, with respect to the accuracy, completeness or utility of this document; nor do they assume any liability for events resulting from the use of, or reliance upon, any information, material or procedure described herein, including but not limited to any claims regarding health, safety, environmental effects, efficacy, performance, or cost made by the source of information.

Acknowledgement

We would like to acknowledge the assistance given by the governmental sectors and the National Ozone Unit Officers of Egypt and Housing & Building National Research Center HBRC for their support in the implementation of the project and their assistance in facilitating communication with different stakeholders.

We also acknowledge the International Technical Review Team “EUROPEAN INDUSTRY ASSOCIATION Eurovent” that assist the project team in reviewing the process, results and report of the project.

Acknowledgement also goes to the “Egyptian Russian University ERU” for providing the testing yard, facilities (Electrical feeding, water supply ... etc.). In the same manner, Acknowledgement also goes to the “Movenpick Soma Bay Hurghada hotel” for providing the testing yard and the facilities (Electrical feeding, water supply, Wi-Fi network and so).

The project team also acknowledges the OEM manufacturers who built the IEC-H and DX system prototypes to be tested at the two definite locations.

- Delta Construction & Manufacturing DCM
- MISR Engineering Industries
- TIBA Engineering Industries Co.
- VOLTA EGYPT

Acknowledgement also goes to the OEM manufacturers who still actively working on building the IEC-H and DX system prototypes to be tested at the new expansion phase of the project.

- Egyptian German Air Treatment Company (EGAT)
- Misr Refrigeration & Air Conditioning MFG Co. (MIRACO)

Project Team

This Project is contracted between the UNITED NATIONS INDUSTRIAL DEVELOPMENT ORGANIZATION "UNIDO" and Housing & Building National Research Center "HBRC". WHEREAS, UNIDO has been designated by the MULTILATERAL FUND FOR THE IMPLEMENTATION OF THE MONTREAL PROTOCOL as IMPLEMENTING AGENCY; and has agreed to provide assistance to the Egyptian Government in carrying out the project entitled "HCFC PHASE-OUT MANAGEMENT PLAN (HPMP) EGYPT (STAGE II)"

The National Ozone Unit – Ministry of Environment, Egypt: The ministry team provided guidance and direction and participated at project meetings and discussions. The project is funded by the HCFC Phase-out Management Plan (HPMP) of Egypt.

The Project Management: UNIDO and UN Environment provided overall management and coordination of the project, established the link with the technology providers, and oversaw the development of the report of the project. The Project was managed by **Mr. Ole Nielsen, Dr. Iino Fukuya**, Program Officer – UNIDO and **Eng. Ayman El-Talouny**, International Partnership Coordinator, Ozone Action Program – UN Environment

The Coordination Consultant, Eng. Shahenaz Fouad and Eng. Ahmed El-Korashy provided logistical support and coordination for the project.

The Project general Manager and Technical Consultant and writer of the report, Dr. Alaa Olama advised OEMs during prototype design and construction. Devised testing methodology and testing TOR, consulted with OEMs to provide technical solutions for problems as they arose wrote the report and provided analysis of data.

HBRC organized testing including testing results in both climatic zones, tabulated and created the excel sheets including figures, drawings and review and edit of the report

The project personnel provided by the HBRC are as follows:

Name	Project Function
Prof. Sayed Shebl Mohamed	Team Leader
Eng. Sally Aladdin Ali	Expert Testing Engineer
Eng. Aya Mohamed Zaki	Expert Testing Engineer
Eng. Nourhan Abdel Rahman Mohamed	Expert Testing Engineer
Mr. Mohamed Shebl Mohamed	Specialized Accountant Manager
Mr. Shady Gamal Abdel Aziz	Specialized Awareness and Hospitality Assistant
Mr. Farid Rashed Ibrahim	Specialized Testing Technician
Mr. Ahmed Maher Mohamed	Specialized Testing Technician
Mr. Mostafa Abdullah Hamad	Specialized Testing Technician
Mr. Ahmed Ezzat Mahmoud	Specialized IT Assistant
Mss. Hebatallah Waheed Ismail	Secretarial Work
Mr. Mohamed Hassan Ahmed	Secretarial Work
Mr. Mohamed Ibrahim Abdel Moety	Driver

Table of Contents

List of Figures	6
List of Tables	7
Acronyms.....	8
Executive Summary.....	9
1. Results and analysis of the testing and measurements for the prototypes for all OEMs in two locations.....	13
1.1. Selection of climatic zones 2 and 5.....	13
1.2. OEMs1 and 5 did not participate in the tests.....	14
1.3. OEMs active participation in the testing program.....	14
1.4. Report no. 1, the Pre-testing phase.....	14
1.5. How were the tests performed?.....	15
1.6. The testing methodology (annex 2).....	15
2. Tabulation formats for compiling and presenting the results of the project (Results in CZ 2 and CZ 5).....	17
3. Provision of the technical parameters for the financial model (capital and operating costs of OEMs).....	18
4. Analysis of testing and measurements for the prototypes and DX units.....	20
4.1 OEM2, Climatic zone 2.....	20
4.2 OEM2, Climatic zone 5.....	24
5. The Final Results Analysis with Conclusion and Recommendation for Future Work.....	29
5.1. The Final results analysis.....	29
5.1.1. EER high and low, CZ2.....	29
5.1.2. Capacity high and low, CZ2.....	29
5.1.3. EER high and low, CZ5.....	30
5.1.4. Capacity high and low, CZ5.....	30
5.2. Conclusion.....	30
5.3. Recommendation for Future Work.....	31
6. Reporting on the Advocacy and Outreach Campaign.....	33
7. Review and recommendation on how to update the national institutional technical documents of the new technologies.....	35
 Annex (1) Provision of the technical parameters for the financial model (capital and operating costs of OEMs).....	36
Annex (2) Pre-testing report no. 1.....	57
Annex (3) Testing methodology.....	97
Annex (4) Results in CZ2.....	109
Annex (5) Results in CZ5.....	118
Annex (6) Accuracy and Sensitivity of Measurements.....	128
Annex (7) The presentation of the outreach campaign.....	132

List of Figures

Figure 1:The Eight Climatic Zones of Egypt.....	13
Figure 2:Schematic Diagram of the Test Arrangement with Instrumentation	16
Figure 3:Inlet ambient temperature versus outlet temperature of IEC Hybrid and DX units for OEM2 at CZ2	21
Figure 4: EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM2 at CZ2	21
Figure 5:Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM2 at CZ2	21
Figure 6:Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM2 at CZ2	22
Figure 7:Power consumption of DX unit and IEC Hybrid unit components for OEM2 at CZ2	22
Figure 8:Inlet ambient temperature versus outlet temperature of IEC Hybrid unit & DX unit for OEM2 at CZ5.....	25
Figure 9:EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM2 at CZ5	25
Figure 10:Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM2 at CZ5	25
Figure 11:Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM2 at CZ5	26
Figure 12:Power consumption of DX unit and IEC Hybrid unit components for OEM2 at CZ5	26
Figure 13:High and Low EER for Climatic Zone 2	29
Figure 14:High and Low Cooling Capacity for Climatic Zone 2	29
Figure 15:High and Low EER for Climatic Zone 5	30
Figure 16:High and Low Cooling Capacity for Climatic Zone 5	30
Figure 17:Inlet ambient temperature versus outlet temperature of IEC Hybrid unit & DX unit for OEM3 at CZ2.....	34
Figure 18:EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM3 at CZ2	34
Figure 19:Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM3 at CZ2	34
Figure 20:Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM3 at CZ2	35
Figure 21:Power consumption of DX unit and IEC Hybrid unit components for OEM3 at CZ2	35
Figure 22:Inlet ambient temperature versus outlet temperature of IEC Hybrid unit & DX unit for OEM3 at CZ5.....	37
Figure 23:EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM3 at CZ5	37
Figure 24:Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM3 at CZ5	38
Figure 25:Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM3 at CZ5	38
Figure 26:Power consumption of DX unit and IEC Hybrid unit components for OEM3 at CZ5	38
Figure 27:Inlet ambient temperature versus outlet temperature of IEC Hybrid unit & DX unit for OEM4 at CZ2.....	41
Figure 28:EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM4 at CZ2	41
Figure 29:Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM4 at CZ2	42
Figure 30:Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM4 at CZ2	42
Figure 31:Power consumption of DX unit and IEC Hybrid unit components for OEM4 at CZ2	43
Figure 32:Inlet ambient temperature versus outlet temperature of IEC Hybrid unit & DX unit for OEM4 at CZ5.....	44
Figure 33:EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM4 at CZ5	45
Figure 34:Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM4 at CZ5	45
Figure 35:Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM4 at CZ5	46
Figure 36:Power consumption of DX unit and IEC Hybrid unit components for OEM4 at CZ5	46
Figure 37:Inlet ambient temperature versus outlet temperature of IEC Hybrid unit & DX unit for OEM6 at CZ2.....	49
Figure 38:EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM6 at CZ2	49
Figure 39:Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM6 at CZ2	49
Figure 40:Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM6 at CZ2	50
Figure 41:Power consumption of DX unit and IEC Hybrid unit components for OEM6 at CZ2	50
Figure 42:Inlet ambient temperature versus outlet temperature of IEC Hybrid unit & DX unit for OEM6 at CZ5.....	52
Figure 43:EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM6 at CZ5	52
Figure 44:Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM6 at CZ5	53
Figure 45:Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM6 at CZ5	53
Figure 46:Power consumption of DX unit and IEC Hybrid unit components for OEM6 at CZ5	54

List of Tables

Table 1 Testing in climatic zones 2 and 5	14
Table 2 Basic Information for OEM2 at Climatic Zone 2.....	20
Table 3 High and Low readings for OEM2 at Climatic Zone 2.....	22
Table 4 Basic Information for OEM2 at Climatic Zone 5.....	24
Table 5 High and Low readings for OEM2 at Climatic Zone 5.....	26
Table 6 Concluding remarks on the performance of OEM2 IEC-H unit and the DX unit in CZ2 and CZ5.....	28
Table 7 Basic Information for OEM3 at Climatic Zone 2.....	33
Table 8 High and Low readings for OEM 3 at Climatic Zone 2.....	35
Table 9 Basic Information for OEM3 at Climatic Zone 5.....	36
Table 10 High and Low readings for OEM3 at Climatic Zone 5.....	39
Table 11 Concluding remarks on the performance of OEM3 IEC-H unit and the DX unit in CZ2 and CZ5	40
Table 12 Basic Information for OEM4 at Climatic Zone 2.....	40
Table 13 Basic Information for OEM4 at Climatic Zone 5.....	44
Table 14 High and Low readings for OEM4 at Climatic Zone 5.....	46
Table 15 Concluding remarks on the performance of OEM4 IEC-H unit and the DX unit in CZ2 and CZ5	47
Table 16 Basic Information for OEM6 at Climatic Zone 2.....	48
Table 17 High and Low readings for OEM6 at Climatic Zone 2.....	50
Table 18 Basic Information for OEM6 at Climatic Zone 5.....	51
Table 19 High and Low readings for OEM6 at Climatic Zone 5.....	54
Table 20 Concluding remarks on the performance of OEM6 IEC-H unit and the DX unit in CZ2 and CZ5	55

Acronyms

HPMP	HCFC Phase-out Management Plan
IEC-H	Indirect Evaporative Cooling - Hybrid
DX	Direct Expansion
CZ	Climatic Zone
GWP	Global Warming Potential
NPV	Net Present Value
EFLH	Equivalent Full Load Hours Per Year
EER	Energy Efficiency Ratio
COP	Coefficient of Performance
IRR	The internal rate of return
EGP	Egyptian Pound
$T_{db\ amb}$	Ambient dry bulb temperature for both Units
$T_{wb\ amb}$	Ambient wet bulb temperature for both Units
RH_{amb}	Ambient Relative Humidity for both Units
$T_{db\ out\ IEC-H}$	Outlet dry bulb temperature for IEC Hybrid Unit
$T_{wb\ out\ IEC-H}$	Outlet wet bulb temperature for IEC Hybrid Unit
$RH_{out\ IEC-H}$	Outlet Relative Humidity for IEC Hybrid Unit
$W_{Lvl\ IEC-H}$	Water level change for IEC Hybrid Unit per hour
$W_{Vol\ IEC-H}$	Evaporated Water Consumed for IEC Hybrid Unit per hour (Volumetric Flow Rate)
Comp. IEC-H	Compressor power consumption for IEC Hybrid Unit
Pump IEC-H	Pump consumption for IEC Hybrid Unit
Evap. Fan IEC-H	Evaporative Fan consumption for IEC Hybrid Unit
Sup. Fan IEC-H	Supply Fan consumption for IEC Hybrid Unit
$Pw_{Tot\ IEC-H}$	Total Power consumption for IEC Hybrid Unit
$T_{db\ out\ DX}$	Outlet dry bulb temperature for DX Unit
$T_{wb\ out\ DX}$	Outlet wet bulb temperature for DX Unit
$RH_{out\ DX}$	Outlet relative humidity for DX Unit
$Pw_{Tot\ DX}$	Total Power consumption for DX Unit
h_{amb}	Enthalpy of Ambient inlet Air
$h_{out\ DX}$	Enthalpy of outlet Air for DX Unit
$h_{out\ IEC-H}$	Enthalpy of outlet Air for IEC Hybrid Unit
ρ_{amb}	Density of Ambient Air

Executive Summary:

This Project is contracted to provide assistance to the Egyptian Government in carrying out the project entitled “HCFC PHASE-OUT MANAGEMENT PLAN (HPMP) EGYPT (STAGE II)”

The project required each OEMs to individually manufacture a custom-built Indirect Evaporative Cooling Hybrid Air Conditioner (IEC-H) prototypes and a central DX unit to test and compare their performances under actual operating conditions in two of the eight climatic zones of Egypt.

The five figures below show the results of one OEM only in the two climatic zones tested. The figures below show the comparisons of the performance between the IEC-H unit and the DX unit over a 24 hours period. The tests results compared the values of the dry bulb temperatures out of the IEC-H and the DX units, the wet bulb temperatures, the EERs and the unit’s capacities. The tests were conducted for each OEM’s IEC-H and DX units simultaneously for a 24 hours period in two climatic zones.

Figure 3: Inlet ambient temperature versus outlet temperature of IEC Hybrid and DX units for OEM2 at CZ2




Fig 4: EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM2 at CZ2




Fig 5: Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM2 at CZ2




Fig 6: Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM2 at CZ2





Fig 7: Power consumption of DX unit and IEC Hybrid unit components for OEM2 at CZ2



All OEMs results (see Annex 1) showed better EER for their IEC-H units compared to their respective DX unit in the two climatic zones where the tests were conducted. The highest and lowest EERs of all OEMs are shown below in the two climatic zones.

In that sense, the report showed that an IEC-H system is superior thermodynamically to a DX system because it achieves higher EERs.

Fig 13: High and Low EER (in BTU/W.hr) for Climatic Zone 2





Fig 15: High and Low Capacity (in W) for Climatic Zone 5



Although the air discharge of both units for each OEM were the same, compressor capacity for each OEM varied considerably. OEMs used different capacity compressor in their IEC-H units compared to their respective DX unit tested. The tests showed that the capacity of the IEC-H unit when compared to the capacity of the respective DX unit also varied considerably. For a certain OEM, for some it was higher and for others inferior.

However, the report recommends further work to decide on the optimum size of compressor suitable for the IEC-H systems at all climatic zones assisted by further tests at the harshest climatic zone, CZ 8 to complete the tests needed for the writing of a code for Direct Indirect Evaporative Cooling.

The report breaks new ground for NIK air conditioning technologies and provides an alternative full fresh air system for air conditioning application that exceeds the efficiency of existing DX systems.


Chapter 1

1. Results and Analysis of the Testing and Measurements for the Prototypes for all OEMs in Two Locations

1.1. Selection of Climatic Zones 2 and 5

Figure 1: The Eight Climatic Zones of Egypt

1	North Coast Region	5	Eastern Coast Region
2	Delta and Cairo region	6	High Heights Region
3	North Upper Egypt Region	7	Desert Region
4	Southern Upper Egypt Region	8	South of Egypt Region



Ambient temperatures in Egypt's are at their highest during June, July and August. This is why these months were targeted for the tests.

The tests were repeated in two climatic zones to show the effect of dry bulb temperature increase versus relative humidity decrease on the efficiency and capacity of the prototypes. Changes in these two parameters in two diverse zones, climatic zone 2 and climatic zone 5, would indicate the viability of an IEC-H system in lower humidity/higher ambient climates when compared to a DX system.

Figure 1 shows the different climatic zones of Egypt. Climatic zone 2 encompass the capital Cairo and its suburban cities across its latitude in the span west in the lower delta south of Alexandria's longitude and east across the Sinai Peninsula. Climatic zone 2 would be generally characterized

by its relatively higher humidity because it is in the lower delta with its extensive population clusters and its large agriculture fields. Tests in CZ 2 were performed at Badr city.

Climatic zone 5 is the eco-climatic zone around the shores of the red sea north from Suez to south in Halayeb and Shalatein and across south Sinai on the banks of the gulfs of Suez and Aqaba. Its dry bulb temperatures are moderate compared to further south in Egypt.

Climatic zone 5 is characterized by its higher dry bulb temperatures compared to CZ 2 and its lower humidity. Tests were performed in Hurghada city in CZ 5.

Comparison between the results in these two climatic zones would indicate the feasibility of the IEC-H system compared to a DX system as the dry bulb increases and the humidity decreases.

1.2. OEMs 1 and 5 did not Participate in the Tests

Although all manufacturers of central air-condition units in Egypt declared their intentions to participate in the project, in the end four out of six actively participated.

Two OEMs declined participation because of inability to allocate time or funds to manufacture IEC-H units. Both OEMs, though declared their intentions to participate in future projects in the same subject.

1.3. OEMs Active Participation in the Testing Program

Table 1: Testing in climatic zones 2 and 5

Status of Testing IEC Hybrid Prototypes and DX Units for all OEMs in August 2022				
OEM	Both Units Ready	Climatic Zone 2 Testing Date in Badr City	Climatic Zone 5 Testing Date in Hurghada	Comments
1	No	---	---	<i>Will not be ready this summer</i>
2	Yes	22- Aug	25- Aug	<i>Finished testing in both CZ2 and CZ5</i>
3	Yes	16- Jun	5- Jul	<i>Finished testing in both CZ2 and CZ5</i>
4	Yes	4- Aug	27- Aug	<i>Finished testing in both CZ2 and CZ5</i>
5	Declined Participation	---	---	<i>Declined testing – Needs technical assistance</i>
6	Yes	19- Jun	3- Jul	<i>Finished testing in both CZ2 and CZ5</i>

Although all six OEMs manufacturing central air conditioning units in Egypt consented to participate in the testing program, only four OEMs tested their units in the two climatic Zones. Not all OEMs prototypes were ready for testing during these months. Table 1 shows the status of testing of the OEMs at the end of August 2022.

The reasons some OEMs could not participate in testing are elaborated on in 1.2.

1.4. Report no. 1, the Pre-Testing Phase

In report no. 1, the Pre-testing phase was reported and its results were listed. In this Pre-testing phase, the same criteria for testing were used, together with the same unit's arrangement. Please

refer to **annex 2** for the first report. The Pre-testing phase provided data and information on the problems associated with testing and also validated the selection of CZ 2 as a climatic zone with relatively higher humidity.

1.5. How the Tests were Performed?

Each OEM tested two of his units in the same 24 hours, one IEC-H next to one DX unit.

Each OEM tested in the two designated climatic zones, 2 and 5.

Both units tested were full fresh air and had the same air flow rate.


Initially it was hoped the OEMs will use lower-GWP refrigerants approved to use in Egypt, R-32 and R-454 B. Unfortunately, this proved impossible because of the difficulties obtaining compressors for these refrigerants locally. To wait until compressors were sent from abroad, we would have missed the summer month's window and delayed the project a full year.

1.6. The Testing Methodology

This is a brief description of the testing methodology. The complete testing methodology is shown in **annex 3**; the testing methodology follows EUROVENT recommendations.

- There were no intentions to compare the performance of OEMs units, one against the other. This is why OEMs are labelled by a confidential number and not by their original name.
- The purpose of the tests is to find out if there are energy efficiency advantages obtained by adopting a hybrid IEC system, IEC-H, when compared to a DX or chilled water system for the Egyptian climatic zones 2 and 5.
- Both units tested simultaneously were full fresh air units with rate of air discharge of one unit regulated so that it matches the other.
- To try to maintain 15 °C primary air outlet dry bulb temperature.
- For each OEM, testing was performed over a 24hr period for both units simultaneously.
- The tests performed for all OEMs, one after the other.
- The tests were considered completed once a 24 hours cycle is recorded for both IEC hybrid and DX units. If any of the units stopped working during the test, the test results were discarded.
- The tests meteorological readings were recorded.
- The tests were performed to obtain the total cooling capacities (watts) and the energy efficiency ratios (BTU/W.hr) of both IEC-H and the DX unit for each OEM simultaneously and compare the results over a 24 hours period; see the Egyptian standard EOS 3795:2013.
- In this report, the test values are plotted and analysed to help obtaining a definite understanding of the advantages of the systems at various climatic zones.
- An economic comparison is made by an economic expert to compare the Net Present Value (NPV) of the IEC-H to a DX unit over its lifetime to check its economic feasibility.
- The results of the economic study are now being calculated by the economic expert. The results of the economic analysis will be published when finished.
- Figure 2 shows the Schematic Diagram of the Test Arrangement with Instrumentation.

Fig 2: Schematic Diagram of the Test Arrangement with Instrumentation



Chapter 2

2. Tabulation Formats for Compiling and Presenting the Results of the Project (Results in CZ2 and CZ5)

The results obtained were tabulated in excel sheets tabs as follows:

- Basic information
- Used apparatus for testing
- Abbreviations
- Final results listing
- Calculations of capacities and EERs for IEC-H
- Calculations of capacities and EERs for DX
- Graphs
- Units' arrangement drawing.

The tabs of the calculations of capacities and EERs for IEC-H units were used to plot the essential graphs in the tab graphs.

The figures show the following:

Figure 3: The ambient dry bulb temperature and the outlet dry bulb temperatures of the IEC-H and the DX units across a whole day

Figure 4: the EERs of both the IEC-H and the DX units and ambient RH across a whole day.

Figure 5: The cooling capacities of the IEC-H and DX unit and the ambient dry bulb temperature and RH across a whole day

Figure 6: The cooling capacities and the outlet wet bulb temperatures and RHs of the IEC-H and DX units across a whole day

Figure 7: The power consumptions of the DX unit and the IEC-H unit and its components.

This was repeated for each OEM in the two designated climatic zones, 2 and 5.

These figures were used in the analysis that follows each OEM.

All tabulated excel sheets are included in annexes 4 and 5.

Chapter 3

3. Provision of the Technical Parameters for the Financial Model (Capital and Operating Costs of OEMs)

The financial analysis will provide us with figures that will help us decide if an IEC-H system is economically advantageous compared to a DX system.

In order to clarify how the economic study is made for all OEMs, a simplified example for OEM2 in CZ 2 is listed here. All figures used in this example are provided by the OEM2 or from the tests conducted for the OEM2 in CZ 2.

OEM2 CZ2 - Basic Assumptions:

- **Investment Cost:**

Unit Type	DX unit	IEC Hybrid
Total Price, EGP	355,000	385,000

- **Annualizing the test:**

Testing between the two units was conducted on August 22, 2022, and an EFLH (equivalent full load hours per year) is assumed to characterize the test results annually.

The annual operation is assumed based on EFLH of 50% of total annual working hours as illustrated in the following table:

Months Operating		12
Days Operating		365
Yearly working hours	hr	8,760
Equivalent Full Load Hours	%	50%
EFLH per year	hr	4,380

- **Cost of Operations:**

The main costs incurred for producing the required energy is illustrated as in below.

Maximum Power Consumption	W/hr	Annual Electricity Consumption
IEC Hybrid Unit	8,607	37,698,660
DX Unit	10,802	47,314,512
Average Cost	kW/hr	1.60 (EGP)
Electricity cost Increase	%	0.00%
Electricity Cost		
IEC Hybrid Unit	EGP	60,318
DX Unit	EGP	75,703
Difference -Saving	EGP	15,385

The main costs incurred for the required water is illustrated as in below.

Maximum Water Consumption	Litres/hour	Annual Water consumption
IEC Hybrid Unit	54	236,520
DX Unit	-	-
Average Cost per Cubic meter		5.00 (EGP)
water cost Increase	%	0.00%
Water Cost		
IEC Hybrid Unit	EGP	1,183
DX Unit	EGP	-
Difference -Saving	EGP	(1,183)

■ **Total Saving and Returns:**

The test showed a favorable difference for IEC Hybrid Unit, as it achieved total saving in its operation cost amount EGP 14,203 as illustrated in the following table:

Electricity Saving	15,385
Water Expenditure	(1,183)
Net Saving	14,203

The test showed a favorable difference for IEC-H unit, as it achieved total saving in its investment cost amount EGP 30k as illustrated in the following table:

UNITS PRICES (EGP)	
IEC Hybrid Unit	385,000.00
DX Unit	355,000.00
Difference -Costs	(30,000.00)

The following table, the IEC Hybrid Unit shows favorable IRR of 46%, and NPV amount EGP 24,621 with a payback period of 3.11 years.

		Year (0)	Year (1)	Year (2)	Year (3)	Year (4)
Net Cash		(30,000)	14,203	14,203	14,203	14,203
Cumulative Cash Flows		(30,000)	(15,797)	(1,594)	12,608	26,811
Discount Rate		20%				
NPV	EGP	24,620.57				
IRR	%	46%				
Breakeven Year	Years	3.00				
Fraction	Years	0.11				

Chapter 4

4. Analysis of Testing Results and Measurements for the Prototypes and DX Units.

The testing results and measurements for the prototypes and DX units provide us with figures that show us if an IEC-H system is technically advantageous compared to a DX system. The testing results and measurements for all OEMs are listed in details in Annex (1).

4.1. OEM2, Climatic Zone 2

Table 2: Basic Information for OEM2 at Climatic Zone 2

Basic Information			
Tested Units Name	DX		Direct Expansion Unit
	IEC hybrid		Indirect Evaporative Cooling Hybrid Unit
OEM No.	2		
Air Flow Rate	2000		c.f.m for DX and IEC hybrid Units
Water Bath Area	1000*900		mm ²
Climatic Zone	2 (Delta and Cairo Region)		
	Altitude	208	meter (from sea level)
	Location	30°08' 36" N 31°43' 06" E	
Test Date	22-Aug-22		
Compressor Capacity	DX	10 TR	35.2 kW
	IEC-H	10 TR	35.2 kW
		DX Unit	IEC Hybrid Unit
Compressor brand	Copeland Scroll ZP		Copeland Scroll ZP
Refrigerant	R410 A		R410 A

The figures below show the following:

- Figure 3: The ambient dry bulb temperature and the outlet dry bulb temperatures of the IEC-H and the DX units across a whole day for OEM2 at CZ2.
- Figure 4: The EERs of both the IEC-H and the DX units and ambient RH across a whole day for OEM2 at CZ2.
- Figure 5: The cooling capacity of the IEC-H and DX unit and the ambient dry bulb temperature and RH across a whole day for OEM2 at CZ2.
- Figure 6: The cooling capacities and the outlet wet bulb temperatures and RHs of the IEC-H and DX units across a whole day for OEM2 at CZ2.
- Figure 7: The power consumptions of the DX unit and the IEC-H unit and its components for OEM2 at CZ2.

Fig 3: Inlet ambient temperature versus outlet temperature of IEC Hybrid and DX units for OEM2 at CZ2




Fig 4: EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM2 at CZ2




Fig 5: Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM2 at CZ2




Fig 6: Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM2 at CZ2





Fig 7: Power consumption of DX unit and IEC Hybrid unit components for OEM2 at CZ2



Analysis of the results of OEM2 at CZ 2:

Table 3: High and Low readings for OEM2 at Climatic Zone 2

CZ2					
High and low, °C					
T _{db amb}	RH _{amb}	T _{db out} IEC-H	T _{wb out} IEC-H	T _{db out} DX	T _{wb out} DX
37.7	55.3 @ 22:00	14.2	11.9	12.8	11.1
24.9	29.0 @ 13:00	8.5	7.2	9.6	8.9

➤ **$T_{db\ out}$ Comparison:**

- In figure 3, the outlet dry bulb temperatures of both units are close to each other.
- The swing in $T_{db\ out}$ of DX unit is from 12.8 °C to 9.6 °C, 3.2 °C swing
- The swing in $T_{db\ out}$ of IEC-H unit is from 14.2 °C to 8.5 °C, 5.7 °C swing
- The daily $T_{db\ amb}$ changes from 37.7 °C down to 24.9 °C, a swing of 12.8 °C.
- The changes of $T_{db\ out}$ of IEC-H unit are consistent with the ambient dry bulb, as it goes up it increases and vice versa. The same applies for the DX unit.

➤ **EERs Comparison:**

- In figure 4, the EERs of the IEC-H are consistently higher than those of the DX unit although both use the same compressor capacity.
- The swing in the values of the EERs of both units is consistent with the relative humidity. As the RHs increases the EERs decreases and vice versa.

➤ **Capacities Comparison:**

- In figure 5, the IEC-H capacities are higher than those of the DX unit consistently except in the period 12:00 to 17:00 and 18:00 to 20:00 pm due to the losses in hot gas bypass.
- This is important to note considering that both systems are equipped with the same capacity compressors.

➤ **$T_{wb\ out}$ Comparison:**

- In figure 6, the changes of $T_{wb\ out}$ of IEC-H unit were more pronounced than those of the DX unit across the day. This is understandable because during the day when RH was low more evaporation was used to achieve cooling in the IEC-H unit.
- In the night, when humidity increases lower evaporation occurred in the IEC-H unit resulting in lower $T_{wb\ out}$ of the unit in comparison to the $T_{wb\ out}$ of DX unit.
- The swing in RHs were between 29.0 % at 13:00 to 55.3 % at 22:00

➤ **Power Consumptions Comparison:**

- In figure 7, the total power consumption of the DX unit was consistently higher than that of the IEC-H unit across the whole day.
- The compressor of the IEC-H unit constituted the largest portion of the power consumption of the unit while the evaporation fan, the supply fan and the pump constituted the remaining much lower consumptions.

4.2. OEM2, Climatic Zone 5

Table 4: Basic Information for OEM2 at Climatic Zone

Basic Information			
Tested Units Name	DX		Direct Expansion Unit
	IEC hybrid		Indirect Evaporative Cooling Hybrid Unit
OEM No.	2		
Air Flow Rate	2000		c.f.m for DX and IEC hybrid Units
Water Bath Area	1000*900		mm ²
Climatic Zone	5 (Eastern Coast Region)		
	Altitude	2	meter (from sea level)
	Location	26°49' 39" N 33°56' 13" E	
Test Date	25-Aug-22		
Compressor Capacity	DX	10 TR	35.2 kW
	IEC hybrid	10 TR	35.2 kW
	DX Unit		IEC Hybrid Unit
Compressor brand	Copeland Scroll ZP		Copeland Scroll ZP
Refrigerant	R410 A		R410 A

The figures below show the following:

- Figure 8: the ambient dry bulb temperature and the outlet dry bulb temperatures of the IEC-H and the DX units across a whole day for OEM2 at CZ5
- Figure 9: the EERs of both the IEC-H and the DX units and ambient RH across a whole day for OEM2 at CZ5.
- Figure 10: The cooling capacity of the IEC-H and DX unit and the ambient dry bulb temperature and RH across a whole day for OEM2 at CZ5
- Figure 11: The cooling capacities and the outlet wet bulb temperatures and RHs of the IEC-H and DX units across a whole day for OEM2 at CZ5
- Figure 12: The power consumptions of the DX unit and the IEC-H unit and its components for OEM2 at CZ5.

Fig 8: Inlet ambient temperature versus outlet temperature of IEC Hybrid unit & DX unit for OEM2 at CZ5




Fig 9: EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM2 at CZ5




Fig 10: Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM2 at CZ5




Fig 11: Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM2 at CZ5





Fig 12: Power consumption of DX unit and IEC Hybrid unit components for OEM2 at CZ5



Analysis of the results of OEM2 at CZ5:

Table 5: High and Low readings for OEM2 at Climatic Zone 5

CZ5					
High and low, °C					
T _{db amb}	RH _{amb}	T _{db out IEC-H}	T _{wb out IEC-H}	T _{db out DX}	T _{wb out DX}
38.8	54 @ 3:00	13.8	11.8	14.7	12.3
29.5	29 @ 17:00	8	6.6	9.1	7.5

- **$T_{db\ out}$ Comparison:**
 - In figure 8, the outlet dry bulb temperatures of the DX unit are generally slightly higher than those of the IEC-H except in a few readings when they are almost equal.
 - The swing in outlet dry bulb temperature of the DX unit is from to $14.7\ ^\circ C$ to $9.1\ ^\circ C$, $5.6\ ^\circ C$ swing
 - The swing in outlet dry bulb temperature of the IEC-H unit is from to $13.8\ ^\circ C$ to $8\ ^\circ C$, $5.8\ ^\circ C$ swing
 - The daily ambient dry bulb temperature changes are from $38.8\ ^\circ C$ down to $29.5^\circ C$, a swing of $9.3\ ^\circ C$.
 - The changes of outlet dry bulb temperature of the IEC-H unit are consistent with the ambient db. As it goes up it increases and vice versa. The same applies for the DX unit.

- **$T_{wb\ out}$ Temperature Comparison:**
 - In figure 11, the changes of outlet wet bulb temperature of the IEC-H unit were closer to those of the DX unit across the day, except between 14:00 and 23:30.
 - In the night, when humidity increases lower evaporation occurred in the IEC-H unit resulting in lower outlet wet bulb temperature out of the unit and therefore in comparison the outlet wet bulb temperature of the DX unit is higher.
 - Unusually high ambient RH occurs, 29.3 % at 17:00 to 54 % at 3:00

- **EERs Comparison:**
 - In figure 9, the EER of the IEC-H is consistently higher than that of the DX unit except at 2:30, 5:30 and 8:00 when they were almost equal. This fluctuation arose due to the voltage fluctuation between 350 to 375 volt. This is important to note although both uses the same capacity compressor.
 - The swing in the values of the EER of both units is consistent with the relative humidity. As the RH increase the EERs decreases and vice versa.

- **Capacities Comparison:**
 - In figure 11, the IEC-H capacity is higher than that of the DX unit consistently except in the period 23:30, 2:30 and 5:00 when both are almost equal.
 - Again, this is important to note although both systems are equipped with the same capacity compressors.

- **Power Consumptions Comparison:**
 - In figure 12, the total power consumption of the DX unit was close to that of the IEC-H unit across the whole day. Nevertheless, the ERs of the IEC-H unit were higher than these of the DX unit.
 - This is because of the unusually high ambient RH with consistently high ambient RH which necessitated high compressor power use in the IEC-H unit.
 - The compressor of the IEC-H unit constituted the largest portion of the power consumption of the unit while the evaporation fan, the supply fan and the pump constituted the remaining much lower consumptions.

Table 6: Concluding remarks on the performance of OEM2 IEC-H unit and the DX unit in CZ2 and CZ5

CZ2						CZ5					
High and Low						High and Low					
T _{db} amb	RH _{amb}	T _{db} out IEC-H	T _{wb} out IEC-H	T _{db} out DX	T _{wb} out DX	T _{db} amb	RH _{amb}	T _{db} out IEC-H	T _{wb} out IEC-H	T _{db} out DX	T _{wb} out DX
37.7	55.3	14.2	11.9	12.8	11.1	38.8	54	13.8	11.8	14.7	12.3
24.9	29.0	8.5	7.2	9.6	8.9	29.5	29	8	6.6	9.1	7.5
CZ2						CZ5					
EER		Capacities, W				EER		Capacities, W			
IEC-H	DX	IEC-H	DX	IEC-H	DX	IEC-H	DX	IEC-H	DX	IEC-H	DX
18.2	15.6	42118.08	42751.24	18.5	17.5	52001.32	49622.73	8.9	6.1	21047.24	18311.86
				14.0	12.7	38978.72	36124.40				

- The EER of the IEC-H in CZ2 was between and 18.2 and 8.9 and that of the DX unit was between 15.6 and 6.1
- The EER of the IEC-H in CZ5 was between 18.5 and 14 and that of the DX unit was between 17.5 and 12.7
- The capacity of the IEC-H in CZ2 was between and 42,118 W and 21,047 W and that of the DX unit was between 42,751 W and 18,311 W.
- The capacity of the IEC-H in CZ5 was between and 52,001 W and 38,978 W and that of the DX unit was between 49,623 W and 36,124 W.
- The smaller swing in ambient dry bulb temperature at CZ5 compared to CZ2 (38.8 °C to 29.5°C compared at CZ2, to 37.7 °C to 24.9 °C) together with unusually high relative humidity in CZ5 (29 % at 17:00 to 54 % at 3:00 at CZ5 compared to 29% at 17:00 and 55% at 3:00 at CZ2) made the IEC-H unit unable to use its full potential for evaporation cooling across the day.
- The total capacities delivered by both units in CZ5 were higher than these at CZ2 (42,118 W and 42,751 W in CZ2 compared to 52,001 W and 49,622 W in CZ5).
- The Relative Humidity fluctuation also affected the performance of the IEC-H unit in CZ5.


Chapter 5

5. The Final Results Analysis with Conclusion and Recommendation for Future Work

5.1. The Final Results Analysis


5.1.1. EER HIGH and LOW - CZ2

Fig 13: High and Low EER (in BTU/W.hr) for Climatic Zone 2




5.1.2. CAPACITY HIGH and LOW - CZ2

Fig 14: High and Low Cooling Capacity (in W) for Climatic Zone 2




5.1.3. EER HIGH and LOW - CZ5

Fig 15: High and Low EER (in BTU/W.hr) for Climatic Zone 5



5.1.4. CAPACITY HIGH and LOW - CZ5

Fig 16: High and Low Cooling Capacity (in W) for Climatic Zone 5



5.2. Conclusion

The analysis of the final results of all OEMs shows the following:

- All OEMs show EERs of the IEC-H units that are superior to corresponding DX units.
- The IEC-H unit compressor capacity compared to DX unit is as follows:

OEM	IEC-H Compressor capacity compared to compressor capacity of DX unit	IEC-H unit capacity compared to DX capacity
4	Larger by 20 %	Almost equal unit capacities
2	Equal in capacity	Almost equal unit capacities
3	Smaller by 60%	Lower unit capacities
6	Smaller by 70 %	Lower unit capacities

- Capacities of IEC-H units varied between OEMs; some had almost equal capacities compared to DX units and others had lower capacities.
- There was no direct relationship indicating whether the capacity of the compressor of the IEC-H units had an impact on the capacity of the units and whether there was a critical capacity size defining this relationship. This is an important point that needs further investigation.
- Further tests are needed at the highest ambient dry bulb temperatures and the lowest humidity, climatic zone 8, to deduce the optimum compressor capacity for the systems at all climatic zones, thus optimizing the system through an algorithm that decides compressor capacity for all nominal sizes.
- The financial analysis will provide us with figures that will help us decide if an IEC-H system is economically advantageous compared to a DX system.
- In order to clarify how the economic study is made for all OEMs, a simplified example for OEM2 in CZ were listed. All figures used in this example are provided by the OEM2 or from the tests conducted for the OEM2 in CZ 2.
- For OEM 2 in CZ 2, the IEC Hybrid Unit shows a favorable IRR of 46%, and an NPV of LE 24,621 with a payback period of 3.11 years.
- It remains to be seen according to the results of the ongoing economic study whether the higher price of the IEC-H units justify its use for the remaining OEMs according to the return on investment calculated using the comparison of the NPVs of both systems.
- The project is successful from the point of view of the technical analysis side because of the superior EERs of the IEC-H units despite some smaller capacity compressors used. The capacities of the IEC-H units were not always larger than these of the DX units.

5.3. Recommendation for Future Work

- Defining the critical compressor capacity size that will deduce the optimal capacity of the unit is an important point that needs further investigation.
- Further testing at the highest dry-bulb ambient temperatures and lowest humidity climate zone 8, is needed to derive the optimal compressor capacity for systems in all climatic zones, thus optimizing the system through an algorithm that determines compressor capacity for all nominal sizes.
- However, further work is needed to decide the optimum capacity of compressor suitable for IEC-H systems at all climatic zones assisted by further tests at the harshest climatic zone, CZ 8 to complete the tests needed for the writing of a code for Direct Indirect Evaporative Cooling.
- Compiling a final matrix for defining the extrapolation rules for setting the final reference-testing conditions. This work is being done by EUROVENT.

- It is recommended that for future work the IEC-H prototypes use lower GWP refrigerants approved in Egypt (Promotion of Low-GWP Refrigerants for the Air Conditioning Industry in Egypt, UNEP/UNIDO 2021) refrigerants R-32 and R-454 B.

Chapter (6)

6. Reporting on the Advocacy and Outreach Campaign

INTRODUCTION

Outreach marketing campaign helped in the enforcement of **Transformation of Commercial Air Conditioning Companies in EGYPT** by promoting and publishing the results of the technical study to stakeholders. The services in this outreach campaign are to be made available to all stakeholders. The outreach campaign was designed to be person to person meeting, but because of the pandemic in Egypt, it was decided to change it to virtual meeting which was held on 21st December 2022.

OUTREACH PLAN GOAL

Characteristics of a goal statement should follow the **SMART** principle:

Specific - **M**easurable – **A**ction Oriented - **R**ealistic - **T**ime and Resource Constrained

The outreach marketing campaigns had been targeted as if it can result in the following:

- ✓ Build awareness of the HCFC Phase-out Management Plan (HPMP).
- ✓ Promote and enhance your HVAC field growth by transformation of commercial HVAC companies in Egypt.
- ✓ Generate leads of alternative refrigerants code and direct/indirect evaporative cooling code.
- ✓ Increase HVAC users' retention.
- ✓ Effect collaborations and partnerships.

The objective of the outreach campaign to benefit from the experience gain testing the IEC-H and DX units in two climatic zones in Egypt. The main discussions were of the results of the testing of IEC-H and DX units of all OEMs.

The exact structure of this campaign is flexible and defined based on the outcomes of the deliverables and it was adjusted according to the content of the framework.

We held conferences with different OEMs individually to discuss the (November 2022) results.

Holding the outreach campaign (December 2022)

TARGET STAKEHOLDERS ATTENDING THE OUTREACH CAMPAIGN

Provided in this section is the list of individuals/other entities having a role in the development and implementation of the Plan. The following are the stakeholder groups to receive targeted outreach:

1- The Ministry of Electricity

-
- 2- Specifications and Standards
-
- 3- Municipalities
-
- 4- All OEMs that were included in the program
-
- 5- Local Government Agency Officials and Department Heads
-
- 6- Public Sector HVAC Project Planners
-
- 7- Local Chapters of Regional/National Associations
-
- 8- Local Environmental Organizations
-
- 9- Local HVAC Organizations and Interest Groups
-
- 10- HVAC Companies
-
- 11- Developers and Banks
-
- 12- The General Public
-
- 13- Other
-

Presentation Given at the outreach Campaign held on 21st December 2022

The presentation is attached in **Annex (7)**

Question raised after the presentation

- I. Question posed by Dr. Hesham Safwat (the British University in Egypt, BUC):
 - a. He inquired about the electrical consumption and how it was compared with the tariff in Egypt?
 - b. He inquired about the water consumption, how was it calculated and whether it was taken into consideration when doing financial analysis?
 - c. He asked when the IEC-H specification code will be ready to be used by consulting engineers?
- II. Question posed by Eng. Ahmed Magdy (the head of R&D in MIRACO)
 - a. He inquired how the capital cost used in the financial analysis was calculated?
 - b. He also inquired if the maintenance of the IEC-H units were calculated and included in the financial analysis, because of the higher costs of maintaining evaporation pads?
- III. Question posed by Eng. Hossam Abdelkader (Representing DCM company)
 - a. He inquired if there a plan to produce a code then legislate the usage of IEC-H for the different eight climatic zones of Egypt?
 - b. He inquired why SEER (Seasonal Electric Efficiency Ratio) was not calculated in the results?
- IV. Comment posed by Dr. Ezzat Lewis (the head of the Egyptian NOU)
 - a. Dr. Ezzat inquired about the SEER and alluded to a program by the green fund to work on the SEER in Egypt.

Prof. Sayed Shebl and Prof. Alaa Olama answered all the posed questions.

Chapter (7)

7. Review and recommendation on how to update the national institutional technical documents of the new technologies

- I. There are no Egyptian codes for evaporation cooling.
- II. In view of the high response of the outreach campaign as the interest in determining specification on codes for this new technology by stakeholders, it is recommended to write a Direct-Indirect Evaporation Cooling code of practice
- III. The results obtained by this testing program have made it possible to recommend writing IEC code of practice for Egypt.

How to update:

Stage 1:

- 1- The results obtained by IEC-H in transformation of commercial air conditioning companies project proved that there is important benefit of the IEC technology compared to existing technology
- 2- Although the results obtained are suitable for climatic zone 2 and climatic zone 5, more results are needed to complete the data required for other climatic zones in Egypt
- 3- Following the recommendation suggested by EUROVENT assessments of the results of the test campaign and compiling a final matrix for defining the extrapolation rules for setting the final reference-testing conditions.

Stage 2:

- 1- An empirical correlation that corrected the results in the different climatic zones will be target
- 2- Create guidelines that to put the basis of the Egyptian code of practice for IEC

Stage 3:

- 1- Create the Egyptian code of practice for IEC

Stage 4:

- 1- Enforcement program for the Egyptian code of practice for IEC

Annex (1) Provision of the technical parameters for the financial model (capital and operating costs of OEMs)

▪ OEM3, Climatic zone 2

Table 7: Basic Information for OEM3 at Climatic Zone 2

Basic Information			
Tested Units Name	DX		Direct Expansion Unit
	IEC hybrid		Indirect Evaporative Cooling Hybrid Unit
OEM No.	3		
Air Flow Rate	2025		c.f.m for DX and IEC hybrid Units
Water Bath Area	1728.5*623		mm ²
Climatic Zone	2 (Delta and Cairo Region)		
	Altitude	208	meter (from sea level)
	Location	30°08' 36" N 31°43' 06" E	
Test Date	16-Jun-22		
Compressors and Refrigerants	DX unit		IEC-H unit
Compressor Model	ZP154KCE-TFD		ZP61KCE-TFD
Compressor Manufacturer	Copeland – Hermetic Scroll Compressor		Copeland – Hermetic Scroll Compressor
Compressor Size	12.8 TR (45kW)		5 TR (17.5kW)
Refrigerant	R410 A		R410 A

The figures below show the following:

- Figure 17: the ambient dry bulb temperature and the outlet dry bulb temperatures of the IEC-H and the DX units across a whole day for OEM3 at CZ2
- Figure 18: the EERs of both the IEC-H and the DX units and ambient RH across a whole day for OEM3 at CZ2.
- Figure 19: The cooling capacity of the IEC-H and DX unit and the ambient dry bulb temperature and RH across a whole day for OEM3 at CZ2
- Figure 20: The cooling capacities and the outlet wet bulb temperatures and RHs of the IEC-H and DX units across a whole day for OEM3 at CZ2.
- Figure 21: The power consumptions of the DX unit and the IEC-H unit and its components for OEM3 at CZ2.

Fig 17: Inlet ambient temperature versus outlet temperature of IEC Hybrid unit & DX unit for OEM3 at CZ2




Fig 18: EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM3 at CZ2




Fig 19: Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM3 at CZ2




Fig 20: Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM3 at CZ2





Fig 21: Power consumption of DX unit and IEC Hybrid unit components for OEM3 at CZ2



Analysis of the results of OEM 3 at CZ 2:

Table 8: High and Low readings for OEM3 at Climatic Zone 2

CZ 2					
High and low					
T _{db amb}	RH _{amb}	T _{db out} IEC-H	T _{wb out} IEC-H	T _{db out} DX	T _{wb out} DX
39.70	75.2 @ 5:16	14.90	13.20	12.60	11.40
23.40	27.0 @ 15:16	12.30	10.00	9.40	8.40

➤ T_{db out} comparison:

- In figure 17, the outlet dry bulb temperatures of the IEC-H are higher than those of the DX unit.
- The swing in T_{db out} of DX unit is from 12.6 °C to 9.4 °C, 3.2 °C swing
- The swing in T_{db out} of IEC-H unit is from 14.9 °C to 12.3 °C, 2.6 °C swing
- The daily T_{db amb} changes from 39.7 °C down to 23.4°C, a swing of 16.3 °C.
- The changes in T_{db out} of IEC-H unit are affected by the change in T_{db amb} and relative humidity.

➤ **T_{wb out} comparison:**

- In figure 20, the changes of T_{wb out} of IEC-H unit were more pronounced than those of the DX unit across the day. This is understandable because during the day when RH was low more evaporation was used to achieve cooling in the IEC-H unit.
- T_{wb out} of IEC-H changes from 12.4 to 9.4
- T_{wb out} of DX changes from 11.4 to 8.4
- In the night, when humidity increased lower evaporation occurred in the IEC-H unit resulting in lower T_{wb out} of the unit in compared to T_{wb out} of the DX unit.
- The swing in RH was between 75.2 % at 5:16 to 27.0 % at 15:16

➤ **EERs comparison:**

- In figure 18, the EERs of the IEC-H are consistently higher than that of the DX unit because of the IEC-H uses a smaller capacity compressor 17.6 kW (5 TR) compared to 45 kW (12.8 TR).
- The swing in the values of the EER of IEC-H unit is consistent with the relative humidity. As the RHs increases the EER decreases and vice versa.

➤ **Capacities comparison:**

- In figure 19, the IEC-H capacities are lower than those of the DX unit consistently.

➤ **Power consumptions comparison:**

- In figure 21, the total power consumptions of the DX unit were consistently higher than those of the IEC-H unit across the whole day.
- The compressor of the IEC-H unit constituted the largest portion of the power consumptions of the unit while the evaporation fan, the supply fan and the pump constituted the remaining much lower consumptions.

▪ **OEM3, Climatic zone 5**

Table 9: Basic Information for OEM3 at Climatic Zone 5

Basic Information		
Tested Units Name	DX	Direct Expansion Unit
	IEC hybrid	Indirect Evaporative Cooling Hybrid Unit
OEM No.	3	
Air Flow Rate	2025	c.f.m for DX and IEC hybrid Units
Water Bath Area	1728.5*623	mm ²
Climatic Zone	5 (Eastern Coast Region)	
	Altitude	2 meter (from sea level)
	Location	26°49' 39" N 33°56' 13" E
Test Date	5-Jul-22	
Compressors and Refrigerants	DX unit	IEC-H unit
Compressor Model	ZP154KCE-TFD	ZP61KCE-TFD
Compressor Make	Copeland – Hermetic Scroll Compressor	Copeland – Hermetic Scroll Compressor
Compressor Size	45 kW (12.8 TR)	17.5 kW (5 TR)
Refrigerant	R410 A	R410 A

The figures below show the following:

- Figure 22: the ambient dry bulb temperature and the outlet dry bulb temperatures of the IEC-H and the DX units across a whole day for OEM3 at CZ5
- Figure 23: the EERs of both the IEC-H and the DX units and ambient RH across a whole day for OEM3 at CZ5.
- Figure 24: The cooling capacity of the IEC-H and DX unit and the ambient dry bulb temperature and RH across a whole day for OEM3 at CZ5
- Figure 25: The cooling capacities and the outlet wet bulb temperatures and RHs of the IEC-H and DX units across a whole day for OEM3 at CZ5
- Figure 26: The power consumptions of the DX unit and the IEC-H unit and its components for OEM3 at CZ5.

Fig 22: Inlet ambient temperature versus outlet temperature of IEC Hybrid & DX units for OEM3 at CZ5




Fig 23: EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM3 at CZ5




Fig 24: Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM3 at CZ5




Fig 25: Cooling capacity versus outlet wet bulb temperature for IEC Hybrid & DX units for OEM3 at CZ5





Fig 26: Power consumption of DX unit and IEC Hybrid unit components for OEM3 at CZ5



Analysis of the results of OEM3 at CZ 5:

Table 10: High and Low readings for OEM3 at Climatic Zone 5

CZ 5					
<i>High and low</i>					
Tdb amb	RHamb	Tdb out IEC-H	Twb out IEC-H	Tdb out DX	Twb out DX
37.40	46.20 @ 22:00	18.80	16.60	13.40	12.20
30.10	23.60 @ 10:00	12.10	9.70	7.10	5.70

➤ **T_{db} out comparison:**

- In figure 22, the T_{db} out of DX unit are higher than those of the IEC-H unit.
- The swing in T_{db} out of DX unit is from to 13.4 °C to 7.1 °C, 6.3°C swing
- The swing in of T_{db} out IEC-H unit is from to 18.8 °C to 12.1 °C, 6.7 °C swing
- The daily T_{db} amb changes are from 37.4 °C down to 30.1°C, a swing of 7.3 °C.

➤ **T_{wb} out temperature comparison:**

- In figure 25, the changes of T_{wb} out of IEC-H unit were consistently higher than those of the DX unit across the day.
- In the night, when humidity increases lower evaporation occurred in the IEC-H unit resulting in higher T_{wb} out of the unit.
- Ambient RH are nearer to their expected levels in this time of the year, at 23.6 % at 10:00 to 46.2 % at 22:00

➤ **EERs comparison:**

- In figure 23, the EERs of the IEC-H are consistly higher than those of the DX unit. This is important to note because its compressor's capacity is 17.5 kW (5 TR) compared to 45 kW (12.8 TR) for the DX unit.
- The swing in the values of the EER of both units is consistent with the relative humidity. As the RH increase the EERs decreases and vice versa.

➤ **Capacities comparison:**

- In figure 24, the DX unit capacities are consistently higher than those of the IEC-H unit.

➤ **Power consumption comparison:**

- In figure 26, the total power consumptions of the DX unit are much higher than that of the IEC-H unit across the whole day.
- The compressor of the IEC-H unit constituted the largest portion of the power consumption of the unit while the evaporation fan, the supply fan and the pump constituted the remaining much lower consumptions.

Table 11: Concluding remarks on the performance of OEM3 IEC-H unit and the DX unit in CZ2 and CZ5

CZ2						CZ5					
High and low °C						High and low °C					
T _{db amb}	RH _{amb}	T _{db out} IEC-H	T _{wb out} IEC-H	T _{db out} DX	T _{wb out} DX	T _{db amb}	RH _{amb}	T _{db out} IEC-H	T _{wb out} IEC-H	T _{db out} DX	T _{wb out} DX
39.70	75.2 @ 5:16	14.90	13.20	12.60	11.40	37.40	46.20 @ 22:00	18.80	16.60	13.40	12.20
23.40	27.0 @ 15:16	12.30	10.00	9.40	8.40	30.10	23.60 @ 10:00	12.10	9.70	7.10	5.70
CZ2						CZ5					
EER		Capacities, W				EER		Capacities, W			
IEC-H	DX	IEC-H	DX	IEC-H	DX	IEC-H	DX	IEC-H	DX	IEC-H	DX
31.6	13.7	45624.38	46675.63	20.8	12.7	34017.59	47300.65	15.7	10.5	23079.78	31102.75
				13.6	8.7	20841.57	30486.34				

- The EER of the IEC-H in CZ2 was between and 31.6 and 15.7 and that of the DX unit was between 13.7 and 10.5
- The EER of the IEC-H in CZ5 was between 20.8 and 13.6 and that of the DX unit was between 12.7 and 8.7
- The capacity of the IEC-H in CZ2 was between and 45,624 W and 23,080 W and that of the DX unit was between 46,676 W and 31,103 W.
- The capacity of the IEC-H in CZ5 was between and 34,018 W and 20,842 W and that of the DX unit was between 47,300 W and 30,486 W.

The smaller capacity compressor of the IEC-H units seems to be governing factor in understanding the results of the tests.

- EERs of the IEC-H diminish considerably in CZ5 with the higher humidity of CZ5.
- EERs of the DX unit diminish also but to a much lesser extent.
- The capacities of the IEC-H unit diminish considerably in CZ5 at the higher humidity of CZ5.
- The capacities of the DX unit diminish also but to a much lesser extent.
- Generally, the capacities of the DX unit were higher than these of IEC-H unit.

▪ OEM4, Climatic zone 2

Table 12: Basic Information for OEM4 at Climatic Zone 2

Basic Information						
Tested Units Name	DX		Direct Expansion Unit			
	IEC hybrid		Indirect Evaporative Cooling Hybrid Unit			
OEM No.	4					
Air Flow Rate	1750		c.f.m for DX and IEC hybrid Units			
Water Bath Area	2400*1600		mm ²			
Compressor Capacity	DX	12 TR	42 kW			
	IEC hybrid	14 TR	50 kW			
Climatic Zone	2 (Delta and Cairo Region)					
	Altitude	208	meter (from sea level)			
	Location	30°08' 36" N 31°43' 06" E				
Test Date	4-Aug-22					
Refrigerant	R-410 A		For both IEC-H and DX unit			

The figures below show the following:

- Figure 27: the ambient dry bulb temperature and the outlet dry bulb temperatures of the IEC-H and the DX units across a whole day
- Figure 28: the EERs of both the IEC-H and the DX units and ambient RH across a whole day.
- Figure 29: The cooling capacity of the IEC-H and DX unit and the ambient dry bulb temperature and RH across a whole day
- Figure 30: The cooling capacities and the outlet wet bulb temperatures and RHs of the IEC-H and DX units across a whole day
- Figure 31: The power consumptions of the DX unit and the IEC-H unit and its components.

Fig 27: Inlet ambient temperature versus outlet temperature of IEC Hybrid unit & DX unit for OEM4 at CZ2




Fig 28: EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM4 at CZ2




Fig 29: Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM4 at CZ2




Fig 30: Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM4 at CZ2





Fig 31: Power consumption of DX unit and IEC Hybrid unit components for OEM4 at CZ2



Analysis of the results of OEM4 at CZ2:

Technical problems related to the operation of the DX unit starting at 16:00 prevented analysis. See figures 27, 28 and 29.

▪ OEM4, Climatic zone 5

Table 13: Basic Information for OEM4 at Climatic Zone 5

Basic Information			
Tested Units Name	DX		Direct Expansion Unit
	IEC hybrid		Indirect Evaporative Cooling Hybrid Unit
OEM No.	4		
Air Flow Rate	1750		c.f.m for DX and IEC hybrid Units
Water Bath Area	2400*1600		mm ²
Climatic Zone	5 (Eastern Coast Region)		
	Altitude	2	meter (from sea level)
	Location	26°49' 39" N 33°56' 13" E	
Compressor Capacity	DX	12 TR	42 kW
	IEC hybrid	14 TR	50 kW
Test Date	27-Aug-22		For both IEC-H and DX units
Refrigerants	R-410 A		For both IEC-H and DX units

The figures below show the following:

- Figure 32: the ambient dry bulb temperature and the outlet dry bulb temperatures of the IEC-H and the DX units across a whole day
- Figure 33: the EERs of both the IEC-H and the DX units and ambient RH across a whole day.
- Figure 34: The cooling capacity of the IEC-H and DX unit and the ambient dry bulb temperature and RH across a whole day
- Figure 35: The cooling capacities and the outlet wet bulb temperatures and RHs of the IEC-H and DX units across a whole day
- Figure 36: The power consumptions of the DX unit and the IEC-H unit and its components.

Fig 32: Inlet ambient temperature versus outlet temperature of IEC Hybrid & DX units for OEM4 at CZ5




Figure 33: EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM4 at CZ5




Fig 34: Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM4 at CZ5




Fig 35: Cooling capacity versus outlet wet bulb temperature for IEC Hybrid & DX units for OEM4 at CZ5





Fig 36: Power consumption of DX unit and IEC Hybrid unit components for OEM4 at CZ5



Analysis of the results of OEM 4 at CZ 5:

Table 14: High and Low readings for OEM4 at Climatic Zone 5

CZ 5					
High and low					
Tdb amb	RHamb	Tdb out IEC-H	Twb out IEC-H	Tdb out DX	Twb out DX
37.50	54.80 @ 3:00	16.20	14.60	16.30	14.10
28.40	29.00 @ 9:00	10.30	9.60	9.80	8.90

- **T_{db} out comparison:**
 - In figure 32, the T_{db} out of DX unit are nearly similar to those of the IEC-H unit.
 - The swing in T_{db} out of DX unit is from 16.3 °C to 9.8 °C, 6.5 °C swing
 - The swing in T_{db} out of IEC-H unit is from 16.2 °C to 10.3 °C, 5.9 °C swing
 - The daily T_{db} amb changes are from 37.5 °C down to 28.4°C, a swing of 9.1 °C.
 - The changes of T_{db} out of IEC-H unit are consistent with the T_{db} amb, as it goes up it increases and vice versa. The same applies for the DX unit.
- **T_{wb} out Temperature comparison:**
 - In figure 35, the T_{wb} out of IEC-H unit and the DX unit were changing places as the higher ones across the day.
 - In the night, when humidity increases lower evaporation occurred in the IEC-H unit resulting in lower T_{wb} out of the unit.
 - Ambient RH are nearer to their expected levels in this time of the year, at 29 % at 9:00 to 54.8 % at 3:00
- **EER comparison**
 - In figure 33, the EERs of the IEC-H were consistently higher than those of the DX unit. This is important to note. The compressor's capacity of the IEC-H unit is 50 kW (14 TR) compared to 42 kW (12 TR) for the DX unit, nominally 20% higher.

- The swing in the values of the EER of both units is consistent with the relative humidity. As the RH increase the EERs decreases and vice versa

➤ **Capacities comparison:**

- In figure 34, the IEC-H unit capacities are close to those of the DX unit.

➤ **Power consumptions comparison:**

- In figure 36, the total power consumptions of the DX unit are relatively higher than that of the IEC-H unit across the whole day.
- The compressor of the IEC-H unit constituted the largest portion of the power consumption of the unit while the evaporation fan, the supply fan and the pump constituted the remaining much lower consumptions.

Table 15: Concluding remarks on the performance of OEM4 IEC-H unit and the DX unit in CZ2 and CZ5

CZ2						CZ5					
High and low						High and low					
T _{db amb}	RH _{amb}	T _{db out} IEC-H	T _{wb out} IEC-H	T _{db out} DX	T _{wb out} DX	T _{db amb}	RH _{amb}	T _{db out} IEC-H	T _{wb out} IEC-H	T _{db out} DX	T _{wb out} DX
35.70	46.50 @ 10:30	N/A	N/A	N/A	N/A	37.50	54.80 @ 3:00	16.20	14.60	16.30	14.10
23.60	33.30 @ 13:30	N/A	N/A	N/A	N/A	28.40	29.00 @ 9:00	10.30	9.60	9.80	8.90
CZ2						CZ5					
EER		Capacities, W				EER		Capacities, W			
IEC-H	DX	IEC-H	DX	IEC-H	DX	IEC-H	DX	IEC-H	DX	IEC-H	DX
N/A	N/A	N/A	N/A	19.2	17	38751.24	37991.41	23425.01	27718.04		
N/A	N/A	N/A	N/A	11.3	12.3						

The compressor nominal capacity of the IEC-H unit is higher than that of the DX unit by about 20%. This is unusual; perhaps the special design of the IEC-H unit is the reason.

- T_{db out} achieved by the IEC-H unit are almost equal to those of the DX unit.
- EERs of the IEC-H are also superior to those of the DX unit.
- The capacities of the IEC_H unit are almost equal to these of the DX unit.
- The IEC-H unit performance, both capacity and EER, is remarkable although it uses a relatively larger compressor capacity.

▪ OEM6, Climatic zone 2

Table 16: Basic Information for OEM6 at Climatic Zone 2

Basic Information			
Tested Units Name	DX		Direct Expansion Unit
	IEC hybrid		Indirect Evaporative Cooling Hybrid Unit
OEM No.	6		
Air Flow Rate	2245		c.f.m for DX and IEC hybrid Units
Compressor	IEC-H	Highly	ATE 498SC3Q9RK1
	DX	Danfoss	SH161
Refrigerant	R 410 A		For both units
Water Bath Area	901108		mm2, (1308.3^2-900.3^2)
Climatic Zone	2 (Delta and Cairo Region)		
Compressor Capacity	DX	40 kW	11 TR
	IEC hybrid	12 kW	3.4 TR
	Altitude	208	meter (from sea level)
	Location	30°08' 36" N 31°43' 06" E	
Test Date	19-Jun-22		

The figures below show the following:

- Figure 37: $T_{db\ out}$ of the IEC-H and the DX units across a whole day
- Figure 38: the EERs of both the IEC-H and the DX units and ambient RH across a whole day.
- Figure 39: The cooling capacity of the IEC-H and DX unit and the ambient dry bulb temperature and RH across a whole day
- Figure 40: The cooling capacities and $T_{wb\ out}$ and RHs of the IEC-H and DX units across a whole day
- Figure 41: The power consumptions of the DX unit and the IEC-H unit and its components.

Fig 37: Inlet ambient temperature versus outlet temperature of IEC Hybrid & DX units for OEM6 at CZ2




Fig 38: EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM6 at CZ2




Fig 39: Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM6 at CZ2




Fig 40: Cooling capacity versus outlet wet bulb temperature for IEC Hybrid & DX units for OEM6 at CZ2





Fig 41: Power consumption of DX unit and IEC Hybrid unit components for OEM6 at CZ2



Analysis of the results of OEM 6 at CZ 2:

Table 17: High and Low readings for OEM6 at Climatic Zone 2

CZ 2					
High and low, °C					
T _{db amb}	RH _{amb}	T _{db out} IEC-H	T _{wb out} IEC-H	T _{db out} DX	T _{wb out} DX
34.10	52.5 @ 23:00	16.40	15.70	14.90	13.60
23.40	28.00 @ 13:00	12.90	12.40	9.60	8.60

- **T_{db out} comparison:**
 - In figure 37, the T_{db out} of the IEC-H unit are slightly higher than these of the DX unit.
 - The swing in T_{db out} of DX unit is from 14.9 °C to 9.6 °C, 5.3°C swing
 - The swing in of T_{db out} IEC-H unit is from 16.4 °C to 12.9 °C, 3.5 °C swing
 - The daily T_{db amb} changes are from 34.1 °C down to 23.8°C, a swing of 10.3 °C.
 - The changes of T_{db out} of IEC-H unit are consistent with the T_{db amb}, as it goes up it increases and vice versa. The same applies for the DX unit.
- **T_{wb out} temperature comparison:**
 - In figure 40, the changes of T_{wb out} of IEC-H unit were higher than those of the DX unit
 - Ambient RH are nearer to their expected levels in this time of the year, at 28 % at 13:00 to 52.5 % at 23:00
- **EER comparison:**
 - In figure 38, the EERs of the IEC-H are much higher than these of the DX unit when the RH is low, 12:00 to 22:00 and 6:00 to 12:00. This is important to note.
 - The compressor's capacity of the IEC-H unit is 12 kW (3.4TR) compared to 40 kW (11 TR) for the DX unit, nominally 3.4 times larger.

- The swing in the values of the EER of both units is consistent with the relative humidity. As the RH increase the EERs decreases and vice versa

➤ **Capacities comparison:**

- In figure 39, the DX unit capacities are consistently higher than these of IEC-H unit.
- This is probably because the DX unit compressor capacity is much larger than that of IEC-H unit.

➤ **Power consumptions comparison:**

- In figure 41, the total power consumptions of the DX unit are much higher than that of the IEC-H unit across the whole day. Note the larger capacity compressor of the DX unit.
- The compressor of the IEC-H unit constituted the largest portion of the power consumption of the unit while the evaporation fan, the supply fan and the pump constituted the remaining much lower consumptions

▪ **OEM6, Climate zone 5**

Table 18: Basic Information for OEM6 at Climatic Zone 5

Basic Information			
Tested Units Name	DX		Direct Expansion Unit
	IEC hybrid		Indirect Evaporative Cooling Hybrid Unit
OEM No.	6		
Air Flow Rate	2245		c.f.m for DX and IEC hybrid Units
Refrigerant	R 410 A		For both IEC-h and DX units
Test Date	3-Jul-22		
compressors	IEC-H	Highly	ATE 498SC3Q9RK1
	DX	Danfoss	SH161
Water Bath Area	901108		mm2, (1308.3^2-900.3^2)
Compressor Capacity	DX	40 kW	11 TR
	IEC hybrid	12 kW	3.4 TR
Climatic Zone	5 (Eastern Coast Region)		
	Altitude	2	meter (from sea level)
	Location	26°49' 39" N 33°56' 13" E	

The figures below show the following:

- Figure 42: $T_{db\ out}$ of the IEC-H and the DX units across a whole day
- Figure 43: the EERs of both the IEC-H and the DX units and ambient RH across a whole day.
- Figure 44: The cooling capacity of the IEC-H and DX unit and the ambient dry bulb temperature and RH across a whole day
- Figure 45: The cooling capacities and $T_{wb\ out}$ and RHs of the IEC-H and DX units across a whole day
- Figure 46: The power consumptions of the DX unit and the IEC-H unit and its components.

Fig 42: Inlet ambient temperature versus outlet temperature of IEC Hybrid & DX units for OEM6 at CZ5




Fig 43: EER for IEC Hybrid unit & DX unit versus ambient relative humidity for OEM6 at CZ5




Fig 44: Cooling capacity for IEC Hybrid unit & DX unit versus ambient conditions for OEM6 at CZ5




Fig 45: Cooling capacity versus outlet wet bulb temperature for IEC Hybrid unit & DX unit for OEM6 at CZ5





Fig 46: Power consumption of DX unit and IEC Hybrid unit components for OEM6 at CZ5



Analysis of the results of OEM6 at CZ5:

Table 19: High and Low readings for OEM6 at Climatic Zone 5

CZ5					
High and low, °C					
T _{db amb}	RH _{amb}	T _{db out} IEC-H	T _{wb out} IEC-H	T _{db out} DX	T _{wb out} DX
35.80	48.00 @ 19:00	17.10	16.50	17.40	15.80
27.50	27.00 @ 3:00	8.10	7.70	10.30	8.40

➤ T_{db out} comparison:

- In figure 42, the T_{db out} of DX unit are nearly similar to those of the IEC-H unit.
- The swing in T_{db out} of DX unit is from 17.4°C to 10.3°C, 7.1°C swing
- The swing in T_{db out} of IEC-H unit is from 17.1°C to 8.1°C, 9°C swing
- The daily T_{db amb} changes are from 35.8°C down to 27.5°C, a swing of 8.3°C.
- The changes of T_{db out} of IEC-H unit are consistent with the T_{db amb}, as it goes up it increases and vice versa. The same applies for the DX unit.

- **T_{wb out} Temperature comparison:**
 - In figure 45, the changes of T_{wb out} of IEC-H unit were higher than those of the DX unit except between 2:30 to 10:30.
 - Ambient RH are nearer to their expected levels in this time of the year, at 27 % at 3:00 to 48 % at 19:00

- **EER comparison:**
 - In figure 43, the EERs of the IEC-H are consistently higher than those of the DX unit, this is important to note the compressor's capacity of the IEC-H unit is 12 kW (3.4 TR) compared to 40 kW (11 TR) for the DX unit.

- **Capacities comparison:**
 - In figure 44, the IEC-H unit capacities are lower than these of the DX unit except between 3:30 and 9:00.
 - This is important to note the compressor's capacity of the IEC-H unit is 12 kW (3.4 TR) compared to 40 kW (11 TR) for the DX unit.

- **Power consumptions comparison:**
 - In figure 46, the total power consumptions of the DX unit are relatively much higher than that of the IEC-H unit across the whole day.
 - The compressor of the IEC-H unit constituted the largest portion of the power consumption of the unit while the evaporation fan, the supply fan and the pump constituted the remaining much lower consumptions.

Table 20: Concluding remarks on the performance of OEM6 IEC-H unit and the DX unit in CZ2 and CZ5

CZ2						CZ5					
High and low						High and low					
T _{db amb}	RH _{amb}	T _{db out} IEC-H	T _{wb out} IEC-H	T _{db out} DX	T _{wb out} DX	T _{db amb}	RH _{amb}	T _{db out} IEC-H	T _{wb out} IEC-H	T _{db out} DX	T _{wb out} DX
34.10	52.5	16.40	15.70	14.90	13.60	35.80	48.00	17.10	16.50	17.40	15.80
23.40	28.00	12.90	12.40	9.60	8.60	27.50	27.00	8.10	7.70	10.30	8.40
CZ2						CZ5					
EER		Capacities, W				EER		Capacities, W			
IEC-H		DX		IEC-H		DX		IEC-H		DX	
20.7		11.9		28835.68		38910.58		25.5		10	
6.2		5.6		8407.23		18312.61		12.9		6.3	

The compressor nominal capacity of the DX unit is much larger than that of IEC-H unit, about 3.3 times larger. This is a bold design.

- T_{db out} achieved by the IEC-H unit are nearly similar to the DX unit in CZ5 and slightly higher than in CZ2 except in one instance where they are almost equal.
- The EERs of the IEC-H unit are consistently higher than those of the DX unit in both CZs.
- Capacities performance in CZ5 is generally almost equal to that of the DX unit. In CZ2 the capacity performance of the IEC-H unit is lower than that of the DX unit.
- The IEC-H unit performance, both capacity and EER is remarkable although it uses a much smaller compressor capacity.

Annex (2) Pre-Testing Report No. 1

The Transformation of Commercial Air Conditioning Companies (HCFC Phase-out Management Plan (HPMP) EGYPT (Stage II))

UNIDO ID: 140400

IEC Evaluation program

Pre-Testing Technical Report

June 2022

SUBMITTED BY:

Team of AO and HBRC

Contents

1- Introduction.....	3
2- General Scope of Pre-tests.....	3
3- Egypt Climatic Zones & Field Testing.....	4
4- Prototypes and Testing Plan.....	5
5- Pre-Testing Conditions.....	5
5.1 Description of Hybrid IEC Unit	7
5.2 Description of DX Unit	7
6- Equipment Used In Pre-Testing.....	8
7- Testing Methodology.....	8
7.1 Measuring airflow rate.....	9
7.2 Measuring wet and dry bulb temperature and Relative Humidity.....	9
7.3 Measuring Electrical Parameters.....	10
7.4 Measuring Water consumption.....	10
8- Details of Performed Pre-tests.....	11
9- Final Result.....	12
10- Discussion of Results.....	17
11- Conclusion.....	18
Annex 1.....	19
Annex 2.....	21
Attachment	25

Pre-Testing Technical Report

The Project of the Transformation of Commercial Air Conditioning Companies (HCFC Phase-out Management Plan (HPMP) EGYPT (Stage II)), UNIDO ID: 140400

1. *Introduction:*

The project aims at providing technical assistance for the implementation of low GWP technology as well as examining the introduction of a Not-In-Kind technology, namely: Indirect Evaporative Cooling (IEC).

The project also proposes to look into the introduction of IEC in commercial air conditioning applications. The goal of the project is to secure phase out of HCFC in the commercial air conditioning manufacturing sector.

In September 2015, the world's nations agreed to adopt a set of 17 Sustainable Development Goals (SDGs). Egypt affirmed its commitment to meet the targets set by SDGs by 2030 and outlined a 15-year development strategy. The SDGs, spearheaded by the United Nations, include resilient, stable, and sustainable infrastructure as one of its goals, thus, the green building landscape is expected to soar in the upcoming years.


2. *General Scope of Pre-tests*

Pre-test the hybrid IEC Unit simultaneously with the DX Unit to find out problems during pre-test process and evaluate results to be able to refine and finalize the testing methodology to send the results to UNIDO and EUROVENT.

During the pre-testing problems arose and we were able to overcome them through certain procedures that we recommend to follow during the actual testing undertaken next year.

3. Egypt Climatic Zones & Field Testing

The application of any new technology, in such larger capacities of commercial air-conditioning applications, requires setting the ground to allow market acceptability noting that these are not off-the-shelf products that industry can put in markets in large quantities. Commercial air-conditioning applications are commonly specified by consultants for projects ensure reliability of the product that can justify the initial investment. The project will invite an international organization with experience in guidelines and certification programs for HVAC applications including IEC systems to provide a reference testing methodology for the IEC-hybrid units suitable for Egypt's working conditions. Egypt has 8 climatic zones out of which 7 climatic zones are suitable for IEC applications due to lower humidity conditions across the summer season, where the project is going to endorse and review the results and testing procedures during project implementation. Below figure show Egypt climatic zones:



It is anticipated that the tests will be done in three locations, Cairo, Hurghada and Toshka (representing Zones 2, 5 and 8). The Location's nearest Metrological Station are as per the following Table.

Weather Station Name	Weather Station Name Abbreviation	Weather Station Number	Latitude	Longitude	Altitude
Cairo Airport	HECA	623660	30.13	31.4	64
Hurghada	HEGN	624630	27.15	33.71	16
Toshka	HEBL	624190	22.36	31.61	192

The data to be collected in the three locations are temperatures (dry and wet), relative humidity. The weather in Egypt is almost always sunny and no great changes in the weather conditions occur except the large temperature swing between night and day.

4. Prototypes and Testing Plan

Through intensive round of discussion and consultation with local OEMs and based on formal communication and technical visits to their facilities to better understand capacities and readiness to build the needed prototypes.

Progress of Prototype Building by Local OEM

One OEM was ready with its prototype which was tested at their factory in 10th Ramadan City in Greater Cairo in Climatic Zone 2.

5. Pre-Testing Conditions

The pre-testing was conducted at OEM “Zone 2: Delta and Cairo Region” at altitude of 344.5 Feet above sea level. Figure 1 describes the schematic diagram of the testing site.

- a. Both units were located at the entrance of OEM factory.
- b. The distance between the hybrid IEC Unit and DX Unit was about 3 meters long.
- c. The inlet of both units is directed to the North-East, and the outlet directed to the South-West.
- d. Both units are full fresh air units.




Figure (1) schematic diagram for both units

5.1 Description of Hybrid IEC Unit:

Emerson Compressor	ECU2500
Airflow	1940 cfm
Refrigerant type	R-32
Air	Full fresh air
Compressor capacity	55000 PTU/HR



5.2 Description of DX Unit:

Emerson Compressor	PAS SU/SCX 1206
Airflow	1940 cfm
Refrigerant type	R-410A
Air	Full fresh air
Compressor capacity	154000 PTU/HR

Note: An inverter was connected to the motor of the air blower of the unit to adjust the air flow rate.



6. Measuring Instruments Used in Pre-Testing

Code of Device	Instrument	Model	Number of Devices	Measurement Scope
1	Temperature Humidity Meter	FLUKE 971	1	Temperature & Humidity
2&3	Hygrothermometer	KIMO TH300	2	
4&5	Flow Meter	KIMO CP300	2	Air Flow
6	Power Analyzer	KYORITSU	1	Power Consumption & Energy Efficiency

Note: Catalogues of measuring devices are “attached”

7. Testing Methodology

Prototypes were tested in “OEM Factory” in which the EER and cooling capacities of both (Hybrid IEC & DX) Units are calculated from measurements of inlet and outlet wet and dry bulb temperatures and associated airflow rates, which measured as below:

- The pre-testing preparations included setting the Air flow for both the Hybrid IEC Unit and the DX Unit on the same value (1940 CFM) by using a measuring Flow Meters “**code 4&5**”.
- The pre-testing started at 1:00 PM on 6th October, 2021.
- The pre-testing steps included measuring the ambient conditions (Dry bulb temperature, and relative humidity), the performance of each unit by recording the outlet conditions (Dry bulb temperature, and relative humidity), in addition to the power consumption of both units.
- The recordings were taken hourly with a programmed data logging devices, and manually.
- The ambient temperature and relative humidity were measured by using measuring Temperature Humidity Meter instrument “**code 1**”.
- the temperature, relative humidity, wet bulb, and enthalpy of the Hybrid IEC Unit outlet, measuring by hygrothermometer instrument “**code 2**”.
- Similarly, hygrothermometer instrument “**code 3**” was used to record the temperature, relative humidity, wet bulb, and Enthalpy of the DX Unit.
- The power consumption was measured by using power analyzer “**code 6**”.
- Water consumption of the hybrid IEC unit is measured by monitoring the water level in the basins.

- Measurements are done automatically by programming the aforementioned devices to log data for duration of 24 hours with a sampling time of 1 hour.
- The logged data are then transferred to a PC for tabulation and analysis.
- The pre-testing ended at 3:00 PM, on 7th October, 2021.
- The pre-testing was paused between 3:00 AM to 7:00 AM on 7th October, 2021 in sync with the reduction of the ambient temperature below 20°C.





Figure 2 schematic diagram for the connection of the measuring devices on the site

7.1 Measuring Airflow Rate

- Airflow measuring apparatus (**code 4&5**) is subjected to the outlet of the two tested units in order to measure the airflow.
- The Air flow for both units is measured before starting the pre-test and is found about 1940 CFM for both units.




7.2 Measuring Wet and Dry Bulb Temperatures and Relative Humidity

- Air measuring devices for each unit (Inlet and Outlet) were used to measure average temperature.
- The Temperature Humidity Meter “**code 1**” is located in the inlet of the two tested units to measure both temperature and relative humidity.
- The two hygrothermometer instrument “**code 2&3**” are located in the outlet of the two tested units to measure both temperature and relative humidity.

7.3 Measuring Electrical Parameters:


- The Power Quality Analyzer “**code 6**” is used to measure electrical parameters such as power consumption, applied voltage, current consumption and power factor of both units.



7.4 Measuring Water consumption:

Water consumption of the hybrid IEC unit is measured by monitoring the water level in the basins.

- Water consumption was measured by calculating the decrease in the height of the water and multiplies it with the cross section area of the water bath:
 - ✓ Water bath (1) Dimensions (mm) = 1728.5×623
 - ✓ Water bath (2) Dimensions (mm) = 858.5×920



8. Details of Performed Pre-tests

Three pre-tests were conducted in order to construct a complete study for the performance of the hybrid IEC unit in comparison with the traditional DX unit:

The First Pre-test made by OEM, witnessed and assisted by HBRC: on 23th Sep.,2021.

Note:

- After 8 hours of starting, the hybrid IEC unit stopped because of a technical failure.
- The first pre-test did not finish due to the technical failure in the Hybrid IEC Unit, accordingly the data analysis was not completed.
- The Measuring Data was included in “**Annex 1**”.

a. The second Pre-test made by the OEM after the accuracy of the measuring instruments was checked by the TAB Company.

Note:

- The calibration report, which checked by the TAB company is included in “**Annex 2**”.
 - Contact info. Of TAB Company: “The Engineering Company for Testing and Balancing Services” ([Site: https://www.tab.com.eg/](https://www.tab.com.eg/)).
- b. The third Pre-test made by OEM, witnessed and assisted by HBRC: on 6th Oct., 2021
“The testing report is included in the final results shown below”.

9. Final Results

• LAB	In Site
• Company	OEM
• Aims of Pre-Test :	Comparison between the EER and Capacity of Hybrid IEC unit versus the DX Unit
• Hybrid IEC Unit Model	ECU2500
• DX Unit Model	PAS SU/SCX 1206
• Description of Pre-Tests	<p>The first pre-test on 23th Sep.,2021 was discontinued after the hybrid IEC unit stopped.</p> <p>The second Pre-test was done to check the calibration of measuring instruments (3rd party TAB Company was invited to calibrate) on 28th Sep.,2021 .</p> <p>The final pre-test was the third on 6th Oct, 2021.</p>
• Airflow of Both Units	1940 cfm full fresh air
• Altitude	344.5 ft. above sea level
• Duct size	(28*12 inch)

Remarks:

- Water consumption was measured by calculating the decrease in the height of the water column. The height was multiplied by the cross section area of the water bath:
 - a. Water bath (1) Dimensions (mm) = 1728.5×623
 - b. Water bath (2) Dimensions (mm) = 858.5×920
- Measurements started at 12:50 pm.
- Measurements were recorded hourly until 3 am, when both units stopped at inlet ambient temperature decreased below 20°C (Both hybrid IEC Unit and DX Unit were programmed to stop at 20°C).
- The measurements were restarted at 7 am next day (7th Oct., 2021) when the inlet ambient temperature exceeded 20°C.
- The pre-testing ended at 3 pm (7th Oct., 2021) after 24 records were achieved.

Readings of DX Unit

Table (1) Readings of DX Unit

Hour	DX Unit , Air flow = 1940 cfm , Altitude = 334.5 ft									
	Inlet DB Celsius	Inlet RH %	Outlet DB Celsius	Outlet RH %	Sensible Cooling Btu/h	Latent dehumidifying Btu/h	Cooling Capacity Btu/h	Power kW	EER Btu/hr.watt	
1PM	32.8	35.4	9.8	78	82,245	46,145	128,390	12.05	10.655	
2PM	31.7	29.6	9.3	78.1	80,564	26,558	107,122	12.29	8.716	
3PM	30.8	36.2	9.5	76.7	76,712	39,644	116,356	12.16	9.569	
4PM	31.6	35.3	8.7	82.6	82,258	40,378	122,636	12.04	10.186	
5PM	28.9	41	7.6	83.9	77,132	43,301	120,433	12	10.036	
6PM	26.9	45.6	7.1	86.1	72,151	43,034	115,185	11.78	9.778	
7PM	25.7	53	7.6	88.7	66,130	47,673	113,803	11.64	9.777	
8PM	24.8	59.9	7.4	92.4	47,673	53,613	101,286	11.56	8.762	
9PM	24	63.2	7.2	93.7	61,598	54,369	115,967	11.41	10.164	
10PM	23.1	65.4	6.4	94.8	61,405	54,683	116,088	11.17	10.393	
11PM	22.1	68.8	5.8	95.6	60,109	55,508	115,617	11.01	10.501	
12AM	21.9	70.3	5.4	96.7	60,857	57,393	118,250	10.77	10.980	
1AM	21.1	71.1	5	96.8	59,571	54,857	114,428	10.72	10.674	
2AM	21.2	71.5	4.9	97.2	60,275	56,220	116,495	10.71	10.877	
3AM	20.7	72.9	4.8	97.5	58,895	55,305	114,200	10.62	10.753	
7AM	22.5	68.3	5.2	98.6	63,701	57,834	121,535	10.43	11.652	
8AM	26.1	57.5	9.3	83.5	61,176	55,876	117,052	11.37	10.295	
9AM	26.9	51.4	7.5	89	70,571	51,822	122,393	11.64	10.515	
10AM	31.2	40.8	8.3	83.7	82,208	53,314	135,522	11.87	11.417	
11AM	29.8	40.1	8.9	82.7	75,473	42,180	117,653	12.15	9.683	
12PM	30.1	37.8	9.3	81.3	75,089	37,663	112,752	12.14	9.288	
1PM	33	32	9.7	82.2	83,377	35,062	118,439	12.52	9.460	
2PM	32	30.4	9.1	77.6	82,248	31,050	113,298	12.56	9.021	
3PM	33.5	30.9	10.5	76.6	82,176	35,310	117,486	12.69	9.258	

Prepared by

Eng. Sally Aladdin

Checked by

Prof. Sayed Shebl

Approved by

Prof. Alaa Olama

Eng. Nourhan Abdel Rahman

Readings of Hybrid IEC Unit

Table (2) Readings of Hybrid IEC Unit

Hour	Hybrid IEC Unit , Air flow = 1940 cfm , Altitude = 334.5 ft									
	Inlet DB Celsius	Inlet RH %	Outlet DB Celsius	Outlet RH %	Sensible Cooling Btu/h	Latent dehumidifying Btu/h	Cooling Capacity Btu/h	Power kW	EER Btu/hr.watt	
1PM	32.8	35.4	13.3	80.2	69,845	30,382	100,227	4.524	22.155	
2PM	31.7	29.6	12.4	78.8	69,486	14,162	83,648	4.524	18.490	
3PM	30.8	36.2	12.4	79.5	66,357	26,391	92,748	4.513	20.551	
4PM	31.6	35.3	12.9	79.9	67,272	25,708	92,980	4.56	20.390	
5PM	28.9	41	11.6	81.5	62,738	29,774	92,512	4.555	20.310	
6PM	26.9	45.6	11.3	84.2	56,939	28,183	85,122	4.528	18.799	
7PM	25.7	53	12.2	85.9	49,420	30,680	80,100	4.567	17.539	
8PM	24.8	59.9	12.7	87.7	44,366	34,145	78,511	4.597	17.079	
9PM	24	63.2	12.9	87.1	40,784	34,396	75,180	4.625	16.255	
10PM	23.1	65.4	12.4	87.5	39,423	34,407	73,830	4.508	16.378	
11PM	22.1	68.8	12.1	88.4	36,952	34,133	71,085	4.489	15.835	
12AM	21.9	70.3	11.9	88.2	34,133	36,289	70,422	4.425	15.915	
1AM	21.1	71.1	11.9	88.5	34,111	32,112	66,223	4.436	14.929	
2AM	21.2	71.5	11.7	88.7	35,198	34,128	69,326	4.418	15.692	
3AM	20.7	72.9	11.3	88.4	34,875	35,092	69,967	4.422	15.822	
7AM	22.5	68.3	11.1	89	42,038	40,135	82,173	4.475	18.363	
8AM	26.1	57.5	12.6	86.9	49,262	39,189	88,451	4.554	19.423	
9AM	26.9	51.4	13.3	85.4	49,599	29,901	79,500	4.55	17.473	
10AM	31.2	40.8	12.9	83.8	65,831	34,602	100,433	4.538	22.132	
11AM	29.8	40.1	13.1	82.3	60,418	25,254	85,672	4.567	18.759	
12PM	30.1	37.8	13.4	81.9	60,398	20,245	80,643	4.594	17.554	
1PM	33	32	13.2	82.2	70,952	20,541	91,493	4.614	19.829	
2PM	32	30.4	11.6	80.3	73,341	19,781	93,122	4.589	20.292	
3PM	33.5	30.9	12.8	81.6	74,049	22,187	96,236	4.656	20.669	

Prepared by

Eng. Sally Aladdin

Checked by

Prof. Sayed Shebl

Approved by

Prof. Alaa Olama

Eng. Nourhan Abdel Rahman




Figure (3): Cooling Capacity of (Hybrid IEC & DX) Units

Note: The Plotted Cooling capacity of both units in $Btu/hr(\times 10^3)$.




Figure (4): EER of (Hybrid IEC & DX) Units




Figure (5): ambient (Relative humidity and Temperature) of (Hybrid IEC & DX) Units

10. Discussion of the results

- a. The capacity of the compressor of the hybrid IEC unit is smaller than the DX unit.
- b. Both units are full fresh air units with an inverter installed in the DX unit air blower to provide equality of the air flows.
- c. A testing and balancing third party were invited after the first test to make sure the measuring instruments were well calibrated.
- d. The hybrid IEC unit compressor was switched on continuously, as well as the DX unit compressor.
- e. The pre-testing started on 6th October, 2021 and ended on 7th October, 2021.
- f. In Figure 2:
 - As the ambient RH increases the capacity of the IEC unit decreases and vice versa.
 - The capacity of DX unit is almost constant.
 - As the dry bulb temperature increases the capacity of both units decreases and vice versa.
- g. In Figure 3:
 - The EER of the DX unit is almost constant during all the testing periods.
 - The EER of the hybrid IEC unit is superior than the DX unit throughout all relative humidities.
 - Although the RH increased from 29.6 to 72.9 (59.4 %) the EER of the hybrid IEC unit decreased from 18.49 to 15.822 (Percentage of improvement Hybrid IEC Unit=14.43%).
 - Percentage of improvement Hybrid IEC Unit= 34.0625%.
 - Percentage of improvement DX Unit = 25.2623%.
- h. According to table 1 and 2 we can sum up the following findings:

Type	Min. RH %	Coincident T _{db} (Kelvin)	EER	Cooling Capacity	Max. RH %	Coincident T _{db} (Kelvin)	EER	Cooling Capacity	Diff. EER	Diff. Cooling Capacity
DX	29.6	31.7	8.716	107,122	72.9	20.7	10.753	114,200	2.037	7,078
IEC			18.490	83,648			15.822	69,967	2.668	13,681

11. Conclusions

- a. To make sure the testing comparison is more realistic between the hybrid IEC unit and DX unit; it is recommended that the size of compressors of both units have the same nominal capacity, or the dry bulb temperature of the outlet air for the hybrid IEC and DX unit are kept constant.
- b. Although the pre-testing was conducted at the end of the summer season, the results show the EER of the IEC unit is superior to that the DX unit.
- c. When testing at the height of the summer season the result is expected to be even better.
- d. Climatic Zone 2 “Delta and Cairo region” is relatively high in humidity, other climatic regions except climatic region 1 will show even better results because of the lower humidity.
- e. Consistent results for 24 hours took 3 days of pre-test trials.

Notes:

- The EER is calculated using equation(1)

$$EER = \frac{\text{Total Cooling Capacity } (\frac{\text{Btu}}{\text{hr}})}{\text{Power (watt)}} \quad (1)$$

- The Total Cooling Capacity is calculated using equation (2)

$$\text{Cooling Capacity (Btu/hr)} = \frac{\text{Enthalpy}_{in} - \text{Enthalpy}_{out}}{\text{flow} * \text{Air volume}@344.5 \text{ ft}} \quad (2)$$

Prepared by

Eng. Sally Aladdin

Checked by

Prof. Sayed Shebl

Approved by

Prof. Alaa Olama

Eng. Nourhan Abdel Rahman

Annex 1

Results of the First Pre-Test on 23th Sep., 2021

The Reading of the DX Unit:

Project No.: 140400			Air Flow (CFM): 1932				
End Time: 11:16 AM, 23th Sep.,2021				End Time: 11:16 AM, 24th Sep.,2021			
Item	INLET (fluke 971)			DXU (OEM1)			
	Ambient Temp.	Wet Bulb	Relative Humidity	Dry Bulb	Wet Bulb	Relative Humidity	Enthalpy
	°C	°C	%	°C	°C	%	kJ/kg
1	36.2	26.7	48.7	14	11.9	76.4	33.4
2	40	24.4	29.7	13.3	11.6	79.2	32.7
3	40	24.1	24.1	13.7	11.8	77.8	33.2
4	40.1	24.4	25.4	13.7	11.7	77.4	32.9
5	36.6	23.9	34.5	14.7	12.2	73.8	31.3
6	35.1	23.5	36.9	13.2	11.6	80.8	32.8
7	33	22.8	40.9	12.5	11.1	82.1	31.4
8	30.8	22.5	50	11.7	10.8	85.7	30.6
							8.051

The Reading of the Hybrid IEC Unit:

Project No.: 140400							Air Flow (CFM): 1934					
End Time: 11:16 AM, 23th Sep.,2021					End Time: 11:16 AM, 24th Sep.,2021							
Item	INLET (fluke 971)			ECU-Hybrid (OEM1)								
	Ambient Temp.	Wet Bulb	Relative Humidity	Dry Bulb	Wet Bulb	Relative Humidity	Enthalpy	Water Level	Water Cons.	Power		
	°C	°C	%	°C	°C	%	kJ/kg	mm	m3/hr	kW		
1	36.2	26.7	48.7	17	16.4	89.5	44.3	0	0	2.633		
2	40	24.4	29.7	16.4	15.9	89.2	42.8	26	0.0485	2.741		
3	40	24.1	24.1	17	16.4	89	44.2	27	0.0504	2.59		
4	40.1	24.4	25.4	17	16.4	88.5	44.1	28	0.0523	2.596		
5	36.6	23.9	34.5	17.5	17	89.2	45.7	27	0.0504	2.623		
6	35.1	23.5	36.9	17.9	17.6	90.9	47.4	23	0.0429	2.596		
7	33	22.8	40.9	17.6	17.3	91.4	46.5	24	0.0448	2.641		
8	30.8	22.5	50	18.6	18.5	92.4	50	19	0.0355	2.606		

Note: The first pre-test did not finish due to the technical failure in the Hybrid IEC Unit, accordingly the data analysis was not completed.

Annex 2

Calibration results made by the TAB Company On 28th Sep., 2021

No.	TSI Device (Air flow & Pressure)		KIMO Device (Air flow & Pressure)	
	Air flow (CFM)	Static Pressure	Air flow (CFM)	Static Pressure
1	1927	5	1930	12
2	1657	115	1650	122
3	-	208	-	218
4	-	22	-	32

UNIT DATA		PU	
Equipment Location		-	
Area Served		-	
Equipment Manufacturer		OEM	
Model		BOX BD 10/10 M4	
Serial Number		-	
FAN DATA		DESIGN	MEASURED
Total air Flow (CFM)		2003	1927
Total Static Pressure (Pa)		235	-
External Static Pressure (Pa)		-	12
Fan RPM		1340	N.A
MOTOR DATA		DESIGN	MEASURED
Motor Manufacturer		-	
Motor (KW)		0.59	0.5
Phase/HZ		3PH/50Hz	
Voltage (v)		230	22 7
Amperage (A)		4.5	3.8
Motor RPM		1340	N. A

Point No.	1	2	3	4	5
A	+	+	+	+	+
B	+	+	+	+	+
C	+	+	+	+	+

Design	Duct size (inch)	28*12
	Area (Sq. inch)	336
	Velocity (ft./min)	858
	Flow (CFM)	2003

Point No.	1	2	3	4	5
A	2154	1845	2073	1585	2024
B	2358	1705	2119	1884	1821
C	2072	1894	1753	2070	1553

Measured	Duct size (inch)	28*12
	Area (Sq. inch)	336
	Velocity (ft./min)	826
	Flow (CFM)	1927

Temperature & RH Calibration



No.	AQM (Reference Device)		KIMO2		KIMO3	
	Temp. (°C)	RH %	Temp. (°C)	RH %	Temp. (°C)	RH %
1	26.8	43.4	27.5	44.6	27.9	39
2	27.3	42.9	27.9	44.4	28.4	38.8
3	26.8	43.4	27.5	44.6	27.9	39
4	27.5	42.6	28.2	44.8	28.7	38.5
5	27.8	42.4	28.6	43.8	29.1	38.3
6	27.8	42.4	28.7	43.8	29.1	38.2
7	28.3	42	29.4	43.3	29.7	38.3
8	28.4	42	29.4	43.1	29.7	38.3
9	28.4	42.7	30.3	43.2	30.5	37.3
10	29	42.4	30.5	42.3	30.6	37.6
11	29.2	43	30.9	42.7	31.1	37.5
12	29.2	43.3	30.9	42.6	31.2	37.4
13	33.7	32	34	35.3	34.2	30.2
14	33.7	31.4	34.1	34.9	34.3	29.9
15	33.4	30.8	34.1	34.5	34.4	29.6
16	34.1	31.7	34.5	34.4	34.7	29.7
17	34	31.6	34.5	34.5	34.8	29.7
18	33.4	32	34.7	34.3	34.9	29.5
19	33.7	31.9	34.7	34.3	34.9	29.4
20	33.5	31.8	34.9	33.7	28.8	35.1
21	33.6	32	35	33.8	35.1	29
22	33.5	32.1	35	33.8	35.2	28.9
Average	30.6	37.7	31.6	39.4	31.6	34.5
Deviation from AQM	-	-	1.0	1.7	1.0	-4.9
Deviation %	-	-	3.3%	4.4%	3.3%	13.0%

Temperature & RH Calibration

No.	AQM (Reference Device)		FLUKE	
	Temp. (°C)	RH %	Temp. (°C)	RH %
1	25.3	44.8	24.9	46.6
2	25.5	44.7	25.6	46.9
3	25.7	44.5	25.8	46.7
4	26	44.1	25.9	47.2
5	26.6	43.2	26.1	47.3
6	26.9	43.1	26.4	48
7	26.8	43.4	25.2	47.5
8	27.3	42.9	25.6	46.6
9	26.8	43.4	25.2	47.5
10	27.5	42.6	26.7	46.1
11	27.8	42.4	26.9	46.1
12	28.3	42	27.2	46
13	28.4	42	27	46.1
14	28.4	42.7	27.6	46.4
15	29.2	43	27.4	47.7
16	33.7	32	33.4	35.6
17	34.1	31.7	34.8	33.5
18	34	31.6	34.7	33.5
19	33.4	32	35.3	33.4
20	33.7	31.9	35.5	33.6
21	33.5	31.8	35	33.9
22	33.6	32	34.9	34.4
23	33.5	32.1	34.6	34.6
Average	29.39	39.3	29.2	42.4
Deviation From AQM %	-	-	-0.2	3.1
Deviation %	-	-	0.6%	7.9%

Attachment

Measuring Instrument - Code 1

<p style="text-align: center;">FLUKE.</p> <p style="text-align: center;">971 Temperature Humidity Meter</p> <p style="text-align: center;">Users Manual</p> <p style="text-align: center;">PN 2441047 September 2005 Rev.1, 5/06 © 2005-2006 Fluke Corporation. All rights reserved. Printed in Taiwan All product names are trademarks of their respective companies.</p>	 <p>The diagram shows the front panel of the Fluke 971 meter. It features a digital display at the top showing three readings. Below the display are several buttons: Power (with a battery icon), Data Hold, Data Save, and Data Recall. To the right of the display are buttons for MIN MAX AVG, Backlight, and WB/DP/Ambient Temperature. The bottom of the meter has a sensor protective shutter.</p>																																				
<p>Introduction</p> <p>⚠ Caution</p> <p>To extend sensor life, keep the sensor's protective shutter closed whenever the meter is not in use.</p> <p>The Fluke Model 971 (hereafter referred to as "the Meter") is a battery powered meter that measures relative humidity and temperature. Through a few easy to use controls, the Meter displays three different temperature points of the air surrounding the meter's sensor: ambient, wet bulb, and dew point.</p> <p>Electrical and Safety Symbols</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 2px;">⚠</td> <td style="padding: 2px;">Important information. See manual</td> <td style="padding: 2px;">■</td> <td style="padding: 2px;">Low battery when shown in the display.</td> </tr> <tr> <td style="padding: 2px;">CE</td> <td style="padding: 2px;">Conforms to European Union requirements</td> <td style="padding: 2px;">C</td> <td style="padding: 2px;">Conforms to Australian standards.</td> </tr> <tr> <td style="padding: 2px;">CSA</td> <td style="padding: 2px;">Conforms to Canadian standards</td> <td style="padding: 2px;">○</td> <td style="padding: 2px;">Power ON / OFF</td> </tr> </table>	⚠	Important information. See manual	■	Low battery when shown in the display.	CE	Conforms to European Union requirements	C	Conforms to Australian standards.	CSA	Conforms to Canadian standards	○	Power ON / OFF	<p>971 <i>Users Manual</i></p> <p>Display</p>  <p>The display shows three numerical readings. Callout 1 points to a low battery icon. Callout 2 points to a wet bulb or dew point symbol. Callout 3 points to a min/max record symbol. Callout 4 points to temperature units (°F, °C). Callout 5 points to a relative humidity (% RH) symbol. Callout 6 points to a memory location number (BB). Callout 7 points to a HOLD button.</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>No.</th> <th>Symbol</th> <th>Meaning</th> </tr> </thead> <tbody> <tr> <td>1</td> <td></td> <td>Low battery.</td> </tr> <tr> <td>2</td> <td></td> <td>Wet bulb or dew point temperature displayed.</td> </tr> <tr> <td>3</td> <td>MIN MAX MAX, MIN, AVG</td> <td>Min Max Record enabled. Maximum, minimum, or average reading displayed.</td> </tr> <tr> <td>4</td> <td>°F, °C</td> <td>Temperature measurement units.</td> </tr> <tr> <td>5</td> <td>% RH</td> <td>Relative humidity measurement unit.</td> </tr> <tr> <td>6</td> <td>MEM BB</td> <td>Displayed reading is from memory. Memory location number.</td> </tr> <tr> <td>7</td> <td>HOLD</td> <td>HOLD enabled. Display freezes present reading.</td> </tr> </tbody> </table>	No.	Symbol	Meaning	1		Low battery.	2		Wet bulb or dew point temperature displayed.	3	MIN MAX MAX, MIN, AVG	Min Max Record enabled. Maximum, minimum, or average reading displayed.	4	°F, °C	Temperature measurement units.	5	% RH	Relative humidity measurement unit.	6	MEM BB	Displayed reading is from memory. Memory location number.	7	HOLD	HOLD enabled. Display freezes present reading.
⚠	Important information. See manual	■	Low battery when shown in the display.																																		
CE	Conforms to European Union requirements	C	Conforms to Australian standards.																																		
CSA	Conforms to Canadian standards	○	Power ON / OFF																																		
No.	Symbol	Meaning																																			
1		Low battery.																																			
2		Wet bulb or dew point temperature displayed.																																			
3	MIN MAX MAX, MIN, AVG	Min Max Record enabled. Maximum, minimum, or average reading displayed.																																			
4	°F, °C	Temperature measurement units.																																			
5	% RH	Relative humidity measurement unit.																																			
6	MEM BB	Displayed reading is from memory. Memory location number.																																			
7	HOLD	HOLD enabled. Display freezes present reading.																																			

<p align="center">Temperature Humidity Meter Operation</p> <hr/> <p>Operation</p> <p>Note</p> <p>When moving from one temperature/humidity extreme to another, allow time for the Meter to stabilize.</p> <p>After opening the sensor's protective shutter, press (O) to turn on the Meter and start taking measurements.</p> <p>Temperature readings are displayed in either the Celsius (°C) or Fahrenheit (°F) scale. To switch between °C and °F, remove the battery compartment door and position the temperature scale switch to the desired scale. See Figure 1.</p> <p>Dew Point and Wet Bulb Temperature</p> <p>The Meter displays ambient temperature when first turned on. To display dew point (DP) temperature, press [DP] once. Press [DP] again to switch to wet bulb (WB) temperature. Pressing [DP] a third time returns the Meter to ambient temperature. The display indicates when dew point and wet bulb temperatures are selected.</p> <p>HOLD</p> <p>Pressing [HOLD] causes the meter to freeze the displayed readings. It also causes the meter to stop taking measurements. [HOLD] is displayed when HOLD is enabled. To continue taking measurements, press [HOLD] again.</p>	<p>971 <i>Users Manual</i></p> <hr/> <p>Min Max Record</p> <p>When enabled, Min Max Record stores a new measurement when it is either higher or lower than a previously stored maximum or minimum measurement. Press [MIN MAX] to start Min Max Record. [MIN MAX] appears in the display to indicate Min Max Record mode is enabled.</p> <p>Note</p> <p>The temperature scale switch (°C/°F), Save, Recall, and Hold buttons, as well as the Automatic Power Off (APO) switch are all disabled when Min Max Record is enabled.</p> <p>To view the stored Minimum, Maximum and Average readings, press [MIN MAX] repeatedly to cycle through all three stored sets of measurements. You must select wet bulb, dew point, or ambient before reading their respective Min Max Avg values. The display indicates which stored set of readings is displayed. Pressing [MIN MAX] a fourth time displays the present measurement.</p> <p>To exit Min Max Record mode and resume normal operation, press and hold [MIN MAX] for two seconds.</p> <p>Saving and Recalling Measurements</p> <p>The Meter stores up to 99 readings for later recall. Each memory location stores relative humidity as well as ambient, dew point and wet bulb temperatures.</p>
3	4

<p align="center">Temperature Humidity Meter Operation</p> <hr/> <p>Pressing [SAVE] saves the present readings to a memory location. [MEM] and the memory location number appear in the display to indicate the readings have been stored. Press [RECALL] to return the display to the present reading. After all 99 memory locations are filled, each subsequent save overwrites a memory location starting with the first.</p> <p>To recall the readings from memory, press [RECALL]. If the memory location you are looking for is not already displayed, press ▲ or ▼ until the desired memory location is displayed. To return the Meter to normal operation, press [RECALL] for two seconds.</p> <p>By default, relative humidity and ambient temperature are displayed when a memory location is recalled. Pressing [RECALL] cycles through the Wet Bulb, Dew Point, and Ambient temperatures stored in the memory location displayed.</p> <p>To erase all 99 memory locations, simultaneously press [SAVE] and [RECALL] for five seconds.</p> <p>Automatic Power Off</p> <p>To save battery life, the Automatic Power Off (APO) feature can be used to turn the meter off after 20 minutes of no activity. To enable or disable the APO feature, remove the battery cover and position the APO switch to the desired position. See Figure 1.</p>	<p>971 <i>Users Manual</i></p> <hr/> <p>Maintenance</p> <p>Battery Replacement</p> <p>Meter power is supplied by four 1.5 V (AAA size) batteries. When [BATT] appears in the display, replace the batteries as soon as possible. To replace the batteries:</p> <ol style="list-style-type: none"> 1. Back out the screw at the top of the battery door and lift the door away from the Meter. 2. Remove the four AAA batteries from the compartment. 3. Replace with four new AAA batteries, observing proper polarity as depicted on the bottom of the battery compartment. 4. Replace the battery door and tighten the screw to lock it in place.
5	6




Figure 1. Battery Compartment

Cleaning

Caution

To avoid damage to the case, do NOT use abrasives or solvents for cleaning the meter.

Periodically wipe the case with Fluke Meter Cleaner or a damp cloth and detergent.

7

Specifications

Temperature Range:	-20 to 60 °C (-4 to 140 °F)
Accuracy:	±0.5 °C on 0 to 45 °C ±1.0 °C on -20 to 0 °C, 45 to 60 °C
	±1.0 °F on 32 to 113 °F ±2.0 °F on -4 to 32 °F, 113 to 140 °F
Resolution:	0.1 °C /°F
Update rate:	500 ms
Sensor type:	NTC
Relative Humidity Range:	5 to 95 % RH
Accuracy:	±2.5 % RH (10 to 90 % RH) @23 °C (73.4 °F) ±5.0 % RH (<10, >90 % RH) @23 °C (73.4 °F)
Resolution:	0.1 % RH
Response time:	60 seconds max.
Sensor hysteresis:	±1 % RH with excursion of 90 % to 10 % to 90 %
Sensor type:	Electronic-capacitance polymer film
Temperature Coefficient:	0.1 x (specified accuracy)/°C (< 23 °C or > 23 °C)
Wet Bulb Temperature Range:	-20 to 60 °C (-4 to 140 °F)
Dew Point Temperature Range:	-50 to 60 °C (-58 to 140 °F)

8

Memory:	99 data points
Power:	4 each AAA batteries, 24A, LR03
Battery Life:	200 hours
Environment Storage:	-20 to 60 °C at <80 % R.H. (Batteries removed)
Operating:	Temperature: -20 to 60 °C Humidity: 0 to 95 °C
Weight/Dimensions:	190 g with batteries 194 mm x 60 mm x 34 mm
Safety Approvals/ Certifications:	C Meets Australian requirements CSA Meets CSA requirements CE Meets European requirements Meets EN61326-1, Schedule B Electromagnetic Emissions and Susceptibility

Specifications subject to change without notice

9

LIMITED WARRANTY AND LIMITATION OF LIABILITY

This Fluke product will be free from defects in material and workmanship for one year from the date of purchase. This warranty does not cover fuses, disposable batteries, or damage from accident, neglect, misuse, alteration, contamination, or abnormal conditions of operation or handling. Resellers are not authorized to extend any other warranty on Fluke's behalf. To obtain service during the warranty period, contact your nearest Fluke authorized service center to obtain return authorization information, then send the product to that Service Center with a description of the problem.

THIS WARRANTY IS YOUR ONLY REMEDY. NO OTHER WARRANTIES, SUCH AS FITNESS FOR A PARTICULAR PURPOSE, ARE EXPRESSED OR IMPLIED. FLUKE IS NOT LIABLE FOR ANY SPECIAL, INDIRECT, INCIDENTAL OR CONSEQUENTIAL DAMAGES OR LOSSES, ARISING FROM ANY CAUSE OR THEORY. Since some states or countries do not allow the exclusion or limitation of an implied warranty or of incidental or consequential damages, this limitation of liability may not apply to you.

Fluke Corporation
P.O. Box 9090
Everett, WA 98206-9090
U.S.A.

Fluke Europe B.V.
P.O. Box 1186
5602 BD Eindhoven
The Netherlands

11/99

10

Measuring Instruments - Code 2 & 3

KIMO INSTRUMENTS

Technical Data Sheet

Pressure • Temperature • Humidity • Air Velocity • Airflow • Sound level

Humidity / Temperature transmitter
TH300

New

Part number
To select just enter the code to complete the partnumber

Housing
AISI 304
PC or stainless steel probe
AlU or ABS housing
With or without display

Probe
Probes
Hygrostat
Standard probe
PC or stainless steel probe
AlU or ABS housing
With or without display

Power supply / Output
DC 12V
DC 24V
DC 230V
RS 485
RS 232
Modbus

Probe mounting
Screw
Screw
Screw
Screw

Probe length
100 mm (standard)
100 mm (standard)
100 mm (standard)
100 mm (standard)

Display
0.9 inch
Without display

STH -

Example: TH300-PHENIX-PROB - humidity transmitter type TH300, with AISI housing, 12V DC power supply, without display, with probe reference probe length 50mm.

SENTRONIC AG Support 2 CH - 8432 Busslingen Tel: +41 (0)62 222 54 18 Fax: +41 (0)62 222 12 12 mail@sentronic.com www.sentronic.com

Easy maintenance with the new SMART PRO digital probes.
• **Totally Interchangeable:** they are individually adjusted and are automatically recognized by the transmitter.

Housing dimensions
(including wet-mounting plate)

Probes features

- Polycarbonate probes**
Measuring range: -20 to +100°C
Standard probe: length 100 mm
Short probe: length 300 mm
Cable: PVC Ø 4.8 mm, by 2 m
- Stainless steel probes**
Measuring range: -40 to +100°C
Standard probe: length 100 mm
Short probe: length 300 mm
Cable: stainless steel Ø 4.8 mm, by 2 m

Tip selection

Part number	EPP2	EPOS	EPW0	EPV1	EPV2
Up-mounted	yes	yes	yes	yes	yes
Down-mounted	no	no	no	no	no
Filter type	unfiltered	unfiltered	unfiltered	unfiltered	unfiltered
Mounting position	horizontal	horizontal	horizontal	horizontal	horizontal
Measuring velocity	250mm	250mm	250mm	250mm	250mm
Measuring temperature	-120°C	-120°C	-120°C	-120°C	-120°C
Measuring relative humidity	200%	200%	200%	200%	200%
Cough	30mm	30mm	30mm	30mm	30mm

Application

Measuring location	EPP2	EPOS	EPW0	EPV1	EPV2
Food processing	yes	yes	yes	yes	yes
Cold storage room	yes	yes	yes	yes	yes
Industry	yes	yes	yes	yes	yes
Hygrostat probe / hygrometer	yes	yes	yes	yes	yes
Drier	yes	yes	yes	yes	yes
Storage pool	yes	yes	yes	yes	yes
Food environments	yes	yes	yes	yes	yes
Storage settings	yes	yes	yes	yes	yes
Dust	yes	yes	yes	yes	yes
Industrial products	yes	yes	yes	yes	yes
Gases	yes	yes	yes	yes	yes

EPIC Frequency: (EPF1, EPF2, EPF3) to meet EN 2041

Technical Specifications

Power supply: 24 Vac / Vdc ± 10%
115 Vac or 230 Vac ± 10%, 50-60 Hz
2 x 4.20 mAdc 2 x 0-10 V (4 wires)
Protection: IP65
Display: graphic LCD 1 x 30 mm
protection screen made of PMMA

Connection fittings: AISI model fixed for cable 7 mm max.
AISI 100-53 socket DIN IEC 751
Weight: 0.5 kg

Relays and Alarms

Class 300 transmitters have 4 stand-alone and configurable alarms :
You can set:
- the parameter (pressure, air velocity, temperature)
- the relay output (alarm, alarm reset, time delay, hysteresis, etc.)
- the relay action (single shot, latching, etc.)
- the relay operating mode: positive/negative/normally
- the audible alarms (beeper activation).

Digital communication

• **RS 232 communication**
When the RS 232 connection, TH 300 can display 1 or 2 parameters that are measured by others KIMO Class 200 and 300 transmitters. Benefit: the TH 300 candidacy (in addition to the humidity transmitter) to measure other parameters, pressure, air velocity or airflow with a C200 for example.

• **Via the RS 232 connection, you can also configure your transmitter with the CC-300 software.**

• **The RS 232 connection cable is available in 2 m, 5 m or 10 m (maximum) length.**

Modbus network (RS 485 system)
Class 300 transmitters can be linked in a bus network, on which the RS 485 connection is connected to the RS 485 port of the transmitter. They can also be integrated into existing Modbus networks. When the transmitter is connected to the RS 485 port, the Modbus enables the configuration of distances, to measure 1 or 2 parameters, to use the address of the transmitter.

Configuration

You can configure all the parameters of the transmitter : units, measuring ranges, alarms, outputs, channels, calculation formulas... via the different connection methods.

• **Via keypad: only mode with display**
A code-locking system combined with logical guarantees the security of the installation.

• **Via RS 232 control port: only on models with display**
This is convenient to configure the transmitters located far from the user or hard to reach. Same way as with a keypad.

• **Via RS 485 (Modbus):** simple and easy configuration.

• **Simple and user-friendly configuration. See LCC-300 user manual.**

• **Via MODBUS (optional):** on all models.

• **Configurable analogue outputs**
Configure the range according to your needs. The outputs are automatically adjusted to the new range.

Range with centre nom.: 4000-4900°C, with offset nom.: 3300-3400°C, or standard range with offset nom.: 3300-3400°C. The intermediate ranges according to your needs, between 10% and 100% of the full scale. The minimum configurable range is 10% of the full scale.

Calibration

Site calibration:
The TH 300 is a reference portable instrument which enables you to calibrate your transmitter directly on site. By connecting the transmitter to a multimeter, you can measure the current output of the transmitter and compare it with the expected value.

Output calibration:
In the transmitter, you can check with a multimeter (or a voltmeter) or a PLC/MES filter transmitter outputs work correctly. You can also check the transmitter's output voltage of 0-5 V, 0-10 V or current of 4-20 mA.

Certification:
• Class 300 transmitters are supplied with adjustment certificates. Calibration certificates are offered as an option. Adjustment certificates are issued with adjustment certificates and can also be supplied with calibration certificates offered as an option.

Maintenance

Visualise the transmitter on a wall. Be the cleaning sheet placed on the transmitter to avoid damage to the transmitter.

• The stainless steel plates must be cleaned with a soft cloth and mild detergent.

Options

- Reference probe:
- Instrument THM 300
- Temperature sensors
- Sticky Wings
- Calibration certificates
- Protector film
- Caps for tips

Optional accessories

- Wall mounting plate for humidity sensor probe

SENTRONIC AG Support 2 CH - 8432 Busslingen Tel: +41 (0)62 222 54 18 Fax: +41 (0)62 222 12 12 mail@sentronic.com www.sentronic.com

Measuring Instruments - Code 4 & 5

Measuring Instrument - Code 6



Quick manual



POWER QUALITY ANALYZER

KEW 6310

KYORITSU ELECTRICAL INSTRUMENTS WORKS, LTD.

Contents

The Quick manual is a simplified version of the full instruction manual which can be found in the supplied CD-ROM. This manual is intended only as a handy reference guide and should only be used after having read the full instruction manual which contains full details on each function of this instrument and the items contained in the package.

Safety Warning!
The instruction manual contains warnings and safety procedures which have to be observed to ensure safe operation of the instrument and maintain it in a safe condition. Thus, these operating instructions have to be read prior to using the instrument.

1. Instrument Overview	2
2. Instrument Layout	5
3. Getting started	7
4. Setting SET UP	10
5. Instantaneous value Measurement W	15
6. Integration value Measurement Wh	17
7. Demand Measurement Demand	19
8. WAVE Range Wav	23
9. Harmonic Analysis Harm	25
10. Power Quality QQual	27
Swell / Dip / Short interruption (Int) Measurement	27
Transient Measurement	29
Unbalance current Measurement	31
Unbalance Rate	33
Flicker	35
Capacitance Calculation	37
11. CF Card / Saved data	39
12. Wiring check	42

The latest software can be downloaded from our web site.
<http://www.kew-ltd.co.jp>

Activate Go To Setting
— 1 — KEW6310

1. Instrument Overview

Features

This is a handheld Power Quality Analyzer that can be used for various wiring systems. It can be used for simple measurements of instantaneous/ integration/ demand values, and also for monitoring waveforms and vectors, analyzing harmonics and measuring fluctuations in supply voltages and for the analysis of power factor correction with capacitor banks. Data can be saved either in the internal memory or a CF card, and can be transferred to a PC either via an USB port or a CF card reader.

Safety construction
Designed to meet the international safety standard IEC 61010-1 CAT III 600V CAT II 1000V

Wiring
KEW6310 supports : Single-phase 2-wire, Single-phase 3-wire, Three-phase 2-wire, Three-phase 4-wire.

Measurement and calculation
KEW6310 measures voltage (RMS), current (RMS), and calculates active/reactive/apparent power, power factor, phase angle, frequency, neutral current and active/reactive/apparent electric energy (kWh).

Demand measurement
Electricity consumption can be easily monitored so as not to exceed the target maximum demand values.

Waveform / Vector display
Voltage and current can be displayed by waveform or vector.

Harmonic analysis
Harmonic components of voltage and current can be measured and analyzed.

Power quality analysis
Measuring Swell/Dip/Int, Transient, Unbalance, Unbalance ratio and flicker*, moreover, simulating power factor correction with capacitor banks.
* Higher measurement function is only available with ver2.00 or later.

Saving data
KEW6310 is endowed with a logging function with a preset recording interval. Data can be saved by manual operation or at preset time & date. Screen data can be saved by using Print Screen function.

Dual power supply system
KEW6310 operates either with an AC power supply or with batteries. Both dry-cell batteries (alkaline) and rechargeable Ni-MH batteries can be used. When both types of batteries are installed in the instrument is possible. In the event of interruption, while operating with AC power supply, power to the instrument is automatically restored by the batteries in the instrument.

Log screen
Color display with large screen

Light & compact design
Clip sensor type, compact and light weight design

Applications
Data in the internal memory or CF card can be saved in a PC via a USB lead or a CF Card reader. As well as supplied software facilitates setting, optional analysis software facilitates data analysis.


Input/Output function
Analog signals from thermometers or light sensors can be measured simultaneously with electrical power data via 2 analog inputs. DC voltage signals exceeding a preset threshold values at each range can be transferred to alarm devices via 1 digital output.

— 2 —

Functional Overview


Functional Overview

Instantaneous value measurement
Measures average/max/min values of instantaneous voltage, current, voltage and electric power.




See (Section 5) **W Range** for further details.

Integration value measurement
Measures active/apparent/reactive powers on each CI.



See (Section 6) **Wh Range** for further details.

Demand measurement
Measures demand values based on the preset target values. Digital output signals alert the user that the predicted value may exceed the target value.



See (Section 7) **Demand Range** for further details.

SET UP
Setting of KEW6310 or of measurements.



See (Section 4) **Setting** for further details.

Activate Go To Setting
— 3 — KEW6310

KW6310

Functional Overview

Measurement at WAVE Range
Depicts vector / waveform of voltages and currents per CH
See (Section 8) WAVE Range for further details.

Harmonic measurement
Measures / analyzes harmonic components of current & voltages
See (Section 9) Harmonic Analysis for further details.

Power quality analysis
Measures swell, dip, int., transient, brush current, voltage drop, voltage sag, and also simulates power factor correction with capacitor banks.
* Flicker measurement function is only available with ver.2.00 or later.
See (Section 10) Power Quality for further details.

KEW 6310 — 4 —

Instrument Layout

Front view

Display (LCD)

Keys

LED status indicator

Power

SET UP

Activate V

Activate Setting

KEW 6310 — 5 —

KEW 6310

Connector

Side face

<When the Connector Cover is closed>

<When the Connector Cover is opened>

Or Card Cover, USB Port, Eject Button, CF Card Slot, Analogue Input/Digital output Terminal

Battery Case

*Selector switch is under the Selector switch cover.

KEW 6310 — 6 —

Getting Started

3. Getting Started

The KEW6310 operates with either an AC power supply or batteries. In the event of AC power interruption, power measurement is automatically restored by the batteries in the instrument. Dry cell batteries (alkaline) and rechargeable ones (Ni-MH) can be both used. It is also possible to charge rechargeable batteries in the instrument.

Remove the Selector Switch Cover, and slide the Selector Switch to left or right depending on the batteries to be used.

DRY-CELL BATTERY	RECHARGEABLE BATTERY
Battery can be used Alkaline dry-cell battery (LR6)	Ni-MH Rechargeable battery (HR-15/S1)
Position of Selector switch Slide the switch to the left (D.C.)	Slide the switch to the right (B.A.)
Selector switch cover	Selector switch cover

If the AC supply is interrupted and the batteries haven't been installed, the instrument goes off and the measured data may be lost.

Battery Mark on the LCD / Battery Level

Powered by AC supply	0 - 100% (count by 20%)
Powered by battery	100% (approx. 2 hours*) with alkaline batteries - approx. 5 hours* with Ni-MH rechargeable batteries
ON	Battery exhausted (accuracy not guaranteed) Measurement continues. Data save is ceased. (Measured data is saved.) Data save (measurement) is ceased. (Measured data is saved.)

* reference time when using the instrument with indications on the LCD level.

A continuous measurement with alkaline batteries is limited to 1 hour; use of an ac power supply is recommended. (Batteries should be considered and used as a back-up)

KEW 6310 — 7 —

Charging the rechargeable Ni-MH batteries

Following message to prompt battery charge appears on the LCD automatically when battery level is 40% or less of starting the instrument. Press the → CURSOR keys and ENTER Key according to the following sequence on the LCD:

- Install rechargeable batteries (N-MH)
- Slide the Selector switch to the right till to "RE-CHARGEABLE" position
- Connect the AC Power cord and power on the instrument.
- * After 1 (or 10.24) hours charging, it is the optimum time to initiate a battery charge anytime it is necessary.

"Charge batteries?"

```

graph TD
    A[Charge batteries?] -- No --> B[Return to normal screen.  
Batteries aren't charged.]
    A -- Yes --> C[Proceed to next screen]
    C -- No --> D[Return to normal screen.  
Batteries aren't charged.]
    C -- Yes --> E[Battery charge starts; return to normal screen.]
    
```

Battery charge doesn't initiate only by installing rechargeable batteries and connecting an AC power cord. Above operation is required to start a battery charge.

How to install batteries:

Install batteries in correct polarity as marked inside.

KEW 6310 — 8 —

Cord Connection

Start-up Screen

Model name and software version will be displayed upon powering on the instrument, and self-check routine initiates automatically. The KEW logo will appear. Stop using the instrument if error messages appear on the LCD after the self-check and refer to (Section 15) Troubleshooting in the full instruction manual.

**POWER QUALITY ANALYZER
KEW 6310
ver. 2.00**

Activate V

Activate Setting

KEW 6310 — 9 —

KW6310

4. Setting (SET UP)

The "SET UP" consists of following 4 settings:
Basic Setting: Setting of the KW6310 common to all measurements
Measurement: Setting of each measurement
Save / Other: Setting of data methods
Other Setting: Environmental setting

Press the **◀ ▶ ▲ ▼ □** Keys to browse through setting items.

Each setting

Setting item

Details of Setting

Wiring

Voltage Range

VI Ratio

Clamp / Current Range

CT Ratio

Filter

DC V

Frequency

Basic Setting

Details of Setting

Wire

Voltage Range

VI Ratio

Clamp / Current Range

CT Ratio

Filter

DC V

Frequency

Wiring Configuration

Measurement Setting

Details of Setting

W / Wh / DEMAND

WAVE Range

Harmo. Analysis

MAX HOLD

Save time

V Reference

Swell / Dip / Int measurement

Transient

Threshold value

Imrush current measurement

Unbalance ratio

Flicker

Capacitance

Save / Other Setting

Details of Setting

Recording method

Recording start

Recording end

Destination to save data

Destination to save screenshot

Formatting CF Card

Deleting data from CF Card

Formatting internal memory

Deleting data in the internal memory

Data transfer

Load setting

Save setting

Other Setting

Details of Setting

Language*

Date format

Time and date*

Barrier

CSV file

ID number

LCD contrast

ON/Off*

Auto power off

LCD auto-off

Battery charge

System reset

* Items listed with *** mark won't restore to default after system reset.

Instantaneous (Inst) value measurement

Steps for measurement

Symbol displayed on the LCD

Switching Screens / Zoom

Save data

Activate V

Activate V

Activate V

Activate V

KEW6310 Instantaneous value measurement

Header of the saved data

AVG_A1[A1]

(1) INST : Instantaneous value
(2) AC : Average value
(3) MAX : Max value
(4) MIN : Min value
(5) V : Voltage per phase
(6) A : Active power per phase
(7) F : Frequency
(8) P : Active power
(9) Q : Reactive power
(10) S : Apparent power
(11) PF : Power factor
(12) FA : Phase angle
(13) DC : Direct current voltage
(14) OH number : * 1 ~ 4
(15) Unit : System

* Saved data with no number at this space contains the sum of the measured values.

Saving instantaneous values

1 Press Start → Mode → Mode → Complete to start recording after checking the settings.
Press the Start button at least 2 sec to start recording immediately.

<Manual>
File name for saving data is displayed.
Data saving starts.
Status indicator LED is ON. LED flashes and (●) or (■) is displayed. (Flashes in red according to the preset interval)
Standby until preset time comes.

2 Preset start time comes.
Status indicator LED is ON. LED flashes and (●) or (■) is displayed. (Flashes in red according to the preset interval)
No setting change can be made during data saving.

3 Preset termination time comes.
File name for saving data is displayed.
Status indicator LED goes off. (●) or (■) goes off.

KEW6310 - 16 -

KEW6310 Integration value measurement

Header of the saved data

INTEG_WP+[Wh]

(1) INTEG : Integration value
(2) MP+ : Active power energy (consumption)
(3) WS+ : Apparent power energy (consumption)
(4) WS- : Apparent power energy (regenerating)
(5) WQ+ : Reactive power energy (consumption) / lagging
(6) WQ- : Reactive power energy (consumption) / leading
(7) WQc+ : Reactive power energy (regenerating) / lagging
(8) WQc- : Reactive power energy (regenerating) / leading
(9) Unit : System

Saving integration values

1 Press Start → Mode → Mode → Complete to start recording after checking the settings.
Press the Start button at least 2 sec to start recording immediately.

<Manual>
File name for saving data is displayed.
Data saving starts.
Status indicator LED is ON. LED flashes and (●) or (■) is displayed. (Flashes in red according to the preset interval)
Standby until preset time comes.

2 Preset start time comes.
Status indicator LED is ON. LED flashes and (●) or (■) is displayed. (Flashes in red according to the preset interval)
No setting change can be made during data saving.

3 Preset termination time comes.
File name for saving data is displayed.
Status indicator LED goes off. (●) or (■) goes off.

KEW6310 - 18 -

KEW6310 Demand measurement

INTVL_WP+[Wh]

(1) INTLG : Integration value
(2) INTV : Variation in interval
(3) INTL : Target value
(4) TARGET : Target value
(5) W+ : Active power energy (consumption)
(6) W- : Active power energy (regenerating)
(7) WS+ : Apparent power energy (consumption)
(8) WS- : Apparent power energy (regenerating)
(9) WQ+ : Reactive power energy (consumption) / lagging
(10) WQ- : Reactive power energy (consumption) / leading
(11) WQc+ : Reactive power energy (regenerating) / lagging
(12) WQc- : Reactive power energy (regenerating) / leading
(13) Unit : System

* (3)(4) will be black if it is DEM or TARGET.

Saving of demand values

1 Press Start → Mode → Mode → Complete to start recording after checking the settings.
Press the Start button at least 2 sec to start recording immediately.

<Manual>
File name for saving data is displayed.
Data saving starts.
Status indicator LED is ON. LED flashes and (●) or (■) is displayed. (Flashes in red according to the preset interval)
Standby until preset time comes.

2 Preset start time comes.
Status indicator LED is ON. LED flashes and (●) or (■) is displayed. (Flashes in red according to the preset interval)
No setting change can be made during data saving.

3 Preset termination time comes.
File name for saving data is displayed.
Status indicator LED goes off. (●) or (■) goes off.

KEW6310 - 20 -

KEW6310 Instantaneous value measurement

6 . Integration value measurement

Steps for measurement

SET UP Range

Ensuring your safety
Preparation for measurement
Setting
Wiring
Integration value measurement

Basic Setting **Measurement setting** **Save Setting**
Interval
Wiring
VT Ratio
A Range
Filter
DC V
Frequency

Recording method
Item selection (W)
• Inst value Recording termination
• Avg value Destination to save data
• Max value Destination to save screen shot
• Min value
• Total value
• Details

Symbol displayed on the LCD

WP+ Active electric energy (consumption) WS+ Apparent electric energy (consumption) WQ+ Reactive electric energy (lagging) WQc+ Reactive electric energy (leading)
WP- Active electric energy (generating) WS- Apparent electric energy (generating) WQ- Reactive electric energy (leading) WQc- Reactive electric energy (lagging)

Switching displays / Viewing W Range

Select a system Cursor Key
Select a channel Cursor Key
Display for WH Range
Display for W Range

* Press [Z] Key to switch the displays for WH Range and W Range.

Save data

File ID : 6310402

Saved time & date	ELAPSED TIME	Active power energy (consumption / regenerating)	Apparent power energy (consumption / regenerating)	Reactive power energy (lagging)	Reactive power energy (leading)	Demand	TARGET
DATE	TIME	ELAPSED TIME	INTLG, MP	INTEV, WS	INTLG, WQ	INTLG, WQ	DEM, TARGET
yyyymmdd	hh:mm:ss	hh:mm:ss					
year/month/day hour:minute:second	hour:minute:second						

* At DEMAND Range, a record will be made and place information (logging) or loading data.
* At WH Range, data measured at W Range and above measurement data are recorded at the same time.

Activate \ Go to Setting

- 17 - KEW6310

KEW6310 Demand measurement

7 . Demand measurement

Steps for measurement

SET UP Range

Ensuring your safety
Preparation for measurement
Setting
Wiring
Demand measurement

Basic Setting **Measurement setting** **Save Setting**
Interval
Wiring
VT Ratio
A Range
CT Ratio
Filter
DC V
Demand
Frequency

Recording method
Item selection (DEMAND)
• Inst value Recording start
• Avg value Destination to save data
• Max value Destination to save screen shot
• Min value
• Total value
• Details

Demand measurement

SET UP Range

* Readings are displayed right after the recording of demand measurement starts.

Switching displays / Viewing W Range and Wh Range

Selecting screens Cursor Key
Display for DEMAND
Display for WH Range
Display for W Range

* Press [Z] Key to switch the displays for DEMAND, WH Range and W Range.

Save data

File ID : 6310403

Saved time & date	ELAPSED TIME	Active power energy (consumption / regenerating)	Apparent power energy (consumption / regenerating)	Reactive power energy (lagging)	Demand	TARGET		
DATE	TIME	ELAPSED TIME	Integration INTLG, MP	Variation INTEV, MP	INTLG, WS	INTEV, WQ	DEM	TARGET
yyyymmdd	hh:mm:ss	hh:mm:ss						
year/month/day hour:minute:second	hour:minute:second							

(* value x 10⁴)

* At DEMAND Range, data measured at WH Range and above measurement data are recorded at the same time.

Activate \ Go to Setting

- 19 - KEW6310

KEW6310 Demand measurement

Measurement Screen

Remaining time (Time left)
Demand interval is counted down.
Predicted value
Predicted demand value when preset demand value is exceeded (Present value) / present interval (Present value) / present interval (Elapsed time)
* Integrations and Calculations are done as time elapses.

Measured max demand with time & date information
Max demand recorded in a measuring period is displayed. (Displayed value will be refreshed if any higher demand is detected.)

Present value
Demand value (average power) within a demand interval. (Max = 1 hour)
Integration and calculations are done as time elapses.

Shifts in specific period

Remaining time (Time left)
Demand interval is counted down.
Load factor
Percentage of the present value against the target value.
[Present value] / [Target value]

Prediction
Percentage of the predicted value against the target value.
[Predicted value] / [Target value]
Arrow mark on the graph. ← is blue while the value is within the target demand, and becomes red when the target value is exceeded.

Target value
Digital output signal when predicted value exceeds the target value.

Target value
Target value
Demand value (present value)

Activation point
Prediction inspection cycle
Demand inspection cycle
Demand interval
Start point

Activate \ Go to Setting

- 21 - KEW6310

KEW6310 — 22 —

Demand change

Measurement demand with time & date information. Demand value is displayed with recorded time & date info where cursor is placed.

Target demand

White bar : Percentage of target value. Blue bar : Percentage of the present displayed area

Recording start time

Most recent recorded time

Max demand value (displayed on the measurement screen)

Demand start

Demand termination

Demand measurement

KEW6310 — 23 —

8. WAVE Range

Steps for measurement

Ensuring your safety

Preparation for measurement

Setting

Wire

Measurement

Range

Symbol displayed on the LCD

V Voltage A Current

Switching displays : Vector / Waveform (switching CH)

Vector Display

Waveform Display

* Press the **[Δ]** key to switch the Waveform and Vector display.
* Press the **[Δ]** key to check whether the wave configuration is correct or not.
* Pressing the **[Δ]** or **[∇]** keys at Waveform display changes the magnification of vertical axis (voltage/current).

Save data

File ID: 631004 (Waveform data)

Saved time & date	ELAPSED TIME	Channel	Instantaneous value
DATE	TIME	CH	* Line 1/line 2 1/128 ~ 129/256
yyyy/mm/dd	h : mm : ss	A/V	($\times 10^6$) m
year/month/day	hour:minute:second	A/V	($\times 10^6$) m

* 1~128 measured instantaneous values are saved to Line 1, 129~256 are to Line 2.

File ID: 631005 (Vector data)

Saved time & date	ELAPSED TIME	Instantaneous	Average	Max	Min
DATE	TIME	INST	($\times 10^6$) m	MAX	MIN
yyyy/mm/dd	h : mm : ss	hour:sec	($\times 10^6$) m	($\times 10^6$) m	($\times 10^6$) m
year/month/day	hour:minute:second	hour:sec	($\times 10^6$) m	($\times 10^6$) m	($\times 10^6$) m

Activate **Go to Setting**

KEW6310 — 24 —

KEW6310 — 25 —

Header of the saved data

File ID: 631004 (Waveform data)

5/133	Sampling sequence
(1) 1~128	(2) 129~256

File ID: 631005 (Vector data)

INST	Instantaneous value
Avg	Average value
Max	Max value
Min	Min value
V	Voltage per phase
A	Current per phase
(3) CH No.	(1)~(4)
(4) Unit	Unit

* when [deg] is displayed at source (4), it means phase angle.

Saving at WAVE Range

1. Press **Start** → **Next** → **Next** → **Complete**. To start recording after checking the settings. Press the **Start** button at least 2 sec to start recording immediately.

2. File name for saving data is displayed. Data saving starts. **File** appears and flashes. Status indicator LED flashes. Standby until preset time comes.

3. Status indicator LED is ON. Flashes and **ON** or **OFF** is displayed. Blinks in red according to the preset interval. **No setting change can be made during data saving.**

4. Press **Stop**. Preset termination time comes. File name for saving data is displayed. Status indicator LED goes off. **ON** and **OFF** goes off.

KEW6310 — 26 —

KEW6310 — 27 —

9. Harmonic Analysis

Steps for measurement

Ensuring your safety

Preparation for measurement

Setting

Wire

Measurement

Range

Harmonic Analysis

KEW6310 — 28 —

10. Power Quality

Swell / Dip / Int measurement

Steps for measurement

Ensuring your safety

Preparation for measurement

Setting

Wire

Swell / Dip / Int Measurement

Range

KEW6310 — 29 —

Swell / Dip / Int measurement

Steps for measurement

Ensuring your safety

Preparation for measurement

Setting

Wire

Swell / Dip / Int Measurement

Range

KEW6310 — 30 —

Timing of data recording

Measured data will be saved when an event occur or at the preset interval during measurement.

Recording at event occurrence

Recording at every interval

File ID: 631007

Save data

File ID: 631007

KEW6310 — 31 —

KEW6310 **Swell / Dip / Int measurement**

File ID : 6310-13
Duration Max / Min Data
DURATION MAX/MIN 201
start h : mm : ss.ss min(Swell) min(Dip/Int) (x) value x 10⁴
end min(Swell) min(Dip/Int) (x) value x 10⁴

Saved time & date File ID : 6310-13
DATE Elapsed TIME Instantaneous Average Max Min
year/month/date hour:mins:sec INST AVG MAX MIN
year/month/date hour:mins:sec hour:mins:sec (x) value x 10⁴

Header of the saved data
50 ~ 1_1 ~ 150 (1) 201 data in total : Data No.
(e.g. trigger point is set to Part 50 / Next 150.)

Saving Swell / Dip / Int

1 Press Start → Next → Next → Complete to start recording after checking the settings.
Press the Start button at least 2 sec to start recording immediately.

File ID : 6310-13
<Manual>
File name for saving data is displayed.
Data saving starts. Status indicator LED flashes.
Standby until preset time comes.

2 Preset start time comes.
Status indicator LED is ON. Red LED flashes and (A) or (B) is displayed.
(No setting change can be made during data saving.)

3 Press Stop. Preset termination time comes.
File name for saving data is displayed. Status indicator LED goes off. Red LED and (A) or (B) goes off.

Start End Alert End (A) (B) (C) (D) (E)

KEW6310 - 28 -

KEW6310 **Transient measurement**

File ID : 6310-13
Duration Max / Min Data
DURATION MAX/MIN 201
start h : mm : ss.ss min(Swell) min(Dip/Int) (x) value x 10⁴
end min(Swell) min(Dip/Int) (x) value x 10⁴

Saved time & date File ID : 6310-13
DATE Elapsed TIME Instantaneous Average Max Min
year/month/date hour:mins:sec INST AVG MAX MIN
year/month/date hour:mins:sec hour:mins:sec (x) value x 10⁴

Header of the saved data
50 ~ 1_1 ~ 150 (1) 201 data in total : Data No.
(e.g. trigger point is set to Part 50 / Next 150.)

Saving Transient Measurement

1 Press Start → Next → Next → Complete to start recording after checking the settings.
Press the Start button at least 2 sec to start recording immediately.

File ID : 6310-13
<Manual>
File name for saving data is displayed.
Data saving starts. Status indicator LED flashes.
Standby until preset time comes.

2 Preset start time comes.
Status indicator LED is ON. Red LED flashes and (A) or (B) is displayed.
(No setting change can be made during data saving.)

3 Press Stop. Preset termination time comes.
File name for saving data is displayed. Status indicator LED goes off. Red LED and (A) or (B) goes off.

Start End Alert End (A) (B) (C) (D) (E)

KEW6310 - 30 -

KEW6310 **Inrush Current Measurement**

File ID : 6310-09
Saved time & date File ID : 6310-09
DATE Elapsed TIME Instantaneous Average Max Min
year/month/date hour:mins:sec INST AVG MAX MIN
year/month/date hour:mins:sec hour:mins:sec (x) value x 10⁴

Header of the saved data
50 ~ 1_1 ~ 150 (1) 201 data in total : Data No.
(e.g. trigger point is set to Part 50 / Next 150.)

Saving Inrush Current Measurement

1 Press Start → Next → Next → Complete to start recording after checking the settings.
Press the Start button at least 2 sec to start recording immediately.

File ID : 6310-09
<Manual>
File name for saving data is displayed.
Data saving starts. Status indicator LED flashes.
Standby until preset time comes.

2 Preset start time comes.
Status indicator LED is ON. Red LED flashes and (A) or (B) is displayed.
(No setting change can be made during data saving.)

3 Press Stop. Preset termination time comes.
File name for saving data is displayed. Status indicator LED goes off. Red LED and (A) or (B) goes off.

Start End Alert End (A) (B) (C) (D) (E)

KEW6310 - 31 -

KEW6310 **Unbalance Ratio**

File ID : 6310-10
Saved time & date File ID : 6310-10
DATE Elapsed TIME Instantaneous Average Max Min
year/month/date hour:mins:sec INST AVG MAX MIN
year/month/date hour:mins:sec hour:mins:sec (x) value x 10⁴

Symbol displayed on the LCD
V Voltage A Current P Active Power + consumption Q Reactive Power + lagging
PF Factor + lagging PA Phase angle f Frequency
An Neutral current DC Analogue input DCA Analogue input DCB Voltage at 12h

Switching displays / Viewing Vector W Range display

Select a system (A) (B) (C) (D) (E) Cursor Key
Select an item (A) (B) (C) (D) (E) Cursor Key

Press the (E) Key to switch the Vector and W Range displays.

Save Data

File ID : 6310-10
Saved time & date File ID : 6310-10
DATE Elapsed TIME Instantaneous Average Max Min
year/month/date hour:mins:sec INST AVG MAX MIN
year/month/date hour:mins:sec hour:mins:sec (x) value x 10⁴


Activate V Go to Setting

KEW6310 - 33 -

Transient measurement **KEW6310**

Transient measurement


Steps for measurement



* Readings are displayed right after the recording of transient measurement starts.

Timing of data recording

Measured data will be saved when an event occurs or at the preset interval during measurement.




Inst value: max value of 10,000 data obtained at 100ms/1sec before the preset interval comes.
Avg value: Avg of inst values obtained in the preset and interval.
Max value: Max inst values obtained in the preset and interval.
Min value: Min inst values obtained in the preset and interval.

Activate V
Go to Setting

Inrush Current Measurement **KEW6310**

Inrush Current Measurement


Steps for measurement



* Readings are displayed right after the inrush current measurement starts.

Timing of data recording

Measured data will be saved when an event occurs or at the preset interval during measurement.




Inst value: Avg of 100 data (80ms) obtained 1 sec before the preset interval comes (red).
Avg value: Avg of rms values obtained in the preset and interval.
Max value: Max rms values obtained in the preset and interval.
Min value: Min rms values obtained in the preset and interval.

Activate V
Go to Setting

Unbalance Ratio **KEW6310**


Unbalance Ratio

Steps for measurement



* Measurements can be made with any of wiring configurations (B), (B), (B).

Symbol displayed on the LCD
V Voltage A Current P Active Power + consumption Q Reactive Power + lagging
PF Factor + lagging PA Phase angle f Frequency



Save Data

File ID : 6310-10							
Saved time & date		Elapsed TIME		Instantaneous		Average Max Min	
DATE		INST		INST		MAX MIN	
year/month/date	hour:mins:sec	year/month/date	hour:mins:sec	year/month/date	hour:mins:sec	(x) value x 10 ⁴	

Activate V
Go to Setting

KW6310 **Quality** Unbalance Ratio

Header of the saved data

AVG_A1[A1_1]

INST	: Instantaneous value
Avg	: Average value
MAX	: Max value
MIN	: Min value
V	: Voltage of each phase
UA	: Current unbalance ratio
A	: Voltage of each phase
I	: Frequency
P	: Active power
Q	: Reactive power
PF	: Power factor
PA	: Apparent power
VA	: Phase angle
VI	: Average input voltage
CH number	: Channel number
Unit	: Unit
System	: System

* Saved data with no number at the space contains the sum of the measured values.

Saving PFC calculation results

1 Press Start → Next → Next → Continue → to start recording after checking the settings.
Press the Start button at least 2 sec to start recording immediately.

2 Status indicator LED is ON. Flashes and (S) or (P) is displayed. (Flashes in red according to the preset interval).
Preset start time comes.

3 File name for saving data is displayed. Status indicator LED goes off. (S) and (P) or (U) goes off.
Press Stop. Preset termination time comes.

KEW6310 – 34 –

Flicker **Quality**

An optional voltage sensor KEW632SF is required for Flicker measurement.

Steps for measurement

Ensuring your safety	Measurement setting	Save Setting
Preparation for measurement	Range	Save Setting
Setting	Filter	Recording method
Wiring	Output item	Recording start
Flicker	Output threshold	Recording termination

Preliminary measurement for 10 sec will be done automatically prior to Flicker measurement.

Save data

File ID: 6310-1		Voltage		Short time intensity		Long time intensity	
Saved time & date	ELAPSED TIME	Frequency	Average	Max	Min	Pst	Pt
DATE	TIME	ELAPSED TIME	t	Avg_V	Max_V	Min_V	Pst
yy/mm/dd	hh:mm:ss	hh:mm:ss	(s)	(V)	(V)	(V)	(min)
periodic measurement	measured	calculated	(s)	(V)	(V)	(V)	(min)

Data is saved at every 1 min, but Pst is saved at every 10 min and Pt is at every 10 min in 2 hours later.

Saving Flicker data

The saving procedure is same to the one for the other measurements. See the previous corresponding pages.

Activate Go to Setting

KW6310 **Quality** Flicker

V

Pt is displayed at every 1 min. It takes time to calculate the data. When the calculation is completed, the value of measurement is displayed. When the value is increased, Max Pt is calculated and displayed at every 10 min. Max Pt is Max Pt (long time intensity) through to beginning to the end of measurement. It is reflected when the value is increased.

Pst is calculated and displayed at every 10 min. Pst is calculated until the latest 12 values (date in 2 hours).

Pst (1min)

Pst value is displayed. A cursor indicates the value. Trend graph Change of the latest 120 data (Pst) from 1 min ago.

Pt

Pt value is displayed. A cursor indicates the value. Trend graph Change of the latest 120 data (Pt) from 1 min ago.

KEW6310 – 36 –

Capacitance Calculation **Quality**

Capacitance Calculation - Sizing of capacitor banks for Power factor correction (PFC)

Steps for measurement

Ensuring your safety	Measurement setting	Save Setting
Preparation for measurement	Range	Save Setting
Setting	Filter	Recording method
Wiring	Output item	Recording start
Frequency	Output threshold	Recording termination

Switching displays / Zoom

Select a system Select an item

Total measured Measured per CH List

* Press to switch on the Axes and Z-axis display. Refer to "Section 6 Instantaneous measurement" for an explanation on continuing the zoom display.

Save data

File ID: 6310-11							
Saved time & date	ELAPSED TIME	Instantaneous	Average	Max	Min		
DATE	TIME	INST	Avg	Max	Min		
yy/mm/dd	hh:mm:ss	hh:mm:ss	(s)	(A)	(A)	(A)	(A)
hour/month/date	hour:minute:second	hour:minute:second	(s)	(A)	(A)	(A)	(A)
			(s)	(A)	(A)	(A)	(A)

Activate Go to Setting

KW6310 **Quality** Capacitance Calculation

Header of the saved data

AVG_A1[A1_1]

INST	: Instantaneous value
Avg	: Average value
MAX	: Max value
MIN	: Min value
V	: Voltage of each phase
UA	: Current unbalance ratio
A	: Voltage of each phase
I	: Frequency
P	: Active power
Q	: Reactive power
PF	: Power factor
PA	: Apparent power
VI	: Average input voltage
CH number	: Channel number
Unit	: Unit
System	: System

* Saved data with no number at the space contains the sum of the measured values.

Saving PFC calculation results

1 Press Start → Next → Next → Continue → to start recording after checking the settings.
Press the Start button at least 2 sec to start recording immediately.

2 Status indicator LED is ON. Flashes and (S) or (P) is displayed. (Flashes in red according to the preset interval).
Preset start time comes.

3 File name for saving data is displayed. Status indicator LED goes off. (S) and (P) or (U) goes off.
Press Stop. Preset termination time comes.

KEW6310 – 38 –

CF Card / Saved data

11. CF Card / Saved data

CF Card (operation time is completed)

CF Card	3MB	6MB	12MB	25MB	512MB	1GB	2GB
SanDisk Corp.*	300B-32	300B-64	300B-128	300B-256	300B-512	300B-1G	300B-2G
Adic co., Ltd.	AD-G132	AD-G164	AD-G128	AD-G256	—	AD-G1K	AD-G2K
BFY Co., Ltd.	—	—	—	30212M	30215M	30218M	30219M

* CF Card with more or less capacity other than listed above is also available.

All company names and model names are the trademarks or the registered trademark of their respective companies. The products are subject to the manufacturer's specification change, etc.

Please use above device when purchasing commercially available CF Cards. We can offer following CF Cards. SanDisk, ADIC, BFY, and others are the trademarks of their respective companies.

Max number of saved data / Possible recording time

Destination to save data

Capacity	CF Card	Internal Memory					
1sec	TSM	1D	20D	40D	100D	200D	2000D
1min	TSM	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	G1	1D	10D	20D	80D	3min	—
1min	G1	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
30min	7M	1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	6D	1D	24D	1M	2M	2M	3H
1min	6D	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	10	3D	40D	100D	1M	20min	—
1min	10	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	10M	2D	21D	1M	2M	20min	—
1min	10M	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	30	7D	1M	9M	4M	44min	—
1min	30	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
30min	1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	SM	1M	1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1min	SM	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	3D	1Y	60D	120D	240D	1M	2M
1min	3D	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	SM	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1min	SM	2D	110	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	SM	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1min	SM	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	140	29D	1M	2M	2M	1Y	2Y
1min	140	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	7M	1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1min	7M	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	100	20D	1M	2M	2M	1M	1H
1min	100	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	10M	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1min	10M	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y	Over 1Y
1sec	512	—	—	—	—	—	—
1min	512	—	—	—	—	—	—

* In case that no file exist in the CF card or the internal memory, the maximum number of files is 1000.

* Assumed one event occur per minute and take 1 sec.

Activate Go to Setting

KW6310

Data transfer
Data in the CF card or internal memory can be transferred to a PC via USB connection or CF card reader.

Transfer to PC via:	CF card data (file)	Internal memory data (file)
USB	Card reader	

*1 It is recommended to transfer the data with file size by a use of CF card reader since transfer of such data via USB takes less time than file size (AM2/avg).

*2 Data in the internal memory can be transferred to a CF card.

*As to the manipulation of the CF card, please refer to the instruction manual attached to the card.

*In order to save the data without any problem, make sure to delete the file other than the data measured with this instrument in the CF card.

File format and name
File Name : 01 - CF_001.KAS

Configuration file
File Name : ME_0000123.KAS

Bitmap file
File Name : 01 - CF_001.BMP

Backup Memory
In case one CF card is removed and inserted while saving data:

- (1) A file is created in the CF card, when CF card is selected as a save item, measurement data and measurement data is saved to the CF card.
- (2) When inserting the CF card again during a data saving, further data will be saved to the last available space in CF card (Over write).
- (3) Saving completes
Backup files in the internal memory are automatically transferred to the last available space in a CF card. (Time-series is as follows.)
- (4) Download completes
Use of supplied software (KW-PQA MASTER) enables to sort files in time-series.

Activate \ Go to Setting

- 40 -

- 41 -

- 42 -

12. Wiring check
Proper wiring can be checked at WAVE Range.

1. Ordinal screen	2. Checking wiring	3. Check completes
Press the 12 Key.	Wiring check starts. Check	Wiring check completes. In case of NG, error message is displayed. 12 Key when OK is displayed.
* Check results may be affected if great power factors exist at the measurement sites.		

Criteria of Judgment and cause

Check	Criteria of Judgment	Case
Frequency	Frequency of V1 is between 42 and 50 Hz.	Voltage clip is firmly connected to the X0/T1 terminal.
Voltage input	Voltage input is 10% or more of Voltage Range x V1.	<ul style="list-style-type: none"> Voltage clip is firmly connected to the X0/T1 terminal. Measurement range is appropriate for the voltage input terminals on the instrument.
Voltage balance	Voltage phase angle is within ±30° of reference voltage phase angle (not judged by single-phase mode).	<ul style="list-style-type: none"> Setting against the wire under test are matched! Voltage test leads are firmly connected to the X0/T1 terminal. Voltage test leads are firmly connected to the X0/T1 terminal.
Voltage phase	Phase of voltage input is within ±10° of reference voltage phase angle.	Voltage test leads are properly connected!
Current input	Current input is 5% or more of Current Range x C11.	<ul style="list-style-type: none"> Clamp sensors are firmly connected to the Power supply to flow current. Setting for Current Range is appropriate for input level.
Current phase	Current input is within ±65° of reference value (proper vector).	<ul style="list-style-type: none"> Flow mark on a Clamp sensor and the orientation of flowing current is matched! (Power supply to flow current) Clamp sensors are connected properly!

Annex (3) Testing Methodology

The Transformation of Commercial Air Conditioning Companies (HCFC Phase-out Management Plan (HPMP) EGYPT (Stage II))

UNIDO ID: 140400

IEC Evaluation program

Guiding Principles for on-site Testing

(Testing Methodology)

June 2022

SUBMITTED BY:

Team of AO and HBRC

Contents

1- Introduction.....	3
2- General Scope of the tests.....	3
3- EUROVENT role, Egypt Climatic Zones and Field Testing	4
4- Testing Plan.....	6
5- General Testing Conditions.....	6
6- Testing Methodology.....	8
6.1 Eurovent	
6.2 Total Cooling Capacity	
6.3 Energy Efficiency Ratio	
6.4 Measurements	
7- The Final Report.....	10
8- Standards used in the tests.....	11

**TESTING METHODOLOGY OF THE PROJECT OF THE TRANSFORMATION OF
COMMERCIAL AIR CONDITIONING COMPANIES (HCFC PHASE-OUT
MANAGEMENT PLAN (HPMP) EGYPT (STAGE II)),**

UNIDO ID: 140400

1. Introduction:

The project aims to provide technical assistance for the implementation of low GWP technology as well as examining the introduction of a Not-In-Kind technology, namely: Indirect Evaporative Cooling (IEC).

The project also proposes to look into the introduction of IEC in commercial air conditioning applications. The goal of the project is to secure phase out of HCFC in the commercial air conditioning manufacturing sector.

In September 2015, the world's nations agreed to adopt a set of 17 Sustainable Development Goals (SDGs). Egypt affirmed its commitment to meet the targets set by SDGs by 2030 and outlined a 15-year development strategy. The SDGs, spearheaded by the United Nations, include resilient, stable, and sustainable infrastructure as one of its goals, thus, the green building landscape is expected to soar in the upcoming years.

2. General Scope of tests

To test hybrid IEC Unit simultaneously with the DX Unit to find out the performance of the hybrid IEC unit compared to the DX unit, in particular its total cooling capacity and the energy efficiency ratio EER at various ambient operating conditions. The tabulation, evaluation and plotting of the results will be included in the program final report and will include an economic evaluation of the IEC hybrid system to help establish its commercial feasibility in the local market.

3. EUROVENT role, Egypt Climatic Zones and Field Testing


EUROVENT:

The application of any new technology, in larger capacities of commercial air-conditioning applications, requires setting the ground to allow market acceptability noting that these are not off-the-shelf products that industry can put in markets in substantial quantities. Commercial air-conditioning applications are commonly specified by consultants for projects to ensure reliability of the product that can justify the initial investment.

The project invited EUROVENT, the internationally renowned organization with experience in guidelines and certification programs for HVAC applications including IEC systems, to provide a reference testing methodology for the IEC hybrid units suitable for Egypt's working conditions. EUROVENT provided testing procedures (see EUROVENT XX/1- 2022 Hybrid Indirect Evaporative Cooling Equipment: Requirement and Test Method), will review and endorse the results of the project.

Egypt has 8 climatic zones out of which 7 are suitable for IEC applications due to lower humidity conditions across the summer season. Below figure shows:

Egypt climatic zones:



1	North Coast Region	5	Eastern Coast Region
2	Delta Cairo and middle Sinai Region	6	High Heights Region
3	North Upper Egypt Region	7	Desert Region
4	Southern Upper Egypt Region	8	South of Egypt Region

Field Testing:

Field Testing will be done in the open air throughout a whole day, for both the IEC hybrid unit and the DX unit.

4. Testing Plan

Testing plans were developed after intensive rounds of discussion and consultation with local OEMs and formal communication. Technical visits were made to manufacturing facilities to better understand capacities and readiness to build prototypes.

It was decided to start the tests in Climatic Zone 2 (Delta, Cairo Region and middle Sinai) at an altitude of 344.5 feet above sea level.


The first testing batch will start on the 15th of June 2022 in Climate Zone 2 (Delta Cairo and middle Sinai Region) followed by a second testing batch starting in the second half of July 2022 at Climatic Zone 5 or 8.

5. General Testing Conditions

The testing will be conducted for all OEMs that indicated the readiness of their units by the time the start date indicated for in Climatic Zone 2 (Delta, Sinai central and Cairo Region).

- a. There are no intentions to compare the performance of OEMs units, one against the other. This is why OEMs are labelled by a confidential number and not by their original name.
- b. The purpose of the tests is to make sure there are energy efficiency advantages obtained by adopting a hybrid IEC system when compared to a DX or Chilled Water system for the Egyptian Climate Zones 2 and 5 or 8.
- c. The schematic diagram below shows the position of the units during testing. Both DX and hybrid units are to be located at the same site, with a distance in between to guard against short cycling.
- d. Both units to be full fresh air with air discharge of one unit regulated so that it matches the other.
- e. The primary air outlet dry bulb temperature will try to maintain 15 °C.
- f. For each OEM, testing will be performed over a 24hr period for both units simultaneously.
- g. The tests will be performed for all OEMs, one after the other.
- h. The tests will be considered completed once a 24 hrs cycle is recorded for both IEC hybrid and DX units.

- i. The tests meteorological readings will be recorded.
- j. The tests are be performed to obtain the total cooling capacities and the energy efficiency ratios of both IEC hybrid and the DX unit for each OEM simultaneously and compare the results over a 24 hours period.
- k. In the final report, the test values will be plotted and analysed to help in obtaining a definite understanding of the advantages of the systems at various Climatic Zones.
- l. An economic comparison will be made comparing the Net Present Value (NPV) of the IEC hybrid compared to a DX unit over its lifetime to check its economic feasibility.



Schematic diagram of testing unit's emplacement at the test site.

6. Testing Methodology

6.1 EUROVENT

The testing methodology is based on:

“Eurovent XX/1 — 2022 Hybrid Indirect Evaporative Cooling Equipment: Requirements and Test Method”

Recorded Individual data for each OEM

- Date of test
- Test identification number
- Latitude of the location where the test is done
- Longitude of the location where the test is done
- Altitude of the location where the test is done
- Indication of the Egypt climate zone
- Serial number
- Model dimensions

6.2 Calculation of total cooling capacity (q_{tot})

The Total Cooling Capacity (kW) of the Indirect Evaporative Cooling Units is calculated as follows:

$$q_{tot} = 1.21 Qp (h1 - h2)$$

Where:

q_{tot} = Total Cooling Capacity, kW

$h1$ = Primary air inlet enthalpy (from psychrometric chart and calculation), [kj/kg]

$h2$ = Primary air outlet enthalpy (from psychrometric chart and calculation), [kj/kg]

Qp = Primary air flow rate, [kg/s]

6.3 Calculation of Energy Efficiency ratio (EER)

The Energy Efficiency Ratios the ratio of the total cooling capacity to the power input:

$$EER = \frac{q_{tot}}{W}$$

Where:

EER = Energy Efficiency Ratio, B.t.u/hr. W and in W/W

q_{tot} = Total cooling capacity, kW

W = Total Power input [kW] = $W_p + W_s + W_c + W_{DX}$

W_p = Power of the fans for primary air

W_s = Power of the fans for secondary air

W_c = Power of the recirculating pump

W_{DX} = Power of the direct expansion coils/system

6.4 Measurements:

The tests will record the following values, on the hour, every hour for a 24 hours period:

- the Primary air inlet dry bulb temperature
- the Primary air outlet dry bulb temperature
- the Secondary air inlet wet bulb
- the Secondary air inlet dry bulb
- the Primary air flow rate
- the Total Power input
- the EER
- the total cooling Capacity
- the power of fans for primary air

- the power of fans for secondary air
- the power of the recirculating pump
- the power of direct expansion coils/system
- the water consumption

7. The Final Report

The final report will include the following:

- Individual data for each OEM.
 - o Hourly readings of the IEC hybrid unit
 - o Hourly readings of the DX unit
 - o Calculation of total cooling capacity
 - o Calculation of Energy Efficiency ratio
 - o Graph showing the total cooling capacity of the IEC hybrid and the DX unit versus the hours for 24 hours cycle, and including the ambient dry bulb and ambient relative humidity
 - o Graph showing the total energy efficiency ratio of the IEC hybrid and the DX unit versus the hours for 24 hours cycle, and including the ambient dry bulb and ambient relative humidity
 - o Cooling Effectiveness of the IEC hybrid unit versus the hours for 24 hours cycle
 - o Discussion of the results
 - o Economic Net Present value comparison of the IEC hybrid versus the DX system to help establish its commercial feasibility to local market.

8. Standards used in the tests

- ANSI/ASHRAE Standard 133-2015 - Method of Testing Direct Evaporative Coolers, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., Atlanta.
- EN 14511-3: 2013. – Air-conditioner, Liquid Chiller packages & Heat Pumps with electrically driven compressor for space heating & cooling – Part 3 - Tolerance for reading temperature measurement.
- ANSI/ASHRAE Standard 143-2015 - Method of Test for Rating Indirect Evaporative Coolers, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc., Atlanta.
- ASHRAE Standard 41.2-2018 - Standard Methods for Air Velocity and Airflow Measurement
- ISO 5801-2017 - Fans Performance testing using standardised airways
- ECP-24 EC:2021 - Technical certification rules of the Eurovent Certified Performance Mark-Evaporative Cooling-

Annex (4) Results in CZ2

Results and Calculations for OEM2 - CZ2

IEC Hybrid Unit , Air flow = 2000 cfm (3398 m3/hr), Altitude = 208 m, , water bath area = (1000*900) mm2, size of duct for air balancing = 0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out IEC-H	RH out IEC-H	Twb out IEC-H		h amb	ρ amb	h out IEC-H	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C		kJ/kg	kg/m3	kJ/kg	kg/s	W	W	w/w	Btu/W.hr
11:00	34.7	30.5	12.7	78.7	10.7		62.94	1.11	31.48	1.05	32961.06	8043.4	4.098	14.0
12:00	35.8	30	13	77.5	10.9		65.36	1.11	31.72	1.05	35245.08	7642.8	4.612	15.7
13:00	37.6	29	14.2	82.4	12.5		69.32	1.10	35.9	1.04	34699.14	8215.3	4.224	14.4
14:00	37.7	29.75	13.8	80.7	11.9		70.27	1.10	34.52	1.04	37118.32	8113.2	4.575	15.6
15:00	36.9	32.25	13.1	85.7	11.7		70.58	1.10	34	1.04	37980.08	8060.9	4.712	16.1
16:00	36.5	35.75	12.6	87	11.4		73.12	1.10	33.21	1.04	41437.54	8124.6	5.100	17.4
17:00	35.4	36.5	11.6	85.6	10.3		70.68	1.11	30.48	1.05	42118.08	8257.1	5.101	17.4
18:00	33.4	43	11.5	87.4	10.4		70.32	1.11	30.65	1.05	41562.79	8067.1	5.152	17.6
19:00	31.5	50.25	11.6	89.5	10.7		70.08	1.12	31.26	1.06	41038.65	7930.1	5.175	17.7
20:00	30.6	50.25	10.6	87.9	9.5		67.21	1.12	28.73	1.06	40679.22	7849.7	5.182	17.7
21:00	29.1	55	11.3	88.8	10.3		65.93	1.13	30.49	1.07	37799.99	7661.7	4.934	16.8
22:00	28.4	55.25	11	89.7	10.1		63.88	1.13	30.06	1.07	36072.11	7678.4	4.698	16.0
23:00	28	55.25	11.3	88.9	10.3		62.64	1.13	30.51	1.07	34269.57	7812.4	4.387	15.0
0:00	27.4	52.75	10.7	89.5	9.8		59.17	1.14	29.26	1.08	32184.06	7932.5	4.057	13.8
1:00	26.4	53.25	10.2	89.7	9.3		56.8	1.14	28.2	1.08	30774.46	8087.1	3.805	13.0
2:00	26.1	54.25	9.6	91.4	8.9		56.44	1.14	27.26	1.08	31398.56	8084	3.884	13.3
3:00	25.8	52.5	9.8	91.2	9.1		54.56	1.14	27.67	1.08	28934.45	8368.8	3.457	11.8
4:00	25.4	49.25	9.6	89.5	8.7		51.66	1.15	26.74	1.09	27049.88	8331.4	3.247	11.1
5:00	24.9	41.25	9.5	91.3	8.8		46.33	1.15	26.94	1.09	21047.24	8109.5	2.595	8.9
6:00	25.5	40.5	9.6	90	8.8		47.31	1.15	26.85	1.09	22208.69	8542.1	2.600	8.9
7:00	27.9	37.5	9.2	88.5	8.3		51.38	1.14	25.84	1.08	27481.81	8298	3.312	11.3
8:00	30.1	37.25	8.5	84.5	7.2		56.64	1.13	23.57	1.07	35272.17	8232.2	4.285	14.6
9:00	32.1	39.25	10.4	82.5	8.9		63.52	1.12	27.11	1.06	38490.92	8395	4.585	15.6
10:00	33.9	35.25	9.5	81.3	7.9		65.13	1.11	24.98	1.05	42065.69	7903.5	5.322	18.2
11:00	35.4	31.75	10.7	81	7.9		66.1	1.11	27.45	1.05	40494.12	7928.3	5.108	17.4

Results and Calculations for OEM2 - CZ2

DX Unit , Air flow = 2000 cfm (3398 m³/h), Altitude = 208 m, duct size =0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out DX	RH out DX	Twb out DX		h amb	p amb	h out DX	Air mass Flow rate (Q _p)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C		kJ/kg	kg/m3	kJ/kg	kg/s	W	W	w/w	Btu/W.hr
11:00	34.7	30.5	11.6	82	10.0		62.94	1.11	29.67	1.05	34857.43	9419.5	3.701	12.6
12:00	35.8	30	12.7	82.9	11.1		65.36	1.11	32.41	1.05	34522.16	8743	3.949	13.5
13:00	37.6	29	12.6	83.2	11.0		69.32	1.10	32.17	1.04	38571.90	9793.5	3.939	13.4
14:00	37.7	29.75	12.8	83	11.0		70.27	1.10	32.73	1.04	38976.83	10802.4	3.608	12.3
15:00	36.9	32.25	12.5	83.6	11.0		70.58	1.10	32.17	1.04	39880.13	9576	4.165	14.2
16:00	36.5	35.75	12.3	84.7	10.9		73.12	1.10	31.97	1.04	42725.00	9936.3	4.300	14.7
17:00	35.4	36.5	12.1	86.6	10.9		70.68	1.11	31.86	1.05	40672.24	9984.2	4.074	13.9
18:00	33.4	43	11.4	88.2	10.3		70.32	1.11	30.66	1.05	41552.31	9595.5	4.330	14.8
19:00	31.5	50.25	10.9	89.4	10.0		70.08	1.12	29.64	1.06	42751.24	9337.8	4.578	15.6
20:00	30.6	50.25	10.3	89.5	9.4		67.21	1.12	28.36	1.06	41070.37	9431.5	4.355	14.9
21:00	29.1	55	11.2	91.5	10.5		65.93	1.13	30.92	1.07	37341.36	8845.7	4.221	14.4
22:00	28.4	55.25	11.5	93.3	10.9		63.88	1.13	32.01	1.07	33992.26	8992.5	3.780	12.9
23:00	28	55.25	11.4	94	10.9		62.64	1.13	31.92	1.07	32765.68	9206.7	3.559	12.1
0:00	27.4	52.75	11.1	92.8	10.5		59.17	1.14	30.81	1.08	30516.21	9409.4	3.243	11.1
1:00	26.4	53.25	10.8	93.5	10.2		56.8	1.14	30.4	1.08	28407.19	9729.6	2.920	10.0
2:00	26.1	54.25	10.3	93.4	9.7		56.44	1.14	29.08	1.08	29440.18	9781.1	3.010	10.3
3:00	25.8	52.5	10.4	93.6	9.9		54.56	1.14	29.5	1.08	26965.31	10022	2.691	9.2
4:00	25.4	49.25	10.5	93.7	10.0		51.66	1.15	29.6	1.09	23945.44	10189	2.350	8.0
5:00	24.9	41.25	10.4	93.8	9.9		46.33	1.15	29.46	1.09	18311.86	10326	1.773	6.1
6:00	25.5	40.5	10.3	93.8	9.8		47.31	1.15	29.15	1.09	19712.11	10417	1.892	6.5
7:00	27.9	37.5	10.1	93	9.5		51.38	1.14	28.69	1.08	24415.12	10054	2.428	8.3
8:00	30.1	37.25	9.6	92.2	9.0		56.64	1.13	27.33	1.07	31261.79	9892.9	3.160	10.8
9:00	32.1	39.25	10	87.7	9.0		63.52	1.12	27.42	1.06	38163.20	10068.2	3.790	12.9
10:00	33.9	35.25	10.8	90.1	9.9		65.13	1.11	29.71	1.05	37110.01	9401.4	3.947	13.5
11:00	35.4	31.75	10.7	89.3	9.8		66.1	1.11	29.15	1.05	38713.01	9565.8	4.047	13.8

Results and Calculations for OEM3 - CZ2

IEC Hybrid Unit , Air flow = 2025 cfm , Altitude = 208 m , water bath area = (1728.5*623) mm², size of duct for air balancing = 0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out IEC-H	RH out IEC-H	Twb out IEC-H	h amb	p amb	h out IEC-H	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C								
12:16	35.4	29.9	13.2	75	10.8	64.3	1.11	31.6	1.06	34688.48	4996.3	6.943	23.7
13:16	35.4	32.4	13	74.2	10.5	66.7	1.11	30.9	1.06	37976.99	4989.8	7.611	26.0
14:16	36	29.6	12.5	73.7	10.0	65.5	1.11	29.8	1.06	37870.91	4978.4	7.607	26.0
15:16	36.1	27	13.4	73.9	10.9	63.3	1.11	31.8	1.06	33415.51	4926.4	6.783	23.2
16:16	35.7	28.8	12.7	74.5	10.3	63.9	1.11	30.4	1.06	35537.13	4932.7	7.204	24.6
17:16	35.4	30.8	12.8	74.6	10.4	65.1	1.11	30.6	1.06	36597.94	5048.6	7.249	24.7
18:16	34.4	33.7	12.8	75	10.4	65.1	1.11	30.8	1.06	36385.78	4996.9	7.282	24.9
19:16	32	38.4	13.3	75.2	10.9	62.5	1.12	31.8	1.07	32860.26	4944	6.646	22.7
20:16	29.7	56.5	14.6	79.5	12.5	69	1.13	35.9	1.08	35745.47	5012	7.132	24.3
21:16	28.3	57.9	14.6	81.6	12.8	65.2	1.13	36.5	1.08	30993.81	5076.1	6.106	20.8
22:16	27.8	60	14.9	81.3	13.0	64.9	1.13	37.3	1.08	29805.89	5028.4	5.928	20.2
23:16	27.6	58.8	14.5	82	12.7	63.4	1.14	36.3	1.09	29524.92	4955.8	5.958	20.3
0:16	27.2	67.4	14.5	82.2	12.7	67.6	1.14	36.5	1.09	33882.84	5048.1	6.712	22.9
1:16	25.3	69.8	14.7	82.6	13.0	62.4	1.14	36.9	1.09	27781.75	5038.9	5.513	18.8
2:16	24.6	73.2	14.8	83.4	13.1	61.9	1.15	37.6	1.10	26706.60	5059	5.279	18.0
3:16	23.5	73.7	14.8	84.4	13.2	58.7	1.15	37.7	1.10	23079.78	5005.2	4.611	15.7
4:16	23.4	74.3	14.6	84.7	13.1	58.7	1.15	37.4	1.10	23409.49	5030.9	4.653	15.9
5:16	24.1	75.2	14.2	84.3	12.7	61.2	1.15	36.3	1.10	27366.03	5022.6	5.449	18.6
6:16	24.6	64.5	13.2	81.9	11.5	57.4	1.15	33.2	1.10	26596.70	4916.3	5.410	18.5
7:16	27.3	60.9	12.5	80.8	10.7	63.9	1.14	31.3	1.09	35517.06	4903.4	7.243	24.7
8:16	28.1	53.2	12.6	78.7	10.6	61.4	1.13	31	1.08	32829.68	4926.1	6.664	22.7
9:16	29.7	47.6	12.5	77.8	10.4	62.6	1.13	30.7	1.08	34449.56	4928.4	6.990	23.9
10:16	31.5	44.9	12.3	75.3	10.0	65.9	1.12	29.7	1.07	38747.27	4900.2	7.907	27.0
11:16	35.9	40.3	13.4	76.1	11.1	75.6	1.10	32.2	1.05	45624.38	4929	9.256	31.6
12:16	39.7	29.2	13.7	74.4	11.2	75.1	1.09	32.4	1.04	44480.43	4982.6	8.927	30.5

Results and Calculations for OEM3 - CZ2

DX Unit , Air flow = 2025 cfm , Altitude = 208 m, duct size =0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out DX	RH out DX	Twb out DX	h amb	p amb	h out DX	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C	kJ/kg	kg/m3	kJ/kg	kg/s	W	W	w/w	Btu/W.hr
12:16	35.4	29.9	11.2	80.2	9.4	64.3	1.11	28.4	1.06	38083.07	11200	3.400	11.6
13:16	35.4	32.4	11.6	79.7	9.8	66.7	1.11	29.1	1.06	39886.45	11600	3.438	11.7
14:16	36	29.6	11.4	79.7	9.6	65.5	1.11	28.7	1.06	39037.80	11600	3.365	11.5
15:16	36.1	27	11.6	80.5	9.8	63.3	1.11	29.2	1.06	36173.62	11600	3.118	10.6
16:16	35.7	28.8	11.9	79.1	10.0	63.9	1.11	29.7	1.06	36279.70	11700	3.101	10.6
17:16	35.4	30.8	11.8	81.3	10.1	65.1	1.11	29.9	1.06	37340.51	11700	3.191	10.9
18:16	34.4	33.7	11.6	81.7	9.9	65.1	1.11	29.6	1.06	37658.75	11300	3.333	11.4
19:16	32	38.4	10.9	82.5	9.4	62.5	1.12	28.2	1.07	36713.58	11200	3.278	11.2
20:16	29.7	56.5	11.5	87.7	10.4	69	1.13	30.7	1.08	41361.07	11100	3.726	12.7
21:16	28.3	57.9	12.5	88.2	11.4	65.2	1.13	33.1	1.08	34665.55	10800	3.210	11.0
22:16	27.8	60	11.7	88.3	10.6	64.9	1.13	31.3	1.08	36285.43	10700	3.391	11.6
23:16	27.6	58.8	11.1	88.6	10.1	63.4	1.14	30	1.09	36388.65	10300	3.533	12.1
0:16	27.2	67.4	11.4	88.8	10.4	67.6	1.14	30.6	1.09	40310.77	10600	3.803	13.0
1:16	25.3	69.8	11.3	89.2	10.3	62.4	1.14	30.4	1.09	34863.37	10400	3.352	11.4
2:16	24.6	73.2	11.2	90.4	10.5	61.9	1.15	30.7	1.10	34289.96	10200	3.362	11.5
3:16	23.5	73.7	11.1	90.7	10.3	58.7	1.15	30.4	1.10	31102.75	10100	3.079	10.5
4:16	23.4	74.3	10.8	91	10.0	58.7	1.15	29.8	1.10	31762.18	10100	3.145	10.7
5:16	24.1	75.2	10.2	90.5	9.4	61.2	1.15	28.4	1.10	36048.42	10000	3.605	12.3
6:16	24.6	64.5	9.4	88.4	8.4	57.4	1.15	26.2	1.10	34289.96	10200	3.362	11.5
7:16	27.3	60.9	10	87.1	8.9	63.9	1.14	27.1	1.09	40092.88	10500	3.818	13.0
8:16	28.1	53.2	10.3	87	9.2	61.4	1.13	27.8	1.08	36285.43	10700	3.391	11.6
9:16	29.7	47.6	10.8	84.9	9.5	62.6	1.13	28.5	1.08	36825.39	10700	3.442	11.7
10:16	31.5	44.9	10.8	83.2	9.3	65.9	1.12	28.2	1.07	40352.82	11000	3.668	12.5
11:16	35.9	40.3	12.3	82.5	10.7	75.6	1.10	31.2	1.05	46675.63	11600	4.024	13.7
12:16	39.7	29.2	12.6	81.6	10.9	75.1	1.09	31.9	1.04	45001.27	11500	3.913	13.4

Results and Calculation for OEM4 - CZ2

IEC Hybrid Unit , Air flow = 1750 cfm , Altitude = 208 m , water bath area = (2400*1600) mm², size of duct for air balancing = 0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out IEC-H	RH out IEC-H	Twb out IEC-H	h amb	ρ amb	h out IEC-H	Air mass Flow rate (Q _p)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C				kg/s	W	W	w/w	Btu/W.hr
10:30	31.9	46.5	14.5	84.3	12.9	68.5	1.12	37.2	0.93	28952.76	6899	4.197	14.3
11:30	33	42.2	14.7	84.7	13.2	68.6	1.12	37.6	0.93	28675.26	6898	4.157	14.2
12:30	34.3	35.3	13.5	84.8	12.0	66.2	1.11	34.7	0.92	28877.60	6879.9	4.197	14.3
13:30	35.7	33.3	13.7	84.7	12.2	68.4	1.11	35.3	0.92	30344.40	6812.1	4.454	15.2
14:30	35.5	34.8	15.1	86.7	13.8	69.3	1.11	39.2	0.92	27594.15	6777.1	4.072	13.9
15:30	34.9	34.8	14.8	86.2	13.4	67.5	1.11	38.3	0.92	26769.08	6771.1	3.953	13.5
16:30	34.7	37.3	14.8	86.7	13.5	69.2	1.11	38.6	0.92	28052.53	6752.3	4.155	14.2
17:30	33.4	43.5	15.5	88	14.3	70.9	1.11	40.7	0.92	27685.83	6866.3	4.032	13.8
18:30	31.2	45.8	16.2	89.4	15.1	65.7	1.12	43	0.93	20997.69	6817.8	3.080	10.5
19:30	29	46.3	16	90.4	15.0	59.7	1.13	42.7	0.93	15865.54	6819.3	2.327	7.9
20:30	28	45.3	17	90.8	16.0	56.2	1.14	45.7	0.94	9886.03	6844.9	1.444	4.9
21:30	27	45.5	16.6	91	15.7	54	1.14	44.6	0.94	8850.35	6730	1.315	4.5
22:30	26	46.3	16.1	91.9	15.3	51.8	1.14	43.5	0.94	7814.67	6693.8	1.167	4
23:30	25.2	45.8	16	91.9	15.2	49.4	1.15	43.2	0.95	5888.67	6679.8	0.882	3
0:30	24.7	44.3	15.9	92.2	15.1	47.5	1.15	42.9	0.95	4369.01	6610.6	0.661	2.3
1:30	24.3	43.8	15.6	92	14.8	46.3	1.15	42.2	0.95	3894.12	6535.2	0.596	2
2:30	23.6	44.5	15.4	92.6	14.7	44.9	1.15	41.8	0.95	2944.33	6644.7	0.443	1.5
3:30	23.8	45.8	15.4	92.6	14.7	46	1.15	41.6	0.95	4179.06	6705.3	0.623	2.1
4:30	23.7	44.3	15.2	91.5	14.4	45.1	1.15	40.8	0.95	4084.08	6609.4	0.618	2.1
5:30	23.9	43	15.1	92	14.3	44.8	1.15	40.8	0.95	3799.14	6661.3	0.570	1.9
6:30	23.9	41.3	14.8	91.5	14.0	44.1	1.15	39.9	0.95	3989.10	6668.1	0.598	2
7:30	23.9	40.5	15.1	91.4	14.2	43.7	1.15	40.5	0.95	3039.31	6602.4	0.460	1.6
8:30	25.6	39.3	15.3	89.7	14.3	46.9	1.15	40.6	0.95	5983.65	6612.9	0.905	3.1
9:30	27.6	40.3	15.2	88.5	14.0	52.3	1.14	40	0.94	11580.77	6686.7	1.732	5.9
10:30	30.3	39.8	14.6	88.5	13.5	58.8	1.13	38.4	0.93	19038.65	6655.9	2.860	9.8

Results and Calculation for OEM4 - CZ2

DX Unit , Air flow = 1750 cfm , Altitude = 208 m, duct size =0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out DX	RH out DX	Twb out DX	h amb	ρ amb	h out DX	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C				kg/s	W	W	w/w	Btu/W.hr
10:30	31.9	46.5	15.1	85.5	13.7	68.5	1.12	38.8	0.93	27472.75	7980	3.443	11.7
11:30	33	42.2	18.4	79.4	16.1	68.6	1.12	45.9	0.93	20997.69	7969	2.635	9
12:30	34.3	35.3	17.6	71.9	14.5	66.2	1.11	41.2	0.92	22918.73	8060	2.844	9.7
13:30	35.7	33.3	19	72.2	15.8	68.4	1.11	44.9	0.92	21543.61	7980	2.700	9.2
14:30	35.5	34.8	21	72.7	17.7	69.3	1.11	50.6	0.92	17143.21	7630	2.247	7.7
15:30	34.9	34.8	22.3	78.5	19.6	67.5	1.11	57.1	0.92	9534.19	7960	1.198	4.1
16:30	34.7	37.3	17.5	75	14.7	69.2	1.11	41.9	0.92	25027.25	7830	3.196	10.9
17:30	33.4	43.5	17.5	75.6	14.8	70.9	1.11	42.1	0.92	26402.38	7829	3.372	11.5
18:30	31.2	45.8	17.5	76.3	14.9	65.7	1.12	42.3	0.93	21645.19	7940	2.726	9.3
19:30	29	46.3	17.8	76.8	15.2	59.7	1.13	43.4	0.93	15212.26	8090	1.880	6.4
20:30	28	45.3	18.6	76.7	16.0	56.2	1.14	45.5	0.94	10074.33	8190	1.230	4.2
21:30	27	45.5	18.3	76.7	15.7	54	1.14	44.5	0.94	8944.50	8092	1.105	3.8
22:30	26	46.3	17.4	77	14.9	51.8	1.14	42.3	0.94	8944.50	8167	1.095	3.7
23:30	25.2	45.8	17.9	77.4	15.4	49.4	1.15	43.7	0.95	5413.78	8197	0.660	2.3
0:30	24.7	44.3	17.7	77.8	15.3	47.5	1.15	43.3	0.95	3989.10	7881	0.506	1.7
1:30	24.3	43.8	18.2	79.6	15.9	46.3	1.15	45.4	0.95	854.81	7995	0.107	0.4
2:30	23.6	44.5	17.7	80.5	15.6	44.9	1.15	44.3	0.95	569.87	7994	0.071	0.2
3:30	23.8	45.8	17.8	80	15.6	46	1.15	44.3	0.95	1614.63	7845	0.206	0.7
4:30	23.7	44.3	18	79.8	15.8	45.1	1.15	44.8	0.95	284.94	8114	0.035	0.1
5:30	23.9	43	17.4	79.2	15.1	44.8	1.15	43.2	0.95	1519.66	8106	0.187	0.6
6:30	23.9	41.3	17.1	78.2	14.7	44.1	1.15	41.9	0.95	2089.53	8050	0.260	0.9
7:30	23.9	40.5	17.3	78.2	14.9	43.7	1.15	42.5	0.95	1139.74	8060	0.141	0.5
8:30	25.6	39.3	17.2	78.6	14.9	46.9	1.15	42.3	0.95	4369.01	7900	0.553	1.9
9:30	27.6	40.3	17.6	78.7	15.3	52.3	1.14	43.3	0.94	8473.74	8090	1.047	3.6
10:30	30.3	39.8	17.7	77.9	15.3	58.8	1.13	43.5	0.93	14278.99	7814	1.827	6.2

Results and Calculations for OEM6 - CZ2

IEC Hybrid Unit , Air flow = 2245 cfm , Altitude = 208 m , water bath area = (1308.3^2-900.3^2) mm2, size of duct for air balancing = 0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out IEC-H	RH out IEC-H	Twb out IEC-H	h amb	ρ amb	h out IEC-H	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C				kg/s	W	W	w/w	Btu/W.hr
12:00	31.3	30.8	13.4	93.4	12.8	54.8	1.13	36.6	1.20	21789.92	4478.4	4.866	16.6
13:00	33	28	13.2	93.9	12.6	56.6	1.12	36.4	1.19	23970.40	4709.1	5.090	17.4
14:00	33.5	29.8	13.5	93.8	12.9	59.4	1.12	37.1	1.19	26462.37	4672	5.664	19.3
15:00	34.1	28.8	12.9	94.1	12.4	60	1.11	35.6	1.18	28695.82	4733.1	6.063	20.7
16:00	33.7	32.3	14.5	93.4	13.9	61.8	1.12	39.4	1.19	26581.04	4807.1	5.530	18.9
17:00	32.1	35.5	14.5	94.2	13.9	60.5	1.12	39.8	1.19	24563.73	5021.3	4.892	16.7
18:00	31.5	39.3	13.5	95	13.0	61.6	1.12	37.3	1.19	28835.68	4820	5.983	20.4
19:00	30.1	42.5	13.2	94.9	12.7	60.2	1.13	36.5	1.20	28374.79	4772.4	5.946	20.3
20:00	29.2	47.8	14.6	94.9	14.1	61.4	1.13	40.3	1.20	25261.94	4755.6	5.312	18.1
21:00	27.3	50.3	16.2	93.4	15.5	57.5	1.14	44.2	1.21	16064.32	4772.7	3.366	11.5
22:00	26.1	51.3	16.4	93.3	15.7	54.9	1.14	44.8	1.21	12199.22	4687.2	2.603	8.9
23:00	25.5	52.5	15.4	93.4	14.7	53.7	1.15	42.1	1.22	14133.89	4702.7	3.005	10.3
0:00	24.9	49	15.6	92.6	14.9	50.4	1.15	42.4	1.22	9747.51	4643.6	2.099	7.2
1:00	24.4	48.5	14.6	93.4	14.0	48.6	1.15	39.9	1.22	10600.42	4686.9	2.262	7.7
2:00	24	46.8	14.4	92.6	13.7	47	1.15	39	1.22	9747.51	4700.3	2.074	7.1
3:00	24.2	44.3	13.4	92.7	12.7	46.4	1.15	36.5	1.22	12062.54	4740.6	2.545	8.7
4:00	23.4	44.3	13.7	92.5	13.0	44.4	1.16	37.3	1.23	8726.14	4787.8	1.823	6.2
5:00	23.8	41.8	13.8	91.7	13.0	44.2	1.15	37.3	1.22	8407.23	4654.8	1.806	6.2
6:00	24.3	40.5	13.3	91.6	12.5	44.6	1.15	36.1	1.22	10356.73	4641.7	2.231	7.6
7:00	25	38.5	13.5	92.6	12.8	45.3	1.15	36.7	1.22	10478.57	4641.7	2.257	7.7
8:00	27.3	38.5	13.5	92.8	12.8	50.4	1.14	36.8	1.21	16426.67	4631.1	3.547	12.1
9:00	28.4	38.3	14.3	93.4	13.7	52.9	1.14	38.9	1.21	16909.81	4578.1	3.694	12.6
10:00	29.9	38	14	94.4	13.5	56.6	1.13	38.6	1.20	21550.47	4498	4.791	16.4
11:00	31.3	39.3	14.2	93.3	13.6	61.3	1.12	38.6	1.19	26937.03	4756.8	5.663	19.3
12:00	32.5	35.5	14.2	93.2	13.5	61.6	1.12	38.7	1.19	27174.36	4750.4	5.720	19.5

Results and Calculations for OEM6 - CZ2

DX Unit , Air flow = 2245 cfm , Altitude = 208 m, duct size =0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out DX	RH out DX	Twb out DX	h amb	p amb	h out DX	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C				kg/s	W	W	w/w	Btu/W.hr
12:00	31.3	30.8	11.2	79.5	9.4	54.8	1.13	28.3	1.20	31727.09	11200	2.833	9.7
13:00	33	28	11.5	78.6	9.6	56.6	1.12	28.7	1.19	33107.63	11600	2.854	9.7
14:00	33.5	29.8	11.4	78.8	9.5	59.4	1.12	28.6	1.19	36548.93	11600	3.151	10.8
15:00	34.1	28.8	11.2	79.9	9.4	60	1.11	28.3	1.18	37281.05	11600	3.214	11
16:00	33.7	32.3	12	78.5	10.0	61.8	1.12	29.9	1.19	37854.25	11700	3.235	11
17:00	32.1	35.5	11.8	81.6	10.1	60.5	1.12	30.1	1.19	36074.26	11700	3.083	10.5
18:00	31.5	39.3	11.4	81.8	9.8	61.6	1.12	29.2	1.19	38447.57	11300	3.402	11.6
19:00	30.1	42.5	10.6	83	9.1	60.2	1.13	27.7	1.20	38910.58	11200	3.474	11.9
20:00	29.2	47.8	14.9	87	13.6	61.4	1.13	38.8	1.20	27057.82	11100	2.438	8.3
21:00	27.3	50.3	13	88.1	11.9	57.5	1.14	34.4	1.21	27901.19	11800	2.365	8.1
22:00	26.1	51.3	11.6	88.1	10.5	54.9	1.14	31.1	1.21	28746.68	11700	2.457	8.4
23:00	25.5	52.5	10.9	88.1	9.9	53.7	1.15	29.4	1.22	29608.06	11300	2.620	8.9
0:00	24.9	49	11.3	88.5	10.3	50.4	1.15	30.4	1.22	24368.78	11600	2.101	7.2
1:00	24.4	48.5	11.1	89	9.3	48.6	1.15	30.1	1.22	22541.12	11400	1.977	6.7
2:00	24	46.8	11.1	90.1	10.2	47	1.15	30.4	1.22	20226.08	11200	1.806	6.2
3:00	24.2	44.3	11.1	90.4	10.3	46.4	1.15	30.3	1.22	19616.86	11100	1.767	6
4:00	23.4	44.3	10.7	90.8	9.9	44.4	1.16	29.5	1.23	18312.61	11100	1.650	5.6
5:00	23.8	41.8	10.1	90.7	9.3	44.2	1.15	28.2	1.22	19495.02	11000	1.772	6
6:00	24.3	40.5	9.6	88.6	8.6	44.6	1.15	26.7	1.22	21810.05	11200	1.947	6.6
7:00	25	38.5	10.1	87.5	9.0	45.3	1.15	27.6	1.22	21566.37	11500	1.875	6.4
8:00	27.3	38.5	10.1	87	9.0	50.4	1.14	27.4	1.21	27780.40	11700	2.374	8.1
9:00	28.4	38.3	10.8	85.3	9.5	52.9	1.14	28.6	1.21	29350.60	11700	2.509	8.6
10:00	29.9	38	10.7	83.7	9.3	56.6	1.13	28.1	1.20	34121.58	11000	3.102	10.6
11:00	31.3	39.3	12.3	83.2	10.7	61.3	1.12	31.5	1.19	35362.27	11600	3.048	10.4
12:00	32.5	35.5	12.4	82.2	10.7	61.6	1.12	31.5	1.19	35718.27	11500	3.106	10.6

Annex (5) Results in CZ5

Results and Calculations for OEM 2 - CZ5

IEC Hybrid Unit , Air flow = 2000 cfm (3398 m3/hr), Altitude = 208 m , water bath area = (1000*900) mm2, size of duct for air balancing = 0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out IEC-H	RH out IEC-H	Twb out IEC-H	h amb	p amb	h out IEC-H	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C	kJ/kg	kg/m3	kJ/kg	kg/s	W	W	w/w	Btu/W.hr
11:00	38.4	38.8	13.2	79.4	11.2	81.31	1.12	32.12	1.06	52001.32	9726.4	5.346	18.2
12:00	38.1	33.5	13.8	78.6	11.7	74.24	1.12	33.27	1.06	43311.53	9243	4.686	16.0
13:00	38.8	35	13.5	79.4	11.5	78.18	1.12	32.78	1.06	47994.71	9795.3	4.900	16.7
14:00	38.3	33	12.8	79.5	10.9	74.52	1.12	31.23	1.06	45764.12	9979.7	4.586	15.7
15:00	38.7	34.8	12.4	80.3	10.6	77.67	1.12	30.67	1.06	49686.16	9963	4.987	17.0
16:00	37.5	30.8	11.4	79.2	9.5	69.61	1.13	28.11	1.07	44263.53	10164.4	4.355	14.9
17:00	36.6	29.3	10.3	78.4	8.4	65.56	1.13	25.64	1.07	42578.32	9872.4	4.313	14.7
18:00	35.3	32.3	9.5	79.3	7.8	65.12	1.14	24.32	1.08	43902.02	9855.8	4.454	15.2
19:00	32.7	41.8	8.5	79.8	6.9	65.94	1.15	22.43	1.09	47228.75	9394.8	5.027	17.2
20:00	31.2	42	8	81.7	6.6	61.92	1.15	21.77	1.09	43581.58	9677.9	4.503	15.4
21:00	31.3	44.8	8.3	83.1	7.0	64.16	1.15	22.6	1.09	45112.09	9457.2	4.770	16.3
22:00	30.1	43	8.1	83.9	6.8	59.61	1.15	22.21	1.09	40596.54	9502.8	4.272	14.6
23:00	29.9	42.5	8.5	83.9	7.2	58.67	1.16	23.07	1.09	38978.72	9514.3	4.097	14.0
0:00	31	44	9.2	83.1	7.8	62.8	1.15	24.35	1.09	41736.28	9641.4	4.329	14.8
1:00	32.2	48.8	10.5	83.6	9.1	69.99	1.15	27.16	1.09	46490.63	9687.2	4.799	16.4
2:00	31.2	51.8	10.3	83.9	8.9	69.24	1.15	26.87	1.09	45991.32	9898.9	4.646	15.9
3:00	30.3	54	10.3	84	8.9	68.06	1.15	26.74	1.09	44851.57	9682.8	4.632	15.8
4:00	30	53.3	9.7	84.5	8.4	66.5	1.15	25.59	1.09	44406.53	9729.3	4.564	15.6
5:00	29.8	51.8	9.5	85.1	8.3	64.66	1.16	25.28	1.09	43117.47	10019	4.304	14.7
6:00	29.5	51.3	8.9	84.3	7.6	63.63	1.16	24.02	1.09	43369.30	9935.5	4.365	14.9
7:00	31.9	44.3	9.6	82.1	8.1	65.63	1.15	25.06	1.09	44037.47	9761.4	4.511	15.4
8:00	33.4	41.3	10.5	81.9	8.9	67.82	1.14	26.82	1.08	44117.23	9714.6	4.541	15.5
9:00	34.5	44.3	12.3	80.7	10.5	73.81	1.14	30.38	1.08	46731.98	9395.4	4.974	17.0
10:00	36.2	44.8	13.7	80	11.8	80	1.13	33.47	1.07	49628.49	9161.1	5.417	18.5
11:00	35.6	47.3	13.6	79	11.6	80.25	1.13	33	1.07	50396.43	9411.9	5.355	18.3

Results and Calculations for OEM 2 - CZ5

DX Unit , Air flow = 2000 cfm (3398 m³/h), Altitude = 208 m, duct size =0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out DX	RH out DX	Twb out DX	h amb	p amb	h out DX	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C	kJ/kg	kg/m3	kJ/kg	kg/s	W	W	w/w	Btu/W.hr
11:00	38.4	38.8	13.8	82.6	12.1	81.31	1.12	34.37	1.06	49622.73	9767.7	5.080	17.3
12:00	38.1	33.5	14.7	76.3	12.3	74.24	1.12	34.93	1.06	41556.66	10072.4	4.126	14.1
13:00	38.8	35	14	77.1	11.8	78.18	1.12	33.37	1.06	47370.99	10054.7	4.711	16.1
14:00	38.3	33	13.7	79.1	11.7	74.52	1.12	33.17	1.06	43713.25	10151.6	4.306	14.7
15:00	38.7	34.8	13.9	77.7	11.7	77.67	1.12	33.37	1.06	46831.85	10186.1	4.598	15.7
16:00	37.5	30.8	13.3	78.2	11.2	69.61	1.13	32.12	1.07	39986.50	10555.5	3.788	12.9
17:00	36.6	29.3	12.9	75	10.5	65.56	1.13	30.4	1.07	37501.35	10067.2	3.725	12.7
18:00	35.3	32.3	11.6	76.7	9.5	65.12	1.14	28.13	1.08	39802.35	9845.8	4.043	13.8
19:00	32.7	41.8	11.6	79.2	9.7	65.94	1.15	28.68	1.09	40444.57	9314	4.342	14.8
20:00	31.2	42	11.5	80.4	9.7	61.92	1.15	28.64	1.09	36124.40	9387.1	3.848	13.1
21:00	31.3	44.8	10.5	82.6	9.0	64.16	1.15	26.96	1.09	40379.44	9247.7	4.366	14.9
22:00	30.1	43	9.9	82.9	8.5	59.61	1.15	25.67	1.09	36840.81	9392.6	3.922	13.4
23:00	29.9	42.5	9.1	81	7.5	58.67	1.16	23.7	1.09	38288.92	9593.2	3.991	13.6
0:00	31	44	11.3	82.6	9.8	62.8	1.15	28.62	1.09	37101.33	9895	3.750	12.8
1:00	32.2	48.8	11.2	83.1	9.7	69.99	1.15	28.5	1.09	45036.10	9769	4.610	15.7
2:00	31.2	51.8	10.6	83.1	9.1	69.24	1.15	27.27	1.09	45557.13	9887.5	4.608	15.7
3:00	30.3	54	10.2	87.4	9.1	68.06	1.15	27.26	1.09	44287.13	10126	4.374	14.9
4:00	30	53.3	10.2	86.5	9.1	66.5	1.15	27.17	1.09	42691.49	9668.8	4.415	15.1
5:00	29.8	51.8	9.5	83.5	8.1	64.66	1.16	24.97	1.09	43456.89	10278	4.228	14.4
6:00	29.5	51.3	9.8	84.4	8.5	63.63	1.16	25.83	1.09	41387.51	9967.4	4.152	14.2
7:00	31.9	44.3	11.3	80.3	9.5	65.63	1.15	28.13	1.09	40705.08	9834.2	4.139	14.1
8:00	33.4	41.3	10.8	80.4	9.1	67.82	1.14	27.23	1.08	43676.06	9702.4	4.502	15.4
9:00	34.5	44.3	12.6	82.6	11.0	73.81	1.14	31.58	1.08	45440.75	9623.2	4.722	16.1
10:00	36.2	44.8	13.9	80.3	12.0	80	1.13	34.02	1.07	49041.86	9571.3	5.124	17.5
11:00	35.6	47.3	13.7	82.2	12.0	80.25	1.13	34.1	1.07	49223.18	9576.3	5.140	17.5

Results and Calculations for OEM 3 - CZ5

IEC Hybrid Unit , Air flow = 2025 cfm , Altitude = 2 m , water bath area = (1728.5*623) mm², size of duct for air balancing = 0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out IEC-H	RH out IEC-H	Twb out IEC-H	h amb	ρ amb	h out IEC-H	Air mass Flow rate (Q _p)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C								
10:00	36	23.6	15.9	74	13.2	58.7	1.14	37	1.09	23641.72	5341.3	4.426	15.1
11:00	36.6	26.6	16.3	74.5	13.6	63	1.13	38.2	1.08	26782.10	5363.6	4.993	17.0
12:00	36.5	34.1	17.5	76.7	15.0	70.3	1.13	41.9	1.08	30669.83	5735.8	5.347	18.2
13:00	37.4	34.2	18.1	77.8	15.6	73	1.13	43.7	1.08	31641.76	5489.1	5.764	19.7
14:00	37	38.7	18.6	78.2	16.2	76.7	1.13	45.2	1.08	34017.59	5581.4	6.095	20.8
15:00	36.8	37.7	18.5	78.1	16.1	75	1.13	44.9	1.08	32505.70	5601	5.804	19.8
16:00	35.8	39.6	17.7	78.6	15.4	73.7	1.13	44.9	1.08	31101.80	5510.9	5.644	19.3
17:00	35.7	41.5	18.8	80.6	16.6	75.1	1.13	46.5	1.08	30885.81	5544.6	5.570	19.0
18:00	34	36.5	17.3	75.8	14.7	65.5	1.14	40.9	1.09	26801.22	5605.3	4.781	16.3
19:00	32.8	32.9	15.5	74.8	12.9	59.3	1.15	36.3	1.10	25277.86	5411.1	4.671	15.9
20:00	32	35.1	15.7	75.1	13.1	58.8	1.15	36.8	1.10	24178.82	5479	4.413	15.1
21:00	30.4	44.7	17.2	75.8	14.6	61.7	1.15	40.7	1.10	23079.78	5692.1	4.055	13.8
22:00	30.1	46.2	16.6	78.8	14.4	61.9	1.16	40.3	1.11	23945.63	5752.7	4.163	14.2
23:00	30.5	46	16.4	78.2	14.1	62.8	1.15	39.6	1.10	25497.66	5640.5	4.520	15.4
0:00	31	34	13.6	76.6	11.3	55.6	1.15	32.4	1.10	25497.66	5642.1	4.519	15.4
1:00	30.5	28.3	12.1	75	9.8	50.4	1.16	28.8	1.11	23945.63	5559	4.308	14.7
2:00	30.6	24.2	12.1	74.5	9.7	47.6	1.16	28.7	1.11	20952.43	5262.4	3.982	13.6
3:00	31.1	25.2	12.4	74.7	10.0	49.3	1.16	29.4	1.11	22061.02	5255.1	4.198	14.3
4:00	30.5	26.9	12.7	75.6	10.4	49.3	1.16	30.2	1.11	21174.15	5218.1	4.058	13.8
5:00	30.4	26.7	12.6	75.8	10.3	48.9	1.16	30.1	1.11	20841.57	5243.3	3.975	13.6
6:00	31.8	25.3	12.9	74.3	10.5	50.9	1.15	30.2	1.10	22750.07	5322.5	4.274	14.6
7:00	35.1	24.8	14.6	76.8	12.3	57.7	1.14	34.7	1.09	25058.05	5259.1	4.765	16.3
8:00	36.2	25.5	14.6	76.4	12.2	61	1.13	34.6	1.08	28509.98	5208.6	5.474	18.7
9:00	36.1	27.3	16	77.5	13.7	62.5	1.13	38.4	1.08	26026.16	5381.1	4.837	16.5
10:00	36.5	31.7	18.1	77.1	15.6	67.8	1.13	43.5	1.08	26242.14	5541.9	4.735	16.2

Results and Calculations for OEM 3 - CZ5

DX Unit , Air flow = 2025 cfm , Altitude = 2 m, duct size =0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out DX	RH out DX	Twb out DX	h amb	ρ amb	h out DX	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C	kJ/kg	kg/m3	kJ/kg	kg/s	W	W	w/w	Btu/W.hr
10:00	36	23.6	11.5	77.7	9.5	58.7	1.14	27.9	1.09	33556.00	13200	2.542	8.7
11:00	36.6	26.6	11.3	82.5	9.7	63	1.13	28.7	1.08	37041.38	13000	2.849	9.7
12:00	36.5	34.1	13.4	87	12.2	70.3	1.13	34.4	1.08	38769.26	13000	2.982	10.2
13:00	37.4	34.2	13.4	85.6	12.0	73	1.13	34.1	1.08	42009.03	12500	3.361	11.5
14:00	37	38.7	12.9	85.7	11.6	76.7	1.13	32.9	1.08	47300.65	12700	3.724	12.7
15:00	36.8	37.7	12.7	86.5	11.5	75	1.13	32.7	1.08	45680.77	12700	3.597	12.3
16:00	35.8	39.6	12.8	87.1	11.6	73.7	1.13	33.1	1.08	43844.90	12800	3.425	11.7
17:00	35.7	41.5	12.3	87.3	11.1	75.1	1.13	32	1.08	46544.70	12700	3.665	12.5
18:00	34	36.5	11.6	86.9	10.4	65.5	1.14	30.2	1.09	38458.66	12300	3.127	10.7
19:00	32.8	32.9	10.2	85.9	9.0	59.3	1.15	26.9	1.10	35608.81	12100	2.943	10
20:00	32	35.1	10.1	86.3	8.9	58.8	1.15	26.9	1.10	35059.29	12200	2.874	9.8
21:00	30.4	44.7	10.7	87.3	9.6	61.7	1.15	28.2	1.10	36817.75	11800	3.120	10.6
22:00	30.1	46.2	10	87.2	8.9	61.9	1.16	26.8	1.11	38911.65	11600	3.354	11.4
23:00	30.5	46	10	85.1	8.7	62.8	1.15	26.3	1.10	40114.86	11100	3.614	12.3
0:00	31	34	7.2	82	5.8	55.6	1.15	20.2	1.10	38905.92	11300	3.443	11.8
1:00	30.5	28.3	7.1	82.1	5.7	50.4	1.16	20	1.11	33701.26	11400	2.956	10.1
2:00	30.6	24.2	7.3	80.5	5.8	47.6	1.16	20.1	1.11	30486.34	11800	2.584	8.8
3:00	31.1	25.2	8.2	80.4	6.6	49.3	1.16	21.8	1.11	30486.34	11600	2.628	9
4:00	30.5	26.9	7.7	81.1	6.2	49.3	1.16	21.1	1.11	31262.35	11600	2.695	9.2
5:00	30.4	26.7	7.6	81.5	6.2	48.9	1.16	20.8	1.11	31151.49	11400	2.733	9.3
6:00	31.8	25.3	7.4	82.3	6.0	50.9	1.15	20.7	1.10	33190.92	11700	2.837	9.7
7:00	35.1	24.8	8.8	81.6	7.3	57.7	1.14	23.3	1.09	37478.13	12300	3.047	10.4
8:00	36.2	25.5	9.2	79.9	7.5	61	1.13	23.7	1.08	40281.15	12600	3.197	10.9
9:00	36.1	27.3	10.7	80	9.0	62.5	1.13	26.8	1.08	38553.27	12700	3.036	10.4
10:00	36.5	31.7	12.3	81.4	10.6	67.8	1.13	30.6	1.08	40173.16	12800	3.139	10.7

Results and Calculations for OEM4 - CZ5

IEC Hybrid Unit , Air flow = 1750 cfm , Altitude = 2 m , , water bath area = (2400*1600) mm2, size of duct for air balancing = 0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out IEC-H	RH out IEC-H	Twb out IEC-H	h amb	ρ amb	h out IEC-H	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C				kg/s	W	W	w/w	Btu/W.hr
9:00	34.2	45.3	15.1	87.2	13.8	73.8	1.14	38.7	0.94	33047.57	7015	4.711	16.1
10:00	34.2	44.3	15.4	88.6	14.3	72.8	1.14	39.9	0.94	30976.21	7005	4.422	15.1
11:00	36.4	40.8	15.7	84.3	14.1	76.5	1.13	39.6	0.93	34437.56	7233	4.761	16.2
12:00	36.8	37.5	15.7	85.3	14.2	74.6	1.13	39.7	0.93	32571.03	7218	4.512	15.4
13:00	36.7	41.8	16.2	84.4	14.6	78.5	1.13	40.7	0.93	35277.50	7135	4.944	16.9
14:00	36.7	38.5	15	83.4	13.3	75.3	1.13	37.5	0.93	35277.50	7083	4.981	17
15:00	37.5	38	15.2	83.7	13.6	77.3	1.13	38.2	0.93	36490.75	7206	5.064	17.3
16:00	37.5	34	14.2	83.4	12.6	73.1	1.13	35.5	0.93	35090.85	7110	4.935	16.8
17:00	36.4	41.3	14.6	85.6	13.2	77.1	1.13	37.2	0.93	37237.36	7253	5.134	17.5
18:00	35.7	37	13.5	86.3	12.2	70.6	1.13	34.6	0.93	33597.62	7073	4.750	16.2
19:00	34.3	41.5	12.9	86.6	11.7	70.7	1.14	33.2	0.94	35307.23	7014	5.034	17.2
20:00	32.7	47	11.7	85.3	10.4	70.3	1.14	30.1	0.94	37849.36	6929	5.462	18.6
21:00	33.1	43	11.6	86.3	10.4	68.3	1.14	30.1	0.94	35966.30	6865	5.239	17.9
22:00	32.6	44	11.5	86.3	10.3	67.5	1.15	30	0.95	35616.95	7242	4.918	16.8
23:00	31.8	48	11.6	87.5	10.5	68.3	1.15	30.5	0.95	35901.88	6970	5.151	17.6
0:00	31.8	48	12.6	87.5	11.5	68.3	1.15	32.7	0.95	33812.36	7092	4.768	16.3
1:00	31.2	50	11.5	87.2	10.4	67.9	1.15	30	0.95	35996.86	6907	5.212	17.8
2:00	31.6	50.8	10.9	87.6	9.8	69.6	1.15	28.8	0.95	38751.24	6880	5.632	19.2
3:00	29.9	54.8	10.6	88.8	9.6	67	1.15	28.4	0.95	36661.71	6831	5.367	18.3
4:00	29.6	53	10.3	89	9.6	65	1.16	27.8	0.96	35639.25	6827	5.220	17.8
5:00	29.8	52.8	10.5	89.2	9.6	65.5	1.16	28.4	0.96	35543.44	6907	5.146	17.6
6:00	28.4	52.3	11.1	89	9.6	60.9	1.16	29.7	0.96	29890.98	6806	4.392	15
7:00	30.9	52.3	12.3	89.6	11.4	68.7	1.15	32.6	0.95	34287.25	7032	4.876	16.6
8:00	33.8	45	13	88.3	11.2	72	1.14	33.8	0.94	35966.30	7035	5.112	17.4
9:00	36	29	13.1	87	11.9	63.8	1.13	38.7	0.93	23425.01	7045	3.325	11.3

Results and Calculations for OEM4 - CZ5

DX Unit , Air flow = 1750 cfm , Altitude = 2 m, duct size =0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out DX	RH out DX	Twb out DX	h amb	p amb	h out DX	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C	kJ/kg	kg/m3	kJ/kg	kg/s	W	W	w/w	Btu/W.hr
9:00	34.2	45.3	15	84.1	13.4	73.8	1.14	37.8	0.94	33894.95	7787	4.353	14.9
10:00	34.2	44.3	15.9	82.8	14.1	72.8	1.14	39.6	0.94	31258.67	7888	3.963	13.5
11:00	36.4	40.8	15.2	83.6	13.6	76.5	1.13	38	0.93	35930.79	8368	4.294	14.7
12:00	36.8	37.5	15.7	83.8	14.0	74.6	1.13	39.4	0.93	32851.01	7709	4.261	14.5
13:00	36.7	41.8	15.8	81.5	13.9	78.5	1.13	38.9	0.93	36957.38	7867	4.698	16
14:00	36.7	38.5	15	77.7	12.7	75.3	1.13	39	0.93	33877.60	8031	4.218	14.4
15:00	37.5	38	16.3	77.5	13.9	77.3	1.13	39	0.93	35744.14	7688	4.649	15.9
16:00	37.5	34	14.8	76.8	12.5	73.1	1.13	35.2	0.93	35370.83	7851	4.505	15.4
17:00	36.4	41.3	15.8	81	13.8	77.1	1.13	38.7	0.93	35837.46	7591	4.721	16.1
18:00	35.7	37	14.9	80.3	12.9	70.6	1.13	36.4	0.93	31917.74	8201	3.892	13.3
19:00	34.3	41.5	13.4	80.2	11.5	70.7	1.14	32.9	0.94	35589.69	8129	4.378	14.9
20:00	32.7	47	14.3	83.5	12.7	70.3	1.14	35.9	0.94	32388.50	8126	3.986	13.6
21:00	33.1	43	11.7	82.7	10.1	68.3	1.14	29.7	0.94	36342.91	8112	4.480	15.3
22:00	32.6	44	11.4	82.8	9.9	67.5	1.15	29	0.95	36566.73	8127	4.499	15.4
23:00	31.8	48	11.4	85.3	10.1	68.3	1.15	29.6	0.95	36756.69	7365	4.991	17
0:00	31.8	48	11.5	84.8	10.1	68.3	1.15	29.7	0.95	36661.71	7959	4.606	15.7
1:00	31.2	50	11.5	87.7	10.4	67.9	1.15	30.2	0.95	35806.90	7615	4.702	16
2:00	31.6	50.8	11.3	87.3	10.2	69.6	1.15	29.6	0.95	37991.41	7818	4.859	16.6
3:00	29.9	54.8	10.7	90.5	9.9	67	1.15	29.1	0.95	35996.86	8301	4.336	14.8
4:00	29.6	53	10.4	89.5	9.5	65	1.16	28.1	0.96	35351.83	8256	4.282	14.6
5:00	29.8	52.8	9.8	88.9	8.9	65.5	1.16	26.8	0.96	37076.31	8214	4.514	15.4
6:00	28.4	52.3	10.2	90.9	9.4	60.9	1.16	28	0.96	31519.66	7435	4.239	14.5
7:00	30.9	52.3	11.8	89.5	10.9	68.7	1.15	31.3	0.95	35521.97	7527	4.719	16.1
8:00	33.8	45	13.8	82.9	12.2	72	1.14	34.4	0.94	35401.39	7587	4.666	15.9
9:00	36	29	13.8	81.8	12.0	63.8	1.13	34.1	0.93	27718.04	7718	3.591	12.3

Results and Calculations for OEM6 - CZ5

IEC Hybrid Unit , Air flow = 1750 cfm , Altitude = 2 m , , water bath area = (2400*1600) mm2, size of duct for air balancing = 0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out IEC-H	RH out IEC-H	Twb out IEC-H	h amb	ρ amb	h out IEC-H	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C								
10:00	35.7	35.1	16	93.3	15.3	68.8	1.13	42.8	1.20	31128.46	4752	6.551	22.4
11:00	35	36.4	15.8	94.1	15.2	68.2	1.14	42.7	1.21	30800.01	4754.5	6.478	22.1
12:00	34.8	36.8	17.1	93.8	16.5	68	1.14	46.1	1.21	26451.78	4706	5.621	19.2
13:00	34.6	38.9	16.1	94.4	15.5	69.1	1.14	43.4	1.21	31041.58	4666.5	6.652	22.7
14:00	34.3	38.5	16.5	94.3	15.9	68	1.14	44.7	1.21	28142.76	4600.1	6.118	20.9
15:00	35.2	38.3	15.6	94.3	15.0	70.5	1.14	42.2	1.21	34181.98	4607.4	7.419	25.3
16:00	34	37.3	16.1	94.8	15.6	66	1.14	43.5	1.21	27176.48	4605.5	5.901	20.1
17:00	34.3	42.5	15.6	94.9	15.1	71.6	1.14	42.3	1.21	35389.82	4735.8	7.473	25.5
18:00	31.1	47.5	16.5	94.5	15.9	65.7	1.15	44.6	1.22	25709.06	4714.4	5.453	18.6
19:00	31.1	48	15	94.4	14.5	66.2	1.15	40.5	1.22	31313.88	4576.9	6.842	23.4
20:00	30.6	45.1	14.9	94.5	14.4	62.4	1.15	40.3	1.22	26927.50	4587.1	5.870	20
21:00	31	43.4	14.6	95	14.1	62.5	1.15	39.5	1.22	28024.09	4740.1	5.912	20.2
22:00	29.6	41.2	14.6	95.8	14.2	57	1.16	39.7	1.23	21262.29	4795.1	4.434	15.1
23:00	29.6	31.7	10.9	95.1	10.5	50.8	1.16	30.4	1.23	25072.29	4839.7	5.181	17.7
0:00	29.3	30.7	10.2	95.2	9.8	49.4	1.16	28.8	1.23	25318.10	4858.6	5.211	17.8
1:00	28.2	30.8	9.3	95	8.9	47.1	1.17	26.7	1.24	25288.43	5067	4.991	17
2:00	28	30.5	9.2	95.1	8.8	46.5	1.17	26.5	1.24	24792.58	4881.8	5.079	17.3
3:00	28.4	27	9.1	95	8.7	45.1	1.17	26.4	1.24	23181.06	4924	4.708	16.1
4:00	28.5	27.3	8.1	95.1	7.7	45.5	1.17	24.3	1.24	26280.14	4993.5	5.263	18
5:00	27.5	29.8	8.4	95.2	8.0	45	1.17	24.8	1.24	25040.51	4970.6	5.038	17.2
6:00	29.2	28.5	11.6	95.6	11.2	47.8	1.16	32.2	1.23	19172.93	5068.6	3.783	12.9
7:00	33.4	27.3	10.7	95.5	10.3	56.1	1.15	30	1.22	31801.25	4859	6.545	22.3
8:00	35	29.5	12.1	95.8	11.7	61.7	1.14	33.5	1.21	34061.19	4784.4	7.119	24.3
9:00	34.9	29.8	14.1	96.1	13.7	61.9	1.14	38.6	1.21	28142.76	4723.5	5.958	20.3
10:00	35.8	30	14.9	95.8	14.5	64.4	1.13	40.6	1.20	28494.52	4765.4	5.979	20.4

Results and Calculations for OEM6 - CZ5

DX Unit , Air flow = 1750 cfm , Altitude = 2 m, duct size =0.3 m * 0.7 m

Hour	Tdb amb	RH amb	Tdb out DX	RH out DX	Twb out DX	h amb	ρ amb	h out DX	Air mass Flow rate (Qp)	Total Cooling Capacity (q_tot)	Total Power Input (W)	COP	EER
	°C	%	°C	%	°C	kJ/kg	kg/m3	kJ/kg	kg/s	W	W	w/w	Btu/W.hr
10:00	35.7	35.1	16.3	81.7	14.4	68.8	1.13	40.2	1.20	34241.31	13200	2.594	8.9
11:00	35	36.4	16.1	78.6	13.9	68.2	1.14	38.9	1.21	35389.82	13200	2.681	9.2
12:00	34.8	36.8	17.4	85.2	15.8	68	1.14	44.2	1.21	28746.68	13200	2.178	7.4
13:00	34.6	38.9	16.4	81.6	14.5	69.1	1.14	40.4	1.21	34665.11	13200	2.626	9
14:00	34.3	38.5	16.7	82.5	14.9	68	1.14	41.6	1.21	31887.07	13000	2.453	8.4
15:00	35.2	38.3	16.5	80.9	14.5	70.5	1.14	40.5	1.21	36235.31	12900	2.809	9.6
16:00	34	37.3	16.5	81.8	14.6	66	1.14	40.8	1.21	30437.66	12900	2.360	8.1
17:00	34.3	42.5	16.2	83.7	14.5	71.6	1.14	40.7	1.21	37322.37	12700	2.939	10
18:00	31.1	47.5	16.4	88.4	15.2	65.7	1.15	42.6	1.22	28145.94	12200	2.307	7.9
19:00	31.1	48	14.6	86	13.2	66.2	1.15	37.2	1.22	35334.73	12100	2.920	10
20:00	30.6	45.1	14.4	85.9	13.0	62.4	1.15	36.8	1.22	31192.03	12000	2.599	8.9
21:00	31	43.4	13.6	86.5	12.3	62.5	1.15	34.9	1.22	33628.91	12000	2.802	9.6
22:00	29.6	41.2	13.9	87.1	12.7	57	1.16	35.6	1.23	26301.33	11900	2.210	7.5
23:00	29.6	31.7	11.1	82.2	9.5	50.8	1.16	28.2	1.23	27776.17	11600	2.394	8.2
0:00	29.3	30.7	11	81.4	9.4	49.4	1.16	27.7	1.23	26670.04	11400	2.339	8
1:00	28.2	30.8	10.3	80.8	8.6	47.1	1.17	26.2	1.24	25908.25	11300	2.293	7.8
2:00	28	30.5	10.4	80.4	8.7	46.5	1.17	26.2	1.24	25164.47	11200	2.247	7.7
3:00	28.4	27	11.1	77	9.1	45.1	1.17	27	1.24	22437.29	11400	1.968	6.7
4:00	28.5	27.3	10.5	75.6	8.4	45.5	1.17	25.6	1.24	24668.62	10800	2.284	7.8
5:00	27.5	29.8	10.6	79	8.8	45	1.17	26.5	1.24	22933.14	10300	2.227	7.6
6:00	29.2	28.5	12.4	80.5	10.6	47.8	1.16	30.7	1.23	21016.48	11400	1.844	6.3
7:00	33.4	27.3	12.6	78.7	10.6	56.1	1.15	30.7	1.22	30948.35	11700	2.645	9
8:00	35	29.5	14.6	79.6	12.6	61.7	1.14	35.5	1.21	31645.50	12600	2.512	8.6
9:00	34.9	29.8	16.4	82.4	14.6	61.9	1.14	40.7	1.21	25606.29	12700	2.016	6.9
10:00	35.8	30	16.1	80.2	14.0	64.4	1.13	39.3	1.20	30050.94	13000	2.312	7.9

Annex (6) Accuracy and Sensitivity of Measurements:

In order to ensure reliable results, all measurements were carried out using instruments that have been calibrated at internationally accredited laboratories. The accuracy of the measurements was scrutinized to determine the degree of how close a calculated or measured value is to the actual value. One factor that can determine the accuracy of results is the measurement tool used, as it can only record as many digits as it allows.

Accuracy of measurements is guaranteed by following the posterior steps:

- 1- Collecting data: records for all measurements were electronically saved using the equipment's software programs to tools such as spreadsheets.
- 2- Values were sorted to help determining the range of data collected.
- 3- The average value of the data, gives a measurement of accuracy.
- 4- Each individual measurement was subtracted from the average value to give a set of absolute deviations. The absolute deviation of each measurement show how close the value is to the average value.
- 5- Precision was measured as the average value plus or minus the average deviation.
- 6- The uncertainty is calculated by defining the sources of uncertainty in the measurement.
- 7- The uncertainty from each source is estimated then combined to give an overall estimation.
- 8- There are two approaches to estimate Uncertainty:
 - a. Type A evaluations: uncertainty estimated using statistics (repeated readings)
 - b. Type B evaluations: uncertainty estimated from any other information (resolution, annual drift in errors, manufacture's specifications, and environmental conditions).

The following Table shows the names, model numbers, serial numbers, scale ranges, accuracy and expanded uncertainty of each instrument used during the tests performed.

Used Apparatus	Code of Used Apparatus	Measured Property	Model	Serial Number	Scale Range	Accuracy	Expanded Uncertainty	Item Photo
Air Flow Meter	K; CFM	Air flow	KIMO CP300	06072114	0 to 100000 m ³ /h	±1 cfm	0.24%	
Weather Station,	WS; T _{amb}	Inlet dry bulb temperature for both Units	HOBO U30 ONSET	10221018	0:50°C 0:100%RH	±0.1°C ±0.7%RH	1.7%, 0.4°C	
	WS; RH _{amb}	Inlet Relative humidity for both Units						
Thermo-Hygrometer	K2; T _{out}	Outlet dry bulb temperature for IEC Hybrid Unit	KIMO TH300	MEH1000821	-40:180°C, 0:100%	±0,3%°C ±1,5%RH	1.7%, 0.4°C	
	K2; RH _{out}	Outlet Relative humidity for IEC Hybrid Unit						

Used Apparatus	Code of Used Apparatus	Measured Property	Model	Serial Number	Scale Range	Accuracy	Expanded Uncertainty	Item Photo
Compressor power meter - IEC hybrid unit	Comp.; IEC-H	Power consumption of the Compressor of the IEC hybrid Unit	ENTES	---	Max V: 690V Current: 1/5A Freq.: 45:65Hz	±1.5%	0.08 kW	
Pump power meter - IEC hybrid unit	Pump; IEC-H	Power consumption of the Pump of the IEC hybrid Unit	ENTES	---	Max V: 690V Current: 1/5A Freq.: 45:65Hz	±1.5%	0.08 kW	
Evaporative Fan power meter - IEC hybrid unit	Evap. Fan; IEC-H	Power consumption of the Evaporator Fan of the IEC hybrid Unit	ENTES	---	Max V: 690V Current: 1/5A Freq.: 45:65Hz	±1.5%	0.08 kW	
Supply fan power meter - IEC hybrid unit	Sup. Fan; IEC-H	Power consumption of the Supply Fan of the IEC hybrid Unit	ENTES	---	Max V: 690V Current: 1/5A Freq.: 45:65Hz	±1.5%	0.08 kW	

Used Apparatus	Code of Used Apparatus	Measured Property	Model	Serial Number	Scale Range	Accuracy	Expanded Uncertainty	Item Photo
Power Analyzer of total power consumption of IEC hybrid Unit	Pw _{Tot} ; IEC-H	Total Input power of IEC Hybrid Unit	Fluke 435-II	19673107	Max 6000 MW	±1%	0.06 kW	
Air meter	F975; T _{out}	Outlet dry bulb temperature for DX Unit	Fluke 975	2149015	-20:50°C, 0:100%	±0.5°C	1.7 %, 0.4 °C	
Thermo-Hygrometer	K3; T _{out}	Outlet Relative humidity for DX Unit	KIMO TH300	MEH1000820	-40:180°C, 0:100%	±0,3%°C ±1,5%RH	1.7 %, 0.4 °C	
Power meter of total power consumption of DX Unit	Pw _{Tot} ; DX	Total Input power of DX Unit	6300 - Kyoritsu KEW	---	Max 200 MW	±0.2%f.s	0.06 kW	

Annex (7) The presentation of the outreach campaign:



Dear Invitee,

UNIDO, UN environment and HBRC are pleased to invite you to attend a workshop on output of:

"Project of The Transformation of Commercial Air Conditioning Companies"

HCFC Phase-out Management Plan (HPMP II- EGYPT)

Date: Wednesday 21st December 2022.

The meeting will be held at HBRC, Address: 87 El-Tahrir ST. Dokki - Giza.

Kindly note that the meeting starts at 10:30 a.m. and is planned to end at 2:00 p.m. (Cairo time).

Prof. Sayed Shebl



Team Leader, Director of
Electro – Mechanical Institute, HBRC

Prof. Alaa Olama



Project Manager and Technical Consultant



Project of the Transformation of Commercial Air Conditioning Companies (HCFC Phase-out Management Plan (HPMP) EGYPT (Stage UNIDO project: No.140400)

HBRC – Wednesday 21 December 2022, 10:30 AM– 14:00 PM

Abstract

The project aims at providing technical assistance for the implementation of low GWP technology as well as examining the introduction of a Not-In-Kind technology, namely: Indirect Evaporative Cooling (IEC). The project also proposes to look into the introduction of IEC in commercial air conditioning applications. The goal of the project is to secure phase out of HCFC in the commercial air conditioning manufacturing sector.

Program

- 10:30 – 11:00 am **Registration**
- 11:00 – 11:45 am **First Lecture**
-Testing Methodology and Instrumentation
Prof. Sayed Shebl
Director of Electro- Mechanical Institute HBRC
- 11:45 – 12:15 pm **Coffee Break**
- 12:15 – 13:00 pm **Second Lecture**
- Discussion OF Findings and Conclusion
Prof. Alaa Olama
International Expert and UN RTOC member
- 13:00 – 14:00 pm **Open Discussion**



Transformation of Commercial Air Conditioning Companies Project (HCFC Phase- out Management Plan (HPMP) EGYPT (Stage II)), UNIDO ID:140400

Workshop

SPEAKERS

Prof.Sayed Shebl

Director of Electro- Mechanical Institute HBRC

Prof. Alaa Olma

International Expert and UN RTOC member

21 Wednesday 2022 11:00 AM - 14:00 PM

(())

Zoom Meeting ID: 8360149880

Passcode: hbrc2021

 HBRC
87 El-Tahreer ST. Dokki - Giza

Annex(7): The presentation of the outreach campaign:

Transformation of Commercial Air Conditioning Companies

HCFC Phase-out Management Plan (HPMP) EGYPT (Stage II), UNIDO ID:140400



Direct Indirect Evaporative Cooling in Egypt

Presented by:

Prof. Alaa Olama;

The Project general Manager and Technical Consultant

Prof. Sayed Shebl;

Director of Electro-Mechanical Research Institute EMI, HBRC, Egypt



Phase-out & Phase-down Strategies

Presented by:

Eng. Ayman Eltalouny;

International Partnerships Coordinator
OzonAction, Law Division
UN Environment Programme (UNEP)



Why Refrigeration and Air-Conditioning Sector is of high importance



Economics

- One of the fastest Growing sectors globally
- Protecting Capital Expenditures (CAPEX) & Minimizing Operating Expenditures (OPEX)

- Competent workforce and employment opportunities



Environment

- Environmental Footprint
- Emissions Reduction
- Climate Action
- Energy Efficiency
- Refrigerant Management




Sustainability

- Contribution to Food Security and Food Safety
- Sustainable Urban Planning & Cities
- Renewables
- Innovation and Smart Operations
- Sustainable Consumption of Materials



Population Growth & Energy Bill

- Cooling is the fastest growing use of energy in buildings
- Cooling will drive peak electricity demand, especially in hot countries
- Most homes in hot countries have not yet purchased their first AC
- Investing in more efficient ACs could cut future energy demand in half



Montreal Protocol – A tool to protect ozone & climate



Handbook for the Montreal Protocol on Substances that Deplete the Ozone Layer

Twelfth edition (2018)



HFC control measures as per the 2016 Kigali Amendment

Non-Article 5 parties

Baseline formula

Average HFC consumption for 2011-2013 + 15% of HCFC baseline*



A5 parties – “Group 1”

Baseline formula

Average HFC consumption for 2020-2022 + 65% of hydrochlorofluorocarbon (HCFC) baseline



A5 parties – “Group 2”


Baseline formula

Average HFC consumption for 2024-2026 + 65% of HCFC baseline



Refrigerant (re)evolution – transition to low-GWP

- 1830s-1930s – **whatever worked**: primarily familiar solvents and other volatile fluids including ethers, ammonia (NH_3), carbon dioxide (R-744), sulphur dioxide (R-764) and others
- 1931-1990s – **safety and durability**: primarily chlorofluorocarbons (CFCs), hydrochlorofluorocarbons (HCFCs), ammonia, and water (mostly used in absorption cycles).
- 1990s – 2010s – **avoidance of Ozone Depleting Substances**, following attention to stratospheric ozone protection arising from the Montreal Protocol.
- **2010s onwards** – intention to adopt refrigerants with **as low a GWP as practicable** due to the focus on climate change.



100 Year GWP	Classification
< 30	Ultra-low or Negligible
< 100	Very low
< 300	Low
300-1000	Medium
> 1000	High
> 3000	Very high
> 10000	Ultra-high

Refrigerant Selection Criteria



Climate impact

Other environmental impacts, including ODP

Energy efficiency

Thermal energy storage

Refrigerant cost

Commercial availability

Technological level

High ambient temperature fitness

Safety risk

Flammability & decomposition after refrigerant releases

Liability, responsibility

Testing Strategies and Setup

Presented by:

Prof. Sayed Shebl;
The Project Team Manager





Direct Indirect Evaporative Cooling (IEC) in Egypt

Start date

May 25, 2021

End date

Dec. 31, 2022


NIK Technology

Scope

- Phase out of HCFC in the commercial air conditioning manufacturing sector.
- Transformation of Commercial Air Conditioning Companies.

Purpose

- Introduction of a not-in-kind cooling technologies.
- Adoption of low-GWP technologies



Milestones

- ◆ 1 | Technical Assistance for product design
- ◆ 2 | Incorporate IEC technology in existing systems
- ◆ 3 | Field testing and commercial feasibility




UN
environment



Direct Indirect Evaporative Cooling (IEC) in Egypt

OEMs		Approval committee	
Delta Construction & Manufacturing (DCM)	TIBA Engineering Industries Co.	UNIDO & NOU	Steering Committee
MISR Engineering Industries	VOLTA EGYPT	UNEP	Advisor
Egyptian German Air Treatment Company (EGAT)	Misr Refrigeration & Air Conditioning MFG Co. (MIRACO)	EUROVENT	Provide a reference testing methodology for the IEC hybrid units suitable for Egypt's working conditions



Which Climatic Zone?

Two climatic zones out of Eight representing Egypt



Field Testing Logistics


Testing Locations, and Used Apparatuses

Analyzing Data

Provide technical parameters obtained from field testing

Climatic Zones and the New Cities of Egypt

	North Coast		
1	<ul style="list-style-type: none"> Tourist villages New Damietta Alamein 	<ul style="list-style-type: none"> East of Port Said New Burj Al Arab New Rashid 	<ul style="list-style-type: none"> West of Port Said New Mansoura Bir El- Abd
	Delta And Cairo		
2	<ul style="list-style-type: none"> 10th of Ramadan El shrouk New Cairo The new capital New Salfia Sheikh Zayed 	<ul style="list-style-type: none"> New of October Obour City El- Sadat Badr New Zayed New Ismailia 	<ul style="list-style-type: none"> New El Obour Nubaria New Nubaria New Alexandria New Sphinx Capital Gardens
	North Upper Egypt		
3	<ul style="list-style-type: none"> 15th May New Fayoum New Beni Suef 	<ul style="list-style-type: none"> South New Cairo 6th October New Minya 	<ul style="list-style-type: none"> October Gardens West of Mallawi The new of El Fashn
	Southern Upper Egypt		
4	<ul style="list-style-type: none"> New Assiut New Sohag New Akhmim 	<ul style="list-style-type: none"> West Qena New Luxor 	<ul style="list-style-type: none"> New Qena New Tiba
	Eastern Coast		
5	<ul style="list-style-type: none"> New Hurghada 	<ul style="list-style-type: none"> Suez Gulf 	<ul style="list-style-type: none"> New Suez
	High Heights		
	Desert		
7	<ul style="list-style-type: none"> East Owainat 	<ul style="list-style-type: none"> West Assiut 	
	South of Egypt		
8	<ul style="list-style-type: none"> New Aswan 	<ul style="list-style-type: none"> Toshki 	



First Location - Climatic Zone 2 (Egyptian Russian University - Badr)

Location

30°08' 36" N 31°43'
06" E



Altitude

208 m
(above sea level)



Second Location - Climatic Zone 5 (Movenpick Soma Bay - Hurghada)



Location

26°49' 39" N 33°56'
13" E

Altitude

2 m
(above sea level)



Testing Progress

**Setup prototypes
in testing location**

Step 1




**Connect Measuring
Apparatuses**



Step 2

Step 2

Adjust Airflow



Step 4

**Record measurements
for 24 hours**



Setup prototypes in testing location – CZ2



Setup prototypes in testing location – CZ5




Airflow Setup



Record Measurement for 24 hours – CZ2



Record Measurement for 24 hours – CZ5





Findings & Future Work

Current Achievements

01



Final Report

02



Guidelines
for IEC in
Egypt for
the eight
climatic
zones

Recommended Future Work

03



Code of IEC

04



Enforcement
of IEC code



Feasibility Study & Financial Analysis


Presented by:

Dr. Hossam Heiba

Manager Director of the General
Authority for Investment and Free Zones



Feasibility Study



Max. Power Consumption IEC Hybrid Unit (W/hr)	8,607
Max. Power Consumption DX Unit (W/hr)	10,802
Annual Electricity Consumption IEC Hybrid Unit	37,698,660
Annual Electricity Consumption DX Unit	47,314,512
Average Cost (kW/hr)	1.60 (EGP)
Electricity cost for IEC Hybrid Unit (EGP)	60,318
Electricity cost for DX Unit (EGP)	75,703
Maximum Water Consumption for IEC Hybrid Unit (Liters/hr)	54
Annual Water consumption for IEC Hybrid Unit (Liters/hr)	236,520
Water Cost per Cubic meter	5.00 (EGP)
Water Cost for IEC Hybrid Unit (EGP)	1,183
Electricity Saving	15,385
Water Expenditure	(1,183)
Net Saving	14,203

Results & Technical Analysis


Presented by:

Prof. Alaa Olama;
The Project general Manager and
Technical Consultant



Schematic Diagram

The project required each OEMs to individually manufacture a custom-built Indirect Evaporative Cooling Hybrid Air Conditioner (IEC-H) prototypes and a central DX unit to test and compare their performances under actual operating conditions in two of the eight climatic zones of Egypt (CZ2 & CZ5).



General Testing Conditions



Full Fresh Air

Both units to be **full fresh air** with air discharge of one unit regulated so that it matches the other.



Compressor Size

Compressor size of IEC-H Unit left to each OEM to decide.



Primary Air Outlet


The primary air outlet dry bulb temperature maintained at 15°C




Confidentiality

No intentions to compare the performance of OEMs units. OEMs were labelled by a **confidential number**

Program Components



Associated Activities



Collaborative Progress



Cooling Tower

1st Stage

2nd Stage

3rd Stage

Serpentine and air being cooled through it

Evaporation of water in the stream




Psychrometric Process

49.7 °C (DRY) / 21.85 °C (WET)



5000 CFM




49.7 °C (DRY)


17.53 °C (DRY)
21.85 °C (WET)

21.85 °C (WET)


73°F / 69°F
23°C / 21°C

79°F / 58.6°F
26°C / 14.8°C






Results Sample – Inlet Versus Outlet Temperature




Inlet Ambient Temperature Versus Outlet Temperature of IEC Hybrid and DX units for OEM2 at CZ5

Results Sample - EER




EER for IEC Hybrid Unit Versus DX unit for OEM2 at CZ5

Results Sample – Cooling Capacity




Cooling Capacity for IEC Hybrid Unit & DX Unit Versus Ambient Conditions for OEM2 at CZ5

Results Sample – Wetbulb




Cooling Capacity versus Outlet Wet Bulb Temperature for IEC Hybrid Unit & DX Unit for OEM2 at CZ5

Results Sample – Power Components



Power Consumption of DX Unit and IEC Hybrid Unit Components for OEM2 at CZ5

IEC-H Unit Compressor capacity compared to DX Unit compressor capacity




Observations


No direct relationship indicating whether the capacity of the compressor of the IECH units had an impact on the capacity of the units and whether there was a critical capacity size defining this relationship

Important point that needs further investigation!


EER in CZ2




Cooling Capacity in CZ2



EER in CZ5



Cooling Capacity in CZ5



Conclusion



All OEMs show EERs of the IEC-H units that are superior to corresponding DX units.

IEC-H system is economically advantageous compared to a DX system

Further tests are needed at the highest ambient dry bulb temperatures and the lowest humidity, climatic zone 8.

Superior EERs of the IEC-H units despite the smaller capacity compressors used. The capacities of the IEC-H units were not always larger than these of the DX units.

Future Work



Use **lower GWP refrigerants** approved in Egypt (Promotion of Low-GWP Refrigerants for the Air Conditioning Industry in Egypt, UNEP/UNIDO 2021) refrigerants R-32 and R-454 B.



The **capacity of the compressor** of the IEC-H units had an impact on the capacity of the unit. There was a critical capacity size defining this relationship associated with the climatic zone where it is located.



Further tests are needed at the highest ambient dry bulb temperatures and the lowest humidity, **climatic zone 8**



Thank you

